
From: Vigil-Holterman, Luciana R
Sent: Monday, December 29, 2014 3:10 PM
To: Pullen, Steve, NMENV (steve.pullen@state.nm.us)
Cc: Timothy.Hall@state.nm.us; John Kieling; Brandt, Michael Thomas; Erickson, Randy; Grieggs, Tony; Dorries, Alison Marie; Vigil-Holterman, Luciana R; Pete Maggiore; Nickless, David J; Turner, Gene E; Sharp-Geiger, Raeanna Racine; Haagenstad, Mark P; dave.cobrain@state.nm.us; Frederici, Dave; Diaz, Tammy; Juarez, Catherine L
Subject: Fire Watch at TA-54, Area G, Dome 231

Steve-

As a follow-up to our phone conversation, a Fire Watch has been established within Dome 231 since 2:30 am on 12/29/2014 after a nitrogen leak was discovered in the dry pipe suppression system. The Fire Watch will be in effect until the system can be repaired early next week.

The above information will be included in the daily technical submissions until the leak is repaired.

Please contact me at 505-927-7776 if you need more information and I will help to track down what you need.

Thank you for your time.

--Luciana

Luciana Vigil-Holterman
Environmental Protection Division
Los Alamos National Laboratory
PO Box 1663, MS K404
Los Alamos, NM 87532
505-665-3435