
From: Haagenstad, Mark P
Sent: Wednesday, June 24, 2015 8:15 AM
To: Kieling, John, NMENV; Cobrain, Dave, NMENV; Briley, Siona, NMENV; Dhawan, Neelam, NMENV; Smith, Coleman, NMENV; ricardo.maestas@state.nm.us; kathryn.roberts@state.nm.us
Cc: Brandt, Michael Thomas; Sharp-Geiger, Raeanna Racine; Dorries, Alison Marie; McCann, John Phillips; Grieggs, Tony; Saladen, Michael Thomas; Vigil-Holterman, Luciana R; Diaz, Tammy; Bacigalupa, Gian A; Erickson, Randy; Funk, David John; Torres, Enrique; Maggiore, Peter; Bishop, M. Lee; Turner, Gene E; Nickless, David J; Juarez, Catherine L; Gelles, Christine
Subject: RE: Unremediated Nitrate Salt-Bearing Waste Isolation Plan Temperature Control Update

Good morning Katie and John:

LANL Maintenance and Site Services (MSS) personnel were able to repair the TA-54 Dome 375 HVAC unit yesterday (6/23/2015) evening and the system appears to be functioning well. Reduced ambient temperatures were observed overnight in the Permacon. The repaired system will be monitored to ensure continued performance.

This information will also be provided in the Weekly Technical Submission Report and call on Thursday June 25th. Please contact me if additional information would be helpful. Thanks!

Mark Haagenstad
Environmental Protection Division
RCRA Permitting and Compliance Team Leader
Los Alamos National Security
Los Alamos National Laboratory
Office: (505) 665-2014
Mobile: (505) 699-1733

From: Haagenstad, Mark P
Sent: Tuesday, June 23, 2015 6:13 PM
To: 'Kieling, John, NMENV'; 'Cobrain, Dave, NMENV'; 'Briley, Siona, NMENV'; 'Dhawan, Neelam, NMENV'; 'Smith, Coleman, NMENV'; 'ricardo.maestas@state.nm.us'; 'kathryn.roberts@state.nm.us'
Cc: Brandt, Michael Thomas; Sharp-Geiger, Raeanna Racine; Dorries, Alison Marie; McCann, John Phillips; Grieggs, Tony; Saladen, Michael Thomas; Vigil-Holterman, Luciana R; Diaz, Tammy; Bacigalupa, Gian A; Erickson, Randy; Funk, David John; Torres, Enrique; Maggiore, Peter; 'Bishop, M. Lee'; Turner, Gene E; Nickless, David J; Juarez, Catherine L; 'Gelles, Christine'
Subject: RE: Unremediated Nitrate Salt-Bearing Waste Isolation Plan Temperature Control Update

Hello Katie and John:

Per our conversations earlier today, LANL is providing the following update regarding temperature control for the TA-54 Dome 375 Permacon:

- The LANL Maintenance and Site Services (MSS) organization received replacement parts earlier today and is currently in the process of making repairs on the system. MSS personnel have extended their work schedule into the evening to continue repairs.
- Compensatory measures currently being implemented until repairs can be completed include:
 - the use of portable cooling units outside the Permacon within Dome 375,
 - turning off the inlet air for the failed HVAC unit,
 - and opening up air communication between the cells within the Permacon via the roll-up doors.
- Upon completion of repairs and validation that the system is functioning properly, LANL will provide an update to NMED.

The information will also be provided in the Weekly Technical Submission Report and call on Thursday June 25th. Please contact me if additional information would be helpful. Thanks!

Mark Haagenstad
 Environmental Protection Division
 RCRA Permitting and Compliance Team Leader
 Los Alamos National Security
 Los Alamos National Laboratory
 Office: (505) 665-2014
 Mobile: (505) 699-1733

From: Haagenstad, Mark P
Sent: Monday, June 22, 2015 5:41 PM
To: Kieling, John, NMENV; 'Cobrain, Dave, NMENV'; Briley, Siona, NMENV; Dhawan, Neelam, NMENV; Smith, Coleman, NMENV; 'ricardo.maestas@state.nm.us'; 'kathryn.roberts@state.nm.us'
Cc: Brandt, Michael Thomas; Sharp-Geiger, Raeanna Racine; Dorries, Alison Marie; McCann, John Phillips; Grieggs, Tony; Saladen, Michael Thomas; Vigil-Holterman, Luciana R; Diaz, Tammy; Bacigalupa, Gian A; Erickson, Randy; Funk, David John; Torres, Enrique; Maggiore, Peter; 'Bishop, M. Lee'; Turner, Gene E; Nickless, David J; Juarez, Catherine L; Gelles, Christine
Subject: Unremediated Nitrate Salt-Bearing Waste Isolation Plan Temperature Control Update

Hello Katie and John:

Per our discussion with Katie and the message I left John earlier today (6/22/2015), LANL is providing the following update regarding temperature control for the TA-54 Dome 375 Permacon:

LANL management was notified today (6/22/2015) that two of the hourly ambient temperature measurements (90.61 and 90.04 °F) and one of the measurements from a SWB (90.20 °F) in the Permacon at TA-54 Dome 375 exceeded the 90 °F target temperature identified in the Isolation Plan during the hourly monitoring on 6/21/2015 (the hottest day of the year to date). Notification was made at the Plan of The Day for Area G. Investigation into the cause of the temperature increase identified that the compressor fan for HVA-003 had failed. As a result of this failure, there was no longer heat exchange taking place between the coils and the inflowing outside air. As a result, the temperature of the 54-0375 Permacon rose to near the ambient values (the HVAC system kept blowing the ambient air into the Permacon). Upon identification of the fan failure issue, an urgent request for repairs is being executed by the LANL Maintenance and Site Services (MSS) organization. A fan as well as a back-up compressor is being purchased and overnighed with repairs expected to be completed tomorrow (6/23/2015).

LANL will continue hourly temperature and visual monitoring and develop/evaluate compensatory measures in the event that repairs are delayed. LANL will provide updated notifications to NMED-HWB prior to implementation of compensatory measures. The information will also be provided in the Weekly Technical Submission Report and call on Thursday June 25th.

Please contact me if additional information would be helpful. Thanks!

Mark Haagenstad
Environmental Protection Division
RCRA Permitting and Compliance Team Leader
Los Alamos National Security
Los Alamos National Laboratory
Office: (505) 665-2014
Mobile: (505) 699-1733