

AI 856 | Los Alamos National Laboratory

Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1–June 30, 2018

ATTACHMENT A1007.A.b.

Degreaser


Completed Work Practice Checklist

MONTHLY WORK PRACTICE CHECK LIST

TA-55-DG-1 DEGREASER

R 04/20/2015

Date of Action: 1/31/18	Location of Source : (TA/BLDG/Room) TA-55-PF4-319	
Monitoring Requirements(A1007.A¹):	Yes/No	Comments
1. Does the operator monitor and record the amount of solvent added to the degreaser?	Yes	
Recordkeeping Requirements (A1007.A¹)	Yes/No	Comments
1. Are the actual emissions rate (pounds/month) of VOC and HAPS based on the quantity of solvent lost to evaporation calculated on a monthly basis?	Yes	Emissions are calculated using the Degreaser Compliance Database by air quality compliance personnel.
2. Are the semi-annual emissions rate (tons/year) calculated for this source category and added to the facility-wide emissions rates in Table 106.B (Facility-wide Allowable Emissions)?	Yes	Emissions are calculated using the Degreaser Compliance Database by air quality compliance personnel.
3. Does the operator maintain records of the degreaser solvent content?	Yes	
4. Does the operator maintain work practice checklists?	Yes	
5. Does the operator maintain records in accordance with Section B109, General Recordkeeping Requirements?	Yes	
Operational Requirements (A1007.A¹)	Yes/No	Comments
1. Does the operator ensure the degreaser is closed with a tight fitting cover whenever not in use?	Yes	
2. Does the operator maintain a freeboard ratio of 0.75 or greater?	Yes	Glove box is included in freeboard ratio determination.
3. Does the operator ensure that all collected and stored waste solvent and wipe rags are placed in closed containers?	Yes	
4. Does the operator ensure that flushing is performed only within the freeboard area only?	Yes	All rinsing is performed within the freeboard area.
5. Does the operator allow cleaned parts to drip for 15 seconds or until dripping stops (whichever is longer)?	Yes	
6. Does the operator ensure that the solvent level does not exceed the fill line on the solvent level?	Yes	
7. Does the operator ensure that all spills are wiped up immediately?	Yes	
8. Does the operator ensure that there is no creation of observable splashing with agitation device?	N/A	An air or pump agitated solvent bath is not used.

MONTHLY WORK PRACTICE CHECK LIST TA-55-DG-1 DEGREASER		
R 04/20/2015		
Operational Requirements (A1007.A ¹) continued	Yes/No	Comments
9. Does the operator ensure that the degreaser is not exposed to drafts greater than 40 meters per minute (132 feet per minute)?	yes	Glove box air flow rates based on system design descriptions average between 5 acfm (normal operating) up to 40 acfm maximum for a single glove box.
10. Does the operator ensure that no sponges, fabric, wood or paper products are cleaned in the degreaser?	yes	
Notification Requirements: If any of the boxes were checked with "No", please contact Air Quality Compliance Personnel at 665-1338.		
Comments: 		
Form completed by: <div style="display: flex; justify-content: space-between; align-items: flex-end;"> <div style="text-align: center;">  Signature </div> <div style="text-align: center;"> Arsenio Salazar Name (print) </div> <div style="text-align: center;"> 163477 Z number </div> <div style="text-align: center;"> 1/31/18 Date </div> </div>		

The permit section or condition noted at the end of each requirement is from the following reference:

¹ Title V Operating Permit No: P100-R2

All required documentation must be kept for a minimum of 5 years from the date it was gathered or from the date of the operating permit issuance (February 27, 2015).


At the end of each assessment period this form must be filed as an official record.

MONTHLY WORK PRACTICE CHECK LIST

TA-55-DG-1 DEGREASER

R 04/20/2015

Date of Action: 2/27/18	Location of Source : (TA/BLDG/Room) TA-55-PF4-319	
Monitoring Requirements(A1007.A¹):	Yes/No	Comments
1. Does the operator monitor and record the amount of solvent added to the degreaser?	Yes	
Recordkeeping Requirements (A1007.A¹)	Yes/No	Comments
1. Are the actual emissions rate (pounds/month) of VOC and HAPS based on the quantity of solvent lost to evaporation calculated on a monthly basis?	Yes	Emissions are calculated using the Degreaser Compliance Database by air quality compliance personnel.
2. Are the semi-annual emissions rate (tons/year) calculated for this source category and added to the facility-wide emissions rates in Table 106.B (Facility-wide Allowable Emissions)?	Yes	Emissions are calculated using the Degreaser Compliance Database by air quality compliance personnel.
3. Does the operator maintain records of the degreaser solvent content?	Yes	
4. Does the operator maintain work practice checklists?	Yes	
5. Does the operator maintain records in accordance with Section B109, General Recordkeeping Requirements?	Yes	
Operational Requirements (A1007.A¹)	Yes/No	Comments
1. Does the operator ensure the degreaser is closed with a tight fitting cover whenever not in use?	Yes	
2. Does the operator maintain a freeboard ratio of 0.75 or greater?	Yes	Glove box is included in freeboard ratio determination.
3. Does the operator ensure that all collected and stored waste solvent and wipe rags are placed in closed containers?	Yes	
4. Does the operator ensure that flushing is performed only within the freeboard area only?	Yes	All rinsing is performed within the freeboard area.
5. Does the operator allow cleaned parts to drip for 15 seconds or until dripping stops (whichever is longer)?	Yes	
6. Does the operator ensure that the solvent level does not exceed the fill line on the solvent level?	Yes	
7. Does the operator ensure that all spills are wiped up immediately?	Yes	
8. Does the operator ensure that there is no creation of observable splashing with agitation device?	N/A	An air or pump agitated solvent bath is not used.

MONTHLY WORK PRACTICE CHECK LIST TA-55-DG-1 DEGREASER		
R 04/20/2015		
Operational Requirements (A1007.A ¹) continued	Yes/No	Comments
9. Does the operator ensure that the degreaser is not exposed to drafts greater than 40 meters per minute (132 feet per minute)?	yes	Glove box air flow rates based on system design descriptions average between 5 acfm (normal operating) up to 40 acfm maximum for a single glove box.
10. Does the operator ensure that no sponges, fabric, wood or paper products are cleaned in the degreaser?	yes	
Notification Requirements: If any of the boxes were checked with "No", please contact Air Quality Compliance Personnel at 665-1338.		
Comments: 		
Form completed by: <div style="display: flex; justify-content: space-between; align-items: flex-end;"> <div style="text-align: center;">  Signature </div> <div style="text-align: center;"> Arsenio Salazar Name (print) </div> <div style="text-align: center;"> 163429 Z number </div> <div style="text-align: center;"> 2/27/18 Date </div> </div>		

The permit section or condition noted at the end of each requirement is from the following reference:

¹ Title V Operating Permit No: P100-R2


All required documentation must be kept for a minimum of 5 years from the date it was gathered or from the date of the operating permit issuance (February 27, 2015).

At the end of each assessment period this form must be filed as an official record.

MONTHLY WORK PRACTICE CHECK LIST **TA-55-DG-1 DEGREASER**

R 04/20/2015

Date of Action: 3/30/18		Location of Source : (TA/BLDG/Room) TA-55-PF4-319	
Monitoring Requirements(A1007.A¹):		Yes/No	Comments
1. Does the operator monitor and record the amount of solvent added to the degreaser?		yes	
Recordkeeping Requirements (A1007.A¹)		Yes/No	Comments
1. Are the actual emissions rate (pounds/month) of VOC and HAPS based on the quantity of solvent lost to evaporation calculated on a monthly basis?		Yes	Emissions are calculated using the Degreaser Compliance Database by air quality compliance personnel.
2. Are the semi-annual emissions rate (tons/year) calculated for this source category and added to the facility-wide emissions rates in Table 106.B (Facility-wide Allowable Emissions)?		Yes	Emissions are calculated using the Degreaser Compliance Database by air quality compliance personnel.
3. Does the operator maintain records of the degreaser solvent content?		yes	
4. Does the operator maintain work practice checklists?		yes	
5. Does the operator maintain records in accordance with Section B109, General Recordkeeping Requirements?		yes	
Operational Requirements (A1007.A¹)		Yes/No	Comments
1. Does the operator ensure the degreaser is closed with a tight fitting cover whenever not in use?		yes	
2. Does the operator maintain a freeboard ratio of 0.75 or greater?		yes	Glove box is included in freeboard ratio determination.
3. Does the operator ensure that all collected and stored waste solvent and wipe rags are placed in closed containers?		yes	
4. Does the operator ensure that flushing is performed only within the freeboard area only?		yes	All rinsing is performed within the freeboard area.
5. Does the operator allow cleaned parts to drip for 15 seconds or until dripping stops (whichever is longer)?		yes	
6. Does the operator ensure that the solvent level does not exceed the fill line on the solvent level?		yes	
7. Does the operator ensure that all spills are wiped up immediately?		yes	
8. Does the operator ensure that there is no creation of observable splashing with agitation device?		N/A	An air or pump agitated solvent bath is not used.

MONTHLY WORK PRACTICE CHECK LIST TA-55-DG-1 DEGREASER		
R 04/20/2015		
Operational Requirements (A1007.A ¹) continued	Yes/No	Comments
9. Does the operator ensure that the degreaser is not exposed to drafts greater than 40 meters per minute (132 feet per minute)?	Yes	Glove box air flow rates based on system design descriptions average between 5 acfm (normal operating) up to 40 acfm maximum for a single glove box.
10. Does the operator ensure that no sponges, fabric, wood or paper products are cleaned in the degreaser?	Yes	
Notification Requirements: If any of the boxes were checked with "No", please contact Air Quality Compliance Personnel at 665-1338.		
Comments: 		
Form completed by: <div style="display: flex; justify-content: space-between; align-items: flex-end;"> <div style="text-align: center;">  Signature </div> <div style="text-align: center;"> Arsenio Salazar Name (print) </div> <div style="text-align: center;"> 163479 Z number </div> <div style="text-align: center;"> 3/30/12 Date </div> </div>		

The permit section or condition noted at the end of each requirement is from the following reference:

¹ Title V Operating Permit No: P100-R2


All required documentation must be kept for a minimum of 5 years from the date it was gathered or from the date of the operating permit issuance (February 27, 2015).

At the end of each assessment period this form must be filed as an official record.

MONTHLY WORK PRACTICE CHECK LIST **TA-55-DG-1 DEGREASER**

R 04/20/2015

Date of Action: 4/30/18		Location of Source : (TA/BLDG/Room) TA-55-PF4-319	
Monitoring Requirements(A1007.A¹):		Yes/No	Comments
1. Does the operator monitor and record the amount of solvent added to the degreaser?		Yes	
Recordkeeping Requirements (A1007.A¹)		Yes/No	Comments
1. Are the actual emissions rate (pounds/month) of VOC and HAPS based on the quantity of solvent lost to evaporation calculated on a monthly basis?		Yes	Emissions are calculated using the Degreaser Compliance Database by air quality compliance personnel.
2. Are the semi-annual emissions rate (tons/year) calculated for this source category and added to the facility-wide emissions rates in Table 106.B (Facility-wide Allowable Emissions)?		Yes	Emissions are calculated using the Degreaser Compliance Database by air quality compliance personnel.
3. Does the operator maintain records of the degreaser solvent content?		Yes	
4. Does the operator maintain work practice checklists?		Yes	
5. Does the operator maintain records in accordance with Section B109, General Recordkeeping Requirements?		Yes	
Operational Requirements (A1007.A¹)		Yes/No	Comments
1. Does the operator ensure the degreaser is closed with a tight fitting cover whenever not in use?		Yes	
2. Does the operator maintain a freeboard ratio of 0.75 or greater?		Yes	Glove box is included in freeboard ratio determination.
3. Does the operator ensure that all collected and stored waste solvent and wipe rags are placed in closed containers?		Yes	
4. Does the operator ensure that flushing is performed only within the freeboard area only?		Yes	All rinsing is performed within the freeboard area.
5. Does the operator allow cleaned parts to drip for 15 seconds or until dripping stops (whichever is longer)?		Yes	
6. Does the operator ensure that the solvent level does not exceed the fill line on the solvent level?		Yes	
7. Does the operator ensure that all spills are wiped up immediately?		Yes	
8. Does the operator ensure that there is no creation of observable splashing with agitation device?		N/A	An air or pump agitated solvent bath is not used.

MONTHLY WORK PRACTICE CHECK LIST TA-55-DG-1 DEGREASER		
R 04/20/2015		
Operational Requirements (A1007.A ¹) continued	Yes/No	Comments
9. Does the operator ensure that the degreaser is not exposed to drafts greater than 40 meters per minute (132 feet per minute)?	yes	Glove box air flow rates based on system design descriptions average between 5 acfm (normal operating) up to 40 acfm maximum for a single glove box.
10. Does the operator ensure that no sponges, fabric, wood or paper products are cleaned in the degreaser?	yes	
Notification Requirements: If any of the boxes were checked with "No", please contact Air Quality Compliance Personnel at 665-1338.		
Comments: 		
Form completed by: <div style="display: flex; justify-content: space-between;"> <div style="text-align: center;">  Signature </div> <div style="text-align: center;"> Arsenio Salazar Name (print) </div> <div style="text-align: center;"> 163419 Z number </div> <div style="text-align: center;"> 4/30/18 Date </div> </div>		

The permit section or condition noted at the end of each requirement is from the following reference:

¹ Title V Operating Permit No: P100-R2

All required documentation must be kept for a minimum of 5 years from the date it was gathered or from the date of the operating permit issuance (February 27, 2015).


At the end of each assessment period this form must be filed as an official record.

MONTHLY WORK PRACTICE CHECK LIST

TA-55-DG-1 DEGREASER

R 04/20/2015

Date of Action: 5/29/18	Location of Source : (TA/BLDG/Room) TA-55-PF4-319	
Monitoring Requirements(A1007.A¹):	Yes/No	Comments
1. Does the operator monitor and record the amount of solvent added to the degreaser?	Yes	
Recordkeeping Requirements (A1007.A¹)	Yes/No	Comments
1. Are the actual emissions rate (pounds/month) of VOC and HAPS based on the quantity of solvent lost to evaporation calculated on a monthly basis?	Yes	Emissions are calculated using the Degreaser Compliance Database by air quality compliance personnel.
2. Are the semi-annual emissions rate (tons/year) calculated for this source category and added to the facility-wide emissions rates in Table 106.B (Facility-wide Allowable Emissions)?	Yes	Emissions are calculated using the Degreaser Compliance Database by air quality compliance personnel.
3. Does the operator maintain records of the degreaser solvent content?	Yes	
4. Does the operator maintain work practice checklists?	Yes	
5. Does the operator maintain records in accordance with Section B109, General Recordkeeping Requirements?	Yes	
Operational Requirements (A1007.A¹)	Yes/No	Comments
1. Does the operator ensure the degreaser is closed with a tight fitting cover whenever not in use?	Yes	
2. Does the operator maintain a freeboard ratio of 0.75 or greater?	Yes	Glove box is included in freeboard ratio determination.
3. Does the operator ensure that all collected and stored waste solvent and wipe rags are placed in closed containers?	Yes	
4. Does the operator ensure that flushing is performed only within the freeboard area only?	Yes	All rinsing is performed within the freeboard area.
5. Does the operator allow cleaned parts to drip for 15 seconds or until dripping stops (whichever is longer)?	Yes	
6. Does the operator ensure that the solvent level does not exceed the fill line on the solvent level?	Yes	
7. Does the operator ensure that all spills are wiped up immediately?	Yes	
8. Does the operator ensure that there is no creation of observable splashing with agitation device?	N/A	An air or pump agitated solvent bath is not used.

MONTHLY WORK PRACTICE CHECK LIST TA-55-DG-1 DEGREASER		
R 04/20/2015		
Operational Requirements (A1007.A ¹) continued	Yes/No	Comments
9. Does the operator ensure that the degreaser is not exposed to drafts greater than 40 meters per minute (132 feet per minute)?	yes	Glove box air flow rates based on system design descriptions average between 5 acfm (normal operating) up to 40 acfm maximum for a single glove box.
10. Does the operator ensure that no sponges, fabric, wood or paper products are cleaned in the degreaser?	yes	
Notification Requirements: If any of the boxes were checked with "No", please contact Air Quality Compliance Personnel at 665-1338.		
Comments: 		
Form completed by: <div style="display: flex; justify-content: space-between; align-items: flex-end;"> <div style="text-align: center;">  Signature </div> <div style="text-align: center;"> Arsenio Salazar Name (print) </div> <div style="text-align: center;"> 163479 Z number </div> <div style="text-align: center;"> 5/29/18 Date </div> </div>		

The permit section or condition noted at the end of each requirement is from the following reference:

¹ Title V Operating Permit No: P100-R2


All required documentation must be kept for a minimum of 5 years from the date it was gathered or from the date of the operating permit issuance (February 27, 2015).

At the end of each assessment period this form must be filed as an official record.

MONTHLY WORK PRACTICE CHECK LIST
TA-55-DG-1 DEGREASER

R 04/20/2015

Date of Action: 6/26/18	Location of Source : (TA/BLDG/Room) TA-55-PF4-319	
Monitoring Requirements(A1007.A¹):	Yes/No	Comments
1. Does the operator monitor and record the amount of solvent added to the degreaser?	Yes	
Recordkeeping Requirements (A1007.A¹)	Yes/No	Comments
1. Are the actual emissions rate (pounds/month) of VOC and HAPS based on the quantity of solvent lost to evaporation calculated on a monthly basis?	Yes	Emissions are calculated using the Degreaser Compliance Database by air quality compliance personnel.
2. Are the semi-annual emissions rate (tons/year) calculated for this source category and added to the facility-wide emissions rates in Table 106.B (Facility-wide Allowable Emissions)?	Yes	Emissions are calculated using the Degreaser Compliance Database by air quality compliance personnel.
3. Does the operator maintain records of the degreaser solvent content?	Yes	
4. Does the operator maintain work practice checklists?	Yes	
5. Does the operator maintain records in accordance with Section B109, General Recordkeeping Requirements?	Yes	
Operational Requirements (A1007.A¹)	Yes/No	Comments
1. Does the operator ensure the degreaser is closed with a tight fitting cover whenever not in use?	Yes	
2. Does the operator maintain a freeboard ratio of 0.75 or greater?	Yes	Glove box is included in freeboard ratio determination.
3. Does the operator ensure that all collected and stored waste solvent and wipe rags are placed in closed containers?	Yes	
4. Does the operator ensure that flushing is performed only within the freeboard area only?	Yes	All rinsing is performed within the freeboard area.
5. Does the operator allow cleaned parts to drip for 15 seconds or until dripping stops (whichever is longer)?	Yes	
6. Does the operator ensure that the solvent level does not exceed the fill line on the solvent level?	Yes	
7. Does the operator ensure that all spills are wiped up immediately?	Yes	
8. Does the operator ensure that there is no creation of observable splashing with agitation device?	N/A	An air or pump agitated solvent bath is not used.

MONTHLY WORK PRACTICE CHECK LIST TA-55-DG-1 DEGREASER		
R 04/20/2015		
Operational Requirements (A1007.A ¹) continued	Yes/No	Comments
9. Does the operator ensure that the degreaser is not exposed to drafts greater than 40 meters per minute (132 feet per minute)?	yes	Glove box air flow rates based on system design descriptions average between 5 acfm (normal operating) up to 40 acfm maximum for a single glove box.
10. Does the operator ensure that no sponges, fabric, wood or paper products are cleaned in the degreaser?	yes	
Notification Requirements: If any of the boxes were checked with "No", please contact Air Quality Compliance Personnel at 665-1338.		
Comments: 		
Form completed by: <div style="display: flex; justify-content: space-between; align-items: flex-end;"> <div style="text-align: center;">  Signature </div> <div style="text-align: center;"> Arsenio Salazar Name (print) </div> <div style="text-align: center;"> 163479 Z number </div> <div style="text-align: center;"> 6/26/18 Date </div> </div>		

The permit section or condition noted at the end of each requirement is from the following reference:

¹ Title V Operating Permit No: P100-R2

All required documentation must be kept for a minimum of 5 years from the date it was gathered or from the date of the operating permit issuance (February 27, 2015).

At the end of each assessment period this form must be filed as an official record.

AI 856 | Los Alamos National Laboratory

Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1–June 30, 2018

ATTACHMENT A1104.A.

Internal Combustion

TA-33-G-1-P Daily Operating Logs

Daily TA-33-G-1-P Cummins/ONAN/DFHD 1000 kW Generator Hour Log

This generator has the following air quality permit requirements:

This generator engine is authorized to operate **no more than eight (8) hours per day.**

This unit can operate only between the hours of 7:00 AM and 5:00 PM

The permittee shall monitor the time(s) of operation each day.

The permittee shall monitor and keep records of the time(s) of operation each day, and the daily, monthly, and the monthly rolling 12-month total hours of operation of the genset (LANL ENV-CP will maintain this)

[illegible]

Version June 2018 | Air Quality Permit P100-R2M1 & P100-R2M2, Section A1104

Asked operators to note time of operation.

Contact: Paul Sanchez, 505-231-4342

AI 856 | Los Alamos National Laboratory

Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1–June 30, 2018

ATTACHMENT A1104.B.

Internal Combustion Permitted Generator Hours

YEAR				2018										Permitted Generators										First Half				Second Half			
Permit ID	Location	ID #	Engine Make	Engine Model	Engine Serial #	gen kW/e	engine kW/m	Reading 2nd half of previous year	6 Month Reading Date	Reading	Hours Run	12 Month Reading Date	Reading	Hours Run	* Total Run Hours																
TA-33-G-1P	33-Port	G-0053	Cummins	QST30-G5	37199764	1000	281.25	Dec-17	Jun-18	694.7	696.1	1.4		0.0	1.4																
TA-33-G-2	33-209	G-0008	Kohler/Yanm ar	4TNE84T	52993	20	25	Dec-17	Jun-18	488.9	469.0	0.1		0.0	0.1																
TA-33-G-3	33-280	G-0010	Kohler/Yanm ar	4TNE84T	52992	20	25	Dec-17	Jun-18	233.9	233.9	0.0		0.0	0.0																
TA-33-G-4	33-151	G-0007	Caterpillar	3306	8JJ00615	225	281.25	Dec-17	Jun-18	3766.0	3770.0	4.0		0.0	4.0																
RLUOB-GEN-1	55-585	G-0058	Cummins	KTA50G9	25314401	1500	1656.1	Dec-17	Jun-18	221.9	221.9	0.0		0.0	0.0																
RLUOB-GEN-2	55-584	G-0059	Cummins	KTA50G9	25314399	1500	1656.1	Dec-17	Jun-18	172.7	215.7	43.0		0.0	43.0																
RLUOB-GEN-3	55-583	G-0060	Cummins	KTA50G9	33165566	1500	1656.1	Dec-17	Jun-18	159.4	172.9	13.5		0.0	13.5																
TA-48-GEN-1	TA-48-1	G-0067	Cummins	QSB7-G3 NR3	73176927	150	186					0.0		0.0	0.0																
TA-55-GEN-1	TA-55-PF10	G-0065	Isuzu	BZ-4LE2T	4LE2-298868	30	40.2	Dec-17	Jun-18	15.0	15.0	0.0		0.0	0.0																
TA-55-GEN-2	TA-55-PF11	G-0066	Isuzu	BZ-4LE2T	4LE2-299432	30	40.2	Dec-17	Jun-18	14.0	14.0	0.0		0.0	0.0																
TA-55-GEN-3	TA-55-371	G-0064	Caterpillar	C32	SYCO5263	900	1335	Dec-17	Jun-18	91.7	98.6	6.9		0.0	6.9																

Note: TA-33-G-1 has been removed and no longer on site. TA-48-GEN-1 has not started up as of June 2018

The TA-33 225 kW & two 20 kW generators have limits of 500 hrs/yr.

RLUOB-GENs, TA-48 GEN, TA-55-GENs are subject to NSPS IIII regulation; nonemergency operation limited to 100 hrs/yr

AI 856 | Los Alamos National Laboratory

Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1–June 30, 2018

ATTACHMENT A1106.A.

Internal Combustion Method 9 Opacity Reports

Opacity measurements were not required or conducted during this monitoring period.

AI 856 | Los Alamos National Laboratory

Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1–June 30, 2018

ATTACHMENT A1107.A.

Internal Combustion

Operating Records for RLUOB Generators

Cummins Generator		Cummins Serial # 1060976810 Gen A				Model DFLE 5754172
Authorized Worker	Date	Start Time	End Time	Run Time	Run Time Accumulative	Reason/Notes
Michael Soumyez	8/22/16	1405	1530	1.5	209.7	Monthly PM
Michael Soumyez	9-20-16	1300	1530	2.5	212.8	Monthly PM
Michael Soumyez	10/13/16	0900	1100	2.0	214.8	Monthly PM
Michael Soumyez	11-3-16	1400	1530	1.5	216.3	Monthly PM
Michael Soumyez	12-7-16	0950	1302	1.8	218.1	Monthly PM
Michael Soumyez	6-13-17	0800	0830	0.7	218.8	Open OS house used air for TS/Rep
Michael Soumyez	7-6-17	0945	1100	1.3	220.1	Monthly PM
Michael Soumyez	9/14/17	0930	1130	1.8	221.9	Monthly PM Trouble Shooting

Cummins Generator		Cummins Serial # 1060976811 Gen B				Model DFLE 5754172
Authorized Worker	Date	Start Time	End Time	Run Time	Run Time Accumulative	Reason/Notes
Michael Dominguez	9.20.16	8:15	11:20	3.4	160.2	Monthly PM
Michael Dominguez	10/13/16	12:50	15:20	2.5	162.7	Monthly PM
Michael Dominguez	11.3.16	8:30	11:00	2.3	165.0	Monthly PM
Michael Dominguez	12.7.16	10:05	13:15	2.0	167.0	Monthly PM
Michael Dominguez	2.7.17	12:00	13:00	0.7	167.7	Monthly PM
Michael Dominguez	6.13.17	08:30	08:49	0.1	167.8	Code 05 hours used for TS/Repair
Michael Dominguez	7.6.17	—	—	0	167.8	Monthly PM
Michael Dominguez	9/14/17	0930	1400	3.7	171.0	Monthly PM
Michael Dominguez	10/26/17	1005	1415	1.7	172.7	Monthly PM
Michael Dominguez	11/7/17	0935	1330	1.9	174.6	Monthly PM
Michael Dominguez	12/5/17	1015	1400	2.1	176.7	Monthly PM
Michael Dominguez	01/21/17	0930	1130	1.8	178.5	Monthly PM
Michael Dominguez	02/08/18	0945	1400	4.2	182.7	Monthly PM
Michael Dominguez	3/8/18	1000	1345	3.2	185.9	Monthly PM
Michael Dominguez	4/4/18	1100	2000	24.2	210.1	Monthly PM / Test, ATIS-F
Michael Dominguez	5/2/18	8:40	1300	3.3	213.4	Monthly PM
Michael Dominguez	6/4/18	0945	1330	2.3	215.7	Monthly PM

Cummins Generator		Cummins Serial # 1060976812 Gen C				Model DFLE 575A172
Authorized Worker	Date	Start Time	End Time	Run Time	Run Time Accumulative	Reason/Notes
FEED SEYBET	11-19-15	0500	1500	1.6	132.3	MONTHLY PM
FEED SEYBET	12-17-15	0845	1513	1.6	133.9	MONTHLY PM
FEED SEYBET	12-29-15	0814	0838	0.4	134.3	MONTHLY GLITCH
FEED SEYBET	01-13-16	0845	1530	1.7	136.0	MONTHLY PM
FEED SEYBET	1-15-16	0951	1616	0.4	136.4	1YR/5YR PM
FEED SEYBET	2-18-16	0850	1330	1.5	137.9	MONTHLY PM
FEED SEYBET	3-27-16	0915	1515	1.5	139.4	MONTHLY LOAD TEST
FEED SEYBET	3-28-16	1130	1215	0.4	139.8	MONTHLY ATS TEST
FEED SEYBET	4-28-16	0935	1047	1.6	141.4	MONTHLY PM
FEED SEYBET	5-5-16	0930	1100	1.6	143.0	MONTHLY PM
FEED SEYBET	6-28-16	0935	1035	0.5	143.5	MONTHLY PM
FEED SEYBET	7-7-16	0948	1100	1.7	146.9	MONTHLY PM
FEED SEYBET	8/4/16	2000	2010	0.2	147.1	Power Ramp
FEED SEYBET	8/22/16	1400	1500	0.9	148.0	MONTHLY PM
FEED SEYBET	9-20-16	1300	1530	3.2	151.2	MONTHLY PM
FEED SEYBET	10-13-16	1250	1520	2.2	153.4	MONTHLY PM
FEED SEYBET	11-3-16	0830	1100	1.9	155.3	MONTHLY PM
FEED SEYBET	12-7-16	1035	1345	1.6	156.9	MONTHLY PM
FEED SEYBET	2-7-17	1200	1300	0.4	157.3	MONTHLY PM
FEED SEYBET	6-13-17	1000	1200	1.8	159.1	Gen OS hours used for TS/Repair
FEED SEYBET	7-6-17	—	—	0	159.1	MONTHLY PM
FEED SEYBET	9/14/17	9:30	10:00	0.3	159.4	MONTHLY PM
FEED SEYBET	10/26/17	10:00	1500	1.7	161.1	MONTHLY PM
FEED SEYBET	10/26/17	—	—	—	—	Gen C placed out of service
FEED SEYBET	2/8/18	0900	1150	1.5	162.6	MONTHLY PM
FEED SEYBET	3/8/18	0950	1230	1.6	164.2	MONTHLY PM
FEED SEYBET	4/14/18	11:30	2000	5.5	169.7	MONTHLY PM
FEED SEYBET	5/2/18	8:40	12:00	1.4	171.1	MONTHLY PM
FEED SEYBET	6/14/18	0945	1300	1.8	172.9	MONTHLY PM

AI 856 | Los Alamos National Laboratory

Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1 – June 30, 2018

Attachment A1107.B. Generators – Operating records

TA-48-Gen-1 has not been installed.

See Attachment A1104.B. for TA-55-GEN-1, TA-55-GEN-2 and TA-55-GEN-3 records.

AI 856 | Los Alamos National Laboratory

Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1–June 30, 2018

ATTACHMENT A1207.A.

Data Disintegrator

Operating Logs

2018 TA-52 Data Disintegrator (EQPT 89)

Data Entry		Data Entry	
Month	Boxes ^(c) Shredded	Month	Boxes ^(c) Shredded
January	656	July	
February	734	August	
March	650	September	
April	776	October	
May	870	November	
June	1561	December	
6 mo. Total:	5,247	6 mo. Total:	0

Annual Boxes: ^(g)	5,247
------------------------------	-------

Reviewed By / Date:

V. Carretti 7/03/2018

AI 856 | Los Alamos National Laboratory

Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1–June 30, 2018

ATTACHMENT A1207.B.

Data Disintegrator

Maintenance Performed

LANL Data Disintegrator - Maintenance Records

January - June 2018							
TA/BLDG	Work Order	Task	Job Type	Task Title	Task Status	Actual Start Date	Completion Date
52/0011	00589389	1	CM	520011 Replace Bag Filters at Shaker/baghouse unit	CLOSED	3/5/2018	5/17/2018
52/0011	00604872	1	PM	520011 6M Cyclone Separator/Shaker Lube Inspection	CLOSED	4/4/2018	5/10/2018

*Starting in 2016 all Maintenance documentation is being done electronically via iPads. Copy of Work Order and Screen Shot of documented completion is attached.

July - December 2018							
TA/BLDG	Work Order	Task	Job Type	Task Title	Task Status	Actual Start Date	Completion Date

*Starting in 2016 all Maintenance documentation is being done electronically via iPads. Copy of Work Order and Screen Shot of documented completion is attached.

A1207.B Data Disintegrator - Control Equipment Maintenance Performed

LANL Air Quality Permit P100-R2M1 and P100-R2M2

2018 Data Disintegrator Maintenance Records

LANL ADESH-18-050 / LA-UR-18-26940

AI856 / LANL 2018H1 Semi-Annual Monitoring Report

Facility: F07 Unit: 520011 Proj:

Task Title: 3GF 52-0011 MULTI-CRAFTS-DESTRUCTION

FACILITY-MAINT

W/O Type: CO W/O Group: 3J ROMER Task Priority: 3

Planner : 090467 ROMERO A J

W/O Title: 3GF 52-0011 MULTI-CRAFTS-DESTRUCTION FAC

Written To: (WO) GF 52-0011 MULTI-CRAFTS-DESTRUCTION

Task Dspln: M Due Date: 08/03/2017



D-B Determination: NON-COVERED D-B Date: 11/28/17

Tracking Number: 18-442

Hazard: MODERATE IWD Reqmt: TASK SPECIFIC



Work Order Task

00589389 01

MASTER

Date: 01/26/2018

Page: 1

Work Order Task Written To

Facility : F07

Unit : 520011

Op Sys :

Room :

Area :

Sys/Cls:

Equipment :

Component:

Location : TA 52, BLDG 0011

Job Type : CO

Tag 1 :



Tag 2 :

Work Item :

Ops Review Reqd: N

Authorization

Start Permission :  ☐ ☐ ☐
Complete Notice :  ☐ ☐ ☐

Start Date:  ☐ ☐ ☐
Complete Date:  ☐ ☐ ☐

NOTE:

* Refer to attached Form 2101 - Non-Tenant Activity Form - or Form 2102-Tenant Activity Form - for a description of site specific training or escort and access requirements.

Work Order Task Instructions

CREW NO. SUPERVISOR NO:su092185 KENNY CHAVEZ CELL: 231-1635

IWD REQUIRED TM 094821 8/7/17

.Contact Information

Primary MC Joe Allen Romero 667-3662; 699-6852; 664-1513 TA-3-142-7

Backup MC Tony Rodriguez 665-5285; 670-6584; 664-4059 ta3-142-7

Ops Manager Bill Schleft 667-8941; 699-5790; 664-3536

M/L:4

TEXT DESCRIPTION

Facility: F07 Unit: 520011 Proj:
Task Title: 3GF 52-0011 MULTI-CRAFTS-DESTRUCTION
FACILITY-MAINT

W/O Type: CO W/O Group: 3J ROMER Task Priority: 3
Planner : 090467 ROMERO A J
W/O Title: 3GF 52-0011 MULTI-CRAFTS-DESTRUCTION FAC
Written To: (WO) GF 52-0011 MULTI-CRAFTS-DESTRUCTION
Task Dspln: M Due Date: 08/03/2017



D-B Determination: NON-COVERED D-B Date: 11/28/17
Tracking Number: 18-442
Hazard: MODERATE IWD Reqmt: TASK SPECIFC



Work Order Task

00589389 01

MASTER

Date: 01/26/2018
Page: 2

CALIBRATED TOOL REQUIRED () YES () NO

FILE NO:

EXPIRATION DATE:

DATE CHECKED OUT:

NOTE: ASSIGNED CRAFTS SHALL FOLLOW ALL APPLICABLE STATE, FEDERAL AND LANL
CODES AND STANDARDS.

ORIGINATOR: JOE ROMERO

TELEPHONE#: 7-3662

CONFIGURATION MANAGEMENT REVIEW REQUIRED] [] YES [X] NO

CHECK CRAFTS REQUIRED:

[] CUSTODIAL	[] ELECTRICIANS	[] LABORERS
[] TEAMSTERS	[] OPERATING ENGINEERS	[] PAINTERS
[] FITTERS	[] CEMENT MASONS	[XX] CARPENTERS
[] ROOFERS	[XX] IRON WORKERS	[] INSULATORS
[XX] SHEETMETAL	[XX] MECHANICS	[] ENGINEERING
[] OTHER (SPECIFY) :		

AUTHORIZED FUNDING LEVEL:

FUNDING APPROVED BY:

Z#

DATE:

LOG-IN REQUIRED: [X] YES [] NO LOG-OUT REQUIRED: [X] YES [] NO

LOCATION OF LOG-IN: TA-3-142

Weekly Schedule or Plan of the Day

Facility: F07 Unit: 52001 Proj:

Task Title: 3GF 52-0011 MULTI-CRAFTS-DESTRUCTION
FACILITY-MAINT

W/O Type: CO W/O Group: 3J ROMER Task Priority: 3

Planner : 090467 ROMERO A J

W/O Title: 3GF 52-0011 MULTI-CRAFTS-DESTRUCTION FAC

Written To: (WO) GF 52-0011 MULTI-CRAFTS-DESTRUCTION

Task Dspln: M Due Date: 08/03/2017



D-B Determination: NON-COVERED D-B Date: 11/28/17

Tracking Number: 18-442

Hazard: MODERATE IWD Reqmt: TASK SPECIFC

**Work Order Task**

00589389 01

MASTER

Date: 01/26/2018

Page: 3

*
CHECK-IN REQUIRED: [X] YES [] NO CHECK-OUT REQUIRED: [X] YES [] NO
LOCATION OF CHECK-IN/CHECK-OUT:

*
PLANT ENGINEERING REVIEW:

PE REVIEW REQUIRED [] YES [X] NO

PE INSPECTION APPROVAL [] YES [X] NO

*
All debris/trash created by this work will be removed prior to completion
of job or work day.

*
REQUESTING THE MECHANICS TO REPLACE MULTIPLE
Mechanics replace bag filters at the shaker/bag house unit. This will
include carpenters to install scaffolding also requesting Sheet metal to
remove outer panels to get access to this bag filters. Iron workers to
fabricate a shaker arm once unit is disassembled.

POC: JOHNNY D. MAES 665-7752

QC Requirements/Comments**Rework Reason/Cause**

CDSG CUSTOMER DESIGN

IMCW IMPROPER CONSTRUCTION/WORKMANSHIP

IMDN IMPROPER DESIGN

PDMS PARTS/MATERIAL DID NOT MEET SPECIFICATIONS

WR WARRANTY REWORK/REPAIR

(Y/N)

Date:

Hours:

Crew:

Shift:

Comments:

Facility: F07 Unit: 520011 Proj:
 Task Title: 3GF 52-0011 MULTI-CRAFTS-DESTRUCTION
 FACILITY-MAINT

W/O Type: CO W/O Group: 3J ROMER Task Priority: 3
 Planner : 090467 ROMERO A J
 W/O Title: 3GF 52-0011 MULTI-CRAFTS-DESTRUCTION FAC
 Written To: (WO) GF 52-0011 MULTI-CRAFTS-DESTRUCTION
 Task Dspln: M Due Date: 08/03/2017



D-B Determination: NON-COVERED D-B Date: 11/28/17
 Tracking Number: 18-442
 Hazard: MODERATE IWD Reqmt: TASK SPECIFIC



Work Order Task

00589389 01

MASTER

Date: 01/26/2018
 Page: 4

Rework/Approval

Deficiency Tag No.: Loc: Tag Removed:
 ReWork Job : N Comments:

Trouble Found/Work Performed

Continued on Additional Sheets? : _____

Work Delay Reason

				(Y/N)
A ACCESS	Date: <input type="text"/>	Hours: <input type="text"/>	Crew: <input type="text"/>	<input type="checkbox"/>
EQPT EQUIPMENT	Date: <input type="text"/>	Hours: <input type="text"/>	Crew: <input type="text"/>	<input type="checkbox"/>
IWD IWD WORKABILITY	Date: <input type="text"/>	Hours: <input type="text"/>	Crew: <input type="text"/>	<input type="checkbox"/>
MAT MATERIAL	Date: <input type="text"/>	Hours: <input type="text"/>	Crew: <input type="text"/>	<input type="checkbox"/>
OPS OPERATIONS	Date: <input type="text"/>	Hours: <input type="text"/>	Crew: <input type="text"/>	<input type="checkbox"/>
RCT RCT AVAILABILITY	Date: <input type="text"/>	Hours: <input type="text"/>	Crew: <input type="text"/>	<input type="checkbox"/>
SP SAFETY PAUSE	Date: <input type="text"/>	Hours: <input type="text"/>	Crew: <input type="text"/>	<input type="checkbox"/>
TEL TOOLS/EQUIP/LIFTS	Date: <input type="text"/>	Hours: <input type="text"/>	Crew: <input type="text"/>	<input type="checkbox"/>
W WEATHER	Date: <input type="text"/>	Hours: <input type="text"/>	Crew: <input type="text"/>	<input type="checkbox"/>

Comments:

LANL ADESH-18-050 / LA-UR-18-26940
Facility: F07 Unit: 5200

Proj:

AI856 / LANL 2018H1 Semi-Annual Monitoring Report

Task Title: 3GF 52-0011 MULTI-CRAFTS-DESTRUCTION
FACILITY-MAINT

W/O Type: CO W/O Group: 3J ROMER Task Priority: 3

Planner : 090467 ROMERO A J

W/O Title: 3GF 52-0011 MULTI-CRAFTS-DESTRUCTION FAC

Written To: (WO) GF 52-0011 MULTI-CRAFTS-DESTRUCTION

Task Dspln: M Due Date: 08/03/2017



D-B Determination: NON-COVERED D-B Date: 11/28/17

Tracking Number: 18-442

Hazard: MODERATE IWD Reqmt: TASK SPECIFC



Work Order Task

00589389 01

MASTER

Date: 01/26/2018

Page: 5

Major Failure/Action Taken

Major Failure : Action Taken :
Deficiency Tag Loc: Removed (Y/N):
Deficiency Tag No.: Limited Cond Operation:

Work Completion Signatures

Name	Function/Dept.	Date
Eric Fernandez	Mech For 7	4-2-18


Comments:
(rework?)

***** E N D O F R E P O R T *****

Cost Center: 8K040A
Percentage : 100.000

Activity : 640CL000 User Def:
Acct No : WL2300 00000000

FORM 2100-WC

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision #: 0		Activity/Task Title: TA-52-0011 MULTI-CRAFTS-DESTRUCTION FACILITY-MAINT	
Work Document #: (WO # / Task) 589389-01		Planner/Preparer (Name/Z#/Date) Ralph Dominguez, 100538 01-09-18	
TA: 52	Building: 0011	Room:	Additional Location Description:

1. SCOPE OF WORK

Mechanics replace bag filters at the shaker/bag house unit. This will include carpenters to install scaffolding also requesting Sheet metal to remove outer panels to get access to this bag filters. Iron workers to fabricate a shaker arm once unit is disassembled. POC: JOHNNY D. MAES 665-7752

Hazard Analysis (HA) Team: Ralph Dominguez, Eric Fernandez and Daniel Calanche

Date: 01-09-18

2. PRECAUTIONS AND LIMITATIONS

- 2.1. If steps cannot be completed as described, or if unforeseen situations occur, **PAUSE WORK**, stabilize the situation, contact your supervisor, and await further instructions before proceeding.
- 2.2. When operating a circuit breaker, stand to one side of panel, use one hand to operate the handle of the circuit breaker and keep the head turned away from the panel.

3. PREREQUISITES/INITIAL CONDITIONS

Entry Conditions:

- 3.1. Notify OMC Thomas Hallock 695-5761 **prior** to starting work in building.
- 3.2. The following permits, forms, and documents are required to complete this work:
 - LO/TO
 - Scaffolding Inspection form
- 3.3. Establish barricade flagging and robust barriers (this will be field directed during Pre-Job Briefing) to clearly define work execution area.
- 3.4. Follow lock out/ tag out procedures in accordance with Lock Out/Tag Out for control of electrical energy sources for personnel safety (red lock procedures).
- 3.5. LO/TO devices shall be applied in accordance with requirements of P101-3 "Lock Out/Tag Out for Hazardous Energy Control"

4. SPECIAL TRAINING/MEDICAL REQUIREMENTS


- 4.1. The following trainings are required for the General Hazard Section:
 - Basic Craft Worker PPE #10968
 - LO/TO Authorized worker TP #127
 - Non Energized/Non-Electrical - Training Plan # 2909
 - Scaffold User TP # 3949
 - Fall Protection, LANL TP # 9257

5. SPECIAL TOOLS/EQUIPMENT

- 5.1. The following basic PPE is required:
 - Safety Shoes
 - Safety glasses with side shields.
 - Work Gloves
 - Bump cap ,or Hard hat
 - Reflective vest

Wear Tyvex, goggles, paper dust masks while working on paper shredder. JD-3, 3/26/18 Clint Carron, 117208 3/26/18

FORM 2100-WC

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision #: 0		Activity/Task Title: TA-52-0011 MULTI-CRAFTS-DESTRUCTION FACILITY-MAINT	
Work Document #: (WO # / Task) 589389-01		Planner/Preparer (Name/Z#/Date) Ralph Dominguez, 100538 01-09-18	
TA: 52	Building: 0011	Room:	Additional Location Description:

6. WORK INSTRUCTIONS

Carpenter Crafts:

- 6.1. **ERECT** scaffolding under direction of scaffold competent person.
- Scaffolding must be erected, with top railing, mid railing and toe board for fall Protection.
- 6.2. **DAILY SCAFFOLD INSPECTION FORM REQUIRED.**
- The competent person must also inspect the scaffold before each work shift.
 - Dismantle scaffolding once work is completed.



Mechanics:

- 6.3. **LO/TO** power to shaker/bag house unit.
- 6.4. **VERIFY** absence of hazardous energy.



Sheet Metal:

- 6.5. **APPLY** LO/TO to shaker/bag house unit.
- 6.6. **VERIFY** absence of hazardous energy.
- 6.7. **PERFORM** removal of outer side panels of the shaker/bag house unit.



Mechanics:

- 6.8. **REPLACE** bag filters to shaker/bag house unit.
- 6.9. **REMOVE/REPLACE** shaker arm to shaker/bag house unit. Order arm part to shaker/bag house unit if possible. Second option get with iron workers to fabricate an arm at iron workers shop.



Mechanics / Sheet Metal:

- 6.10. **REMOVE** LO/TOS.



Mechanics:


- 6.11. **RE- ENERGIZE** shaker/bag house unit.



7. POST WORK ACTIVITIES

Mechanics:

- 7.1. **TEST** shaker/bag house unit for proper operation.




8. CLOSEOUT

- 8.1. **CLEAN** the work area and dispose of all work generated debris.



FORM 2100-WC

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision #: 0		Activity/Task Title: TA-52-0011 MULTI-CRAFTS-DESTRUCTION FACILITY-MAINT	
Work Document #: (WO # / Task) 589389-01		Planner/Preparer (Name/Z#/Date) Ralph Dominguez, 100538 01-09-18	
TA: 52	Building: 0011	Room:	Additional Location Description:

8.2. **CONTACT** the MC and inform them the work is completed. Complete all the required documentation and return the Master Work Package to the Area Work Control Office.

Insert Rows above for additional Tasks/Steps or attach pages to clearly communicate ESH&Q/S&S hazards and associated controls.	The RLM, and FOD or FOD Representative (if required or recommended by RLM, e.g. high hazard) approval indicates IWM has been applied appropriately, work is authorized, workers are qualified, work will be performed in accordance with ESH&Q/S&S requirements and the IWD, and facility safety basis, aggregate hazards, and collocated hazards were appropriately included in the hazard analysis and acknowledges completion of a peer review.	RLM (Signature/Z#/Date) Required <u>204635</u> <u>Ronald R. Chang 1/24/18</u> FOD or Representative (Signature/Z#/Date) If Required or Recommended by RLM <u>100538 1-18-18</u> ESO Review (Signature/Z#/Date) If Required <u>100538 1-18-18</u> Safety Review (Signature/Z#/Date) Required <u>117kcs, 1/16/18</u>
	IWD Type <input checked="" type="checkbox"/> Moderate-Hazard <input type="checkbox"/> High-Hazard/Complex <input type="checkbox"/> Standing IWD	Date when RLM re-approval is required <u>1/31/19</u> Other Conditions for Re-Approval <u>Changes in Scope / Hazards</u> (Print) Name of Primary PIC <u>Ryan Campbell</u> Name of Alternate PIC <u>ERIC FERNANDEZ</u> Name of Alternate PIC <u>Matt + Robert S</u>



NATIONAL LABORATORY
EST. 1943

Integrated Work Document (IWD) Part 2, FOD Requirements and Approval for Entry and Area Hazards and Controls

Form 2101
Non-Tenant
Activity Form

1358/1711

IWD No./Work Request No: _____ Revision #: _____

Facility Operation Director (FOD) must determine the facility entry and coordination requirements and identify the Environment, Safety, Health (ESH)/Security and Safeguards (S&S) hazards and controls associated with the activity location.

FOD 7	TA 52	Bldg. 0011	Room All	Other Location N/A
FOD Designated	Name Bill Schleft	Phone 699-5790	Pager 664-3536	Email schleft@lanl.gov

Entry and Coordination Requirements (Check one or more of the following)

- | | | |
|--|--|--|
| <input type="checkbox"/> No Entry/Coordination Requirements | <input type="checkbox"/> FOD-designated facility Point-of-Contact must sign IWD Part 3 | |
| <input checked="" type="checkbox"/> Plan of the Day/Plan of the Week (POTD/POTW) | <input checked="" type="checkbox"/> Check in at Start of Work | <input type="checkbox"/> Work-Area Training Required |
| <input type="checkbox"/> Security Clearance Requirements | <input checked="" type="checkbox"/> Work must be Scheduled | <input checked="" type="checkbox"/> Check in Daily |
| <input type="checkbox"/> Co-located Hazards/Concerns | <input type="checkbox"/> Other Security Requirements (ex.: Cellphone, No Foreign Nationals, etc.) | <input checked="" type="checkbox"/> Check out Daily |
| <input checked="" type="checkbox"/> Check out at End of Work | <input type="checkbox"/> Quality Issues | |
| <input type="checkbox"/> Escort Required | <input type="checkbox"/> Review under Authorization Basis (AB)/Safety Basis/Unreviewed Safety Question (USQ) | |
| <input type="checkbox"/> Other Bounding Conditions: _____ | | |

Additional Comments (refer to Job Hazard Analysis [JHA] Tool Facility Notes)

Instructions: In the block below, identify work-area hazards that could potentially affect the worker(s) or others. Specify the facility controls and preventive measures that must be implemented by the worker(s) to protect against the site hazards as well as any special training required.

ESH/S&S WORK AREA HAZARDS & CONTROLS				
Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
<input type="checkbox"/> No Work Area Hazards				
Ionizing Radiation Work in posted radiological areas, work with radioactive materials, or work on or near radiation producing devices.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Specify Hazard:				

ESH/S&S WORK AREA HAZARDS & CONTROLS

Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
Worker Exposure Working near non-ionizing radiation, beryllium, noise, chemicals, hazardous biological materials, lead, asbestos, temperature/humidity extremes, or high explosives. Specify Hazards:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
energized and Operative Systems Working near energized electrical parts, pressure systems, steam lines; near unprotected belts, pulleys, chains or rotating equipment; fuel fired equipment other than vehicles; or spark or flame producing operations. Specify Hazards:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Ensure worker recognize hazards associated with working near rotating equipment.		
Confined Spaces Entry into tanks, manholes, cooling towers, sumps, or any other area with potentially low oxygen concentration or other hazards such as toxic vapors or engulfment. Specify Hazards:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Elevated Work Surface Elevated work when fall protection is not provided by conventional handrail systems or required per <u>P101-20, Fall Protection Program</u>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Environmental Impact Activities conducted in areas containing potential release site, contaminated soil, sensitive species, watercourse wetlands, floodplain, historical/archeological sites, or other work area condition that can be impacted by or can impact the environment. Specify Hazards:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Security Requirements Specify:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Other Hazards Specify:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			

I have verified that the hazards identified above adequately identify the area hazards and that the IWM process has been applied appropriately.

FOD or Representative (Signature/Z #/Date) Approval Required
 Date Approval Expires: 12/31/18

schleif@lanl.gov

Digitally signed by schleif@lanl.gov
 DN: cn=schleif@lanl.gov
 Date: 2014.10.20 17:50:23 -0700



Integrated Work Document (IWD) Part 2, FOD Requirements and Approval for Entry and Area Hazards and Controls

Form 2101
Non-Tenant
Activity Form

IWD No./Work Request No.: _____

Revision #: _____

Facility Operation Director (FOD) must determine the facility entry and coordination requirements and identify the Environment, Safety, Health (ESH)/Security and Safeguards (S&S) hazards and controls associated with the activity location.

FOD 7	TA 16	Bldg. 137d	Room All	Other Location N/A
FOD Designated Facility Point-of-Contact	Name Bill Schleft	Phone 699-5790	Pager 664-3536	Email schleft@lanl.gov

Entry and Coordination Requirements (Check one or more of the following)

<input type="checkbox"/> No Entry/Coordination Requirements	<input type="checkbox"/> FOD-designated facility Point-of-Contact must sign IWD Part 3
<input checked="" type="checkbox"/> Plan of the Day/Plan of the Week (POTD/POTW)	<input checked="" type="checkbox"/> Check in at Start of Work
<input type="checkbox"/> Security Clearance Requirements	<input type="checkbox"/> Work-Area Training Required
<input type="checkbox"/> Co-located Hazards/Concerns	<input checked="" type="checkbox"/> Work must be Scheduled
<input checked="" type="checkbox"/> Check out at End of Work	<input type="checkbox"/> Other Security Requirements (ex.: Cellphone, No Foreign Nationals, etc.)
<input type="checkbox"/> Escort Required	<input type="checkbox"/> Quality Issues
<input type="checkbox"/> Other Bounding Conditions: _____	<input checked="" type="checkbox"/> Check out Daily
<input type="checkbox"/> Review under Authorization Basis (AB)/Safety Basis/Unreviewed Safety Question (USQ)	

Additional Comments (refer to Job Hazard Analysis [JHA] Tool Facility Notes)

Instructions: In the block below, identify work-area hazards that could potentially affect the worker(s) or others. Specify the facility controls and preventive measures that must be implemented by the worker(s) to protect against the site hazards as well as any special training required.

ESH/S&S WORK AREA HAZARDS & CONTROLS				
Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
<input checked="" type="checkbox"/> No Work Area Hazards Ionizing Radiation Work in posted radiological areas, work with radioactive materials, or work on or near radiation producing devices. Specify Hazard:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			

IWM No./Work Request No.: _____ Revision #: _____

ESH/S&S WORK AREA HAZARDS & CONTROLS

Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
Worker Exposure Working near non-ionizing radiation, beryllium, noise, chemicals, hazardous biological materials, lead, asbestos, temperature/humidity extremes, or high explosives.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Specify Hazards:				
Energized and Operative Systems Working near energized electrical parts, pressure systems, steam lines; near unprotected belts, pulleys, chains or rotating equipment; fuel fired equipment other than vehicles; or spark or flame producing operations.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Specify Hazards:				
Confined Spaces Entry into tanks, manholes, cooling towers, sumps, or any other area with potentially low oxygen concentration or other hazards such as toxic vapors or engulfment.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Specify Hazards:				
Elevated Work Surface Elevated work when fall protection is not provided by conventional handrail systems or required per <u>P101-20, Fall Protection Program</u>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Environmental Impact Activities conducted in areas containing potential release site, contaminated soil, sensitive species, watercourse wetlands, floodplain, historical/archeological sites, or other work area condition that can be impacted by or can impact the environment	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Specify Hazards:				
Security Requirements Specify:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Other Hazards Specify:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			

I have verified that the hazards identified above adequately identify the area hazards and that the IWM process has been applied appropriately.

FOD or Representative (Signature/Z #/Date) **Approval Required**Date Approval Expires: 12/31/18

schleff@lanl.gov

Digitally signed by schleff@lanl.gov
DN: cn=schleff@lanl.gov, o=LANL, ou=LANL, email=schleff@lanl.gov

Attachment B, LO/TO Orders

Lock Coordinator Name		Z#:	Phone #:		Alternate Lock Coordinator Name		Z#:	Phone #:	
Jill K. Remore		23414	7-334142						
Section 1: General Information									
1. Work Document Number (i.e., Package/Procedure #):					589389-01				
2. LO/TO (Parent) Record #:					13443				
Location of Equipment to be Isolated									
3. TA:	52	4. Bldg:	11	5. Rm:	OSW	6. Equipment Description (e.g. Machinery/Name/CMMS Number):			
						SHAKER - CYCLONE - OPERATOR			
7. Name of Equipment Owner/Operator:									
Jill K. Remore									
8. Reason for LO/TO:									
Remove Filters / Parts									
9. Energy Type to be Isolated (check all that apply):									
<input checked="" type="checkbox"/> Electrical <input checked="" type="checkbox"/> Mechanical <input type="checkbox"/> Hydraulic <input type="checkbox"/> Pneumatic <input type="checkbox"/> Steam <input type="checkbox"/> Capacitors <input type="checkbox"/> Compressed Energy <input type="checkbox"/> Gravity <input type="checkbox"/> Other (specify):									
10. Verification required for LO/TO:									
<input checked="" type="checkbox"/> Installation <input type="checkbox"/> Removal <input type="checkbox"/> N/A (Verification Not Required)									
11. Verification Type:									
<input checked="" type="checkbox"/> Peer <input type="checkbox"/> Independent <input type="checkbox"/> N/A									
12. Specific Sequencing of LO/TO devices required for:									
<input type="checkbox"/> Installation <input type="checkbox"/> Removal <input checked="" type="checkbox"/> N/A (Sequencing Not Required)									
13. LO/TO Orders Addendum with Operational Instructions/Procedures attached?									
<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No									
Equipment Owner/Operator Comments:									
N/A									
Section 2: LO/TO Installation & Removal Details									
14. Group LO/TO? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No									
Name of Lead Authorized Worker: Nancy Romero									
15. Group Lock Box used? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No									
If yes, enter ID# of Lock Box:									
LO/TO Installation									
16. Approval to Install LO/TO		Signature: Jill K. Remore		Z#:		23414		Call #:	
								N/A	
NOTE: Approver must ensure Affected Workers are notified prior to Authorized Workers performing LO/TO									
17. Energy Isolation Device (use Specific ID)		18. Location of Energy Isolation Device		19. LO/TO Installation Sequence		20. Required LO/TO Position or Alignment		23. Approval to Remove LO/TO	
Signature: Jill K. Remore		Signature: Jill K. Remore		Signature: Jill K. Remore		Signature: Jill K. Remore		Signature: Jill K. Remore	
CDD-6		Panel L/D		NONE		NONE		NONE	
CDD-7		Panel L/D		"		"		"	
CDD-8		Panel L/D		"		"		"	
24. LO/TO Removal									
25. Required Position/Alignment following Removal									
26. As-Left Position									
27. LO/TO has been Removed & Isolation Devices Positioned:									
Signature: Jill K. Remore									
Z#:									
23414									
Date: 3-26-18									
28. Removal and Positioning verified by:									
Signature: Jill K. Remore									
Z#:									
23414									
Date: 3/26/18									

Attachment B, LO/TO Orders

Attachment B, LO/TO Orders (Cont.)

1. Work Document Number (i.e., Package/Procedure #):

589389-01

2. LO/TO (Parent) Record #:

73443

Section 3: All Authorized Workers (anyone applying a lock for this activity)

29. Authorized Workers Name(s)	Z#	30. Date worker's lock is hung	31. Date worker's lock is removed
1. Larry Romero	117864	3-26-18	
2. Nathan Boylan	31006	3-26-18	
3. Emilio Navarro	239745	3-26-18	
4.			
5.			
6.			
7.			
8.			
9.			
10.			
11.			
12.			
13.			
14.			
15.			
16.			
17.			
18.			
19.			
20.			

Section 4: Return of Lock(s)/Tag(s) and Locking Devices

All Lock(s)/Tag(s) and Locking Devices have been removed and returned to the Lock Coordinator:

32. Signature of Lock Coordinator:

[Signature]

Z#:

000467

Date:

4/6/18

*Instructions for completing this form (by numbered steps) appear on the last two pages of this document. Take the completed forms back to the Lock Coordinator for closeout.

Continuation Page (print as needed)

[illegible]

Attachment B, LO/TO Orders

Instructions by Numbered Steps

Lock Coordinator (Header): Identify the individual who will issue Red Locks to persons performing LO/TO (individual[s] identified by the FOD).

1. Enter the Work Document Number. This will be the number from the IWD or the procedure number (i.e., TA88-DOP-0001).
2. Enter the LO/TO Parent Record number. This is obtained from the Lock Coordinator when the lock(s) are issued. The Remedy LO/TO database generates this number.
3. Enter the TA where the equipment is located.
4. Enter the Building number where the equipment is located.
5. Enter the Room number where the equipment is located.
- NOTE:** Responses to steps 3 through 5 need to match information, identically, within both the LO/TO Orders and the tag (Attachment A).
6. Enter the Equipment/Machinery/Name/Number (example, HVA-001 [NOTE: LOG is to follow nomenclature contained within CMMS/MEL]).
7. Enter the Name of the Equipment Owner/Operator. The Equipment Owner/Operator is designated by the FOD. There may be both programmatic and facility Equipment Owner/Operators.
8. Write a brief description of the reason for LO/TO (example, removing and replacing exhaust fan belts).
9. Check the appropriate energy type to be isolated (check all that apply). Make sure you have considered all energy sources; if "Other" is checked, specify what "Other" is.
10. Is verification of the energy isolation configuration required for this LO/TO for installation and/or removal? Check the appropriate box(es).
NOTE: Contact the FOD/Designee regarding verification requirements. Additionally, verification may be required by the Equipment Owner/Operator.
11. If verification is required, check the appropriate box (either "Peer" or "Independent"). If verification is NOT required, check the "N/A" box.
NOTE: Independent verification may be required per *P315, Conduct of Operations Manual*, as determined by the FOD/Designee.
12. When installing the lock(s)/tag(s), is there a specific sequence in which the isolation devices are to be positioned? If a specific sequence must be followed for installation and/or Removal, check the appropriate box(es) and subsequently identify the sequence order in column numbers 19 and/or 24, accordingly. If there is not a specific sequence to follow, check the "N/A" box and place N/A in columns 19 and/or 24.
13. If an operating procedure/instruction/etc. is to be used in conjunction with the LO/TO Orders, check the "Yes" box and attach the pertinent document as an addendum. Additionally, a space is provided for Equipment Owner/Operator comments, if applicable.
14. Check either "Yes" or "No" to indicate if a Group LO/TO is applicable. A Group LO/TO is where two or more authorized workers, regardless of their occupation or craft, lock out and tag out the same equipment to perform servicing or maintenance. Enter the name of the Lead Authorized Worker.
15. Check either "Yes" or "No" to indicate if a Group Lock Box is to be used. If "Yes", enter the lock box ID#. Each organization that issues locks will be required to uniquely number and track lock boxes in their possession.
16. The FOD-designated Equipment Owner/Operator signs and enters their Z#, authorizing the installation of the LO/TO. The Approver is responsible to notify all Affected Workers prior to the Authorized Workers performing LO/TO ("Affected Workers" are those who either may work with the equipment or are affected by LO/TO activities).
17. Enter the specific energy isolation device/ID (e.g., MCC-A, A4). The ID used in the LO/TO orders must match information used on tag (Attachment A).
18. Location of energy isolation device (TA, Bldg, Rm, etc.). The location used in the LO/TO orders must match information used on tag (Attachment A).

Attachment B, LO/TO Orders

19. If the LO/TO needs to be installed in a particular order (refer to Step #12), number the sequence in which the locks need to be installed. If sequencing is not applicable, then place N/A in this column.
20. Required Position/Alignment for LO/TO (open, closed, connected, disconnected, on, off, etc.). Follow the nomenclature on the piece of equipment (e.g., if a service disconnect has "ON"/"OFF" posted, ensure the position/alignment entered on this form matches the piece of equipment ["ON" or "OFF"]).
21. The Lead Authorized Worker documents (signature) that the energy isolation devices have been positioned correctly, that locks and tags have been installed on those energy isolation devices and a Zero Energy Check has been performed.
NOTE: The Lead Authorized Worker may also be designated as the Person-in-Charge (PIC).
22. Is verification required (see #10)? If verification is required, the person who performs the verification signs, and places their Z# and the date here. If verification is not required, check the "N/A" box.
23. Documentation of Approval to Remove LO/TO. Equipment Owner/Operator or FOD Designee signs and places his/her Z# in this box. Alternatively, authorization per telecommunication may be performed via a phone number identified for the Lead Authorized Worker to call the Equipment Owner/Operator or FOD Designee. Once verbal authorization is given, the Lead Authorized Worker documents the authorization as "per telecom" and enters his/her initials. Example: John Smith per telecom, JS. By checking the "N/A" box, a phone call is NOT REQUIRED by the Lead Authorized Worker to the Equipment Owner/Operator or FOD Designee.
NOTE: The Equipment Owner/Operator or FOD Designee is responsible to notify all Affected Workers after the LO/TO removal and of the equipment/machine's return to service.
24. If the LO/TO needs to be removed in a particular sequence (as per Step #12), number the sequence in which the locks need to be removed. If the "N/A" box is checked in #12, then place N/A in this column.
NOTE: Often the sequence for removal is opposite the sequence for installation. For example, if the order specified for installation Column #19 is "1,2,3,4", the order specified for removal in Column #24 could be "4,3,2,1". The intention of the LO/TO Orders is to have the entries in Column #s 19 and 24 correspond with the energy isolation devices specified in Column #17.
25. Identify the required position/alignment in which the system/component is to be placed following the removal of the lock(s). Follow the nomenclature as listed on the piece of equipment ("On", "Off", etc.).
26. Enter the As-Left Position.
27. The Lead Authorized Worker documents (signature, Z# and date) that the locks and tags have been removed from the energy isolation devices and the energy isolation devices have been configured as per Equipment Owner/Operator specifications.
NOTE: The Lead Authorized Worker may also be designated as the Person-in-Charge (PIC).
28. If verification is required for the positioning, the person who performs the verification signs here. Otherwise, check N/A.
29. All authorized workers applying a lock for this activity (names/Z#) must be documented. If more than 20 authorized workers are involved in a Group LO/TO, document the required information with an attached list.
30. Enter the date the authorized worker attaches his/her lock.
31. Enter the date the authorized worker removes his/her lock.
32. The Lock Coordinator or designee signs once locks, tags, and locking devices have been removed and returned. If a lock and/or tag are found to be contaminated, the lock and/or tag will be disposed of in accordance with local procedures and a verbal notification will be made to the Lock Coordinator to close out the record within Remedy.



Integrated Work Document (IWD) Part 3, Validation and Work Release

IWD # _____ Revision #: _____ Work Release

589389-01

By signing below, I verify this activity is compatible with current facility configuration and operating conditions.

FOD designated Operations Manager or other facility point-of-contact for work area

Signature/Z#/Date (If required by FOD): _____

Note: For Standing IWD, release may be given concurrently with signatures on Part 2.

By signing below, I have verified the following:

- I have verified authorization by ensuring approval signatures of the RLM and FOD.
- I have jointly conducted a validation walkdown with workers to confirm the IWD can be performed as written, and that required initial conditions and other prerequisites are in place.
- The assigned workers are authorized and are competent to perform the work in a safe, secure, and environmentally responsible manner.
- I have conducted the pre-job briefing, and all workers (including support workers) have been briefed.
- I have ensured coordination with any required FOD work-area representatives (e.g., area work coordinators).

PIC (Signature/Z#/Date) Required: _____

Ken 319242 3/22/18

Alternate PIC Signatures acknowledges PIC authority is assumed for the first time. (Note: Alternate PICs are required to sign only once, but formal handoff includes conferring with previous PIC to obtain all required information associated with the handoff.)

Alternate PIC (Signature/Z#/Date) Required: _____

Dij GML 170010 3/22/2018

Alternate PIC (Signature/Z#/Date) Required: _____

Lori Jennings 107001 3-26-18

Pre-Job Brief Content

- What are the critical steps* or phases of this activity?
- How can we make a mistake at that point?
- What is the worst thing that can go wrong?
- What controls, preventive measures, and bounding conditions are needed?
- What work permits are required and how will we meet their requirements?
- What are the handoffs and coordination requirements among workers and multiple PICs?
- Are there hold-points including those that require sign-offs?
- What are the pause/stop work responsibilities and expectations (e.g., for unanticipated conditions or hazards)?
- How would we respond to alarms and emergencies?
- Are there lessons learned from previous similar work?
- Is other information needed to perform this activity in a safe, secure, and environmentally responsible manner?
- Does everyone agree to the work tasks/steps, hazards, and controls and commit to follow them?

* "Critical steps occur anytime human performance involves a substantial transfer of energy, or movement of solids, liquids, and gases, or the transmission of data and information that, if not performed under control, could cause serious harm to one or more important assets." (Performance Improvement, Vol. 53, no. 9, October 2014)

Pre-Job Brief Attendance Roster

By signing below **as required**, I agree to the following:

- I agree to follow the work steps and implement the controls as written as applicable to my work assignments.
- I agree to pause/stop work when conditions or hazards change or when I encounter unexpected conditions during the execution of work, or when work cannot be performed as written, or instructions become unclear during execution.
- I confirm that I am authorized, qualified, and fit to perform the work.

Worker (Signature/Z#/Date) <i>Daniel Rodriguez</i> 323955 3-22-18	Worker (Signature/Z#/Date) <i>Emiliano Meli</i> 239798 3-26-18
Worker (Signature/Z#/Date) <i>Heidi</i> 296282 3-22-18	Worker (Signature/Z#/Date) <i>Sony Rome</i> 112864 3-26-18
Worker (Signature/Z#/Date) <i>Samuel Quintana</i> 311015 3-23-18	Worker (Signature/Z#/Date) <i>Wendy</i> 326738 3-28-18
Worker (Signature/Z#/Date) <i>Wendy</i> 194830 3-28-18	Worker (Signature/Z#/Date) <i>E</i> 305386 4-3-18
Worker (Signature/Z#/Date) <i>Wendy</i> 326202 3-28-18	Worker (Signature/Z#/Date)
Worker (Signature/Z#/Date) <i>Mike</i> 085931 3/26/18	Worker (Signature/Z#/Date)
Worker (Signature/Z#/Date) <i>Ruth</i> 311004 3-26-18	Worker (Signature/Z#/Date)

Work Order/Task:

Start Date: 3/5/18

Completion Date:

~~3-2-18~~ 4-2-18

SUMMARIZE THE WORK PERFORMED

Date _____

Sheet metal -

3/5/18

Walk down to remove panels and replace
tube filters. ~~3~~ gys 2 days.
Man lift preferred instead of scaffold.
Man lift already on building

3. 22. 18

Prep for material and started building scaffold: 2 carpenters

3.28.18

Continue w/ scaffold and completed building; 3 generators

3-26-18

Sheet Metal - ~~the~~ Prejob. Picked up goggles, dust mask and

~~FOR CORRECTIVE WORK - WHAT FAILED AND WHAT WAS FIXED~~

~~Removed~~ Tyvek. We removed the panel on the north side of the shaker.

4.03.18

Disassemble Tube/Clamp Scaffold and pack material back to TA3-38

FOR PMs – SUMMARIZE AS FOUND AND AS LEFT CONDITIONS BELOW

As found

Down

As left

IN operation

Parts/Repairs

New Filter & New Fresh Air Fan Shaker.
All is working good.

Read/meas.

Post test info.

Problems Encountered (delays, safety, etc.):

3-26-18

Delays - Waiting for IH to get people from their meeting to get dust masks. We had to get the package rewritten to include dust masks, goggles and tyvek. We had to wait for the stationary ladder to get signed off.

Lessons Learned/Recommendations:

Name: _____

Eric Fernandez

Signature:

Ernest

Date:

4-2-1A

PIC/SUPT

☐ PM has been completed in its entirety and ready for closure.

IF A PM COULD NOT BE COMPLETED:

☐ Percentage complete is 100 %

Corrective

☐ Sections that did not work and need to be rescheduled

Reasons why:

MAINTENANCE COORDINATOR/AREA WORK COORDINATOR

Work Package is Complete and may be closed out: YES ☒ NO ☐

IF no: State Reason

Additional Work Needed? ☐ YES ☒ NO

Document UP/WO/FSR Number: _____

ENGINEERING (FOR MD and CD Work Orders)

IF a configuration baseline has been changed, THEN indicate the changes are to be incorporated into the following documents and/or configuration baseline:

☐ Drawings

☐ FDD/SDD

☐ Procedures

☐ Master Equipment List

☐ Permits

☐ Checklists

SE Name:

Signature:

Date:

WORK CONTROL

Moderate/High Hazard – WMC/Planner reviewed for Lessons Learned/Feedback

☐ YES

☐ NO

N/A ☐

☐ Review of the completed work package is complete per AP-WORK-005, and the work package is ready to be set to complete in CMMS.

Facility : F07 **Unit :** **Proj :**
Task Title : 520011 6M CYCLONE SEPERATOR/ SHAKER LUBE/INSP. - MECHANICS
W/O Type : PM **W/O Group :** 3PM MOD **Task Priority :** 4
Planner : 185614 HARRIS JEANETTE S
W/O Title : 520011 6M CYCLONE SEPERATOR/ SHAKER LUBE/INSP. - MECHANICS
Written To : CYCLONE SHAKER (SEPERATOR PARTICULATE) INDOOR/OUTDOOR)
Task Dsplt : MECH **Due Date :** 05/31/2018
Superintendent :
Hazard : MODERATE **IWD Reqmt :** TASK SPECIFC

Work Order Task

00604872 01

MASTER

Date: 03/30/2018**Work Order Task Written To**

Facility : F07 **Unit :** **Op Sys :** BLDG
Room : BLDG **Area :** **Sys/Cls :** P/ML4
Equipment : UNITSPP **Component :**
Location : 52-0011
Job Type : PM
Tag 1 : **Tag 2 :**
Work Item : **Ops Review Reqd :**

Authorization**Start Permission :**

JOE ROMERO

Start Date :

4/4/18

Complete Notice :

JOE ROMERO

Complete Date :

6/13/18

Work Order Task Instructions

M/L:4

TEXT DESCRIPTION

Install Lock-Out/Tag Out to the local disconnect at the Cyclone Unit

Requires 3 lockout/tag out cdd-6, 7 & 8

Verify Zero energy to the unit

Lubricate and inspect the chains on the rotary air lock valve and shaker

Lubrication of Rotor Bearings: Using an EP type grease quality grade 2 grease the existing fittings located on the lubrication manifolds mounted on the pillow blocks

Lubricating Motor Bearings: Remove the drain plug and then inject new grease at the fill hole. Replace the drain plug. Recommended grease should be Polyrea based bearing lubricant

Lubricate, inspect and repair the gear box and chain bearings in gear box

Verify proper operation oil level and add as needed

Change the Air lock valve gear box oil following every

1378/1711

Facility : F07	Unit :	Proj :	Work Order Task
Task Title : 520011 6M CYCLONE SEPERATOR/ SHAKER LUBE/INSP. - MECHANICS			
W/O Type : PM	W/O Group : 3PM MOD	Task Priority : 4	00604872 01
Planner : 185614 HARRIS JEANETTE S			
W/O Title : 520011 6M CYCLONE SEPERATOR/ SHAKER LUBE/INSP. - MECHANICS			MASTER
Written To : CYCLONE SHAKER (SEPERATOR PARTICULATE) INDOOR/OUTDOOR)			
Task Dspln : MECH	Due Date : 05/31/2018		
Superintendent :			Date: 03/30/2018
Hazard : MODERATE	IWD Reqmt : TASK SPECIFC		

5000 hours of operation
Check and lubricate all bearings associated with the Cyclone-Shaker unit as required
Complete any lubrication, adjustments or replacement of any components associated with the conveyor unit, to include bearings, belts, rollers and all other associated components
Complete lubrication of the shaker flange bearings following a 3 year recommended schedule
Complete any maintenance, as needed, on all motors per manufacturers recommendations
Remove the Lock OUT from the local disconnect

POC: Melissa Metcalf

NOTE: ASSIGNED CRAFTS SHALL FOLLOW ALL APPLICABLE STATE, FEDERAL AND LANL
CODES AND STANDARDS
INTO SECURITY AREAS

ORIGINATOR: TELEPHONE#:
CONFIGURATION MANAGEMENT REVIEW REQUIRED] [] YES [X] NO
CHECK CRAFTS REQUIRED:

<input type="checkbox"/> CUSTODIAL	<input type="checkbox"/> ELECTRICIANS	<input type="checkbox"/> LABORERS
<input type="checkbox"/> TEAMSTERS	<input type="checkbox"/> OPERATING ENGINEERS	<input type="checkbox"/> PAINTERS
<input type="checkbox"/> FITTERS	<input type="checkbox"/> CEMENT MASONS	<input type="checkbox"/> CARPENTERS
<input type="checkbox"/> ROOFERS	<input type="checkbox"/> IRON WORKERS	<input type="checkbox"/> INSULATORS
<input type="checkbox"/> SHEETMETAL	<input type="checkbox"/> MECHANICS	<input type="checkbox"/> ENGINEERING
<input type="checkbox"/> OTHER (SPECIFY) :		

AUTHORIZED FUNDING LEVEL:

FUNDING APPROVED BY: () N/A
Z#

DATE :

LOG-IN REQUIRED: [X] YES [] NO LOG-OUT REQUIRED: [X] YES [] NO
LOCATION OF LOG-IN: TA-3-142

Weekly Schedule or Plan of the Day

CHECK-IN REQUIRED: ☒ YES ☐ NO CHECK-OUT REQUIRED: ☒ YES ☐ NO
LOCATION OF CHECK-IN/CHECK-OUT:

PLANT ENGINEERING REVIEW:
PE REVIEW REQUIRED [] YES [X] NO
PE INSPECTION APPROVAL [] YES [X] NO

All debris/trash created by this work will be removed prior to completion of job or work day

Facility : F07 **Unit :** **Proj :**
Task Title : 520011 6M CYCLONE SEPERATOR/ SHAKER LUBE/INSP. - MECHANICS
W/O Type : PM **W/O Group :** 3PM MOD **Task Priority :** 4
Planner : 185614 HARRIS JEANETTE S
W/O Title : 520011 6M CYCLONE SEPERATOR/ SHAKER LUBE/INSP. - MECHANICS
Written To : CYCLONE SHAKER (SEPERATOR PARTICULATE) INDOOR/OUTDOOR
Task Dspln : MECH **Due Date :** 05/31/2018
Superintendant :
Hazard : MODERATE **IWD Reqmt :** TASK SPECIFC

Work Order Task

00604872 01




MASTER

Date: 03/30/2018

Attachment B, LO/TO Orders

Lock Coordinator Name <i>Jim Bonner</i>		Z#: <i>07967</i>	Phone #: <i>7-2664</i>	Alternate Lock Coordinator Name		Z#:	Phone #:
Section 1: General Information							
1. Work Document Number (i.e., Package/Procedure #): <i>604872</i>				2. LO/TO (Parent) Record #: <i>74269</i>			
Location of Equipment to be Isolated							
3. TA: <i>52</i>	4. Bldg: <i>11</i>	5. Rm.:	6. Equipment Description (e.g. Machinery/Name/CMMS Number): <i>Shaker</i>				
7. Name of Equipment Owner/Operator:							
8. Reason for LO/TO: <i>PM</i>							
9. Energy Type to be Isolated (check all that apply): <input checked="" type="checkbox"/> Electrical <input type="checkbox"/> Mechanical <input type="checkbox"/> Hydraulic <input type="checkbox"/> Pneumatic <input type="checkbox"/> Steam <input type="checkbox"/> Capacitors <input type="checkbox"/> Compressed Energy <input type="checkbox"/> Gravity <input type="checkbox"/> Other (specify):							
10. Verification required for LO/TO: <input type="checkbox"/> Installation <input type="checkbox"/> Removal <input checked="" type="checkbox"/> N/A (Verification Not Required)				11. Verification Type: <input type="checkbox"/> Peer <input type="checkbox"/> Independent <input checked="" type="checkbox"/> N/A			
12. Specific Sequencing of LO/TO devices required for: <input type="checkbox"/> Installation <input type="checkbox"/> Removal <input checked="" type="checkbox"/> N/A (Sequencing Not Required)				13. LO/TO Orders Addendum with Operational Instructions/Procedures attached? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Equipment Owner/Operator Comments: <i>N/A</i>							
Section 2: LO/TO Installation & Removal Details							
14. Group LO/TO? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Name of Lead Authorized Worker:				15. Group Lock Box used? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If yes, enter ID# of Lock Box:			
LO/TO Installation				LO/TO Removal / Return to Service			
16. Approval to Install LO/TO Signature: <i>Jim Bonner</i> NOTE: Approver must ensure Affected Workers are notified prior to Authorized Workers performing LO/TO				23. Approval to Remove LO/TO <input type="checkbox"/> N/A Signature: <i>Jim Bonner</i> NOTE: Approver must ensure Affected Workers are notified of LO/TO Removal / Return to Service			
17. Energy Isolation Device (use Specific ID) <i>LOA-1 chis</i>	18. Location of Energy Isolation Device <i>52 11</i>	19. LO/TO Installation Sequence <i>N/A</i>	20. Required LO/TO Position or Alignment <i>N/A</i>	24. LO/TO Removal Sequence <i>N/A</i>	25. Required Position/Alignment following Removal <i>N/A</i>	26. As-Left Position <i>ON/OFF</i>	
<input type="checkbox"/> See continuation page for additional Energy Isolation Devices (continuation page must also be signed if applicable)							
21. Energy Isolation Devices Positioned, Lock(s) and Tag(s) installed, and Zero Energy Checks Performed: Signature: <i>Jim Bonner</i> Z#: <i>07967</i> Date: <i>5/10/18</i>				27. LO/TO has been Removed & Isolation Devices Positioned: Signature: <i>Jim Bonner</i> Z#: <i>07967</i> Date: <i>5/10/18</i>			
22. LO/TO verified by: <input type="checkbox"/> N/A Signature: <i>Jim Bonner</i> Z#: <i>07967</i> Date: <i>5/10/18</i>				28. Removal and Positioning verified by: <input type="checkbox"/> N/A Signature: <i>Jim Bonner</i> Z#: <i>07967</i> Date: <i>5/10/18</i>			

Attachment B, LO/TO Orders

Attachment B, LO/TO Orders (Cont.)			
1. Work Document Number (i.e., Package/Procedure #):		2. LO/TO (Parent) Record #:	
Section 3: All Authorized Workers (anyone applying a lock for this activity)			
29. Authorized Worker Name(s)	Z#	30. Date worker's lock is hung	31. Date worker's lock is removed
Larry Romero 112864	112864	5-10-18	
Amelia Madrid	239798	5-10-18	
4.			
5.			
6.			
7.			
8.			
9.			
10.			
11.			
12.			
13.			
14.			
15.			
16.			
17.			
18.			
19.			
20.			
Section 4: Return of Lock(s)/Tag(s) and Locking Devices			
All Lock(s)/Tag(s) and Locking Devices have been removed and returned to the Lock Coordinator:			
32. Signature of Lock Coordinator: 		Z#: 	Date: 

*Instructions for completing this form (by numbered steps) appear on the last two pages of this document. Take the completed forms back to the Lock Coordinator for closeout.

Continuation Page (print as needed)[illegible]

Attachment B, LO/TO Orders

Instructions by Numbered Steps

Lock Coordinator (Header): Identify the individual who will issue Red Locks to persons performing LO/TO (individual[s] identified by the FOD).

1. Enter the Work Document Number. This will be the number from the IWD or the procedure number (i.e., TA88-DOP-0001).
2. Enter the LO/TO Parent Record number. This is obtained from the Lock Coordinator when the lock(s) are issued. The Remedy LO/TO database generates this number.
3. Enter the TA where the equipment is located.
4. Enter the Building number where the equipment is located.
5. Enter the Room number where the equipment is located.
NOTE: Responses to steps 3 through 5 need to match information, identically, within both the LO/TO Orders and the tag (Attachment A).
6. Enter the Equipment/Machinery/Name/Number (example, HVA-001 [NOTE: LOG is to follow nomenclature contained within CMMS/MEL]).
7. Enter the Name of the Equipment Owner/Operator. The Equipment Owner/Operator is designated by the FOD. There may be both programmatic and facility Equipment Owner/Operators.
8. Write a brief description of the reason for LO/TO (example, removing and replacing exhaust fan belts).
9. Check the appropriate energy type to be isolated (check all that apply). Make sure you have considered all energy sources; if "Other" is checked, specify what "Other" is.
10. Is verification of the energy isolation configuration required for this LO/TO for installation and/or removal? Check the appropriate box(es).
NOTE: Contact the FOD/Designee regarding verification requirements. Additionally, verification may be required by the Equipment Owner/Operator.
11. If verification is required, check the appropriate box (either "Peer" or "Independent"). If verification is NOT required, check the "N/A" box.
NOTE: Independent verification may be required per **P315, Conduct of Operations Manual**, as determined by the FOD/Designee.
12. When installing the lock(s)/tag(s), is there a specific sequence in which the isolation devices are to be positioned? If a specific sequence must be followed for Installation and/or Removal, check the appropriate box(es) and subsequently identify the sequence order in column numbers 19 and/or 24, accordingly. If there is not a specific sequence to follow, check the "N/A" box and place N/A in columns 19 and/or 24.
13. If an operating procedure/instruction/etc. is to be used in conjunction with the LO/TO Orders, check the "Yes" box and attach the pertinent document as an addendum. Additionally, a space is provided for Equipment Owner/Operator comments, if applicable.
14. Check either "Yes" or "No" to indicate if a Group LO/TO is applicable. A Group LO/TO is where two or more authorized workers, regardless of their occupation or craft, lock out and tag out the same equipment to perform servicing or maintenance. Enter the name of the Lead Authorized Worker.
15. Check either "Yes" or "No" to indicate if a Group Lock Box is to be used. If "Yes", enter the lock box ID#. Each organization that issues locks will be required to uniquely number and track lock boxes in their possession.
16. The FOD-designated Equipment Owner/Operator signs and enters their Z#, authorizing the installation of the LO/TO. The Approver is responsible to notify all Affected Workers prior to the Authorized Workers performing LO/TO ("Affected Workers" are those who either may work with the equipment or are affected by LO/TO activities).
17. Enter the specific energy isolation device/ID (e.g., MCC-A, A4). The ID used in the LO/TO orders must match information used on tag (Attachment A).
18. Location of energy isolation device (TA, Bldg, Rm, etc.). The location used in the LO/TO orders must match information used on tag (Attachment A).

Attachment B, LO/TO Orders

19. If the LO/TO needs to be installed in a particular order (refer to Step #12), number the sequence in which the locks need to be installed. If sequencing is not applicable, then place N/A in this column.
20. Required Position/Alignment for LO/TO (open, closed, connected, disconnected, on, off, etc.). Follow the nomenclature on the piece of equipment (e.g., if a service disconnect has "ON"/"OFF" posted, ensure the position/alignment entered on this form matches the piece of equipment ["ON" or "OFF"]).
21. The Lead Authorized Worker documents (signature) that the energy isolation devices have been positioned correctly, that locks and tags have been installed on those energy isolation devices and a Zero Energy Check has been performed.
NOTE: The Lead Authorized Worker may also be designated as the Person-in-Charge (PIC).
22. Is verification required (see #10)? If verification is required, the person who performs the verification signs, and places their Z# and the date here. If verification is not required, check the "N/A" box.
23. Documentation of Approval to Remove LO/TO. Equipment Owner/Operator or FOD Designee signs and places his/her Z# in this box. Alternatively, authorization per telecommunication may be performed via a phone number identified for the Lead Authorized Worker to call the Equipment Owner/Operator or FOD Designee. Once verbal authorization is given, the Lead Authorized Worker documents the authorization as "per telecom" and enters his/her initials. Example: John Smith per telecom, JS. By checking the "N/A" box, a phone call is NOT REQUIRED by the Lead Authorized Worker to the Equipment Owner/Operator or FOD Designee.
NOTE: The Equipment Owner/Operator or FOD Designee is responsible to notify all Affected Workers after the LO/TO removal and of the equipment/machine's return to service.
24. If the LO/TO needs to be removed in a particular sequence (as per Step #12), number the sequence in which the locks need to be removed. If the "N/A" box is checked in #12, then place N/A in this column.
NOTE: Often the sequence for removal is opposite the sequence for installation. For example, if the order specified for installation Column #19 is "1,2,3,4", the order specified for removal in Column #24 could be "4,3,2,1". The intention of the LO/TO Orders is to have the entries in Column #s 19 and 24 correspond with the energy isolation devices specified in Column #17.
25. Identify the required position/alignment in which the system/component is to be placed following the removal of the lock(s). Follow the nomenclature as listed on the piece of equipment ("On", "Off", etc.).
26. Enter the As-Left Position.
27. The Lead Authorized Worker documents (signature, Z# and date) that the locks and tags have been removed from the energy isolation devices and the energy isolation devices have been configured as per Equipment Owner/Operator specifications.
NOTE: The Lead Authorized Worker may also be designated as the Person-in-Charge (PIC).
28. If verification is required for the positioning, the person who performs the verification signs here. Otherwise, check N/A.
29. All authorized workers applying a lock for this activity (names/Z#) must be documented. If more than 20 authorized workers are involved in a Group LO/TO, document the required information with an attached list.
30. Enter the date the authorized worker attaches his/her lock.
31. Enter the date the authorized worker removes his/her lock.
32. The Lock Coordinator or designee signs once locks, tags, and locking devices have been removed and returned. If a lock and/or tag are found to be contaminated, the lock and/or tag will be disposed of in accordance with local procedures and a verbal notification will be made to the Lock Coordinator to close out the record within Remedy.



AP-WORK-004: Attachment 1
Maintenance & Site Services
Worker Engagement Questions

Worker engagement questions are intended to focus attention on the task and ensure uncertainties are addressed. Examples of worker engagement questions are provided below. Worker engagement questions should be tailored to the situation.

Each of the questions listed below will be discussed at each Pre-Job Brief with all affected personnel.

Topic	Completed (X)
What permits, permissions, or support are required to safely start this work?	
What is the most likely thing that could go wrong (not the worst thing) and what, specifically, will prevent it?	
What can cause us to go beyond the scope of the work?	
What hazards in the work area may not have been considered during planning of this job	

Eric Fernandez 107001 5-10-18
Larry Romero 112864 5-10-18



Form 2103

Integrated Work Document (IWD) Part 3, Validation and Work Release

IWD # _____ Revision #: _____ **Work Release**

By signing below, I verify this activity is compatible with current facility configuration and operating conditions.

FOD designated Operations Manager or other facility point-of-contact for work area _____

Signature/Z#/Date (If required by FOD): _____

Note: For Standing IWD, release may be given concurrently with signatures on Part 2.

By signing below, I have verified the following:

- I have verified authorization by ensuring approval signatures of the RLM and FOD.
- I have jointly conducted a validation walkdown with workers to confirm the IWD can be performed as written, and that required initial conditions and other prerequisites are in place.
- The assigned workers are authorized and are competent to perform the work in a safe, secure, and environmentally responsible manner.
- I have conducted the pre-job briefing and all workers (including support workers) have been briefed.
- I have ensured coordination with all required FOD work-area representatives (e.g., area work coordinators).

PIC (Signature/Z#/Date) Required: _____

Alternate PIC Signatures **acknowledges** PIC authority is assumed for the first time. (*Note: Alternate PICs are required to sign only once, but formal handoff includes conferring with previous PIC to obtain all required information associated with the handoff.*)

Alternate PIC (Signature/Z#/Date) Required: _____

Alternate PIC (Signature/Z#/Date) Required: _____

Pre-Job Brief Content

- What are the critical steps* or phases of this activity?
- How can we make a mistake at that point?
- What is the worst thing that can go wrong?
- What controls, preventive measures, and bounding conditions are needed?
- What work permits are required and how will we meet their requirements?
- What are the handoffs and coordination requirements among workers and multiple PICs?
- Are there hold-points including those that require sign-offs?
- What are the pause/stop work responsibilities and expectations (e.g., for unanticipated conditions or hazards)?
- How would we respond to alarms and emergencies?
- Are there lessons learned from previous similar work?
- Is other information needed to perform this activity in a safe, secure, and environmentally responsible manner?
- Does everyone agree to the work tasks/steps, hazards, and controls and commit to follow them?

* "Critical steps occur anytime human performance involves a substantial transfer of energy, or movement of solids, liquids, and gases, or the transmission of data and information that, if not performed under control, could cause serious harm to one or more important assets."

(Performance Improvement, vol. 53, no. 9, October 2014)

Pre-Job Brief Attendance Roster

By signing below **as required**, I agree to the following:

- I agree to follow the work steps and implement the controls as written as applicable to my work assignments.
- I agree to pause/stop work when conditions or hazards change or when I encounter unexpected conditions during the execution of work, or when work cannot be performed as written, or instructions become unclear during execution.

I confirm that I am authorized, qualified, and fit to perform the work.

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)


Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision #: 0		Activity/Task Title: TA-52-0011 6M CYCLONE SEPARATOR/SHAKER LUBE/INSP.	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Ralph Dominguez, 100538 4-25-18	
TA: 52	Building: 0011	Room:	Additional Location Description:

1. SCOPE OF WORK

Install Lock-Out/Tag-Out to the local disconnect at the Cyclone Unit. Requires three LO/TO CDD-6, 7 & 8. Verify Zero energy to the unit. Lubricate and inspect the chains on the rotary air lock valve and shaker. Lubrication of Rotor Bearings: Using an EP type grease quality grade 2. Grease the existing fittings located on the lubrication manifolds mounted on the pillow blocks. Lubricating Motor Bearings: Remove the drain plug and then inject new grease at the fill hole. Replace the drain plug. Recommended grease should be Polyrea based bearing lubricant. Lubricate, inspect and repair the gear box and chain bearings in gear box. Verify proper operation oil level and add as needed. Change the Air lock valve gear box oil following every 5000 hours of operation. Check and lubricate all bearings associated with the Cyclone-Shaker unit as required. Complete any lubrication, adjustments or replacement of any components associated with the conveyor unit, to include bearings, belts, rollers and all other associated components complete lubrication of the shaker flange bearings following a 3 year recommend schedule. Complete any maintenance, as needed, on all motors per manufacturers recommend actions. Remove the LO/TO from the local disconnect. POC: Melissa Metcalf PH # 667-7851

Hazard Analysis (HA) Team: Ralph Dominguez, and Eric Fernandez (HA) Date: 4-25-18

2. PRECAUTIONS AND LIMITATIONS


- 2.1. If steps cannot be completed as described, or if unforeseen situations occur, **PAUSE WORK**, stabilize the situation, contact your supervisor, and await further instructions before proceeding.

3. PREREQUISITES/INITIAL CONDITIONS

Entry Conditions:

- 3.1. Notify facility tenants (maintenance repairs, noise, vibration, etc.) shall be performed.
- 3.2. Establish barricade flagging and robust barriers (this will be field directed during Pre-Job Briefing) to clearly define work execution area.
- 3.3. The following permits, forms, and documents are required to complete this work:
 - LO/TO
 - SDS for Lubricants used
- 3.4. Follow lock out/ tag out procedures in accordance with Lock Out/Tag Out for control of electrical energy sources for personnel safety (red lock procedures).
- 3.5. LO/TO devices shall be applied in accordance with requirements of P101-13
"Lock Out/Tag Out for Hazardous Energy Control"

FORM 2100-WC

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision #: 0		Activity/Task Title: TA-52-0011 6M CYCLONE SEPARATOR/ SHAKER LUBE/INSP.	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Ralph Dominguez, 100538 4-25-18	
TA: 52	Building: 0011	Room:	Additional Location Description:

4.1. The following trainings are required for the General Hazard Section:

- Basic Craft Worker PPE #10968
- LO/TO Authorized worker TP #127
- Non Energized/Non-Electrical - Training Plan # 2909

5. SPECIAL TOOLS/EQUIPMENT

5.1. The following basic PPE is required:

- Safety Shoes
- Safety glasses with side shields.
- Work Gloves
- Hard hat
- Reflective vest

6. WORK INSTRUCTIONS

Group Operator:

6.1. **TURN** off MCP-1.

Mechanic Crafts:

6.2. **LO/TO** Cyclone Separator/ Shaker at local disconnect.

6.3. **LO/TO** MCP-1.

6.4. **VERIFY** absence of hazardous energy.

6.5. **COMPLETE** items list listed on Activity Description. Complete minor repairs as needed.


6.6. **REMOVE** LO/TOS re-energize local disconnect.

Group Operator

6.7. **RE- ENERGIZE** Cyclone Separator/ Shaker at MCP-1.



FORM 2100-WC

 Los Alamos <small>NATIONAL LABORATORY</small> <small>U.S. DEPARTMENT OF ENERGY</small>				Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)	
Revision #: 0			Activity/Task Title: TA-52-0011 6M CYCLONE SEPARATOR/ SHAKER LUBE/INSP.		
Work Document #: (WO # / Task)			Planner/Preparer (Name/Z#/Date) Ralph Dominguez, 100538 4-25-18		
TA: 52	Building: 0011	Room:	Additional Location Description:		

7. Post Work Activities

Group Operator, and Mechanic Crafts:

7.1. TEST Cyclone Separator/ Shaker for proper operation.

8. CLOSEOUT

8.1. **CLEAN** the work area and dispose of all work generated debris.

8.2. **CONTACT** the MC and inform them the work is completed. Complete all the required documentation and return the Master Work Package to the Area Work Control Office.

<p>Insert Rows above for additional Tasks/Steps or attach pages to clearly communicate ESH&Q/S&S hazards and associated controls.</p>	<p>The RLM, and FOD or FOD Representative (if required or recommended by RLM, e.g. high hazard) approval indicates IWM has been applied appropriately, work is authorized, workers are qualified, work will be performed in accordance with ESH&Q/S&S requirements and the IWD, and facility safety basis, aggregate hazards, and collocated hazards were appropriately included in the hazard analysis and acknowledges completion of a peer review.</p>	<p>RLM (Signature/Z#/Date) Required <u>[Signature] 204635 4/26/18</u></p> <p>FOD or Representative (Signature/Z#/Date) If Required or Recommended by RLM <u>[Signature] 100896 4-25-18</u></p> <p>ESO Review (Signature/Z#/Date) If Required <u>[Signature] 100896 4-25-18</u></p> <p>Safety Review (Signature/Z#/Date) Required <u>[Signature] 117205, 4/25/18</u></p>
<p>IWD Type</p> <p><input checked="" type="checkbox"/> Moderate-Hazard</p> <p><input type="checkbox"/> High-Hazard/Complex</p> <p><input type="checkbox"/> Standing IWD</p>	<p>Date when RLM re-approval is required <u>4/30/19</u></p> <p>Other Conditions for Re-Approval <u>Changes in Scope / Hazards</u></p> <p>(Print)</p> <p>Name of Primary PIC <u>Ryan Campbell</u></p> <p>Name of Alternate PIC <u>ERIC FERNANDEZ</u></p> <p>Name of Alternate PIC <u>Tony Marduke</u></p>	<p>Any required classification review completed, _____</p> <p>_____ Signature/Date</p>



Form 2101

**Integrated Work Document (IWD) Part 2,
FOD Requirements and Approval for Entry and Area Hazards and Controls**

Non-Tenant
Activity Form

IWD No./Work Request No: _____

Revision #: _____

Facility Operation Director (FOD) must determine the facility entry and coordination requirements and identify the Environment, Safety, Health (ESH)/Security and Safeguards (S&S) hazards and controls associated with the activity location.

FOD 7	TA 52	Bldg. 0011	Room All	Other Location N/A
FOD Designated Facility Point-of-Contact	Name Bill Schleft	Phone 699-5790	Pager 664-3536	Email schleft@lanl.gov
Entry and Coordination Requirements (Check one or more of the following)				
<input type="checkbox"/> No Entry/Coordination Requirements <input type="checkbox"/> FOD-designated facility Point-of-Contact must sign IWD Part 3				
<input checked="" type="checkbox"/> Plan of the Day/Plan of the Week (POTD/POTW) <input checked="" type="checkbox"/> Check in at Start of Work <input type="checkbox"/> Work-Area Training Required				
<input type="checkbox"/> Security Clearance Requirements <input checked="" type="checkbox"/> Work must be Scheduled <input checked="" type="checkbox"/> Check in Daily				
<input type="checkbox"/> Co-located Hazards/Concerns <input type="checkbox"/> Other Security Requirements (ex.: Cellphone, No Foreign Nationals, etc.)				
<input checked="" type="checkbox"/> Check out at End of Work <input type="checkbox"/> Quality Issues <input checked="" type="checkbox"/> Check out Daily				
<input type="checkbox"/> Escort Required <input type="checkbox"/> Review under Authorization Basis (AB)/Safety Basis/Unreviewed Safety Question (USQ)				
<input type="checkbox"/> Other Bounding Conditions: _____				
Additional Comments (refer to Job Hazard Analysis [JHA] Tool Facility Notes)				

Instructions: In the block below, identify work-area hazards that could potentially affect the worker(s) or others. Specify the facility controls and preventive measures that must be implemented by the worker(s) to protect against the site hazards as well as any special training required.

ESH/S&S WORK AREA HAZARDS & CONTROLS				
Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
<input type="checkbox"/> No Work Area Hazards				
Ionizing Radiation Work in posted radiological areas, work with radioactive materials, or work on or near radiation producing devices. Specify Hazard:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			

IWD No./Work Request No: _____

Revision #: _____

ESH/S&S WORK AREA HAZARDS & CONTROLS				
Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
Worker Exposure Working near non-ionizing radiation, beryllium, noise, chemicals, hazardous biological materials, lead, asbestos, temperature/humidity extremes, or high explosives. Specify Hazards:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Energized and Operative Systems Working near energized electrical parts, pressure systems, steam lines; near unprotected belts, pulleys, chains or rotating equipment; fuel fired equipment other than vehicles; or spark or flame producing operations. Specify Hazards:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Ensure worker recognize hazards associated with working near rotating equipment.		
Confined Spaces Entry into tanks, manholes, cooling towers, sumps, or any other area with potentially low oxygen concentration or other hazards such as toxic vapors or engulfment. Specify Hazards:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Elevated Work Surface Elevated work when fall protection is not provided by conventional handrail systems or required per P101-20, <u>Fall Protection Program</u> .	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Environmental Impact Activities conducted in areas containing potential release site, contaminated soil, sensitive species, watercourse wetlands, floodplain, historical/archeological sites, or other work area condition that can be impacted by or can impact the environment. Specify Hazards:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Security Requirements Specify:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Other Hazards Specify:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			

I have verified that the hazards identified above adequately identify the area hazards and that the IWM process has been applied appropriately.

FOD or Representative (Signature/Z #/Date) Approval Required _____

Date Approval Expires: 12/31/18

schleft@lanl.gov

 Digitally signed by schleft@lanl.gov
 DN: cn=schleft@lanl.gov
 Date: 2014.10.20 17:00:28 -08:00

AI 856 | Los Alamos National Laboratory

Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1–June 30, 2018

ATTACHMENT A1306.A.

TA-03 Power Plant

Opacity for Sources Combusting Natural Gas

No opacity readings were taken for this source while combusting natural gas. Per Section A1306.A – “Use of natural gas fuel meeting the requirement at Condition A1305.A or B constitutes compliance with 20.2.61 NMAC.....”

AI 856 | Los Alamos National Laboratory

Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1–June 30, 2018

ATTACHMENT A1306.B.

TA-03 Power Plant

Opacity for Sources Combusting No. 2 Fuel Oil



LOS ALAMOS NATIONAL LABORATORY (LANL) VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: TA-3-22 Power Plant Boiler #3	
Source Location: TA-3-22	
Type of Source Boiler #3	Type of Control Equipment NA
Describe Emission Point (Top of stack, etc.) Top of Stack	
Height Above Ground Level 150 Feet	Height Relative to Observer 160 Feet
Distance From Observer 200 Feet	Direction of Source From Observer NNW
Description of Plume (stack exit only) <input checked="" type="checkbox"/> Lofting <input type="checkbox"/> Trapping <input type="checkbox"/> Looping <input type="checkbox"/> Fanning <input type="checkbox"/> Coning <input type="checkbox"/> No Plume Present	
Emission Color white	Plume Type <input type="checkbox"/> No Plume Present <input type="checkbox"/> Continuous <input type="checkbox"/> Fugitive <input checked="" type="checkbox"/> Intermittent
Water Droplets Present? <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES IF YES, droplet plume is <input type="checkbox"/> Attached <input type="checkbox"/> Detached	
At what point in the plume was opacity determined? 2-3 ft. above stack	
Describe Background (i.e. blue sky, trees, etc.) Blue sky, partly cloudy	
Background Color Blue, some white clouds	Sky Conditions Partly cloudy
Wind Speed 5 mph	Wind Direction (provide from/to, i.e. from North to South) From South west
Ambient Temperature 40 °F	Relative Humidity 60 %
Additional Comments/Information: Fuel oil Start-up training on Boiler No. 3, Burner 1	

Observation Date 3/14/2018		Start Time 9:18		End Time 9:28		
Min	Sec	0	15	30	45	Comments
1	0	0	20	10		white smoke
2	0	0	5	0		
3	0	0	0	0		
4	0	0	0	0		
5	0	0	0	0		
6	0	0	0	0		
7	0	0	0	0		
8	0	0	0	0		
9	0	0	0	0		
10	0	0	0	0		
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
Average 10-Minute Opacity 0.9				Range of Opacity Readings Min. 0 Max. 20		
OBSERVER (please print) Name: Marjorie Stockton Title: Env. Prof.						
Signature Marjorie Stockton				Date 3/14/2018		
Observer Organization EPC-CP						
Certified by Aeromet				Certification Date 10/26/2017		

Stack with Plume

Sun

Wind

SOURCE LAYOUT SKETCH

140°

SUN LOCATION LINE

Draw Arrow in North Direction



LOS ALAMOS NATIONAL LABORATORY (LANL) VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: <i>TA-3-22 Boiler No. 3</i>	
Source Location: <i>TA-3-22</i>	
Type of Source <i>Boiler No. 3</i>	Type of Control Equipment <i>NA</i>
Describe Emission Point (Top of stack, etc.) <i>Top of Stack</i>	
Height Above Ground Level <i>150</i> Feet	Height Relative to Observer <i>160</i> Feet
Distance From Observer <i>200</i> Feet	Direction of Source From Observer <i>NNW</i>
Description of Plume (stack exit only) <input type="checkbox"/> Lofting <input type="checkbox"/> Trapping <input type="checkbox"/> Looping <input type="checkbox"/> Fanning <input type="checkbox"/> Coning <input checked="" type="checkbox"/> No Plume Present	
Emission Color <i>NA</i>	Plume Type <input checked="" type="checkbox"/> No Plume Present <input type="checkbox"/> Continuous <input type="checkbox"/> Fugitive <input type="checkbox"/> Intermittent
Water Droplets Present? <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES If YES, droplet plume is <input type="checkbox"/> Attached <input type="checkbox"/> Detached	
At what point in the plume was opacity determined? <i>2-3 ft above stack</i>	
Describe Background (i.e. blue sky, trees, etc.) <i>Blue sky</i>	
Background Color <i>Blue sky</i>	Sky Conditions <i>Blue Sky</i>
Wind Speed <i>5</i> mph	Wind Direction (provide from/to, i.e. from North to South) <i>From SW</i>
Ambient Temperature <i>41</i> °F	Relative Humidity <i>50</i> %
Additional Comments/Information: <i>Fuel oil start up training, Boiler No. 3 Burner 3</i>	

Stack with Plume Sun Wind 	<h2>SOURCE LAYOUT SKETCH</h2> <p>Emission Point</p> <p>Draw Arrow in North Direction</p> <p>OBSERVER'S POSITION</p> <p>140°</p> <p>SUN LOCATION LINE</p>
---	--

Observation Date <i>3/14/2018</i>		Start Time <i>9:56</i>		End Time <i>10:06</i>	
Min	Sec	0	15	30	45
Comments					
1	0	0	0	0	<i>Lit Burner 3</i>
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
Average 10-Minute Opacity <i>0</i>				Range of Opacity Readings Min. <i>0</i> Max. <i>0</i>	
OBSERVER (please print) Name: <i>Marjorie Stockton</i> Title: <i>Env. Prof.</i>					
Signature <i>Marjorie Stockton</i>				Date <i>3/14/18</i>	
Observer Organization <i>EPC-CP</i>					
Certified by <i>Aeromet</i>				Certification Date <i>10/26/2017</i>	

[Lab Home](#) | [Phone](#) | [Search](#)

Date: Wednesday, March 14, 2018 | Time: 08:23 MDT (14:23 UTC) | [Time](#)

[Note »](#)

The Weather Machine

LOS ALAMOS NATIONAL LABORATORY

[LANL Observations](#)

[Regional/U.S. Observations](#)

[Forecast Products](#)

[LANL Climatology](#)

[Data Requests](#)

[LANL Observations](#) > Table Summaries

The table below provides a snapshot of current conditions at each tower location. Wind variables are measured at 11 meters above the ground (36 meters at PJMT) and the atmospheric state variables (temperature, humidity, and pressure) are measured at 1.2 meters above the ground (2 meters at PJMT).

Other Text Summaries Available: 15-Minute Short Summary (English)

Current Observations:

English | [Metric](#)

	TA6	TA49	TA53	TA54
Tower (tower)				
Date (mm/dd)	03/14	03/14	03/14	03/14
Time (hhmm)	0715	0715	0715	0715
Wind Speed (mph)	4.5	7.2	10.1	8.3
Wind Direction (deg)	159	207	193	224
Max Gust (mph)	13.6	11.9	18.6	13.6
Max Gust Direction (deg)	231	230	221	228
Time of Max Gust (hhmm)	545	400	400	645
Temperature (deg-F)	35.8	36.7	38.1	37.9
Max Temp Since Midnight (deg-F)	39.4	39.9	41.4	41.4
Time of Max Temp (hhmm)	545		30	230
Min Temp Since Midnight (deg-F)	34.5	35.4	37.9	34.9
Time of Min Temp (hhmm)	500	600	700	615
Pressure (mb)	776.3	-	-	802.7
Relative Humidity (%)	63	60	58	57
Dew Point Temperature (deg-F)	24.6	24.4	24.8	24.4
Precip Last 15 Minutes (in)	0.00	0.00	0.00	0.00
Precip Since Midnight (in)	0.00	0.00	0.00	0.00
Downwelling Shortwave (BTU/hr* ft^2)	20	19	23	23
Wind Chill (deg-F)	31.8	31.1	31.3	32.0

NOTE: All times are reported in Mountain Standard Time (MST).

[About Us](#) | [Contact Us](#) | [Documentation/Analyses](#)

Operated by [Los Alamos National Security, LLC](#) for the [U.S. Department of Energy's](#) NNSA



[Outside](#) | © Copyright 2018 LANS LLC All rights reserved | [Disclaimer/Privacy](#)
505-667-7079 | weather@lanl.gov | webmaster:weather@lanl.gov



LOS ALAMOS NATIONAL LABORATORY (LANL) VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: **TA-3-22 Power & Steam Plant**

Source Location: **TA-3-22**

Type of Source: **Boiler Stack** Type of Control Equipment: **None**

Describe Emission Point (Top of stack, etc.): **TOP of East Stack**

Height Above Ground Level: **150** Feet Height Relative to Observer: **145** Feet

Distance From Observer: **200** Feet Direction of Source From Observer: **N-NW**

Description of Plume (stack exit only)
☐ Lofting ☐ Trapping ☒ Looping ☐ Fanning ☐ Coning
☐ No Plume Present

Emission Color: **White** Plume Type: ☐ No Plume Present
☐ Continuous ☐ Fugitive ☒ Intermittent

Water Droplets Present?
☒ NO ☐ YES If YES, droplet plume is ☐ Attached ☐ Detached

At what point in the plume was opacity determined?
2ft above stack height

Describe Background (i.e. blue sky, trees, etc.): **Blue Sky**

Background Color: **Blue** Sky Conditions: **Clear**

Wind Speed: **2** mph Wind Direction: **E to W**
 (provide from/to, i.e. from North to South)

Ambient Temperature: **44** °F Relative Humidity: **20** %

Additional Comments/Information:
Boiler #3, #1 Burner
Emission only occurred
when burner tripped.

Observation Date		Start Time				End Time
3/21/18		9:24				9:34
Min	Sec	0	15	30	45	Comments
1		0	0	0	25	B1 Tripped
2		0	0	0	0	
3		0	25	0	0	B1 Tripped
4		0	0	25	0	B1 Tripped
5		0	0	0	0	
6		0	0	0	0	
7		25	0	0	0	B1 Tripped
8		0	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						

Average 10-Minute Opacity: **2.5 %** Range of Opacity Readings
 Min. **0** Max. **25**

OBSERVER (please print)

Name: **Jillian Burgin** Title: **DEP**


Signature: **J Burgin** Date: **3/21/18**

Observer Organization: **DESHS-UIS**

Certified by: **ETA** Certification Date: **2/21/18**

Form ENV-CP-Form-1004

04/2015





LOS ALAMOS NATIONAL LABORATORY (LANL) VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: **TA-3-22 Power & Steam Plant**

Source Location: **TA-3-22**

Type of Source: **Boiler Stack** Type of Control Equipment: **None**

Describe Emission Point (Top of stack, etc.): **TOP OF EAST STACK**

Height Above Ground Level: **150** Feet Height Relative to Observer: **145** Feet

Distance From Observer: **200** Feet Direction of Source From Observer: **N-NW**

Description of Plume (stack exit only)
☐ Lofting ☐ Trapping ☒ Looping ☐ Fanning ☐ Coning
☐ No Plume Present

Emission Color: **White** Plume Type: ☐ No Plume Present
☐ Continuous ☐ Fugitive ☒ Intermittent

Water Droplets Present?
☒ NO ☐ YES If YES, droplet plume is ☐ Attached ☐ Detached

At what point in the plume was opacity determined?
2 ft above stack height

Describe Background (i.e. blue sky, trees, etc.): **Blue sky / white clouds**

Background Color: **Blue / White** Sky Conditions: **Broken**

Wind Speed: **2.9** mph Wind Direction: **E to W**
 (provide from/to, i.e. from North to South)

Ambient Temperature: **45** °F Relative Humidity: **19** %

Additional Comments/Information:
Boiler # 3, #1 & 3 Burners
- Emission occurred only
when burner tripped.

Stack with Plume:

Sun:

Wind:

SOURCE LAYOUT SKETCH

Emission Point:

Draw Arrow in North Direction:

OBSERVER'S POSITION:

SUN LOCATION LINE:

140°

Observation Date		Start Time		End Time		
3/21/18		9:34		9:44		
Min	Sec	0	15	30	45	Comments
1	0	25	0	0		B1 tripped
2	0	0	0	0		B3 on/off
3	0	0	0	0		leak on B3 fix gasket
4	0	0	0	0		
5	0	0	0	0		
6	0	0	0	0		
7	0	0	0	0		
8	0	0	0	0		
9	0	0	0	0		
10	0	0	0	0		
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						

Average 10-Minute Opacity: **0.625 %** Range of Opacity Readings: Min. **0** Max. **25**

OBSERVER (please print)
 Name: **Jillian Burgin, DEP** Title: **DEP**

Signature: Date: **3/21/18**

Observer Organization: **DESHS-US**

Certified by: **ETA** Certification Date: **2/21/18**



LOS ALAMOS NATIONAL LABORATORY (LANL) VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: TA-3-22 Power + Steam Plant	
Source Location: TA-3-22	
Type of Source Boiler Stack	Type of Control Equipment NONE
Describe Emission Point (Top of stack, etc.) TOP of EAST Stack	
Height Above Ground Level 150 Feet	Height Relative to Observer 145 Feet
Distance From Observer 200 Feet	Direction of Source From Observer N-NW
Description of Plume (stack exit only) <input type="checkbox"/> Lofting <input type="checkbox"/> Trapping <input checked="" type="checkbox"/> Looping <input type="checkbox"/> Fanning <input type="checkbox"/> Coning <input type="checkbox"/> No Plume Present	
Emission Color White	Plume Type <input type="checkbox"/> Continuous <input type="checkbox"/> Fugitive <input checked="" type="checkbox"/> Intermittent <input type="checkbox"/> No Plume Present
Water Droplets Present? <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES If YES, droplet plume is <input type="checkbox"/> Attached <input type="checkbox"/> Detached	
At what point in the plume was opacity determined? 2 ft above Stack Height	
Describe Background (i.e. blue sky, trees, etc.) Blue sky / White clouds	
Background Color Blue / White	Sky Conditions Broken
Wind Speed 5 mph	Wind Direction (provide from/to, i.e. from North to South) ESE to WNW
Ambient Temperature 44 °F	Relative Humidity 21 %
Additional Comments/Information: Boiler #3, #3 + 1 Burners. -Emission only occurred when burners tripped.	

Observation Date 3/21/18		Start Time 9:56				End Time 10:06
Min	Sec	0	15	30	45	Comments
1		0	0	0	0	B3 lit
2		0	0	25	0	B3 tripped
3		0	0	0	0	
4		0	0	0	25	B3 lit / tripped
5		0	0	0	0	
6		0	0	0	0	B1 lit
7		0	25	0	0	B1 tripped
8		0	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						

Average 10-Minute Opacity 1.875 %	Range of Opacity Readings Min. 0 Max. 25
---	---

OBSERVER (please print) Name: Julian Burgin, DEP	
--	--


Signature J Burgin	Date 3/21/18
------------------------------	------------------------

Observer Organization DESHS-UIS

Certified by ETA	Certification Date 2/21/18
----------------------------	--------------------------------------

Form ENV-CP-Form-1004

04/2015





LOS ALAMOS NATIONAL LABORATORY (LANL) VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: **TA-3-22 Power & Steam Plant**

Source Location: **TA-3-22**

Type of Source: **Boiler Stack** Type of Control Equipment: **NONE**

Describe Emission Point (Top of stack, etc.): **TOP OF EAST STACK**

Height Above Ground Level: **150** Feet Height Relative to Observer: **145** Feet

Distance From Observer: **200** Feet Direction of Source From Observer: **N-NW**

Description of Plume (stack exit only)
☐ Lofting ☐ Trapping ☐ Looping ☐ Fanning ☐ Coning
☒ No Plume Present

Emission Color: **N/A** Plume Type: ☒ No Plume Present
☐ Continuous ☐ Fugitive ☐ Intermittent

Water Droplets Present?
☒ NO ☐ YES If YES, droplet plume is ☐ Attached ☐ Detached

At what point in the plume was opacity determined?
2 ft above stack height

Describe Background (i.e. blue sky, trees, etc.): **Blue sky / White clouds**

Background Color: **Blue/white** Sky Conditions: **Broken**

Wind Speed: **4.7** mph Wind Direction: **E to W**
 (provide from/to, i.e. from North to South)

Ambient Temperature: **46** °F Relative Humidity: **19** %

Additional Comments/Information:
Boiler # 3, #4 Burner

Observation Date		Start Time		End Time		
3/21/18		10:35		10:45		
Min	Sec	0	15	30	45	Comments
1		0	0	0	0	Bl 1:1
2		0	0	0	0	
3		0	0	0	0	
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7		0	0	0	0	
8		0	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						

Average 10-Minute Opacity: **0** Range of Opacity Readings
 Min. **0** Max. **0**

OBSERVER (please print)
 Name: **Jillian Burgin** Title: **DEP**

Signature: **J Burgin** Date: **3/21/18**

Observer Organization: **DESHS-UIS**

Certified by: **ETA** Certification Date: **2/21/18**

Form ENV-CR-Form-1004

04/2015

Stack with Plume:

Sun:

Wind:

SOURCE LAYOUT SKETCH

Emission Point:

Draw Arrow in North Direction:

OBSERVER'S POSITION:

SUN LOCATION LINE:

140°



LOS ALAMOS NATIONAL LABORATORY (LANL) VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: TA-3-22 Power & Steam Plant	
Source Location: TA-3-22	
Type of Source Boiler Stack	Type of Control Equipment NONE
Describe Emission Point (Top of stack, etc.) TOP of EAST Stack	
Height Above Ground Level 150 Feet	Height Relative to Observer 145 Feet
Distance From Observer 200 Feet	Direction of Source From Observer N-NW
Description of Plume (stack exit only) <input type="checkbox"/> Lofting <input type="checkbox"/> Trapping <input type="checkbox"/> Looping <input type="checkbox"/> Fanning <input type="checkbox"/> Coning <input checked="" type="checkbox"/> No Plume Present	
Emission Color N/A	Plume Type <input checked="" type="checkbox"/> No Plume Present <input type="checkbox"/> Continuous <input type="checkbox"/> Fugitive <input type="checkbox"/> Intermittent
Water Droplets Present? <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES If YES, droplet plume is <input type="checkbox"/> Attached <input type="checkbox"/> Detached	
At what point in the plume was opacity determined? 2 ft above stack height	
Describe Background (i.e. blue sky, trees, etc.) Blue sky / white clouds	
Background Color Blue / white	Sky Conditions Broken
Wind Speed 4.9 mph	Wind Direction (provide from/to, i.e. from North to South) ESE to WNW
Ambient Temperature 46 °F	Relative Humidity 18 %
Additional Comments/Information: Boiler # 3, # 1 + 3 Burners	

Observation Date 3/21/18		Start Time 10:53		End Time 11:03	
Min	Sec	0	15	30	45
		Comments			
1		0	0	0	0
2		0	0	0	0
3		0	0	0	0
4		0	0	0	0
5		0	0	0	0
6		0	0	0	0
7		0	0	0	0
8		0	0	0	0
9		0	0	0	0
10		0	0	0	0
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
Average 10-Minute Opacity 0				Range of Opacity Readings Min. 0 Max. 0	
OBSERVER (please print) Name: Julian Burgin, DEP Title: DEP					
Signature Julian Burgin				Date 3/21/18	
Observer Organization DESHS-US					
Certified by ETA				Certification Date 3/21/18	

SOURCE LAYOUT SKETCH

Stack with Plume

Sun

Wind

Emission Point

Draw Arrow in North Direction

OBSERVER'S POSITION

140°

SUN LOCATION LINE



Data is for tower tab.

This file was obtained from the LANL Weather Machine, <http://weather.lanl.gov>.

Request made on Wed Mar 21 10:45:38 2018 MST.

All data times are MST.

month	day	year	hour	minute	day	spd1	dir1	temp0	F	rh
mm	dd	yyyy	hh	mm	ddd	m/s	mph	deg	deg-C	%RH
3	21	2018	8	15	80	0.9	2.01	81 E to W	6.7	44.06
3	21	2018	8	30	80	1.3	2.91	87 E to W	7.4	45.32
3	21	2018	8	45	80	1.4	3.13	79 E to W	7.6	45.68
3	21	2018	9	0	80	2.3	5.14	118 ESE to WNW	7.1	44.78
3	21	2018	9	15	80	1.9	4.25	98 E to W	7.2	44.96
3	21	2018	9	30	80	2.1	4.7	97 E to W	7.8	46.04
3	21	2018	9	45	80	2.2	4.92	119 ESE to WNW	8.2	46.76
3	21	2018	10	0	80	1.8	4.03	117 ESE to WNW	8.9	48.02
3	21	2018	10	15	80	2.1	4.7	107 ESE to WNW	9.1	48.38
3	21	2018	10	15	80	2.1	4.7	107 ESE to WNW	9.1	48.38

Today is Wednesday, March 21, 2018. We are currently in Mountain Daylight Time (MDT)

Please add one hour to times reported on this site, as product and data feed times are reported in MST.

AI 856 | Los Alamos National Laboratory

Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1–June 30, 2018

ATTACHMENT A1307.A.

TA-03 Power Plant Emission Rate Calculations

Monthly Emission Calculation (Natural Gas) 2018

Average Hourly Emissions Rates (pph) for each Emission Unit
(Meets condition A1307.A, monitoring condition 1, of Title V Permit P100-R2M1)

Unit TA-3-22-1 (Boiler 1) pph

	Jan.	Feb.	Mar.	Apr.	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Allowable Emissions ^(a)
NOx	3.69	3.78	3.05	2.44	0.00	0.00							10.2
SOx	0.04	0.04	0.03	0.03	0.00	0.00							1.1
PM	0.48	0.50	0.40	0.32	0.00	0.00							1.3
PM-10	0.48	0.50	0.40	0.32	0.00	0.00							1.3
PM-2.5	0.48	0.50	0.40	0.32	0.00	0.00							1.3
CO	2.55	2.61	2.10	1.69	0.00	0.00							7.0
VOC	0.35	0.36	0.29	0.23	0.00	0.00							1.0

Unit TA-3-22-2 (Boiler 2) pph

	Jan.	Feb.	Mar.	Apr.	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Allowable Emissions ^(a)
NOx	2.37	3.26	2.58	2.19	1.45	1.06							10.2
SOx	0.02	0.03	0.03	0.02	0.02	0.01							1.1
PM	0.31	0.43	0.34	0.29	0.19	0.14							1.3
PM-10	0.31	0.43	0.34	0.29	0.19	0.14							1.3
PM-2.5	0.31	0.43	0.34	0.29	0.19	0.14							1.3
CO	1.63	2.25	1.78	1.51	1.00	0.73							7.0
VOC	0.22	0.31	0.24	0.21	0.14	0.10							1.0

Unit TA-3-22-3 (Boiler 3) pph

	Jan.	Feb.	Mar.	Apr.	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Allowable Emissions ^(a)
NOx	3.04	2.88	1.87	0.00	0.00	0.00							10.2
SOx	0.03	0.03	0.02	0.00	0.00	0.00							1.1
PM	0.40	0.38	0.24	0.00	0.00	0.00							1.3
PM-10	0.40	0.38	0.24	0.00	0.00	0.00							1.3
PM-2.5	0.40	0.38	0.24	0.00	0.00	0.00							1.3
CO	2.09	1.98	1.29	0.00	0.00	0.00							7.0
VOC	0.29	0.27	0.18	0.00	0.00	0.00							1.0

(a) Allowable Emissions are from table A1302A of Permit P100-R2M1.

Condition A1307.A, monitoring condition 3, can't be calculated because the units are based on the emission factor. The emission factor for NOx is in lbs/MMscf, which is converted to lbs/MMBtu by dividing by 1020 (standard number of MMBtu in a MMscf). The NOx emission rate will always be 0.057 lbs/MMBtu unless the Btu value of the fuel changes significantly. The average Btu value for natural gas can be found in the GHG emission calculations in this spreadsheet.

1412/1711

Monthly Emission Calculation (Fuel Oil) 2018

Average Hourly Emissions Rates (pph) for each Emission Unit
(Meets condition A1307.A, monitoring condition 1, of Title V Permit P100-R2M1)

Unit TA-3-22-1 (Boiler 1)													Allowable Emissions ^(a)
	Jan.	Feb.	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Oil
NOx	0.00	0.00	0.00	0.00	0.00	0.00	0.00						11.3
SOx	0.00	0.00	0.00	0.00	0.00	0.00	0.00						9.6
PM	0.00	0.00	0.00	0.00	0.00	0.00	0.00						4.3
PM-10	0.00	0.00	0.00	0.00	0.00	0.00	0.00						3.0
PM-2.5	0.00	0.00	0.00	0.00	0.00	0.00	0.00						2.0
CO	0.00	0.00	0.00	0.00	0.00	0.00	0.00						6.5
VOC	0.00	0.00	0.00	0.00	0.00	0.00	0.00						0.3

Unit TA-3-22-2 (Boiler 2)													Allowable Emissions ^(a)
	Jan.	Feb.	Mar.	Apr.	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Oil
NOx	0.00	0.00	0.00	0.00	0.00	0.00							11.3
SOx	0.00	0.00	0.00	0.00	0.00	0.00							9.6
PM	0.00	0.00	0.00	0.00	0.00	0.00							4.3
PM-10	0.00	0.00	0.00	0.00	0.00	0.00							3.0
PM-2.5	0.00	0.00	0.00	0.00	0.00	0.00							2.0
CO	0.00	0.00	0.00	0.00	0.00	0.00							6.5
VOC	0.00	0.00	0.00	0.00	0.00	0.00							0.3

Unit TA-3-22-3 (Boiler 3)													Allowable Emissions ^(a)
	Jan.	Feb.	Mar.	Apr.	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Oil
NOx	0.00	0.00	10.23	0.00	0.00	0.00							11.3
SOx	0.00	0.00	8.74	0.00	0.00	0.00							9.6
PM	0.00	0.00	3.91	0.00	0.00	0.00							4.3
PM-10	0.00	0.00	2.72	0.00	0.00	0.00							3.0
PM-2.5	0.00	0.00	1.84	0.00	0.00	0.00							2.0
CO	0.00	0.00	5.92	0.00	0.00	0.00							6.5
VOC	0.00	0.00	0.24	0.00	0.00	0.00							0.3

1413/1711

12 Month Rolling Emissions 2018 (Tons) All Three Boilers Combined

Pollutant	TSP	PM10	NOx	CO	VOC	SO ₂
Permit Limit (tons/yr)	8.4	8.2	60.2	41.3	5.6	7.9
12-Month Rolling Total						
January	1.277	1.276	9.733	6.711	0.922	0.106
February	1.288	1.287	9.815	6.768	0.930	0.107
March	1.311	1.310	9.991	6.889	0.947	0.109
April	1.302	1.301	9.920	6.841	0.940	0.108
May	1.275	1.274	9.717	6.701	0.921	0.106
June	1.260	1.259	9.603	6.622	0.910	0.105
July						
August						
September						
October						
November						
December						

Meets permit condition A1307.A, Monitoring Condition 2.

Monthly Emission Totals (Tons)

Pollutant	TSP	PM10	NOx	CO	VOC	SO ₂
January	0.183	0.183	1.394	0.961	0.132	0.014
February	0.149	0.149	1.139	0.785	0.108	0.012
March	0.148	0.148	1.125	0.775	0.107	0.013
April	0.107	0.107	0.818	0.564	0.078	0.008
May	0.071	0.071	0.541	0.373	0.051	0.006
June	0.050	0.050	0.380	0.262	0.036	0.004
July						
August						
September						
October						
November						
December						
Annual Totals	0.707	0.707	5.396	3.721	0.512	0.057

AI 856 | Los Alamos National Laboratory

Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1–June 30, 2018

ATTACHMENT A1307.B.

TA-03 Power Plant

Boiler Fuel Use and Hours of Operation

TA-3 Power Plant Fuel Use Totals 2018 (Data Entry)

DATA ENTRY										
Month	TA-3-22 Power Plant ^b Boiler # 1 (Edgemoor Iron Works, 210 mmBtu/hr)		TA-3-22 Power Plant ^b Boiler # 2 (Edgemoor Iron Works, 210 mmBtu/hr)		TA-3-22 Power Plant ^b Boiler # 3 (Union Iron Works, 210 mmBtu/hr)		Monthly Totals			
	Natural Gas (mmscf) ^a	Fuel Oil (gallons) ^a	Natural Gas (mmscf) ^a	Fuel Oil (gallons) ^a	Natural Gas (mmscf) ^a	Fuel Oil (gallons) ^a	Natural Gas (mmscf) ^a	Fuel Oil (gallons) ^a	Fuel Oil (gallons) ^a	Fuel Oil (gallons) ^a
January	46,473	0	176	0	1,419	0	48,068	0		
February	19,517	0	15,017	0	4,725	0	39,259	0		
March	35,770	0	2,822	0	135	371	38,726	371		
April	9,159	0	19,040	0	1	0	28,199	0		
May	5	0	18,636	0	3	0	18,644	0		
June	0	0	13,112	0	0	0	13,112	0		
July										
August										
September										
October										
November										
December										
Annual Totals:	110,923	0	68,802	0	6,283	371	186,008	371		
Jan. - June	110,923	0	68,802	0	6,283	371	186,008	371		
July - Dec.	0	0	0	0	0	0	0,000	0		

Month	12-Mo. Rolling Total Natural Gas (mmscf)	12-Mo. Rolling Total Fuel Oil (gallons)	Hours of Operation Gas Boiler 1	Hours of Operation Nat Gas Boiler 2	Hours of Operation Nat Gas Boiler 3	Hours of Operation Fuel Oil Boiler 1	Hours of Operation Fuel Oil Boiler 2	Hours of Operation Fuel Oil Boiler 3	12-Month Rolling Total Hours (All Boilers)
January	335.4	1,469	729.5	4.3	27.1	0.0	0.0	0.0	8788.9
February	338.2	1,469	299.4	267.0	95.3	0.0	0.0	0.0	8775.4
March	344.3	1,562	680.3	63.5	4.2	0.0	0.0	0.3	8776.3
April	341.8	1,562	217.3	503.6	0.0	0.0	0.0	0.0	8778.4
May	334.8	1,562	0.0	743.9	0.0	0.0	0.0	0.0	8776.8
June	330.9	1,513	0.0	719.7	0.0	0.0	0.0	0.0	8776.5
July									
August									
September									
October									
November									
December									
Permit Limits:	1000 MMscf	500,000 gal							

12 Month Rolling Fuel Totals For Each TA-3 Power Plant Boiler - 2018

Month	Boiler 1		Boiler 2		Boiler 3	
	Natural Gas (mmscf)	Fuel Oil (gal.)	Natural Gas (mmscf)	Fuel Oil (gal.)	Natural Gas (mmscf)	Fuel Oil (gal.)
January	86	0	168	0	82	1,469
February	105	0	146	0	86	1,469
March	141	0	117	0	86	1,562
April	142	0	119	0	80	1,562
May	122	0	138	0	75	1,562
June	121	0	151	0	59	1,513
July						
August						
September						
October						
November						
December						

AI 856 | Los Alamos National Laboratory

Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1–June 30, 2018

ATTACHMENT A1307.C.

TA-03 Power Plant

Turbine Fuel Use and Hours of Operation

CY2018 Daily Turbine Gas Use (Mscf), 12 Month Rolling Total Gas Use, & Hours of Operation																								
Day	Jan		Feb		Mar		Apr		May		Jun		July		Aug		Sept		Oct		Nov		Dec	
	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs
1	0	0.0	2007	8.0	2139	8.0	0	0.0	0	0.0	0	0.0												
2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0												
3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0												
4	2106	8.0	0	0.0	0	0.0	0	0.0	1041	4.0	0	0.0												
5	0	0.0	0	0.0	0	0.0	2193	8.0	0	0.0	0	0.0												
6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	2	0.0												
7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	916	4.0												
8	0	0.0	2064	8.0	2057	7.0	0	0.0	0	0.0	54	0.2												
9	0	0.0	0	0.0	0	0.0	1553	6.5	0	0.0	0	0.0												
10	0	0.0	0	0.0	0	0.0	4610	16.0	0	0.0	0	0.0												
11	2109	8.0	0	0.0	0	0.0	5175	20.0	25	0.5	1	0.1												
12	0	0.0	0	0.0	0	0.0	5341	23.5	0	0.0	0	0.0												
13	0	0.0	0	0.0	0	0.0	6165	24.0	0	0.0	0	0.0												
14	0	0.0	6	0.02	0	0.0	6093	24.0	14	0.3	29	0.1												
15	0	0.0	82	0.3	837	3.0	5707	24.0	16	0.4	111	0.5												
16	0	0.0	0	0.0	0	0.0	5647	24.0	0	0.0	0	0.0												
17	0	0.0	0	0.0	0	0.0	5881	24.0	0	0.0	0	0.0												
18	1982	8.0	0	0.0	0	0.0	5985	24.0	0	0.0	0	0.0												
19	0	0.0	0	0.0	0	0.0	6415	24.0	0	0.0	21	0.1												
20	0	0.0	0	0.0	0	0.0	5595	24.0	0	0.0	0	0.0												
21	0	0.0	0	0.0	0	0.0	5897	24.0	0	0.0	345	1.5												
22	763	3.0	0	0.0	1960	8.0	4912	21.0	0	0.0	0	0.0												
23	0	0.0	0	0.0	0	0.0	5739	24.0	0	0.0	0	0.0												
24	0	0.0	0	0.0	0	0.0	5823	24.0	1337	6.0	0	0.0												
25	2060	8.0	0	0.0	0	0.0	5887	24.0	0	0.0	0	0.0												
26	0	0.0	0	0.0	0	0.0	3966	24.0	0	0.0	0	0.0												
27	0	0.0	0	0.0	0	0.0	2419	8.5	0	0.0	0	0.0												
28	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	1458	7.0												
29	0	0.0	0	0.0	550	3.0	0	0.0	0	0.0	0	0.0												
30	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0												
31	0	0.0	0	0.0	0	0.0	0	0.0	1773	8.0	0	0.0												
SUM	9020	35	4159	16.32	7543	29	101003	416	4206	19.2	2937	13.5												
Mscf	51,729		51,536		54,845		149,967		148,493		145,870													
MMscf	51.7		51.5		54.8		150.0		148.5		145.9													
Hrs	210		210		222		614		609		599													
First Half Gas Use:							Second Half Gas Use:							Annual Gas Use:							Annual Gas Use:			
128.87							0.0							128.87							128.87			
MMscf							MMscf							MMscf							MMscf			
Permit Limit (12 mo rolling): 1400							MMscf							MMscf							MMscf			
Total Annual Hours: 528.5 Hour							High Heat Value (HHV) for natural gas ^k = 1020							MMBtu/MMscf							MMBtu/MMscf			

AI 856 | Los Alamos National Laboratory

Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1–June 30, 2018

ATTACHMENT A1307.D.

TA-03 Power Plant

Turbine Operating Logs

CGTG TURBINE UTILITIES AND INFRASTRUCTURE						CGTG GAS TURBINE						Hour Beginning (MST/MDT (circle one))																							
		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24						
1	Instrument Air Compressor	(BVT-013) hourly																																	
2	NOTE Blowdown Dry Receiver Tank	(BVT-007) hourly																																	
3	Wet Receiver Air Pressure	PI-002 psig	90	105	120																														
4	Instrument Temperature	TI-001 deg C	20	50																															
5	Fin Fan Cooler	Units	Low	Norm	Max																														
6	Coolant Pressure	PI-250 psig	25																																
7	Coolant PLC Temperature	TI-002 deg F	100	110	120																														
8	Sight glass level Expansion Tank	LI-001 LEVEL	1/3	2/3	FULL																														
9	Coolant Return Differential from GG	FI-001 In W/C	60	80																															
10	Coolant Return Differential from	FI-002 In W/C	37	50																															
11	Control Room	Units	Low	Norm	Max																														
12	Room Temperature	deg F	72	85																															
13	Combustible Gas Detector monitor	% LEL	0%	20%																															
14	WECC Log	operational		Not operational																															
15	Operation of the PSS/on at 6.3MW	Yes		No																															
16	Operation of the AVR Voltage Mode	Yes		No																															
17	@13.6 KV	Yes		No																															
18	Time gas was first introduced into the Turbine (Turbine Rolling)		200	575																															
19	Turbine on line. (When BKR Closes)																																		
20	Turbine off line. (When BKR Opens)																																		
21	Time of No Gas Flow																																		
22	Electronic Control System	Units	Low	Norm	Max																														
23	Air Diagram																																		
18	2000 gal Oily Water Tank Level	LI-231	%		70%																														
19	Air Diagram Page																																		
19	10 gal Gas TG Drain Tank	LI-230	%		70%																														
20	Air Diagram Page/Record on hard S/D trip over 4500 rpm NL Compressor (on line trip)	A636GD	psig	35	20																														
21	Acknowledge Alarms hourly																																		
22	Power Management Page		Amps		1200																														
23	Generator Current	A54A-01																																	
24	Power Management Page		MW		21																														
25	MW Output																																		
26	Power Management Page																																		
27	80 % Base Min Load																																		
28	Running Hours/ Unit Overview Page																																		
29	Ambient Temperature	TI																																	
30	Gas Fuel System/Waste Oil Tank	LI-120	%		70%																														
DATE 1-4-2018		SIGNATURE																																	

McGill

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor	GAS COMPRESSOR START TIME	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Combusible Gas Detector	AAH-303	%		0%	20%																								
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIGHT		BLINK																									
Liquid Level Coalescing	LI-7721	LIQUID		EMPTY	ANY																								
Crankcase Bulb eye	LC-1574	LEVEL	1/4	1/2	FULL																								
Oil Day Tank level	LI-1562	GAL	10		FULL																								
Lubricator Bulb eye		LEVEL	1/2	FULL																									
1st Stage Scrubber Liquid Level	LI-7416	LIQUID		EMPTY	ANY																								
2nd Stage Scrubber Liquid Level	LI-7466	LIQUID		EMPTY	ANY																								
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIGHT		BLINK																									
1 st Stage Inlet Press.	PI-2100	psig		88	140																								
Stage Disch. Press	PI-2101	psig		238	285																								
2nd Stage Inlet Press	PI-2200	psig		267	285																								
2 nd Stage Disch. Press	PI-2201	psig		575	600																								
Final Discharge Pressure	PI-2108	psig		575	600																								
Lube Oil Pressure	PI-1572	psig	40	60																									
Lube Oil Temp	TE-1584	deg		150	170																								
Final Discharge Temp	TE-2120	deg		110	150																								
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297																								
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283																								
1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297																								
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283																								
Motor Frame Vibration	VT-1015	IPS			0.15																								
Compressor Frame Vibration	VT-1512	IPS			0.35																								
Take Once per Shift / at Full Load		psig		Max	psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																							
Natural Gas Comp Discharge Press.																													
Double Block and Bleed Pressure	A63FGDT	49-48=psid			8																								
Fuel Gas Supply Pressure	A63FTG5T	50-49=psid			20																								

DATE 1-4-18

SIGNATURE

Mid Shift

Days Shift

Notes

644011

CGTG GAS TURBINE

DATE: 01.11-2018

Time Gas Introduced (Turbine Rollin):	Time of Turbine Online (Brkr Closed):	Time Turbine Offline (Brkr Open):	Time No Gas Flow:	Notes:																								
					1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Instrument Air Compressor	0642				1	5	5	2																				
1 Blowdown Dry Receiver Tank Hourly	0642-013	✓																										
2 Blowdown Wet Receiver Tank Hourly	0642-007	✓																										
3 Wet Receiver Air Pressure	PI-002	psig	90	105	120																							
4 Instrument Temperature	TI-003	deg C	20	50	50																							
5 In Fan Cooler		Units	Low	Norm	Max																							
6 Coolant Pressure	PI-250	psig	25																									
7 Coolant PLC Temperature	TI-002	deg F	100	110	120																							
8 Sight glass Level Expansion Tank	LI-001	LEVEL	1/3	2/3	FULL																							
9 Coolant Return Differential from GG	FI-001	In WC	60	80	80																							
10 Coolant Return Differential from	FI-002	In WC	37	50	50																							
11 Control Room		Units	Low	Norm	Max																							
12 Room Temperature		deg F	72	85	85																							
13 Combustible Gas Detector monitor		% LEL	0%	0%	20%																							
15 WECC Log		Operational?																										
16 Operation of the PSS/2400 S.M.W.		Yes (Y)			No (N)																							
17 Operation of the AVR Voltage Mode @13.6 KV		Yes (Y)			No (N)																							
18 Entronic Control System		Units	Low	Norm	Max																							
18-2000 gal Oil Water Tank Level	LI-231	%	70%																									
19 Gas TG Drain Tank (air diagram page)	LI-230	%	70%																									
20 Record on hard S/D trip over 4500 rpm	6036610	psig	35	20																								
21 Acknowledge Alarms hourly	517-01	✓																										
22 Generator Current		Amps	1200																									
23 MW Output		MW	27																									
24 80% Base Load minimum		MW																										
25 Running Hours (Unit overview)																												
26 Ambient Temperature	TI inlet																											
27 Waste Oil Tank	LI-120	%	70%																									
28 Total fuel flow	Mscf/h																											
DATE: 01-11-2018	SIGNATURE: [Signature]																											

STRUCTURE

UTILITIES AND INFRASTRUCTURE

NATURAL GAS COMPRESSOR START TIME 06/15					Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Combusitible Gas Detector	AAH 303	%		0%	20%											1/4	1/4	1/4	1/4	1/4	1/4											
Packing Lube Oil Flow Indicator Left Side	FSI 1501B	LIGHT		BLINK												B	B	B	B	B	B											
Liquid Level Coalescing	LI 7121	LIQUID		EMPTY	ANY											E	E	E	E	E	E											
Crankcase Bulb eye	LC 1574	LEVEL	1/4	1/2	FULL											1/2	1/2	1/2	1/2	1/2	1/2											
Oil Tank Level	LI 1562	GAL	10		FULL											45	45	45	45	45	45											
Lubricator Bulb eye		LEVEL	1/2	FULL												F	F	F	F	F	F											
1st Stage Scrubber Liquid Level	LI 7416	LIQUID		EMPTY	ANY											E	E	E	E	E	E											
2nd Stage Scrubber Liquid Level	LI 7466	LIQUID		EMPTY	ANY											E	E	E	E	E	E											
Packing Lube Oil Flow Indicator Right Side	FSI 1501A	LIGHT		BLINK												B	B	B	B	B	B											
1st Stage Inlet Press.	PI 2100	psig		88	140											81	82	82	82	81	81	81										
2nd Stage Disch. Press	PI 2101	psig		238	285											242	246	247	247	248	248	248										
2nd Stage Inlet Press	PI 2200	psig		267	285											242	242	243	244	244	244	244										
2nd Stage Disch. Press	PI 2201	psig		575	600											578	578	579	579	579	579	579										
Final Discharge Pressure	PI 2108	psig		575	600											574	574	574	574	574	574	575										
Lube Oil Pressure	PI 1572	psig	40	60												57	57	57	57	57	57	57										
Lube Oil Temp	TI 1584	deg		150	170											169	170	171	171	171	170	170										
Final Discharge Temp	TI 2120	deg		110	150											70	71	73	75	77	77	79	78									
1st Stage Cylinder Disch. Temperature A	TE 2054 A	deg		226	297											208	208	208	207	207	207	207										
2nd Stage Cylinder Disch. Temperature A	TE 2062 A	deg		258	283											205	205	207	208	207	207	207										
1st Stage Cylinder Disch. Temperature B	TE 2054 B	deg		226	297											206	206	205	204	204	204	204	205									
2nd Stage Cylinder Disch. Temperature B	TE 2062 B	deg		258	283											205	205	207	208	207	207	207										
Motor Frame Vibration	VI 1015	IPS			0.15											0.03	0.03	0.03	0.03	0.03	0.03	0.03										
Compressor Frame Vibration	VI 1572	IPS			0.35											0.05	0.05	0.05	0.05	0.05	0.05	0.05										
Take Once per Shift / at Full Load		psig		Max	psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																										
Natural Gas Comp. Discharge Press.	AG3F(G1)															575																
Double Block and Bleed Pressure	AG3F(G5)															575																
Fuel Gas Supply Pressure	AG3F(G5)															575																

DATE 1-11-18
SIGNATURE *[Signature]*
Days Shift

Notes

CGTG GAS TURBINE

[illegible]

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
Combustible Gas Detector	AAH-303	%		0%	20%								104.4	101.1	104.4	101.1	104.4	101.1											
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIGHT		BLINK									12	13	12	13	12	13	12	13									
Liquid Level Coalescing	LI-7721	LIQUID		EMPTY	ANY								E	E	E	E	E	E	E	E									
Crankcase Bulk eye	LC-1574	LEVEL	1/4	1/2	FULL								1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2									
Oil Day Tank Level	LI-1562	GAL	10	FULL									45	45	45	45	45	45	45	45									
Lubricator Bulk eye		LEVEL	1/2	FULL									E	E	E	E	E	E	E	E									
1st Stage Scrubber Liquid Level	LI-7416	LIQUID		EMPTY	ANY								E	E	E	E	E	E	E	E									
2nd Stage Scrubber Liquid Level	LI-7466	LIQUID		EMPTY	ANY								E	E	E	E	E	E	E	E									
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIGHT		BLINK									13	13	13	13	13	13	13	13									
1 st Stage Inlet Press.	PI-2100	psig	88	140									112.5	112.5	112.5	112.5	112.5	112.5	112.5	112.5									
Stage Disch. Press	PI-2101	psig	238	285									249.2	249.2	249.2	249.2	249.2	249.2	249.2	249.2									
2nd Stage Inlet Press	PI-2200	psig	267	285									294	294	294	294	294	294	294	294									
2 nd Stage Disch. Press	PI-2201	psig	575	600									576	578	578	578	578	578	578	578									
Final Discharge Pressure	PI-2108	psig	575	600									574	574	574	574	574	574	574	574									
Lube Oil Pressure	PI-1572	psig	40	60									57	57	57	57	57	57	57	57									
Lube Oil Temp	TE-1584	deg	150	170									164	170	170	170	170	170	170	170									
Final Discharge Temp	TE-2120	deg	110	150									70	71	74	76	86	82	85	86									
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg	226	297									205	205	206	206	206	206	209	207									
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg	258	283									203	203	206	209	211	214	217	218									
1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg	226	297									203	203	203	204	205	206	206	206									
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg	258	283									203	203	203	204	211	215	215	218									
Motor Frame Vibration	VT-1015	IPS	0.15	0.35									104	103	103	103	103	103	103	104									
Compressor Frame Vibration	VT-1512	IPS	0.35	0.35									105	105	105	106	107	105	105	106									
Take Once per Shift / at Full Load		psig	Max psid										575																
Natural Gas Comp. Discharge Press.	A63FGDT	49-48=psid	8										576																
Double Block and Bleed Pressure	A63FTGST	50-49=psid	20										561																
Fuel Gas Supply Pressure																													

When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer

DATE 1-15-2018

SIGNATURE

Mid Shift

Days Shift

Notes



U/L-06-003-AR2
January 7, 2018

Date: 01-22-2018

MST / MDT (circle one)
Time Gas Introduced (Turbine Rating):
Time of Turbine Online (Bkr Closed):

0755
0908

Time Turbine Offline (Bkr Open):
Time No Gas Flow:

1159
1204

CGTG HOURLY READING LOG

Notes: HAD TWO TRIPLES

Instrument Air Compressor	ID	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
1 Blowdown Dry Receiver Tank Hourly	8V1-013	V												yes	yes	yes														
2 Blowdown Wet Receiver Tank Hourly	8V7-007	V												yes	yes	yes														
3 Wet Receiver Air Pressure	PI-002	psig	90	105	120									104	104	106														
4 Instrument Temperature	TI-001	deg C	20	50	50									104	104	106														
5 Fin Fan Cooler		Units	Low	Norm	Max																									
6 Coolant Pressure	PI-250	psig	25											19.5	19.5	19.5														
7 Coolant P/C Temperature	TI-002	deg F	100	110	120									111	105	105														
8 Sight Glass Level Expansion Tank	LI-001	LEVEL	1/3	2/3	FULL									1/2	1/2	1/2														
9 Coolant Return Differential from GC	PI-001	in WC	40	80	80									63	63	64														
10 Coolant Return Differential from	FI-002	in WC	37	50	50									34	34	35														
11 Control Room		Units	Low	Norm	Max																									
12 Room Temperature		deg F	72	85	85									70	70	70														
13 Combustible Gas Detector Monitor		% LEL	0%	0%	20%									0%	0%	0%														
15 WCCCI Log		Operations?																												
16 Operation of PSS/On at 5.38MV		Yes (Y)			No (N)									yes	yes	yes														
17 Operation of AVR Voltage Mode @ 13.6 KV		Yes (Y)			No (N)									yes	yes	yes														
Electronic Control System		Units	Low	Norm	Max																									
(18-20 found on Air Diagram page)																														
18 2000 gal Oil Water Tank Level	LI-231	%			70%									35%	35%	35%														
19 10 gal gas T/S Drain Tank (Air Diagram page)	LI-230	%			70%									0%	0%	0%														
20 Record on head S/D trip over 4500 rpm NL Compressor (on line trip)	A656G60 57-01	psig	35	20																										
21 Acknowledge Alarms Hourly		V												yes	yes	yes														
(22-24 found on Power Management page)																														
22 Generator Current		Amps			1300									1138	1148	1137														
23 MW Output		MW			27									26.8	26.8	26.8														
24 100% Rate Load Minimum		MW												21.5	21.5	21.5														
25 Running Hours (unit overview)														3249	3250	3251														
26 Ambient Temperature	TI-002													25.0	25.0	25.0														
(27-28 found on Gas Fuel System page)																														
27 Waste Oil Tank	LI-120	%			70%									58%	58%	49														
28 Total Fuel Flow		Mcf/hr												249.6	249	249														
Signature: <i>[Signature]</i>																														
Date: 01-22-16																														

Signature: Randy N. ...

UTILITIES AND INFRASTRUCTURE

EGTG TURBINE

Natural Gas Compressor START TIME	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Natural Gas Compressor	0720																											
Combustible Gas Detector	AAH-303	%	0%	20%																								
Packing Lube Oil Flow Indicator Left side	FSL-1501B	LIGHT	BLINK	ANY																								
Liquid Level Coalescing	LI-7721	LIQUID	EMPTY	ANY																								
Crankcase Bulb eye	LC-1574	LEVEL 1/4	1/2	FULL																								
Oil Day Tank Level	LI-1562	GAL 10	FULL																									
Lubricator Bulb eye		LEVEL 1/2	FULL																									
1st Stage Scrubber Liquid Level	LI-7416	LIQUID	EMPTY	ANY																								
2nd Stage Scrubber Liquid Level	LI-7466	LIQUID	EMPTY	ANY																								
Packing Lube Oil Flow Indicator Right side	FSL-1501A	LIGHT	BLINK																									
1st Stage Inlet Press.	PI-2100	psig	88	140																								
2nd Stage Disch. Press	PI-2101	psig	238	285																								
2nd Stage Inlet Press	PI-2200	psig	267	285																								
2nd Stage Disch. Press	PI-2201	psig	575	600																								
Final Discharge Pressure	PI-2108	psig	575	600																								
Lube Oil Pressure	PI-1572	psig	40	60																								
Lube Oil Temp	TE-1584	deg	150	170																								
Final Discharge Temp	TE-2120	deg	110	150																								
1st Stage Cylinder Disch. Temperature A	TE-2054 A	deg	226	297																								
2nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg	258	283																								
1st Stage Cylinder Disch. Temperature B	TE-2054 B	deg	226	297																								
2nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg	258	283																								
Motor Frame Vibration	VT-1015	IPS		0.15																								
Compressor Frame Vibration	VT-1512	IPS		0.35																								
Take Once per Shift / at Full Load		psig																										
Natural Gas Comp. Discharge Press.																												
Double Block and Bleed Pressure	A63FGDT	49-48=psid		8																								
Fuel Gas Supply Pressure	A63FTGST	50-49=psid		20																								

DATE

SIGNATURE

Shift

Days Shift

Notes

When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer

[illegible]

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME				0%	20%																								
Combustible Gas Detector	A4H 303	%																											
Backflow Lube Oil Flow Indicator Left Side	151 J50118	LIGHT		BLINK																									
Liquid Level Coalescing	11 7721	LIQUID		EMPTY	ANY																								
Graincase Bulls eye	11 1574	LEVEL	1/4	1/2	FULL																								
Oil Day Tank Level	11 1502	GAL	10		FULL																								
Lubricator Bulls eye	11 7416	LEVEL	1/2	FULL																									
3rd Stage Scrubber Liquid Level	11 7416	LIQUID		EMPTY	ANY																								
2nd Stage Scrubber Liquid Level	11 7416	LIQUID		EMPTY	ANY																								
2nd Stage Lube Oil Flow Indicator Right Side	151 J5011A	LIGHT		BLINK																									
4th Stage Inlet Press.	11 2100	psig		88	140																								
3rd Stage Disch. Press	11 2101	psig		238	285																								
2nd Stage Inlet Press	11 2200	psig		267	285																								
5th Stage Disch. Press	11 2201	psig		575	600																								
Final Discharge Pressure	11 2108	psig		575	600																								
Lube Oil Pressure	11 1572	psig	40	60	170																								
Lube Oil Temp	11 1584	deg		150	170																								
Final Discharge Temp	11 2120	deg		110	150																								
1st Stage Cylinder Disch. Temperature A	11 2054 A	deg		226	297																								
2nd Stage Cylinder Disch. Temperature A	11 2062 A	deg		258	283																								
1st Stage Cylinder Disch. Temperature B	11 2054 B	deg		226	297																								
2nd Stage Cylinder Disch. Temperature B	11 2062 B	deg		258	283																								
Motor Frame Vibration	11 1015	IPS			0.15																								
Compressor Frame Vibration	11 1012	IPS			0.35																								
Take Once per Shift / at Full Load		psig			Max psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																							
Natural Gas Comp. Discharge Press.	A631 GDI	49-48=psid		8																									
Double Block and Bleed Pressure	A631 GST	50-49=psid		20																									
Equal Gas Supply Pressure	A631 GST																												

DATE

SIGNATURE

Mid Shift

Days Shift

Notes

LANL ADESH-18-05



U:\06-03-18
January 2018

Date: 02-01-2018

CGTG HOURLY READING LOG

MST / MDT (circle one)
Time Gas Introduced (Turbine Rolling):
Time of Turbine Online (Bkr Closed):

0707
0750

Time Turbine Offline (Bkr Open):
Time No Gas Flow:

1558
1604

Notes:

Instrument	ID	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Blowdown Dry Receiver Tank Hourly	BDV-013	V											yes	yes	yes	yes	yes	yes	yes	yes	yes								
Blowdown Wet Receiver Tank Hourly	BDV-007	V											yes	yes	yes	yes	yes	yes	yes	yes	yes								
Wet Receiver Air Pressure	P-002	psig	90	105	120								110	104	105	110	105	108	110	105	105								
Instrument Temperature	T-001	deg C	20	50									19	20	20	20	20	20	20	20	20								
Fin Fan Cooler		Units	Low	Norm	Max																								
Coolant Pressure	P-250	psig	25										19.5	19.5	19.5	19.5	19.5	19.5	19.5	19.5	19.5								
Coolant P/LC Temperature	T-002	deg F	190	110	120								110	112	105	108	103	105	105	105	105								
Sight glass Level Expansion Tank	U-001	LEVEL	1/3	2/3	FULL								1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2								
Coolant Return Differential from 6G	R-001	In WC	60	80									61	62	63	64	64	64	64	64	64								
Coolant Return Differential from	R-002	In WC	37	50									35	35	35	36	37	37	37	37	37								
Control Room		Units	Low	Norm	Max																								
Room Temperature		deg F	72	85									76	76.5	76.5	76.5	76.5	76.5	76.5	76.5	76.5								
Combustible Gas Detector Monitor		% LEL	0%	20%									0%	0%	0%	0%	0%	0%	0%	0%	0%								
WECC Log		Operation?																											
Operation of PSS on at 6.3 MW		Yes (Y)			No (N)								yes	yes	yes	yes	yes	yes	yes	yes	yes								
Operation of AVR Voltage Mode @ 13.6 KV		Yes (Y)			No (N)								yes	yes	yes	yes	yes	yes	yes	yes	yes								
Emergency Control System		Units	Low	Norm	Max																								
(18-20 found on Air Diagram page)																													
2000 gal Oil Water Tank Level	U-231	%			70%								34%	34%	34%	34%	34%	34%	34%	34%	34%								
10 gal Gas TG Drain Tank (Air Diagram page)	U-230	%			70%								0%	0%	0%	0%	0%	0%	0%	0%	0%								
Record on hand S/O trip over 4500 rpm NL Compressor (on line trip)	A636G0	psig	35	20																									
57-01																													
Acknowledge Alarms Hourly		V											yes	yes	yes	yes	yes	yes	yes	yes	yes								
(22-24 found on Power Management page)																													
Generator Current		Amps			1200								1051	1025	1028	1013	1004	993	982	986	986								
MW Output		MW			27								24.8	24.1	24.2	23.8	23.5	23.5	23.1	23.0	23.0								
Box Base Load Minimum		MW											20.2	19.7	19.4	19.4	19.2	19.1	19.0	19.0	19.0								
Burning Hours (unit overview)													22.1	22.4	22.4	22.5	22.5	22.5	22.5	22.5	22.5								
15 Ambient Temperature	T1 Inlet												43.3	42.1	40.7	43.2	45.2	46.7	47.7	47.7	47.7								
(27-28 found on Gas Fuel System page)																													
Waste Oil Tank	U-120	%			70%								50%	51%	50%	50%	50%	50%	50%	50%	50%								
Total Fuel Flow		mach/h											23.0	23.0	23.0	22.7	22.7	22.4	22.4	22.4	22.4								

Date: 02-01-2018
Signature: (Randy) Paul

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME		06:25																											
Combustible Gas Detector	AAH-303	%		0%	20%								4%																
Exhausting Lube Oil Flow Indicator Left Side	FSI-15013	LIGHT		BLINK									B	B	B	B	B	B	B	B									
Liquid Level Coalescing	LI-7723	LIQUID		EMPTY	ANY								E	E	E	E	E	E	E	E									
Frankcase Bulb eye	IC-1574	LEVEL 1/4		1/2	FULL								1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2									
Oil Day Tank Level	LI-1562	GAL 10			FULL								41	41	41	41	41	41	41	41									
Lubricator Bulb eye	LI-7416	LEVEL 1/2		FULL									F	F	F	F	F	F	F	F									
1st Stage Scrubber Liquid Level	LI-7416	LIQUID		EMPTY	ANY								E	E	E	E	E	E	E	E									
2nd Stage Scrubber Liquid Level	LI-7416	LIQUID		EMPTY	ANY								E	E	E	E	E	E	E	E									
Exhausting Lube Oil Flow Indicator Right Side	FSI-15014	LIGHT		BLINK									B	B	B	B	B	B	B	B									
1st Stage Inlet Press.	PI-2100	psig		88	140								82	82	80	82	80	82	81	81									
2nd Stage Disch. Press	PI-2101	psig		238	285								249	250	248	251	249	252	251	251									
3rd Stage Inlet Press	PI-2200	psig		267	285								246	247	245	248	245	248	247	248									
4th Stage Disch. Press	PI-2201	psig		575	600								574	574	574	574	574	578	574	578									
Final Discharge Pressure	PI-2108	psig		575	600								574	574	575	575	574	575	575	575									
Lube Oil Pressure	PI-1572	psig		40	60								58	58	58	58	59	59	59	59									
Lube Oil Temp	TE-1584	deg		150	170								169	169	169	168	168	166	165										
Final Discharge Temp	TE-2120	deg		110	150								80	87	87	89	91	93	94	94									
1st Stage Cylinder Disch. Temperature A	TT-2054 A	deg		226	297								209	210	210	211	212	212	211										
2nd Stage Cylinder Disch. Temperature A	TT-2062 A	deg		258	283								213	217	219	221	222	223	223	223									
1st Stage Cylinder Disch. Temperature B	TT-2054 B	deg		226	297								207	208	207	208	208	209	209	206									
2nd Stage Cylinder Disch. Temperature B	TT-2062 B	deg		258	283								213	213	219	221	223	224	224	224									
Motor Frame Vibration	VI-1015	IPS			0.15								0.08	0.08	0.08	0.09	0.09	0.09	0.09	0.09									
Compressor Frame Vibration	VI-1512	IPS			0.35								0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09									
Take Once per Shift / at Full Load		psig		Max psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																								
Natural Gas Comp. Discharge Press.	A631GDI	49-48=psid		8									513																
Double Block and Bleed Pressure	A631GDI	50-49=psid		20									501																
Fuel Gas Supply Pressure	A631GDI	50-49=psid		20									554																

DATE 02-21-2018
 SIGNATURE *Randy Hunt*
 Solid Shift
 Days Shift ✓

Notes

64
 1733280000

1434/1711

2-8-18

MST MDI (circle one)

Time of Turbine Online (Bkr Closed):

0657-0708
0752

Time Turbine Offline (Bkr Open)
Time No Gas Flow:

1558
1609

Notes

Instrument	Alarm	Unit	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Blowdown Dry Receiver Tank Hourly	8V1-013	✓											✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Blowdown Wet Receiver Tank Hourly	8V1-007	✓											✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Wet Receiver Air Pressure	PI-002	psig	90	105	120								✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Instrument Temperature	TI-001	deg C	20	50									108	108	106	105	106	104	112	110									
7th Fan Cooler		Units	Low	Norm	Max								18	16	17	18	20	20	20	20									
Coolant Pressure	PI-230	psig	25										19	19	19.2	19	19	19	19.4	19									
Coolant PIC Temperature	TI-002	deg F	100	110	120								97	106	111	105	103	108	109	98									
Sight glass Level Expansion Tank	LI-001	LEVEL	1/3	2/3	FULL								1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2									
Coolant Return Differential from GS	FI-001	in WC	60	80									58	60	60	60	60	61	64	62									
Coolant Return Differential from	FI-002	in WC	37	50									35	35	36	35	35	36	36	36									
Control Room		Units	Low	Norm	Max																								
Room Temperature		deg F	72	85									69	69	70	72	76	75	74	76									
Combustible Gas Detector Monitor		% LEL	0%	0%	20%								0	0	0	0	0	0	0	0									
WEGC Log			Operational?																										
Operation of PSS for at 8.3MW	Yes (Y)				No (N)								yes	yes	yes	yes	yes	yes	yes	yes									
Operation of AIR Voltage Mode @ 13.6 MV	Yes (Y)				No (N)								yes	yes	yes	yes	yes	yes	yes	yes									
Estimate Control System		Units	Low	Norm	Max																								
18-20 found on Air Diagram page)																													
2000 gal Oil Water Tank Level	LI-231	%			70%								35	35	34	34	34	34	34	34									
10 gal Gas TG Drain Tank (Air Diagram page)	LI-230	%			70%								0	0	0	0	0	0	0	0									
Record on Hand S/D trip over 4500 ppm NL (Compressor on line trip)	ASPG-CD ST-01	psig	35	20																									
Acknowledge Alarms Hourly		✓											✓	✓	✓	✓	✓	✓	✓	✓									
22-24 found on Power Management page)																													
Generator Current		Amps			1200								1078	1081	1065	1058	1038	1051	1021	1015									
MW Output		MW			27								25.5	25.5	25.1	24.8	24.4	24.1	24.1	23.8									
80% Base Load Minimum		MW											20.7	20.4	20.1	19.4	19.7	19.5	19.4	19.4									
Running Hours (unit overview)													3270	3272	3273	3274	3274	3275	3276	3277									
Ambient Temperature	TI Inlet												37.4	39.9	43.3	46.6	49	51	52.5	54									
27-28 found on Gas Fuel System page)																													
Waste Oil Tank	LI-120	%			70%								52.5	51	50	50	50	50	51	51									
Total Fuel Flow		mach/h											239	239	237	235	230	229	228	229									
Date: 2-5-18	Signature: [Signature]																												

0653 f-42 Unit TRIP once

Signature: _____

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME												6:3																	
Combustible Gas Detector	AAH-303	%		0%	20%							41.2	19.2	21.4	11.4	11.4													
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIQHT		BLINK								13	13	13	13	13	13	13	13	13									
Liquid Level Coalescing	LI-7721	LIQID		EMPTY	ANY							E	E	E	E	E	E	E	E	E									
Crankcase Bulb eye	LC-1574	LEVEL	1/4	1/2	FULL							1/4	1/2	1/4	1/2	1/2	1/2	1/2	1/2	1/2									
Oil Day Tank Level	LI-1562	GAL	10		FULL							40	40	40	40	40	40	40	40	40									
Lubricator Bulb eye		LEVEL	1/2		FULL							F	F	F	F	F	F	F	F	F									
1st Stage Scrubber Liquid Level	LI-7416	LIQID		EMPTY	ANY							E	E	E	E	E	E	E	E	E									
2nd Stage Scrubber Liquid Level	LI-7466	LIQID		EMPTY	ANY							E	E	E	E	E	E	E	E	E									
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIQHT		BLINK								13	13	13	13	13	13	13	13	13									
1 st Stage Inlet Press.	PI-2100	psig		88	140							81.9	84.9	81.4	80.7	81.8	1	9	0	81									
Stage Disch. Press	PI-2101	psig		238	285							247	248	248	249	249	2	5	0	251									
2nd Stage Inlet Press	PI-2200	psig		267	285							241	241.4	244	244.2	246	246	2	4	6	246								
2 nd Stage Disch. Press	PI-2201	psig		575	600							518	528	527	524	525	74	5	7	529									
Final Discharge Pressure	PI-2108	psig		575	600							574	574	573	573	575	575	5	5	575									
Lube Oil Pressure	PI-1572	psig	40	60								574	572	573	573	582	5	5	8	585	5	5							
Lube Oil Temp	TE-1584	deg		150	170							169	171	171	170	169	168	16	9	167									
Final Discharge Temp	TE-2120	deg		110	150							74	74	74	74	74	8	7	8	8	7	0	9	0					
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297							208	207	209	209	210	21	0	209										
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283							207	208	212	212	220	22	1	22	221									
1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297							205	203	205	205	207	20	7	207	206									
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283							208	204	213	212	219	22	1	22	222									
Motor Frame Vibration	VT-1015	IPS			0.15							03	04	04	03	03	04	04	04	04									
Compressor Frame Vibration	VT-1512	IPS			0.35							05	06	04	05	05	05	05	06	05									
Take Once per Shift / at Full Load		psig			Max psid							576																	
Natural Gas Comp Discharge Press.	A63FGDT	49-48=psid			8							570																	
Double Block and Bleed Pressure	A63FTGST	50-49=psid			20							579																	
Fuel Gas Supply Pressure																													

DATE 2-8-18
 SIGNATURE [Signature]
 Mid Shift
 Days Shift
 Notes



02-14-18

MST / MDT (circle one)
Time Gas Introduced (Turbine Rolling):
Time of Turbine Online (Bkr Closed):


1420

Time Turbine Offline (Bkr Open):
Time No Gas Flow:

1424

CGTG HOURLY READING LOG

Notes: WGS NOT PUT ON FIRE. JUST TEST FOR 15.
AGTC UNATTENDED DO TO SEVERAL ISSUES.

Instrument Air Compressor		ID	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1	Blowdown Dry Receiver Tank Hourly	BYT-013	°																											
2	Blowdown Wet Receiver Tank Hourly	BYT-007	°																											
3	Wet Receiver Air Pressure	PI-002	psig	90	105	120																								
4	Instrument Temperature	TI-001	deg C	20	50																									
5	Fire Fan Cooler		Units	Low	Norm	Max																								
6	Coolant Pressure	PI-250	psig	25																										
7	Coolant PLC Temperature	TI-002	deg F	100	110	120																								
8	Sight glass level Expansion Tank	LI-001	LEVEL	1/3	2/3	FULL																								
9	Coolant Return Differential from GS	PI-001	in WC	60	80																									
10	Coolant Return Differential from	PI-002	in WC	37	50																									
11	Control Room		Units	Low	Norm	Max																								
12	Room Temperature		deg F	72	85																									
13	Combustible Gas Detector Monitor		%LEL	0%	0%	20%																								
15	WECC Log			Operational?																										
16	Operation of PSS on at 6.3MW		Yes (Y)		No (N)																									
17	Operation of AVR Voltage Mode @ 13.6 kV		Yes (Y)		No (N)																									
Electronic Control System			Units	Low	Norm	Max																								
(18-20 found on Air Diagram page)																														
18	2000 gal Oil Water Tank Level	LI-231	%		70%																									
19	10 gal TIC Drain Tank (Air Diagram page)	LI-230	%		70%																									
20	Record on hard S/D trip over 4500 rpm VL Compressor (on line trip)	AE3600	psig	35	20																									
21	Acknowledge Alarms Hourly	SI-011	°																											
(22-24 found on Power Management page)																														
22	Generator Current		Amps		1200																									
23	Max Output		MW		27																									
24	90% Base Load Minimum		MW																											
25	Running Hours (unit overview)																													
26	Ambient Temperature	TI inlet																												
(27-28 found on Gas Fuel System page)																														
27	Waste Oil Tank	LI-220	%		70%																									
28	Total Fuel Flow		kg/hr																											
Date: 02-14-18		Signature: 																												

02-14-18

Signature: *Randy J. Hill*

DATE: 02-15-2018

MST / MDT (circle one)

Time Gas Introduced (Turbine Rollin):

Time of Turbine Online (Bkr Closed):

Time Turbine Offline (Bkr Open):

Time No Gas Flow:

CGTG HOURLY READING LOG

Notes: For TEST ONLY, Per Data Log Unit, Spv to Grid let ramp up then Bkr Eng OFF

	LD	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1 Instrument Air Compressor	LD	Units	Low	Norm	Max																								
2 Blowdown Dry Receiver Tank Hourly	LD	Units	Low	Norm	Max																								
3 Wet Receiver Air Pressure	LD	Units	Low	Norm	Max																								
4 Instrument Temperature	LD	Units	Low	Norm	Max																								
5 Fan Fan Cooler	LD	Units	Low	Norm	Max																								
6 Coolant Pressure	LD	Units	Low	Norm	Max																								
7 Coolant PLC Temperature	LD	Units	Low	Norm	Max																								
8 Sight glass level Expansion Tank	LD	Units	Low	Norm	Max																								
9 Coolant Return Differential from OG	LD	Units	Low	Norm	Max																								
10 Coolant Return Differential from	LD	Units	Low	Norm	Max																								
11 Control Room	LD	Units	Low	Norm	Max																								
12 Room Temperature	LD	Units	Low	Norm	Max																								
13 Combustible Gas Detector Monitor	LD	Units	Low	Norm	Max																								
14 WECC Log	LD	Units	Low	Norm	Max																								
15 Operation of PSS on a 6 MANV	LD	Units	Low	Norm	Max																								
16 Operation of AVN Voltage Mode @ 13.6 KV	LD	Units	Low	Norm	Max																								
17 Electronic Control System	LD	Units	Low	Norm	Max																								
18 2000 gal Oil Water Tank Level	LD	Units	Low	Norm	Max																								
19 10 gal Gas TG Drain Tank (Air Diagram page)	LD	Units	Low	Norm	Max																								
20 Record on hand S/D trip over 4500 rpm NL Compressor (on line trip)	LD	Units	Low	Norm	Max																								
21 Acknowledge Alarm Hourly	LD	Units	Low	Norm	Max																								
22-24 Found on Power Management Page	LD	Units	Low	Norm	Max																								
22 Generator Current	LD	Units	Low	Norm	Max																								
23 MW Output	LD	Units	Low	Norm	Max																								
24 80% Base Load Minimum	LD	Units	Low	Norm	Max																								
25 Running Hours (unit overview)	LD	Units	Low	Norm	Max																								
26 Ambient Temperature	LD	Units	Low	Norm	Max																								
27-28 Found on Gas Fuel System Page	LD	Units	Low	Norm	Max																								
27 Waste Oil Tank	LD	Units	Low	Norm	Max																								
28 Total Fuel Flow	LD	Units	Low	Norm	Max																								

Date: 02-15-2018

Signature: [Signature]

UTILITIES AND INFRASTRUCTURE		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
NATURAL GAS COMPRESSOR START TIME		12:15																							
COMBUSTIBLE GAS DETECTOR		AAH 303																							
PACKING LUBE OIL FLOW INDICATOR LEFT SIDE		ESI 1501A																							
LIQUID LEVEL COALESCING		LI 7721																							
CONDENSATE BULLS EYE		LC 1574																							
OIL DAY TANK LEVEL		LI 1562																							
LUBRICATOR BULLS EYE		LI 7616																							
1ST STAGE SCRUBBER LIQUID LEVEL		LI 7660																							
2ND STAGE SCRUBBER LIQUID LEVEL		ESI 1501A																							
PACKING LUBE OIL FLOW INDICATOR RIGHT SIDE		PI 2100																							
1ST STAGE INLET PRESS.		PI 2101																							
STAGE DISCH. PRESS		PI 2200																							
2ND STAGE INLET PRESS		PI 2201																							
2ND STAGE DISCH. PRESS		PI 2108																							
FINAL DISCHARGE PRESSURE		PI 1572																							
LUBE OIL PRESSURE		PI 1584																							
LUBE OIL TEMP		TI 2120																							
FINAL DISCHARGE TEMP		TI 2054 A																							
1ST STAGE CYLINDER DISCH. TEMPERATURE A		TI 2054 B																							
2ND STAGE CYLINDER DISCH. TEMPERATURE A		TI 2054 B																							
1ST STAGE CYLINDER DISCH. TEMPERATURE B		TI 2062 B																							
2ND STAGE CYLINDER DISCH. TEMPERATURE B		VI 1015																							
MOTOR FRAME VIBRATION		VI 1512																							
COMPRESSOR FRAME VIBRATION		Max psid																							
TAKE ONCE PER SHIFT / AT FULL LOAD		When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																							
NATURAL GAS COMP. DISCHARGE PRESS.		A631GDT																							
DOUBLE BLOCK AND BLEED PRESSURE		49-48=psid																							
FUEL GAS SUPPLY PRESSURE		A631GSI																							
		50-49=psid																							
		8																							
		20																							
DATE 02.15.2018																									
SIGNATURE [Signature]																									
DAILY SHIFT																									
Notes For TEST ONLY																									

Date: 3-1-2018
 Time Gas Introduced (Turbine Rolling): 06:54
 Time of Turbine Online (After Closed): 07:53
 Time Turbine Offline (After Open): 16:08
 Time No Gas Flow: 16:15

CGTG HOURLY READING LOG

Notes:

Instrument	LD	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Blower Dry Receiver Tank Hourly	BT-013	°F																											
2. Blower Wet Receiver Tank Hourly	BT-007	°F																											
3. Wet Receiver Air Pressure	PT-003	psig	90	105	120																								
4. Instrument Temperature	TT-001	deg C	20	50																									
5. Fan Fan Cooler		Units	Low	Norm	Max																								
6. Coolant Pressure	PT-250	psig	25																										
7. Coolant PIC Temperature	TT-002	deg F	100	110	120																								
8. Sight glass level Expansion Tank	LI-001	LEVEL	2/3	2/3	FULL																								
9. Coolant Return Differential from GC	PI-001	in WC	60	80																									
10. Coolant Return Differential from	PI-002	in WC	37	50																									
11. Control Room		Units	Low	Norm	Max																								
12. Room Temperature		deg F	72	85																									
13. Combustible Gas Detection Monitor		% LEL	0%	0%	20%																								
14. WCCCT Log																													
15. Operation of PDS on at 5.3MW		Yes (Y)			No (N)																								
16. Operation of AVR Voltage Mode @ 5.6 KV		Yes (Y)			No (N)																								
17. Instrument Control System		Units	Low	Norm	Max																								
18. 2000 psi Oil Water Tank Level	LI-231	%			70%																								
19. 10 psi gas TO Drain Tank (As Diagram page)	LI-230	%			70%																								
20. Record on hard S/P trip over 4500 rpm ML Compressor (on line trip)	AS6600 ST-01	psig	35	20																									
21. Acknowledge Alarms History		Y																											
22. 24-36 found on Power Management page)																													
23. New Output		Amps			1200																								
24. 80% Base Load Minimum		MW			27																								
25. Burning Hours (unit over/under)		MW																											
26. Ambient Temperature	TT-001																												
27. 24-36 found on Gas Fuel System page)																													
28. Waste Oil Tank	LI-120	%			70%																								
29. Total Fuel Flow	mach																												

Date: 3-1-18 Signature: [Signature]

ULLC-033-42
 January 7, 2018

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
Combustible Gas Detector	AAH-303	%		0%	20%																								
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	U/GHT		BLINK																									
Liquid Level Coalescing	LI-7721	LIQUID		EMPTY	ANY																								
Crankcase Bulb eye	LC-1574	LEVEL	1/4	1/2	FULL																								
Oil Day Tank Level	LI-1562	GAL	10	FULL																									
Lubricator Bulb eye		LEVEL	1/2	FULL																									
1st Stage Scrubber Liquid Level	LI-7416	LIQUID		EMPTY	ANY																								
2nd Stage Scrubber Liquid Level	LI-7466	LIQUID		EMPTY	ANY																								
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	U/GHT		BLINK																									
1 st Stage Inlet Press.	PI-2100	psig		88	140																								
Stage Disch. Press	PI-2101	psig		238	285																								
2nd Stage Inlet Press	PI-2200	psig		267	285																								
2 nd Stage Disch. Press	PI-2201	psig		575	600																								
Final Discharge Pressure	PI-2108	psig		575	600																								
Lube Oil Pressure	PI-1572	psig	40	60																									
Lube Oil Temp	TE-1584	deg		150	170																								
Final Discharge Temp	TE-2120	deg		110	150																								
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297																								
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283																								
1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297																								
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283																								
Motor Frame Vibration	VT-1015	IPS		0.15																									
Compressor Frame Vibration	VT-1512	IPS		0.35																									
Take Once per Shift / at Full Load		psig		Max psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																								
Natural Gas Comp. Discharge Press.	AG3FGDT	49-48=psid		8																									
Double Block and Bleed Pressure	AG3FTGST	50-49=psid		20																									
Fuel Gas Supply Pressure																													

DATE 3-1-18

SIGNATURE

Mid Shift

Days Shift

Notes

0000 - 655207

55666



UJL06A2335
January 4, 2018

CGTG HOURLY READING LOG

Date: 3-8-2018
Time Gas Introduced (Turbine Rating):
Time of Turbine Online (After Closed):

0706
0900

Time Turbine Offline (After Open):
Time No Gas Flow:

1559
1606

Notes:

Instrument Air Compressor	LD	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Shutdown Dry Receiver Tank Hourly	BT-013	V																											
2. Shutdown Wet Receiver Tank Hourly	BT-007	V																											
3. Wet Receiver Air Pressure	PI-002	psig	90	105	120																								
4. Instrument Temperature	TI-001	deg C	20	50	50																								
5. High Air Cooler		Units	Low	Norm	Max																								
6. Coolant Pressure	PI-250	psig	25																										
7. Coolant PLC Temperature	TI-002	deg F	100	110	120																								
8. High Level Expansion Tank	LI-001	LEVEL	1/3	2/3	FULL																								
9. Coolant Return Differential from CG	PI-001	in H ₂ O	60	80																									
10. Coolant Return Differential from	PI-002	in H ₂ O	37	50																									
11. Control Room		Units	Low	Norm	Max																								
12. Room Temperature		deg F	72	85																									
13. Combustible Gas Detector Monitor		% LEL	0%	0%	20%																								
14. WELC Log		Operation?																											
15. Operation of PSS on at 6.3MW		Yes (Y)			No (N)																								
16. Operation of AVR Voltage Mode @ 13.5 MV		Yes (Y)			No (N)																								
17. Intrinsic Control System		Units	Low	Norm	Max																								
18. 3000 gal Oil Water Tank Level	LI-231	%			70%																								
19. 10 gal Gas T6 Drain Tank (for Diagram page)	LI-230	%			70%																								
20. Record on Board C/D O2 over 4500 ppm NL	MS0600	psig	35	20																									
21. Acknowledge Alarm Hourly	ST-01	Y																											
22-24 found on Power Management page																													
25. Generator Current		amps			1200																								
26. MW Output		MW			27																								
27. 1000 Base Load Minimum		MW																											
28. Running Hours (unit overview)																													
29. Ambient Temperature	TI-001																												
30. 27-28 found on Gas Fuel System page																													
31. Waste Oil Tank	LI-120	%			70%																								
32. Total Fuel Flow	Mach																												

Date: 3-8-2018

Signature: [Signature]

UJL06A2335
January 4, 2018

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor			Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME		0640																												
Combustible Gas Detector	AAH-303	%		0%	20%																									
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIGHT		BLINK																										
Liquid Level Coalescing	LI-7721	LIQID		EMPTY	ANY																									
Crankcase Bulk eye	LC-1574	LEVEL	1/4	1/2	FULL																									
Oil Dry Tank Level	LI-1562	GAL	10		FULL																									
Lubricator Bulk eye		LEVEL	1/2	FULL																										
1st Stage Scrubber Liquid Level	LI-7416	LIQID		EMPTY	ANY																									
2nd Stage Scrubber Liquid Level	LI-7466	LIQID		EMPTY	ANY																									
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIGHT		BLINK																										
1st Stage Inlet Press.	PI-2100	psig		88	140																									
2nd Stage Inlet Press	PI-2101	psig		238	285																									
3rd Stage Inlet Press	PI-2200	psig		267	285																									
4th Stage Disch. Press	PI-2201	psig		575	600																									
Final Discharge Pressure	PI-2108	psig		575	600																									
Lube Oil Pressure	PI-1572	psig	40	60																										
Lube Oil Temp	TE-1584	deg		150	170																									
Final Discharge Temp	TE-2120	deg		110	150																									
1st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297																									
2nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283																									
1st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297																									
2nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283																									
Motor Frame Vibration	VT-1015	IPS			0.15																									
Compressor Frame Vibration	VT-1512	IPS			0.35																									
Take Once per Shift / at Full Load		psig			Max psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																								
Natural Gas Comp. Discharge Press.	A63FGDT	49-48=psid		8																										
Double Block and Bleed Pressure																														
Fuel Gas Supply Pressure	A63FTGST	50-49=psid		20																										

DATE 3-8-2018

SIGNATURE *[Signature]*

Mid Shift

Days Shift 1

Notes: 0100 - before power & check about 1st oil temp.

CGTG HOURLY READING LOG

2018 Semi-Annual Monitoring Report

Time Turbine Offline (Bkr Open):
Time No Gas Flow:

1231
1605

1558

Notes:

TESTING BEING DONE ON PASS.

ANL ADESH-18-050 / LA-UR-18-26940																										
Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
														</												

LANL ADESH-18-050 / LA-UR-18-26940

John C. ...
J. ...

UTILITIES AND INFRASTRUCTURE

Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1-2	%	0%	20%																								
3-33	LIGHT	BLINK																									
1518	LIQID	EMPTY	ANY																								
12	LEVEL	1/4	1/2	FULL																							
573	GAL	10		FULL																							
16	LEVEL	1/2	FULL																								
11	LIQID	EMPTY	ANY																								
169	LIQID	EMPTY	ANY																								
131A	LIGHT	BLINK																									
101	psig	88	140																								
102	psig	238	285																								
103	psig	267	285																								
104	psig	575	600																								
105	psig	575	600																								
106	psig	575	600																								
107	psig	575	600																								
108	psig	575	600																								
109	psig	575	600																								
110	psig	575	600																								
111	psig	575	600																								
112	psig	575	600																								
113	psig	575	600																								
114	psig	575	600																								
115	psig	575	600																								
116	psig	575	600																								
117	psig	575	600																								
118	psig	575	600																								
119	psig	575	600																								
120	psig	575	600																								
121	psig	575	600																								
122	psig	575	600																								
123	psig	575	600																								
124	psig	575	600																								
125	psig	575	600																								
126	psig	575	600																								
127	psig	575	600																								
128	psig	575	600																								
129	psig	575	600																								
130	psig	575	600																								
131	psig	575	600																								
132	psig	575	600																								
133	psig	575	600																								
134	psig	575	600																								
135	psig	575	600																								
136	psig	575	600																								
137	psig	575	600																								
138	psig	575	600																								
139	psig	575	600																								
140	psig	575	600																								
141	psig	575	600																								
142	psig	575	600																								
143	psig	575	600																								
144	psig	575	600																								
145	psig	575	600																								
146	psig	575	600																								
147	psig	575	600																								
148	psig	575	600																								
149	psig	575	600																								
150	psig	575	600																								
151	psig	575	600																								
152	psig	575	600																								
153	psig	575	600																								
154	psig	575	600																								
155	psig	575	600																								
156	psig	575	600																								
157	psig	575	600																								
158	psig	575	600																								
159	psig	575	600																								
160	psig	575	600																								
161	psig	575	600																								
162	psig	575	600																								
163	psig	575	600																								
164	psig	575	600																								
165	psig	575	600																								
166	psig	575	600																								
167	psig	575	600																								
168	psig	575	600																								
169	psig	575	600																								
170	psig	575	600																								
171	psig	575	600																								
172	psig	575	600																								
173	psig	575	600																								
174	psig	575	600																								
175	psig	575	600																								
176	psig	575	600																								
177	psig	575	600																								
178	psig	575	600																								
179	psig	575	600																								
180	psig	575	600																								
181	psig	575	600																								
182	psig	575	600																								
183	psig	575	600																								

Date: 3-22-18
 MCT: ADT (circle one)
 Time Gas Introduced (Turbine Rodding):
 Time of Turbine Online (After Close):

0625
 0754

Time Turbine Offline (After Open):
 Time No Gas Flow:

1600
 1600

Notes: 1030 - Ticks on A/C units in control room.

CGTG HOURLY READING LOG

	LD	Unit	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Bleeddown Dry Receiver Tank Hourly	BY-013	✓																											
2. Bleeddown Wet Receiver Tank Hourly	BY-007	✓																											
3. Wet Receiver Air Pressure	PI-002	psig	90	105	120																								
4. Instrument Temperature	TI-001	deg C	20	30	50																								
5. Fan Room Cooler		Units	Low	Norm	Max																								
6. Coolant Pressure	PI-205	psig	25																										
7. Coolant P/LC Temperature	TI-002	deg F	100	110	120																								
8. Sight glass level Expansion Tank	LI-001	LEV/L	1/3	2/3	FULL																								
9. Coolant Return Differential from SG	PI-001	in WC	60	80	80																								
10. Coolant Return Differential from	PI-002	in WC	37	50	50																								
11. Control Room		Units	Low	Norm	Max																								
12. Room Temperature		deg F	72	85	85																								
13. Combustible Gas Detector Monitor		% LEL	0%	0%	20%																								
14. WCC Log		Questions?																											
15. Operation of PSL on at 6.34 MV		Yes (Y)																											
16. Operation of AVR Voltage Mode @ 13.5 MV		Yes (Y)																											
17. Electronic Control System		Units	Low	Norm	Max																								
18. 2000 gal Oil Water Tank Level	LI-231	%			70%																								
19. 10 gal Gas (Oil Drain Tank (for Diagram page))	LI-230	%			70%																								
20. Record on Hard S/D Trip over 4500 rpm RL Compressor (on line trip)	MS/GO 57-01	psig	35	20																									
21. Acknowledge Alarms Hourly		✓																											
22. 24 found on Power Management page																													
23. Generator Current		Amperes		1200																									
24. New Output		MW		27																									
25. 100% React Load Maximum		MW																											
26. Running Hours (link overview)		MW																											
27. Ambient Temperature	TI-100																												
28. 24 found on Gas Fuel System page																													
29. Waste Oil Tank	LI-220	%		70%																									
30. Fuel Fuel Flow		Med/L																											

Date: 3-22-2018 Signature: ML

GTG TURBINE

UTILITIES AND INFRASTRUCTURE

NATURAL GAS COMPRESSOR START TIME					Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Combustible Gas Detector					AAH-303	%		0%	20%								✓	✓	✓	✓	✓	✓	✓									
2. Packing Lube Oil Flow Indicator Left Side					FSL-1501B	LIQUID		BLINK								✓	✓	✓	✓	✓	✓	✓	✓									
3. Liquid Level Collecting					LI-7721	LIQUID		EMPTY	ANY							✓	✓	✓	✓	✓	✓	✓	✓									
4. Crankcase Bulb eye					LC-1574	LEVEL	1/4	1/2	FULL							✓	✓	✓	✓	✓	✓	✓	✓									
5. Oil Day Tank Level					LI-1562	GAL	10	FULL								✓	✓	✓	✓	✓	✓	✓	✓									
6. Lubricator Bulb eye					LEVEL	1/2	FULL									✓	✓	✓	✓	✓	✓	✓	✓									
7. Post Stage Scrubber Liquid Level					LI-7416	LIQUID		EMPTY	ANY							✓	✓	✓	✓	✓	✓	✓	✓									
8. Pre Stage Scrubber Liquid Level					LI-7466	LIQUID		EMPTY	ANY							✓	✓	✓	✓	✓	✓	✓	✓									
9. Packing Lube Oil Flow Indicator Right Side					FSL-1501A	LIQUID		BLINK								✓	✓	✓	✓	✓	✓	✓	✓									
10. 1st Stage Inlet Press.					PI-2100	PSIG		88	140							✓	✓	✓	✓	✓	✓	✓	✓									
11. Stage Disch. Press					PI-2101	PSIG		238	285							✓	✓	✓	✓	✓	✓	✓	✓									
12. 2nd Stage Inlet Press					PI-2200	PSIG		267	285							✓	✓	✓	✓	✓	✓	✓	✓									
13. 2nd Stage Disch. Press					PI-2201	PSIG		575	600							✓	✓	✓	✓	✓	✓	✓	✓									
14. Final Discharge Pressure					PI-2108	PSIG		575	600							✓	✓	✓	✓	✓	✓	✓	✓									
15. Lube Oil Pressure					PI-1572	PSIG		40	60							✓	✓	✓	✓	✓	✓	✓	✓									
16. Lube Oil Temp					TE-1584	deg		150	170							✓	✓	✓	✓	✓	✓	✓	✓									
17. Final Discharge Temp					TE-2120	deg		110	150							✓	✓	✓	✓	✓	✓	✓	✓									
18. 1st Stage Cylinder Disch. Temperature A					TE-2054 A	deg		226	297							✓	✓	✓	✓	✓	✓	✓	✓									
19. 2nd Stage Cylinder Disch. Temperature A					TE-2062 A	deg		258	283							✓	✓	✓	✓	✓	✓	✓	✓									
20. 1st Stage Cylinder Disch. Temperature B					TE-2054 B	deg		226	297							✓	✓	✓	✓	✓	✓	✓	✓									
21. 2nd Stage Cylinder Disch. Temperature B					TE-2062 B	deg		258	283							✓	✓	✓	✓	✓	✓	✓	✓									
22. Motor Frame Vibration					VT-1015	IPS		0.15								✓	✓	✓	✓	✓	✓	✓	✓									
23. Compressor Frame Vibration					VT-1512	IPS		0.35								✓	✓	✓	✓	✓	✓	✓	✓									
24. Take Once per Shift / at Full Load						psig		Max psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																							
25. Natural Gas Comp. Discharge Press.																	575															
26. Double Block and Bleed Pressure					A63FGDT	49-48=psid		8									571															
27. Fuel Gas Supply Pressure					A63FTGST	50-49=psid		20									561															

DATE 3-22-16

SIGNATURE

Grid Shift

Days Shift

Notes

660309 GAS READINGS



U:\OG-03\42
January 2018

CGTG HOURLY READING LOG

Run: 3-29-18
MST (Add side one)
Time Gas Introduced (Turbine Rolling):
Time of Turbine Online (Btrv Closed):

0647
0755

Time Turbine Offline (Btrv Open):
Time No Gas Flow:

1000
1207

Notes:

		LD	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
Instrument Air Compressor																															
1. Blowdown Dry Receiver Tank Hourly	9BT-013	Y												✓	✓	✓															
2. Blowdown Wet Receiver Tank Hourly	9WT-007	Y												✓	✓	✓															
3. Wet Receiver Air Pressure	PI-002	psig	90	105	120									107	106	108															
4. Instrument Temperature	TI-001	deg C	20	50										40	19	19															
5. Fan Fan Cooler		Units	Low	Norm	Max																										
6. Coolant Pressure	PI-250	psig	75											19.8	19.8	19.8															
7. Coolant P/C Temperature	TI-002	deg F	100	110	120									102	98	100															
8. Sight glass Level Expansion Tank	LI-001	LEVEL	1/3	2/3	FULL									1/2	1/2	1/2															
9. Coolant Return Differential from CG	FI-001	in WC	60	80										60	60	60															
10. Coolant Return Differential from	FI-002	in WC	37	50										37	37	38															
11. Control Room		Units	Low	Norm	Max																										
12. Room Temperature		deg F	72	75	85									70	70	70															
13. Combustible Gas Detector Monitor		% LEL	0%	0%	20%									0	0	0															
14. WECC Log																															
15. Operation of PSS/ on at 6.3MW		Yes (Y)			No (N)									Yes	Yes	Yes															
16. Operation of AVR Voltage Mode @ 13.6 KV		Yes (Y)			No (N)									Yes	Yes	Yes															
17. Electronic Control System		Units	Low	Norm	Max																										
(18-20 found on Air Diagram page)																															
18. 2000 gal Oil Water Tank Level	LI-231	%			70%									35	35	35															
19. 10 gal Gas TG Drain Tank (Air Diagram page)	LI-230	%			70%									0	0	0															
20. Record on hard S/D trip over 4500 rpm NL Compressor (on line trip)	ACS600 ST-01	psig	35	20																											
21. Acknowledge Alarms Hourly		Y												✓	✓	✓															
(22-24 found on Power Management page)																															
22. Generator Current		Amps			1200									981	984	984															
23. MW Output		MW			27									23.1	23.1	23.1															
24. 80% Break Level Minimum		MW												20.9	20.4	20.3															
25. Running Hours (Unit Overview)														3313	3314	3315															
26. Ambient Temperature	TI-Inlet													34.9	31.2	41.5															
(27-28 found on Gas Fuel System page)																															
27. Waste Oil Tank	LI-120	%			70%									54	53	53															
28. Total Fuel Flow		Mscf/h												220	221	222															
Signature: A. Cohen																															
Date: 3-29-18																															

Signature: A. V. Vane

GTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	
Natural Gas Compressor START TIME	06:28																											
Combustible Gas Detector	AAG-303	%	0%	20%								20% M9																
Packing Lub Oil Flow Indicator Left Side	FSL-1501B	LIGHT	BLINK									V V																
Liquid Level Collecting	LI-7721	LIQUID	EMPTY	ANY								E E																
Crankcase Bulls eye	LC-1574	LEVEL	1/4	1/2	FULL							1/2 1/2																
Oil Day Tank Level	LI-1562	GAL	10	FULL								3/4 3/4																
Turbocor Bulls eye		LEVEL	1/2	FULL								E E																
Colst Stage Scrubber Liquid Level	LI-7416	LIQUID	EMPTY	ANY								E E																
2nd Stage Scrubber Liquid Level	LI-7466	LIQUID	EMPTY	ANY								E E																
Leading Lube Oil Flow Indicator Right Side	FSL-1501A	LIGHT	BLINK									V V																
1 st Stage Inlet Press.	PI-2100	PSIG	88	140								82 81																
Stage Disch. Press	PI-2101	PSIG	238	285								247 247																
2nd Stage Inlet Press	PI-2200	PSIG	267	285								243 243																
2 nd Stage Disch. Press	PI-2201	PSIG	575	600								578 578																
Final Discharge Pressure	PI-2108	PSIG	575	600								578 575																
Lube Oil Pressure	PI-1572	PSIG	40	60								57 58																
Lube Oil Temp	TE-1584	deg	150	170								169 170																
Final Discharge Temp	TE-2120	deg	110	150								74 76																
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg	226	297								210 217																
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg	258	283								267 269																
1st Stage Cylinder Disch. Temperature B	TE-2054 B	deg	226	297								267 268																
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg	258	283								268 210																
Motor Frame Vibration	VT-1015	IPS		0.15								.03 .03																
Compressor Frame Vibration	VT-1512	IPS		0.35								.05 .03																
Take Once per Shift / at Full Load		psig	Max psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																								
Natural Gas Comp.Discharge Press.	AG3FTGDT	49-48-psid	8									575																
Double Block and Bleed Pressure												571																
Fuel Gas Supply Pressure	AG3FTGST	50-49-psid	20									561																
DATE 3-29-18																												

Twid Shift

Plays Shift

Notes



CGTG HOURLY READING LOG

Date: 4-5-18
 MST (MID/Archie one)
 Time Gas Introduced (Turbine Rolling):
 Time of Turbine Online (Bkr Closed):

66264
0254

Time Turbine Offline (Bkr Open):
 Time No Gas Flow:

1659
1906

Notes: 645 READINGS. 663052

Instrument	LD	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
1 Blowdown Dry Receiver Tank Hourly	BYT-013	V											✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
2 Blowdown Wet Receiver Tank Hourly	BYT-007	V											✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
3 Wet Receiver Air Pressure	PI-002	psig	90	105	120								109	112	111	108	110	108	110	105	106		
4 Instrument Temperature	TI-001	deg C	20	50	50								19	19	19	20	20	20	22	22	22		
5 Fin Fan Cooler		Units	Low	Norm	Max																		
6 Coolant Pressure	PI-250	psig		25									17	19	19	19	19	19	19	19	19		
7 Coolant PLC Temperature	TI-002	deg F	100	110	120								100	99	111	110	101	106	110	105	106		
8 Sight glass Level Expansion Tank	LI-001	LEVEL	1/3	2/3	FULL								12	12	12	12	12	12	12	12	12		
9 Coolant Return Differential from GG	FI-001	In WC		60	80								60	60	60	60	60	60	60	60	60		
10 Coolant Return Differential from	FI-002	In WC		37	50								35	36	36	36	36	36	36	36	36		
11 Control Room		Units	Low	Norm	Max																		
12 Room Temperature		deg F		72	85								70	70	70	71	71	70	70	71	71		
13 Combustible Gas Detector Monitor		% LEL	0%	0%	20%								0	0	0	0	0	0	0	0	0		
15 WECC Log				Operational?																			
16 Operation of PSS on at 6.3MW		Yes (Y)			No (N)								Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes		
17 Operation of AVR Voltage Mode @ 13.6 KV		Yes (Y)			No (N)								Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes		
18 2000 gal Oil Water Tank Level	LI-231	%			70%								34	34	34	34	34	34	34	34	34		
19 10 gal gas TG Drain Tank (Air Diagram page)	LI-230	%			70%								0%	0	0	0	0	0	0	0	0		
20 Record on hard S/D trip over 4500 rpm HL Compressor (on line trip)	A63G6D ST-01	psig	35	20																			
21 Acknowledge Alarms Hourly		V											✓	✓	✓	✓	✓	✓	✓	✓	✓		
22-24 found on Power Management page)																							
22 Generator Current		Amps			1200								1023	1012	1012	991	992	924	916	923	978		
23 MWh Output		MW			27								24.1	23.8	23.4	23.5	23.4	22.8	22.7	22.7	22.7		
24 80% Base Load Minimum		MW											19.9	19.4	19.3	19.1	19.0	18.8	18.8	18.8	18.9		
25 Running Hours (unit overview)													331	733	146	3819	3300	3321	3323	3824	3805		
26 Ambient Temperature	TI Inlet												48.4	54.1	55.8	57.4	59.1	60.8	61.7	60.9	60.1		
27-28 found on Gas Fuel System page)																							
27 Waste Oil Tank	LI-120	%			70%								53	53	53	53	51	51	51	51	51		
28 Total Fuel Flow		Mscf/h											231	228	227	205	223	220	220	222	202		

Date: 4-5-2018

Signature: MG Parity

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
GAS COMPRESSOR START TIME																									
Combustible Gas Detector	AAH-303	%		0%	20%																				
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIGHT		BLINK																					
Liquid Level Coalescing	LI-7721	LIQID		EMPTY	ANY																				
Crankcase Bulb eye	LC-1574	LEVEL	1/4	1/2	FULL																				
Oil Day Tank Level	LI-1562	GAL	10		FULL																				
Lubricator Bulb eye		LEVEL	1/2	FULL																					
1st Stage Scrubber Liquid Level	LI-7416	LIQID		EMPTY	ANY																				
2nd Stage Scrubber Liquid Level	LI-7466	LIQID		EMPTY	ANY																				
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIGHT		BLINK																					
1st Stage Inlet Press.	PI-2100	psig		88	140																				
Stage Disch. Press	PI-2101	psig		238	285																				
2nd Stage Inlet Press	PI-2200	psig		267	285																				
2nd Stage Disch. Press	PI-2201	psig		575	600																				
Final Discharge Pressure	PI-2108	psig		575	600																				
Lube Oil Pressure	PI-1572	psig	40	60																					
Lube Oil Temp	TE-1584	deg		150	170																				
Final Discharge Temp	TE-2120	deg		110	150																				
1st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297																				
2nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283																				
1st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297																				
2nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283																				
Motor Frame Vibration	VT-1015	IPS		0.15																					
Compressor Frame Vibration	VT-1512	IPS		0.35																					
Take Once per Shift / at Full Load		psig		Max psid		When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engine																			
Natural Gas Comp. Discharge Press.																									
Double Block and Bleed Pressure	A63FGDT	49-48=psid		8																					
Fuel Gas Supply Pressure	A63FGST	50-49=psid		20																					


 UJ-06-03342
 January 4, 2018

CGTG HOURLY READING LOG

Date: 4-9-18

MST / MDT (circle one)

Time Gas Introduced (Turbine Rolling):

Time of Turbine Online (Bkr Closed):

 0910
 0923

Time Turbine Offline (Bkr Open):

Time No Gas Flow:

 1558
 1604

Notes:

Instrument Air Compressor	ID	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1 Blowdown Dry Receiver Tank Hourly	BT-013	✓												✓	✓	✓	✓	✓	✓	✓									
2 Blowdown Wet Receiver Tank Hourly	BT-007	✓												✓	✓	✓	✓	✓	✓	✓									
3 Wet Receiver Air Pressure	PI-002	psig	90	105	120									106	105	104	103	104	105	105									
4 Instrument Temperature	TI-001	deg C	20	50										19	19	19	19	20	20	21									
5 Fin Fan Cooler		Units	Low	Norm	Max									195	195	195	195	195	195	195									
6 Coolant Pressure	PI-250	psig		25										82	82	105	111	105	106	107									
7 Coolant P/C Temperature	TI-002	deg F	100	110	120									112	112	112	112	112	112	112									
8 Sight glass level Expansion Tank	LI-001	LEVEL	1/3	2/3	FULL									1/2	1/2	1/2	1/2	1/2	1/2	1/2									
9 Coolant Return Differential from CG	FI-001	in WC	60	80										60	63	64	63	63	63	64									
10 Coolant Return Differential from	FI-002	in WC	37	50										35	35	36	36	36	36	37									
11 Control Room		Units	Low	Norm	Max									73	73	73	73	73	73	73									
12 Room Temperature		deg F		72	85									73	73	73	73	73	73	73									
13 Combustible Gas Detector Monitor		%LEI	0%	0%	20%									0%	0%	0%	0%	0%	0%	0%									
15 WFECC Log			Operational																										
16 Operation of PSS/on 1 5.3M KV		Yes (Y)			Yes (N)									Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes								
17 Operation of AVR Voltage Mode @ 13.6 KV		Yes (Y)			Yes (N)									Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes								
Electronic Control System		Units	Low	Norm	Max									35%	34%	34%	34%	34%	34%	34%									
18-20 found on Air Diagram page																													
18 2000 gal Oil Water Tank Level	LI-231	%			70%									35%	34%	34%	34%	34%	34%	34%									
19 10 gal gas T/C Drain Tank (Air Diagram page)	LI-230	%			70%									0%	0%	0%	0%	0%	0%	0%									
20 Record on hard S/D rpg over 4500 rpm NL Compressor (on line rtp)	AS3G0D ST-01	psig	35	20										✓	✓	✓	✓	✓	✓	✓									
21 Acknowledge Alarms Hourly		✓												✓	✓	✓	✓	✓	✓	✓									
22-24 found on Power Management page														✓	✓	✓	✓	✓	✓	✓									
22 Generator Current		amps			1200									1008	1012	1012	1000	994	983	973									
23 MW Output		MW			27									25.8	23.5	23.5	23.4	23.1	23.7	23.7									
24 80% Base Load Minimum		MW												19.4	19.3	1.9	19.1	19.0	19.1	18.7									
25 Running Hours (unit overview)														3326	3300	3328	3324	3330	3331	3332									
26 Ambient Temperature	TI Inlet													52.5	55.0	55.0	56.7	57.6	59.2	61.7									
27-28 found on Gas Fuel System page														52.6	57%	57%	52%	52%	50%	53%									
27 Waste Oil Tank	LI-220	%			70%									52%	57%	57%	52%	52%	50%	53%									
28 Total Fuel Flow	Mass													228.1	229	223	223	222	219	218									
Date: 4-9-18		Signature:																											

Date: 4-9-18

Signature: [Signature]

 UJ-06-03342
 January 4, 2018

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME	903																												
Combustible Gas Detector	AAH 303	%		0%	20%																								
Packing Lube Oil Flow Indicator Left Side	PSI 1501 B	LIGHT		BLINK																									
Liquid Level Coalescing	LI 7721	LIQID		EMPTY	ANY																								
Crankcase Bulb eye	LI 1574	LEVEL	1/4	1/2	FULL																								
Oil Day Tank Level	LI 1562	GAL	10		FULL																								
Lubricator Bulb eye	LI 7416	LEVEL	1/2	FULL																									
1st Stage Scrubber Liquid Level	LI 7416	LIQID		EMPTY	ANY																								
2nd Stage Scrubber Liquid Level	LI 7416	LIQID		EMPTY	ANY																								
Packing Lube Oil Flow Indicator Right Side	PSI 1501 A	LIGHT		BLINK																									
1st Stage Inlet Press.	PI 2100	psig		88	140																								
Stage Disch. Press	PI 2101	psig		238	285																								
2nd Stage Inlet Press	PI 2200	psig		267	285																								
2nd Stage Disch. Press	PI 2201	psig		575	600																								
Final Discharge Pressure	PI 2108	psig		575	600																								
Lube Oil Pressure	PI 1572	psig	40	60																									
Lube Oil Temp	TE 1584	deg		150	170																								
Final Discharge Temp	TE 2120	deg		110	150																								
1st Stage Cylinder Disch. Temperature A	TE 2054 A	deg		226	297																								
2nd Stage Cylinder Disch. Temperature A	TE 2062 A	deg		258	283																								
1st Stage Cylinder Disch. Temperature B	TE 2054 B	deg		226	297																								
2nd Stage Cylinder Disch. Temperature B	TE 2062 B	deg		258	283																								
Motor Frame Vibration	VI 1015	IPS			0.15																								
Compressor Frame Vibration	VI 1512	IPS			0.35																								
Take Once per Shift / at Full Load		psig		Max psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																								
Natural Gas Comp. Discharge Press.																													
Double Block and Bleed Pressure	A63FGDT	49-48=psid		8																									
Fuel Gas Supply Pressure	A63FTGCT	50-49=psid		20																									

DATE 4-9-18
 SIGNATURE [Signature]
 Mid Shift
 Days Shift

Notes

Date: **4-10-18**

MST / MDT (circle one)

Time Gas Introduced (Turbine Rollings):
Time of Turbine Online (After Closed):Time Turbine Offline (After Open):
Time No Gas Flow:

CGTG HOURLY READING LOG

Notes:

Instrument / Air Compressor	LO	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Blowdown Dry Receiver Tank Hourly	RYT-013	v												✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
2. Blowdown Wet Receiver Tank Hourly	RYT-007	v												✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
3. Wet Receiver Air Pressure	PI-003	psig	90	105	120									110	109	111	110	110	110	111	110	105	111	110	108	108	106	107	
4. Instrument Temperature	TI-001	deg C	20	50										20	18	19	18	19	20	19	21	23	21	21	20	20	19	19	
5. Fan Fan Cooler		Units	Low	Norm	Max																								
6. Coolant Pressure	PI-250	psig		25										19.2	19.5	19.3	17.0	19	19	19	19.2	19.2	19.2	19	19	19	19	19	
7. Coolant P/LC Temperature	TI-002	deg F	100	110	120									100	99	110	111	111	99	104	100	106	102	104	102	100	101	100	
8. Sight Glass Level Expansion Tank	LI-001	LEVEL	1/3	2/3	FULL									1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	
9. Coolant Return Differential from CG	PI-001	in WC		60	80									60	43	63	63	63	64	63	62	63	63	63	63	63	63	63	
10. Coolant Return Differential from	PI-002	in WC		37	50									37	37	37	35	36	39	39	38	39	38	38	35	35	35	35	
11. Control Room		Units	Low	Norm	Max																								
12. Room Temperature		deg F		72	85									69	72	70	70	70	72	73	73	73	74	74	74	72	72	78	
13. Combustible Gas Detector Monitor		% LEL	0%	0%	20%									0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
15. WCCF Log				Operational																									
16. Operation at PSS/On at 6.3kV		Yes (Y)			No (N)									Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
17. Operation of AVR Voltage Mode @ 13.6 kV		Yes (Y)			No (N)									Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
18. 2000 psi Oil Water Tank Level	LI-231	%			70%									35	35	35	34	34	34	34	34	34	34	34	34	34	34	34	
19. 10 psi gas TO Drain Tank (See Diagram page)	LI-230	%			70%									0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
20. Record on hand S/O trip over 4500 rpm NL Compressor (on line trip)	ASGSD 5T-01	psig	35	20										✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
21. Acknowledge Alarms Hourly		v												✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
22. Generator Current		Amps			1200									1058	1052	1027	1013	980	980	958	958	933	938	936	936	986	999	997	
23. MW Output		MW			27									25.1	24.8	24.1	23.8	23.1	23.0	20.4	20.4	22.0	21.8	22.4	22.5	23.5	23.4	23.5	
24. 30% Bar Load Minimum		MW												20.8	19.7	19.4	19.2	18.7	18.8	18.6	18.5	18.2	18.3	18.6	19.3	19.2	19.1	19.2	
25. Running Hours (unit overview)														3334	3335	3336	3337	3337	3340	3341	3342	3343	3344	3345	3346	3347	3348		
26. Ambient Temperature	TI-101													46	49	53	53	61	61	64	64	69	67	64	62	60	57	56	
27. Waste Oil Tank	LI-120	%			70%									53	53%	52	52%	52	53	53	53	53	53	53	54	54	54	54	
28. Total Fuel Flow		Med/h												234	233	229	225	223	220	217	216	212	211	211	220	220	224	223	

Date: 4-10-18

Signature: A.WAR, R.VIGIL, C.GODFREY

Date: **4-10-18**Signature: **A.WAR, A.VIGIL, C. GOWATZ**

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor START TIME		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR	0745																												
Combusible Gas Detector	AAH-303	%		0%	20%																								
Packing Lubre Oil Flow Indicator Left Side	FSL-1501B	LIGHT		BLINK																									
Liquid Level Cooling	LI-7721	LIQUID		EMPTY	ANY																								
Crankcase Bulb eye	LC-1574	LEVEL	1/4	1/2	FULL																								
Oil Day Tank Level	LI-1562	GAL	10		FULL																								
Lubricator Bulb eye		LEVEL	1/2		FULL																								
1st Stage Scrubber Liquid Level	LI-7416	LIQUID		EMPTY	ANY																								
2nd Stage Scrubber Liquid Level	LI-7466	LIQUID		EMPTY	ANY																								
Packing Lubre Oil Flow Indicator Right Side	FSL-1501A	LIGHT		BLINK																									
1st Stage Inlet Press.	PI-2100	psig		88	140																								
2nd Stage Inlet Press	PI-2101	psig		238	285																								
2nd Stage Disch. Press	PI-2200	psig		267	285																								
2nd Stage Disch. Press	PI-2201	psig		575	600																								
Final Discharge Pressure	PI-2108	psig		575	600																								
Lube Oil Pressure	PI-1572	psig	40	60																									
Lube Oil Temp	TE-1584	deg		150	170																								
Final Discharge Temp	TE-2120	deg		110	150																								
1st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297																								
2nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283																								
1st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297																								
2nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283																								
Motor Frame Vibration	VI-1015	IPS			0.15																								
Compressor Frame Vibration	VI-1512	IPS			0.35																								
Take Once per Shift / at Full Load		psig																											
Natural Gas Comp. Discharge Press.																													
Double Block and Bleed Pressure	A63FGDT	49-48=psid			8																								
Fuel Gas Supply Pressure	A63FGST	50-49=psid			20																								

When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer

DATE	4-10-18
SIGNATURE	AK
Mid Shift	
Days Shift	
Notes	

Date: **APR 1 2018**
 MSL (circle one)
 Time Gas Introduced (Turbine Rolling):
 Time of Turbine Online (Pkr Closed):
 Time Turbine Offline (Bkr Open):
 Time No Gas Flow:
 CGTG HOURLY READING LOG
 Notes: **TEIP DUE TO GEMR LOCK BEHINDING HIGH TEMPERATURE**
 Restarted CGTG 0804

Instrument	LO	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24		
1. Bleeddown Dry Receiver Tank Hourly	BRF-013	°				✓	✓	✓	✓				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
2. Bleeddown Wet Receiver Tank Hourly	BRF-007	°				✓	✓	✓	✓				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
3. Wet Receiver Air Pressure	PR-003	psig	80	105	120	106	110	104					112	110	110	108	112	110	105	108	110	108	110	110	110	110	110	110	110	110	
4. Instrument Temperature	TR-003	deg C	20	30	50	19	19	19					20	20	21	22	23	23	23	23	23	26	26	25	22	22	23	26	26		
5. Dry Fan Cooler		Units	Low	Norm	Max																										
6. Coolant Pressure	PR-250	psig		25	—	19	19	19					19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	
7. Coolant PTC Temperature	TR-002	deg F	100	110	120	102	102	104					101	101	99	100	108	110	102	106	100	108	110	111	109	111	110	108	110	110	
8. High Gas Level Expansion Tank	UL-001	LEVEL	1/3	2/3	FULL	✓	✓	✓					✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
9. Coolant Return Differential from CG	PR-001	in WC	80	80	80	65	65	65					62	62	63	64	63	64	63	63	63	64	64	65	65	65	65	65	65	65	
10. Coolant Return Differential from	PR-002	in WC	37	50	50	35	35	35					37	37	37	37	37	37	37	37	37	37	37	37	35	35	35	35	35	35	
11. Control Room		Units	Low	Norm	Max																										
12. Room Temperature		deg F	72	72	85	71	71	71					71	71	70	70	70	70	71.5	71.5	73.5	72.5	73.5	67	67	68	68	68	68	68	
13. Combustible Gas Detector Monitor		% LEL	0%	0%	20%	0	0	0					0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
14. WECC Log																															
15. Operation of PSS on at 6.3 MV		Yes (Y)			No (N)	Yes	Yes	Yes					Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
16. Operation of AVR Voltage Mode @ 13.5 MV		Yes (Y)			No (N)	Yes	Yes	Yes					Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
17. Indirect Control System		Units	Low	Norm	Max																										
18. 2000 psi Oil Water Tank Level	U-231	%			70%	34	34	34					34	34	34	34	34	34	34	34	33	33	33	33	33	33	33	33	33	33	33
19. 10 gal Gas (G) Drain Tank (See Diagram page)	U-230	%			70%	0	0	0					0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
20. Record on hard S/D trip over 4500 rpm HL	ACS660	psig	35	20																											
21. Acknowledge Alarms Hourly	ST-011	°				✓	✓	✓					✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
22. Acknowledge Alarms Hourly		°				✓	✓	✓					✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
23. Generator Current		Amps			1200	1016	1018	1011					972	966	949	934	931	918	917	914	906	907	909	923	951	978	972	977	976	976	976
24. MW Output		MW			27	23.8	24.1	24.1					22.7	22.4	22.1	21.7	21.4	21.4	21.4	21.3	21.1	21.1	21.4	21.4	21.6	22.5	22.7	22.7	22.7	22.7	22.7
25. MW Base Load Minimum		MW				19.4	19.4	19.4					19.1	18.7	18.5	18.2	18.2	18.1	18.1	18.1	17.9	17.9	18.2	18.2	18.4	18.8	18.8	18.8	18.8	18.8	18.8
26. Running Hours (Unit Overview)		Hours				3560	3551	3552					3552	3553	3554	3555	3556	3557	3558	3559	3560	3561	3562	3563	3564	3565	3566	3567	3568	3569	3570
27. Ambient Temperature	TT Inlet	°				54	54	52					58	63	64	68	69	70	70	70	71	71	70	70	70	68	66	64	62	62	62
28. Waste Oil Tank	U-230	%			70%	54	54	54					54	53	52	51	51	52	53	52	53	53	53	53	53	53	53	53	53	53	53
29. Total Fuel Flow		Mscf/h				226.1	226.1	226.5					221	217	215	212	210	210	209	210	207	207	206	206	210	212	219	217	217	217	217

Date: **APR 1 2018**
 Signature: *John*

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

APR 1, 2018

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
Combustible Gas Detector	AAR-303	%		0%	20%																								
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIQUID		BLINK																									
Liquid Level Coalescing	LI-7721	LIQUID		EMPTY	ANY																								
Crankcase Bulb eye	LC-1574	LEVEL	1/4	1/2	FULL	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2		
Oil Day Tank Level	LI-1562	GAL	10		FULL	42	42	42																					
Lubricator Bulb eye		LEVEL	1/2	FULL																									
1st Stage Scrubber Liquid Level	LI-7416	LIQUID		EMPTY	ANY																								
2nd Stage Scrubber Liquid Level	LI-7466	LIQUID		EMPTY	ANY																								
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIQUID		BLINK																									
1st Stage Inlet Press.	PI-2100	psig		88	140	82	82	82																					
2nd Stage Inlet Press	PI-2101	psig		238	285	251	251	251																					
2nd Stage Disch. Press	PI-2200	psig		267	285	247	247	248																					
Final Discharge Pressure	PI-2108	psig		575	600	575	575	575																					
Lube Oil Pressure	PI-1572	psig		60	60	57	57	57																					
Lube Oil Temp	TE-1584	deg		150	170	168	168	168																					
Final Discharge Temp	TE-2120	deg		110	150	90	90	90																					
1st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297	212	212	212																					
2nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283	221	221	221																					
1st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297	210	210	210																					
2nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283	221	221	221																					
Motor Frame Vibration	VT-1015	IPS		0.15	0.05	0.05	0.05	0.05																					
Compressor Frame Vibration	VT-1512	IPS		0.35	0.05	0.05	0.05	0.05																					
Take Once per Shift / at Full Load		psig		Max	psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																							
Natural Gas Comp. Discharge Press.	A63FGDT	49-48=psid		8																									
Double Block and Bled Pressure	A63FTGST	50-49=psid		20																									
Fuel Gas Supply Pressure																													
DATE	APR 1, 2018																												
SIGNATURE																													
Mild Shift	Mild																												
Days Shift	Days																												
Notes																													

UHL-OG-033-R2
January 4 2018

GEAR BOX BEARING TEMP OVERHEAT
UNIT TRIPPED AT 1404 WHILE RUNNING

U4-LOG-033-R2
January 4 2018

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

APRIL 12 2018

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
Combustible Gas Detector	AAH-303	%		0%	20%																								
Packing Lube Oil Flow Indicator Left side	FSL-1501B	LIQUID		BLINK	ANY	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
Liquid Level	LI-7721	LIQUID		EMPTY	ANY	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	
Crankcase Bulb eye	LC-1574	LEVEL		1/4	FULL	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	
Oil Day Tank Level	LI-1562	GAL		10	FULL	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	42	
Lubricator Bulb eye	LI-7416	LEVEL		1/2	FULL	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	
1st Stage Scrubber Liquid Level	LI-7416	LIQUID		EMPTY	ANY	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	
2nd Stage Scrubber Liquid Level	LI-7466	LIQUID		EMPTY	ANY	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	
Packing Lube Oil Flow Indicator Right side	FSL-1501A	LIQUID		BLINK	ANY	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	
1 st Stage Inlet Press.	PI-2100	psig			88	140	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	
Stage Disch. Press	PI-2101	psig			238	285	263	253	253	250	251	250	250	250	251	251	251	251	251	251	251	251	251	251	251	251	251	251	
2nd Stage Inlet Press	PI-2200	psig			267	285	249	249	248	248	247	247	247	247	247	247	247	247	247	247	247	247	247	247	247	247	247	247	
2nd Stage Disch. Press	PI-2201	psig			575	600	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	
Final Discharge Pressure	PI-2108	psig			575	600	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	
Lube Oil Pressure	PI-1572	psig		40	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	
Lube Oil Temp	TE-1584	deg			150	170	164	164	165	165	165	165	165	165	165	165	165	165	165	165	165	165	165	165	165	165	165	165	
Final Discharge Temp	TE-2120	deg			110	150	149	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	148	
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg			226	297	216	216	216	216	214	213	213	213	213	213	213	213	213	213	213	213	213	213	213	213	213	213	
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg			238	283	224	224	224	224	223	223	223	223	223	223	223	223	223	223	223	223	223	223	223	223	223	223	
1st Stage Cylinder Disch. Temperature B	TE-2054 B	deg			226	297	213	213	213	211	211	210	210	210	210	210	210	210	210	210	210	210	210	210	210	210	210	210	
2nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg			238	283	227	227	227	223	224	223	223	223	223	223	223	223	223	223	223	223	223	223	223	223	223	223	
Motor Frame Vibration	VI-1015	IPS			0.15	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
Compressor Frame Vibration	VI-1512	IPS			0.35	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	
Take Once per Shift / at Full Load		psig		Max psid																									
Natural Gas Comp Discharge Press.																													
Double Block and Bleed Pressure	AA3FGDT	49-48=psid			8																								
Fuel Gas Supply Pressure	AA3FTGST	50-49=psid			20																								
DATE	APRIL 12 2018																												

David Owen
Good work
Mike Oliver

APR 13 2018

APR 13 2018

UAC-003342
 04/07/2018

MST (circle one)
 Time Gas Introduced (Turbine Rolling):
 Time of Turbine Online (Bkr Closed):

Time Turbine Offline (Bkr Open):
 Time No Gas Flow:

CGTG HOURLY READING LOG

Notes: CONTINUATION OF SUPPORT FOR PJM.

Instrument Air Compressor		LO	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1	Bleeddown Dry Receiver Tank Hourly	INVT-013	Y				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
2	Bleeddown Wet Receiver Tank Hourly	INVT-007	Y				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
3	Wet Receiver Air Pressure	PI-002	psig	90	105	120	110	106	108	110	108	105	109	106	105	103	105	110	109	110	109	105	108	108	107	110	109	112	106	✓
4	Instrument Temperature	TI-001	deg C	20	50	50	19	19	19	20	20	20	20	20	19	19	18	18	18	18	18	19	19	18	18	18	18	18	16	115
5	Fan Fan Cooler	PI-250	psig	Low	Norm	Max																								
6	Coolant Pressure	PI-002	psig	25			19	19	19	19	19	19	19	19	19.5	19.5	19.5	19.5	19.5	19.5	19.5	19.5	19.5	19	19	19	19	19	19	
7	Coolant P/L Temperature	TI-002	deg F	100	110	120	104	111	107	108	110	109	110	106	110	104	105	110	111	108	108	105	103	105	105	103	103	107	110	
8	Light Gas Level Expansion Tank	LI-001	LEVEL	1/3	2/3	FULL	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	
9	Coolant Return Differential from EG	FI-001	in WC	60	80	80	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	
10	Coolant Return Differential from	FI-002	in WC	37	50	50	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	
11	Control Room		Units	Low	Norm	Max																								
12	Room Temperature		deg F	72	80	85	69	69	70	71	71	70	70	68	66	66	67	67	67	68	68	68	68	68	68	68	68	68	68	
13	Combustible Gas Detector Monitor		% LEL	0%	10%	20%	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
14	WCCS Log		Operation																											
15	Operation of P55 (on 31.5 MW)		Yes (Y)				Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
16	Operation of AVI Voltage Mode @ 13.5 kV		Yes (Y)				Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
17	Diatomic Control System		Units	Low	Norm	Max																								
18	2000 psi Oil Water Tank Level	LI-231	%			70%	34	34	34	34	34	34	34	34	34	34	35	35	35	34	34	34	34	34	34	34	34	34	34	
19	20 psi Gas TO Drain Tank (Air Diagram page)	LI-230	%			70%	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
20	Record on hard 5/10 trip over 4500 rpm NL Compressor (on line trip)	AS-000	psig	35	20																									
21	Acknowledge Alarms Hourly		Y				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
22-24	found on Power Management page																													
25	Generator Current		Amps		1200		1069	1073	1071	1090	1093	1107	1105	1107	1102	1098	1107	1084	1070	1060	1046	1046	1047	1044	1064	1074	1082	1089	1096	
26	MW Output		MW		27		25.5	25.5	25.5	25.6	25.8	26.1	26.1	26.1	25.8	25.5	25.1	25.1	24.8	24.8	24.8	24.8	24.8	25.1	25.1	25.5	25.5	25.8	25.8	
27	80% Steam Load Minimum		MW				20.8	20.8	20.7	21.1	21.2	21.3	21.3	21.3	21.0	20.8	20.5	20.6	20.5	20.1	20.1	20.1	20.1	20.3	20.3	20.4	20.6	20.7	20.7	
28	Running Hours (unit overview)						3593	3594	3595	3596	3597	3598	3599	3600	3601	3602	3603	3604	3605	3606	3607	3608	3609	3610	3611	3612	3613	3614	3615	
29	Ambient Temperature	TI-002					38	36	36	34	32	31	29.1	28.2	27.3	32.4	35.8	38.3	40.8	43.3	44.1	44.1								
30	20-28 found on Gas Fuel System page						54	54	55	55	55	55	55	55	55	55	55	55	55	55	55	55	55	55	55	55	55	55	55	
31	Waste Oil Tank	LI-230	%		70%		235	234	236	238	238	240	241	241	240	239	238	237	234	233	234	231	229							
32	Total Fuel Flow		MMBtu				54	54	55	55	55	55	55	55	55	55	55	55	55	55	55	55	55	55	55	55	55	55	55	

APR 13 2018
Signature: [Signature]
1800 Busby W. 7th Bldg. 1000
+ W. 4th Down - 5th - 10th

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

A-2 13 2018

Natural Gas Compressor		COUNTDOWN																										
GAS COMPRESSOR START TIME	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Combustible Gas Detector	AAH-303	%	0%	20%																								
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIQHT	BLINK		B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
Liquid Level Coalescing	LI-7721	LIQID	EMPTY	ANY	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	
Crankcase Bulb eye	LC-1574	LEVEL	1/4	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	
Oil Day / Tank level	LI-1562	GAL	10	FULL	3/4	3/4	3/4	3/4	3/4	3/4	3/4	3/4	3/4	3/4	3/4	3/4	3/4	3/4	3/4	3/4	3/4	3/4	3/4	3/4	3/4	3/4	3/4	
Lubricator Bulb eye	LI-7416	LEVEL	1/2	FULL	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	
1st Stage Scrubber Liquid Level	LI-7416	LIQID	EMPTY	ANY	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	
2nd Stage Scrubber Liquid Level	LI-7466	LIQID	EMPTY	ANY	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	
Packing Lube Oil Flow Indicator Right side	FSL-1501A	LIQHT	BLINK		B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	
1 st Stage Inlet Press.	PI-2100	psig	88	140	80	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Stage Disch. Press	PI-2101	psig	238	285	1250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	
2 nd Stage Inlet Press	PI-2200	psig	267	285	245	245	246	246	245	245	244	245	246	244	244	244	245	245	245	245	244	244	244	245	246	245	244	
2 nd Stage Disch. Press	PI-2201	psig	575	600	575	575	575	579	579	579	579	579	579	579	579	579	578	578	578	578	578	578	578	578	578	578	578	
Final Discharge Pressure	PI-2108	psig	575	600	575	575	575	575	575	574	574	574	574	574	574	574	573	573	573	573	573	573	573	573	573	573	573	
Lube Oil Pressure	PI-1572	psig	40	60	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	
Lube Oil Temp	TE-1584	deg	150	170	170	170	170	169	169	170	169	169	170	168	168	168	168	168	168	168	168	168	168	168	168	168	168	
Final Discharge Temp	TE-2120	deg	110	150	77	77	75	75	75	75	73	70	70	70	71	74	74	74	74	74	74	74	74	74	74	74	75	
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg	226	297	246	246	247	247	247	244	244	243	241	241	241	241	245	246	246	247	248	247	247	247	247	247	247	
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg	258	283	245	245	245	245	246	245	245	245	245	245	245	245	245	245	245	245	245	245	245	245	245	245	245	
1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg	226	297	247	246	247	246	246	246	245	244	244	244	244	244	245	245	246	246	246	246	246	246	246	246	246	
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg	258	283	247	247	247	246	246	246	245	244	244	244	244	244	245	245	246	246	246	246	246	246	246	246	246	
Motor Frame Vibration	VT-1015	IPS	0.15	0.15	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3		
Compressor Frame Vibration	VT-1512	IPS	0.35	0.35	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6		
Take Once per Shift / at Full Load		psig	Max psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																								
Natural Gas Comp. Discharge Press.	AG3FGDT	49-48=psid	8																									
Double Block and Bleed Pressure	AG3FTG5T	50-49=psid	20																									
Fuel Gas Supply Pressure																												

DATE	Feb 13 2018
SIGNATURE	
Mid Shift	John
Days Shift	
Notes	683941-55666

Date: **APR 14 2018**

MST (MOT) (for one)

Time Gas Introduced (Turbine Rolling):

Time of Turbine Online (After Close):

Time Turbine Offline (After Open):

Time No Gas Flow:

CGTG HOURLY READING LOG

Notes: 0155-Place note about pasts below oil demister
0205- T-test value of new oil tank level at 401.444

Instrument Air Compressor	LO	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1 Blowdown Dry Receiver Tank Hourly	BT-013	V																											
2 Blowdown Wet Receiver Tank Hourly	BT-007	V																											
3 Wet Receiver Air Pressure	PT-003	psig	90	105	120																								
4 Instrument Temperature	TT-001	deg C	20	30	40																								
5 Fan Fan Cooler	PT-001	Units	Low	Norm	Max																								
6 Coolant Pressure	PT-002	psig	25																										
7 Coolant P/LC Temperature	TT-002	deg F	100	110	120																								
8 Sight Glass Level Expansion Tank	LI-001	LEVEL	1/3	2/3	FULL																								
9 Coolant Return Differential from GC	PT-001	in WC	60	80																									
10 Coolant Return Differential from	PT-002	in WC	37	50																									
11 Control Room		Units	Low	Norm	Max																								
12 Room Temperature		deg F	72	85																									
13 Combustible Gas Detector Monitor		% LEL	0%	0%	20%																								
15 WRECC Log				Operation?																									
16 Operation of PSL on at 6.30 AM		Yes (Y)			No (N)																								
17 Operation of A/V Voltage Monitor @ 115 KV		Yes (Y)			No (N)																								
18 2000 gal Oil Water Tank Level	LI-231	%			70%																								
19 10 gal Gas To Drain Tank (See Diagram page)	LI-230	%			70%																								
20 Record on hand S/D note over 4000 ppm NL Compressor (See line 20)	MS-001	ppm	35	20																									
21 Admonitory Alarm Hourly	ST-01	V																											
(22-24) Found on Power Management Page)																													
22 Generator Current		Amps			1200																								
23 New Output		MW			27																								
24 100% Base Load Minimum		MW																											
25 Running Hours (Unit over)		hrs																											
26 Ambient Temperature	TT-001	deg C																											
(27-28) Found on Gas Fuel System Page)																													
29 Waste Oil Tank	LI-230	%			70%																								
30 Fuel Fuel Flow		Mcf/hr																											

Date: **4-14-18**

Signature: *[Signature]*

Doc: *MM Paul*

LA-00000000

January 4 2018

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
Combustible Gas Detector	AAH-303	%		0%	20%																								
Packing Lube Oil Flow Indicator Left side	FSI-1501B	LIQUID	BLINK	ANY	ANY	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	
Liquid Level	LI-7721	LIQUID	EMPTY	ANY	ANY	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	
Crankcase Bulb eye	LC-1574	LEVEL	1/4	1/2	FULL	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	
Oil Day Tank Level	LI-1562	GAL	10	FULL	FULL	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	
Lubricator Bulb eye	LI-7416	LEVEL	1/2	FULL	FULL	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	
1st Stage Scrubber Liquid Level	LI-7466	LIQUID	EMPTY	ANY	ANY	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	
2nd Stage Scrubber Liquid Level	LI-7466	LIQUID	EMPTY	ANY	ANY	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	
Packing Lube Oil Flow Indicator Right Side	FSI-1501A	LIQUID	BLINK	ANY	ANY	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	
1 st Stage Inlet Press.	PI-2100	psig		88	140	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	
2 nd Stage Inlet Press	PI-2101	psig		238	285	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	149	
2 nd Stage Disch. Press	PI-2200	psig		267	285	245	245	245	245	245	245	245	245	245	245	245	245	245	245	245	245	245	245	245	245	245	245	245	
Final Discharge Pressure	PI-2201	psig		575	600	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	
Lube Oil Pressure	PI-2108	psig		575	600	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	
Lube Oil Temp	PI-1572	deg		40	60	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	
Final Discharge Temp	TE-1584	deg		150	170	170	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	
1 st Stage Cylinder Disch. Temperature A	TE-2120	deg		110	150	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	
2 nd Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	
1 st Stage Cylinder Disch. Temperature B	TE-2062 A	deg		258	283	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	
2 nd Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	
Motor Frame Vibration	TE-2062 B	deg		258	283	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	
Compressor Frame Vibration	VT-1015	IPS		0.15	0.35	0.03	0.04	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
Take Once per Shift / at Full Load	VT-1512	IPS		0.35	0.5	0.03	0.04	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
Natural Gas Comp. Discharge Press.		psig		Max psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																								
Double Block and Bleed Pressure	AG3FGDT	49-48=psid		8	575	570																							
Fuel Gas Supply Pressure	AG3FTG8T	50-49=psid		20	538																								

DATE 4-14-18
 SIGNATURE *[Signature]*
 Mid Shift *[Signature]*
 Days Shift *[Signature]*
 Notes
 4-15-18 0:00 689982 55666

685896



4-15-18

Date: 4-15-18
MST (date one)
Time Gas Introduced (Turbine Rolling):
Time of Turbine Online (later closed):

Time Turbine Offline (later Open):
Time No Gas Flow:

CGIG HOURLY READING LOG

Notes: DLE 80 TO BASE MIN. READING SHOWING 777
DLE MODE ON + OK JUST KANT GET NUMBERS

Instrument	ID	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Blowdown Dry Receiver Tank Hourly	8WT-013	V				/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
2. Blowdown Wet Receiver Tank Hourly	8WT-007	V				/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
3. Wet Receiver Air Pressure	PI-002	psig	90	105	120	109	108	106	105	108	105	102	106	110	106	102	106	110	104	102	104	106	105	111	107	109	110	112	108
4. Instrument Temperature	TI-001	deg C	20	20	50	17	17	17	16	15	15	15	16	17	18	14	16	19	20	21	22	22	21	22	21	20	19	19	
5. Pin Fan Cooler		Units	Low	Norm	Max																								
6. Coolant Pressure	PI-250	psig	25	25	25	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	
7. Coolant P.I.C. Temperature	TI-002	deg F	100	110	120	114	114	105	103	100	97	102	110	105	100	110	102	104	106	102	104	106	105	111	107	109	110	112	
8. Sight glass level Expansion Tank	LI-001	LEVEL	L/3	2/3	FULL	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	
9. Coolant Return Differential from GG	PI-001	in WC	60	80	80	62	62	62	62	62	62	62	62	62	62	62	62	62	62	62	62	62	62	62	62	62	62	62	
10. Coolant Return Differential from	PI-002	in WC	37	50	50	36	36	36	36	36	36	36	36	36	36	35	35	35	35	35	35	34	36	36	36	36	36	36	
11. Control Room		Units	Low	Norm	Max																								
12. Room Temperature		deg F	72	72	85	72	71	71	72	72	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	
13. Combustible Gas Detector Monitor		%LEL	0%	0%	20%	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
14. WCC Log		Operation																											
15. Operation of P/S on at 6.30 AM		Yes (Y)				YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	
16. Operation of AVT Voltage Mode @ 13.5 KV		Yes (Y)				YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	
17. Electronic Control System		Units	Low	Norm	Max																								
18. 2000 gal Oil Water Tank Level	LI-231	%			70%	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	
19. 10 gal per 10 Drain Tank (AK Diagram page)	LI-230	%			70%	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
20. Record on hard S/D trip over 4500 rpm RL	AS2000	page	35	20																									
21. Compressor (on line trip)	ST-01	V				/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
22. Acknowledge Alarms Hourly		V				/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	
23. 20-20 found on AK Diagram page)																													
24. 20-25 found on Power Management page)																													
25. Generator Current		Amper			1200	1052	1060	1083	1085	1086	1095	1084	1077	1093	1072	1030	1034	1018	741	902	960	961	954	984	989	1001	1003	1017	
26. MW Output		MW			27	24.8	25.1	25.4	25.8	25.8	25.8	25.6	25.5	24.9	24.2	24.1	23.8	23.5	22.2	22.2	22.7	22.7	22.9	22.7	23.3	23.8	24.0		
27. 80% Base Load Minimum		MW				19.9	20.1	20.3	20.3	20.6	20.7	20.7	20.3	19.9	19.7	19.6	19.5	19.3	19.1	18.7	18.7	18.7	18.7	18.7	18.7	18.7	18.7		
28. Running Hours (unit overviews)		Hours				3441	3442	3443	3444	3445	3446	3447	3448	3449	3450	3451	3452	3453	3454	3455	3456	3457	3458	3459	3460	3461	3462		
29. Ambient Temperature	TI Inlet					45	44	44	40	38	37	36	37	41	47	50	51	53	54	57	62	63	63	62	61	58	55	53	
30. 20-25 found on Gas End System page)																													
31. Waste Oil Tank	LI-230	%			70%	55	55	55	55	55	56	55	55	57	53	53	53	54	54	54	54	54	54	54	54	54	54	54	
32. Total Fuel Flow		Mcf/hr				236	237	240	242	242	243	240	239	235	231	232	230	229	226	226	226	226	226	226	226	226	227	229	
33. Signature:																													
34. Date:																													

Signature: *[Handwritten Signature]*
Date: APR 15 2018
Time: 12:00 PM

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
GAS COMPRESSOR START TIME																														
Combustible Gas Detector	AAH-303	%		0%	20%																									
Packing Lube Oil Flow Indicator Left Side	FSI-1501B	LIGHT		BLINK																										
Liquid Level Coalescing	LI-7721	LIQUID		EMPTY	ANY																									
Crankcase Bulb eye	LC-1574	LIQUID	1/4	1/2	FULL																									
Oil Day Tank Level	LI-1562	GAL	10		FULL																									
Lubricator Bulb eye		LEVEL	1/2	FULL																										
1st Stage Scrubber Liquid Level	LI-7416	LIQUID		EMPTY	ANY																									
2nd Stage Scrubber Liquid Level	LI-7466	LIQUID		EMPTY	ANY																									
Packing Lube Oil Flow Indicator Right Side	FSI-1501A	LIGHT		BLINK																										
1 st Stage Inlet Press.	PI-2100	PSIG			88	140	151	152	152	152	152	152	152	152	151	151	152	152	152	152	152	152	151	152	151	152	152	152	152	
Stage Disch. Press	PI-2101	PSIG			238	285	249	250	250	249	250	249	250	249	250	249	250	249	250	249	250	249	250	249	250	249	250	249	250	
2nd Stage Inlet Press	PI-2200	PSIG			267	285	249	250	250	249	250	249	250	249	250	249	250	249	250	249	250	249	250	249	250	249	250	249	250	
2 nd Stage Disch. Press	PI-2201	PSIG			575	600	575	575	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	
Final Discharge Pressure	PI-2108	PSIG			575	600	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	
Lube Oil Pressure	PI-1572	PSIG	40		60	58	58	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	
Lube Oil Temp	TE-1584	deg			150	170	169	170	170	170	170	170	170	170	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	
Final Discharge Temp	TE-2120	deg			110	150	81	81	78	77	74	74	76	79	79	82	88	89	91	93	99	100	100	98	98	95	93	90	90	
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg			226	297	208	207	206	205	205	206	202	202	209	212	213	213	214	216	216	216	216	216	216	216	216	216	216	
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg			258	283	214	211	211	209	206	207	207	214	220	224	224	224	224	224	224	224	224	224	224	224	224	224	224	
1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg			226	297	208	207	206	205	205	206	202	202	209	212	213	213	214	216	216	216	216	216	216	216	216	216	216	
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg			258	283	214	211	211	209	206	207	207	214	220	224	224	224	224	224	224	224	224	224	224	224	224	224	224	
Motor Frame Vibration	VT-1015	IPS			0.15	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
Compressor Frame Vibration	VT-1512	IPS			0.35	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	
Take Once per Shift / at Full Load		PSIG			Max psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																								
Natural Gas Comp. Discharge Press.	A63FGDT				8	570										579														
Double Block and Bleed Pressure																576														
Fuel Gas Supply Pressure	A63FTGST				20	558										574														

DATE APR 15 2018

SIGNATURE *MDA*

Mid Shift *MDA*

Boys Shift *MDA*

Notes *MDA*

695944

55666

Date: APR 16 2018
 MST (MID) (circle one)
 Time Gas Introduced (Turbine Reading):
 Time of Turbine Online (After Closed):

Time Turbine Offline (After Open):
 Time No Gas Flow:

Notes:
 DLE MODE ON / 11 LUMINATED GREEN
 BUT READING NOT SHOWING JUST 2.2
 0851: HMI 16400000

CGTG HOURLY READING LOG

Instrument Air Compressor	ID	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Blowdown Dry Receiver Tank Hourly	BT-013	°F				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
2. Blowdown Wet Receiver Tank Hourly	BT-007	°F				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
3. Wet Receiver Air Pressure	PT-002	psig	90	105	120	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
4. Instrument Temperature	TI-001	deg C	20	30	40	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
5. Inlet Air Cooler	PT-001	Units	Low	Norm	Max	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
6. Coolant Pressure	PT-002	psig	25	35	45	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
7. Coolant P/LC Temperature	TI-002	deg F	100	110	120	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
8. Sight Glass Level Expansion Tank	LI-001	LEVEL	1/3	2/3	FULL	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
9. Coolant Return Differential from GS	PI-001	in WC	60	80	100	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
10. Coolant Return Differential from	PI-002	in WC	37	47	57	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
11. Control Room		Units	Low	Norm	Max	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
12. Room Temperature		deg F	72	75	78	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
13. Combustible Gas Detector Monitor		% LEL	0%	10%	20%	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
14. WCC/Lag		Operational?				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
15. Operation of P/S on at 5.34 MV		Yes (Y)				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
16. Operation of Air Voltage Mode @ 13.6 KV		Yes (Y)				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
17. Electronic Control System		Units	Low	Norm	Max	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
18. 2000 psi Oil Wator Tank Level	LI-001	%	70%	75%	80%	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
19. 10 psi TO Drain Tank (Air Diagram page)	LI-002	%	70%	75%	80%	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
20. Inert on hand S/D trip over 4500 rpm NL Compressor (on the trip)	AS-001	psig	35	40	45	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
21. Acknowledge Alarms Hourly		Y				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
22. 24 found on Power Management page						✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
23. 24 found on Air Diagram page						✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
24. New Output		Amper				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
25. 24 Base Load Minimum		MW				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
26. Running Hours (with over-view)		MW				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
27. Ambient Temperature	TI-001	°F				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
28. 24 found on Gas Fuel System page						✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
29. Waste Oil Tank	LI-001	%	70%	75%	80%	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
30. Total Fuel Flow		Mcf/h				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓

Date: 4-16-18
 Signature: [Signature]
 Title: Reactant Mins

LANL-03342
 January 2018

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
Combustible Gas Detector	AAH-303	%		0%	20%																								
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIQUID	BLINK	ANY	ANY																								
Liquid Level	LI-7721	LIQUID	EMPTY	ANY	ANY																								
Crankcase Bulb eye	LC-1574	LEVEL	1/4	1/2	3/4																								
Oil Day Tank Level	LI-1562	GAL	10	FULL	FULL																								
Lubricator Bulb eye	LI-7416	LEVEL	1/2	FULL	FULL																								
1st Stage Scrubber Liquid Level	LI-7466	LIQUID	EMPTY	ANY	ANY																								
2nd Stage Scrubber Liquid Level	LI-7466	LIQUID	EMPTY	ANY	ANY																								
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIQUID	BLINK	ANY	ANY																								
1 st Stage Inlet Press.	PI-2100	PSIG		88	140																								
2nd Stage Inlet Press	PI-2101	PSIG		238	285																								
2nd Stage Disch. Press	PI-2200	PSIG		267	285																								
Final Discharge Pressure	PI-2108	PSIG		575	600																								
Lube Oil Pressure	PI-1572	PSIG		575	600																								
Lube Oil Temp	TE-1584	deg		60	150																								
Final Discharge Temp	TE-2120	deg		110	150																								
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297																								
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283																								
1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297																								
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283																								
Motor Frame Vibration	VT-1015	IPS		0.15	0.35																								
Compressor Frame Vibration	VT-1512	IPS		0.35	0.5																								
Take Once per Shift / at Full Load		PSIG		Max psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																								
Natural Gas Comp. Discharge Press.	A63FGDT			49-48=psid	8																								
Double Block and Bleed Pressure	A63FGST	50-49=psid		20	575																								
Fuel Gas Supply Pressure					570																								
					559																								

DATE APR 15 2018

SIGNATURE [Signature]

Mid Shift [Signature]

Days Shift 1

Notes 5-5-666 701721

[illegible]

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
Combustible Gas Detector	AAH-303	%		0%	20%																								
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIGHT		BLINK	ANY	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
Liquid Level Collecting	LL-7721	LIQUID		EMPTY	ANY	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
Crankcase Bulb eye	LC-1574	LEVEL 1/4		1/2	FULL	1/2	1/3	1/3	1/3	1/3	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2
Oil Day Tank Level	LL-1562	GAL 10			FULL	1/2	1/3	1/3	1/3	1/3	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2
Lubricator Bulb eye	LL-7416	LEVEL 1/2		FULL	FULL	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	
1st Stage Scrubber Liquid Level	LL-7416	LIQUID		EMPTY	ANY	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	
2nd Stage Scrubber Liquid Level	LL-7466	LIQUID		EMPTY	ANY	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIGHT		BLINK	ANY	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	
1 st Stage Inlet Press.	PI-2100	psig		88	140	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
Stage Disch. Press	PI-2101	psig		238	285	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
2 nd Stage Inlet Press	PI-2200	psig		267	285	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
2 nd Stage Disch. Press	PI-2201	psig		575	600	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
Final Discharge Pressure	PI-2108	psig		575	600	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
Lube Oil Pressure	PI-1572	psig		60	150	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
Lube Oil Temp	TE-1584	deg		150	170	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
Final Discharge Temp	TE-2120	deg		110	150	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	297	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
Motor Frame Vibration	VT-1015	IPS		0.15	0.3	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
Compressor Frame Vibration	VT-1512	IPS		0.35	0.6	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
Take Once per Shift / at Full Load		psig		Max	psid																								
Natural Gas Comp. Discharge Press.																													
Double Block and Bled Pressure	A63FGDT	49-48=psid		8	575																								
Fuel Gas Supply Pressure	A63FTGST	50-49=psid		20	559																								

DATE 4-17-18

SIGNATURE

Mid Shift

Days Shift

Notes

C. Pacheco

207476-55666

4-17-18
Full
49-20-21 Hc

U4-00-033482
January 7, 2018

1470/1711

Date: 4-18-18
 MST (MST) (circle one)
 Time Gas Introduced (Turbine Rollback):
 Time of Turbine Online (Btr Closed):
 CGTG HOURLY READING LOG
 Time Turbine Offline (Btr Open):
 Time No Gas Flow:
 Notes: 0800 BUSY WITH ADVISE EVALUATION
 Signature: [Signature] Date: APR 18 2018

Instrument	Unit	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Bleeddown Dry Receiver Tank Hourly	BT-015	Y																										
2. Bleeddown Wet Receiver Tank Hourly	BT-007	Y																										
3. Wet Receiver Air Pressure	PT-003	psig	90	105	120	115	106	105	109	106	103	104	110	106	106	112	110	116	106	105	112	110	106	104	104	107	104	110
4. Instrument Temperature	TT-001	deg C	20	30	40	15	15	15	15	13	13	14	16	17	19	19	19	19	20	20	20	20	20	20	20	19	19	18
5. Inlet Air Cooler	PT-001	psig	Low	Norm	Max																							
6. Coolant Pressure	PT-001	psig	25	35	45	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19
7. Coolant P.T. Temperature	TT-002	deg F	100	110	120	111	109	99	100	110	109	100	103	110	111	110	109	105	102	102	99	101	98	110	104	107	106	104
8. Sight glass level Expansion Tank	LL-001	LEVEL	1/3	2/3	FILL	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2
9. Coolant Return Differential from GS	PT-001	in WC	60	80	90	62	62	62	63	63	62	64	64	63	63	64	65	63	65	64	64	64	64	64	62	58	52	63
10. Coolant Return Differential from	PT-001	in WC	37	50	50	36	36	36	36	36	35	35	35	37	39	36	36	38	39	37	39	39	34	36	36	36	36	34
11. Control Room	Units	Low	Norm	Max																								
12. Room Temperature	deg F	72	85	95	67	72	73	73	68	73	69	69		69	70	70	70	70	70	70	71	71	68	71	67	71	69	70
13. Combustible Gas Detector Monitor	% LEL	0%	20%	20%	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
14. WETCOG	Operation	Open/Close																										
15. Operation of PSS on at CSAM	Yes (Y)	No (N)				YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES
16. Operation of AVM Voltage Mode @ 13.6 KV	Yes (Y)	No (N)				YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES
17. Electronic Control System	Units	Low	Norm	Max																								
18. 1000 gal Oil Water Tank Level	U-120	%	70%	70%	34	34	34	34	34	34	34	35	35	34	34	34	34	34	34	33	33	33	33	33	33	33	34	34
19. 10 gal Gas TO Drain Tank (As Diagram page)	U-120	%	70%	70%	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
20. Guard up hard S/P trip over 4500 rpm RL	ACS000	psig	35	20																								
21. Compressed Gas (in line trip)	ST-01	psig	35	20																								
22. ACS000 Alarms Hourly	Y																											
23. 25-30 found on Power Management page)																												
24. New Output	Amper		1200		1090	1091	1098	1103	1117	1118	1109	1085	1069	1060	1050	1048	1027	999	991	958	983	981	992	1023	1030	1039	1046	1054
25. 1000 Base Load Minimum	MW		27		25.8	25.8	26	26.1	26.1	26.1	26.1	25.1	25.1	24.8	24.8	23.5	23.5	23.5	23.5	23.1	23.2	23.5	24.1	24.4	24.4	24.8	24.8	
26. Running Hour (unit over view)	MW				20.7	20.7	20.7	20.9	21.2	21.1	21.0	20.4	20.1	19.7	19.4	19.1	19.0	18.9	18.9	18.9	18.9	19.0	19.5	19.6	19.7	19.8	19.9	
27. Ambient Temperature	TT-001	deg C			35.2	35.3	35.7	35.1	35.1	35.1	35.1	35.1	35.1	35.1	35.1	35.1	35.1	35.1	35.1	35.1	35.1	35.1	35.1	35.1	35.1	35.1	35.1	
28. 25-30 found on Gas Fuel System page)					36	34	34	34	31	31	33	39		44	49	49	52	57	58	59	59	59	58	51	50	49	48	
29. Wet Oil Tank	U-120	%	70%	70%	55	55	56	56	56	56	56	54		53	53	53	53	53	53	54	54	54	54	55	55	55	55	
30. Total Fuel Flow	MG/H				242	242	242	245	246	246	245	240		237	235	233	231	228	226	225	223	223	226	230	233	234	235	

U4-00-033482
January 7, 2018

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
Combustible Gas Detector	AAH-303	%		0%	20%																								
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIQHT	BLINK	ANY	ANY																								
Liquid Level Collecting	LI-7721	LIQD	EMPTY	ANY	ANY																								
Crankcase Bulb eye	LC-1574	LEVEL	1/4	1/2	FULL																								
Oil Day Tank Level	LI-1562	GAL	10	FULL	FULL																								
Lubricator Bulb eye		LEVEL	1/2	FULL	FULL																								
1st Stage Scrubber Liquid Level	LI-7416	LIQD	EMPTY	ANY	ANY																								
2nd Stage Scrubber Liquid Level	LI-7466	LIQD	EMPTY	ANY	ANY																								
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIQHT	BLINK	ANY	ANY																								
1st Stage Inlet Press.	PI-2100	psig	88	140	52	92	52	82	52	82	52	91	91	52	91	52	91	52	91	52	91	52	91	52	91	52	91		
Stage Disch. Press	PI-2101	psig	238	285	249	245	245	244	246	244	247	249	229	251	250	258	251	251	258	251	251	258	251	251	251	251	251		
2nd Stage Inlet Press	PI-2200	psig	267	285	245	245	245	245	245	244	247	249	229	251	250	258	251	251	258	251	251	258	251	251	251	251	251		
2nd Stage Disch. Press	PI-2201	psig	575	600	578	578	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579		
Final Discharge Pressure	PI-2108	psig	575	600	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579		
Lube Oil Pressure	PI-1572	psig	40	60	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57		
Lube Oil Temp	TE-1584	deg	150	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170		
Final Discharge Temp	TE-2120	deg	110	150	74	74	74	74	74	74	74	74	74	74	74	74	74	74	74	74	74	74	74	74	74	74	74		
1st Stage Cylinder Disch. Temperature A	TE-2054 A	deg	226	297	204	204	204	203	203	203	204	204	204	204	204	204	204	204	204	204	204	204	204	204	204	204	204		
2nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg	258	283	205	205	205	205	205	205	205	205	205	205	205	205	205	205	205	205	205	205	205	205	205	205	205		
1st Stage Cylinder Disch. Temperature B	TE-2054 B	deg	226	297	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202	202		
2nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg	258	283	206	206	206	206	206	206	206	206	206	206	206	206	206	206	206	206	206	206	206	206	206	206	206		
Motor Frame Vibration	VT-1015	IPS	0.15	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04		
Compressor Frame Vibration	VT-1512	IPS	0.35	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05		
Take Once per Shift / at Full Load		psig	Max	psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																								
Natural Gas Comp. Discharge Press.	A63FGDT	49-48=psid		8	578																								
Double Block and Bled Pressure	A63FTGST	50-49=psid		20	559																								
Fuel Gas Supply Pressure																													

DATE APR 18 2018

SIGNATURE

Mid Shift C Pacheco

Days Shift John Haines

Notes 0800 Day with noise evaluation.

0800 BUSY WITH NOISE EVALUATION

7/3/10 - 55666


4-19-18

MST (Add one)
Time Gas Introduced (Turbine Rollup):
Time of Turbine Online (After Close):

Time Turbine Offline (After Open):
Time No Gas Flow:

GTG HOURLY READING LOG

Notes: 1400 PLEKED COMBUSTION IN THE FILTER
CLEANING SYSTEM ON LINE IN AUTO

Instrument Air Compressor	LD	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Shutdown Dry Receiver Tank Hourly	RT-013	✓				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
2. Shutdown Wet Receiver Tank Hourly	RT-007	✓				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
3. Wet Receiver Air Pressure	PI-002	psig	90	105	120	105	104	110	103	106	109	109	106	105	109	110	105	100	105	100	105	105	106	102	108	104	106	108	103
4. Instrument Temperature	TI-001	deg C	20	20	50	17	17	17	17	17	17	17	18	18	16	19	20	19	19	20	20	20	20	20	19	19	19	19	
5. Pin Fan Cooler		Units	Low	Norm	Max																								
6. Coolant Pressure	PI-020	psig	25	25		19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	
7. Coolant P/C Temperature	TI-002	deg F	100	110	120	106	108	103	107	111	102	100	111	108	103	107	105	107	110	100	101	111	110	108	100	102	99	101	100
8. Sight glass Level Expansion Tank	LI-001	LEVEL	L/3	2/3	FULL	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	
9. Cooling Return Differential from EG	FI-001	in WC	40	40	40	63	63	62	62	62	62	62	63	63	63	63	63	63	63	63	63	65	65	65	65	65	65	65	
10. Cooling Return Differential from	FI-002	in WC	37	37	50	36	36	36	36	36	36	36	36	37	35	35	35	35	35	35	35	35	35	35	35	35	35	35	
11. Control Room		Units	Low	Norm	Max																								
12. Room Temperature		deg F	72	72	85	66	70	70	70	71	72	72	72	72	70	70	70	70	70	70	70	70	70	70	68	68	66	66	
13. Combustible Gas Detector Monitor		% LEL	0%	0%	20%	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
14. WECC Log		Operational?																											
15. Operation of ESS on at 6.34M		Yes (Y)			No (N)	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	
16. Operation of AVR Voltage Mode @ 13.6 kV		Yes (Y)			No (N)	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	
17. Electronic Control System		Units	Low	Norm	Max																								
18. 2000 gal Oil Water Tank Level	LI-031	%			70%	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	
19. 10 gal gas 70 Drain Tank (Air Diagram page)	LI-030	%			70%	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
20. Record on hand 510 trip over 4500 rpm NL Compressor (on line trip)	AB000	psig	35	20																									
21. Acknowledge Alarm Hourly		✓				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
22. Generator Current		Amps			1200	1060	1064	1075	1078	1085	1085	1094	1072	1075	1048	1034	1012	1000	989	964	974	976	978	995	1011	1022	1028	1066	1061
23. MW Output		MW			27	25.1	25.1	25.5	25.5	25.5	25.5	25.9	25.1	24.8	24.4	23.8	23.5	23.1	22.7	22.7	23.1	23.1	23.1	24.1	24.1	24.1	24.1	24.1	
24. 30% Base Load Minimum		MW				20	20.1	20.3	20.3	20.4	20.4	20.4	20.1	20.0	19.8	19.4	18.5	18.5	18.1	18.1	18.5	18.5	18.8	18.8	19.6	19.7	19.6	19.8	
25. Running Hours (unit over/under)						3536	3537	3538	3539	3540	3541	3542	3543	3544	3545	3546	3547	3548	3549	3550	3551	3552	3553	3554	3555	3556	3557	3558	
26. Ambient Temperature	TI-001					45	44	41	41	39	39	39	43	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	
27. Water Oil Tank	LI-030	%			70%	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	
28. Total Fuel Flow		Mach				236	231	240	240	240	240	240	236	236	233	232	224	224	224	224	224	224	224	224	224	224	224	224	
Signature: 						MIDS																							
Date: APR. 19 - 2018						R. VILGIL DAVIS J. WILKINSON MIDS																							

Date: APR-19-2018

Signature: [Signature]

miss

R. VIGIL

DAVIS

SWANSON

MIDS

0.186 981 18.56

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor				Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																															
Combustible Gas Detector	AAH-303	%	0%	20%																											
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIQHT	BLINK	ANY	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B
Liquid Level Coalescing	LT-7721	LIQID	EMPTY	ANY	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	1/8	
Crackcase Bulb eye	LC-1574	LEVEL	1/4	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	
Oil Day Tank Level	LT-1562	GAL	10	FULL	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	4/8	
Lubricator Bulb eye	LT-7416	LEVEL	1/2	FULL	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	
1st Stage Scrubber Liquid Level	LT-7416	LIQID	EMPTY	ANY	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	
2nd Stage Scrubber Liquid Level	LT-7466	LIQID	EMPTY	ANY	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIQHT	BLINK	ANY	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	
1 st Stage Inlet Press.	PI-2100	psig	88	140	81	81	82	82	82	82	82	82	82	82	81	81	81	81	81	81	81	81	81	81	81	81	81	81	81	81	
Stage Disch. Press	PI-2101	psig	238	285	250	250	250	250	250	250	250	250	250	250	250	251	251	251	251	251	251	251	251	251	251	251	251	251	251	251	
2 nd Stage Inlet Press	PI-2200	psig	267	285	246	246	246	247	246	246	246	246	246	246	246	247	247	247	247	247	247	247	247	247	247	247	247	247	247	247	
2 nd Stage Disch. Press	PI-2201	psig	575	600	578	578	578	578	578	578	578	578	578	578	578	578	579	579	579	579	579	579	579	579	579	579	579	579	579	579	
Final Discharge Pressure	PI-2108	psig	575	600	574	574	574	574	574	574	574	574	574	574	574	574	575	575	575	575	575	575	575	575	575	575	575	575	575	575	
Lube Oil Pressure	PI-1572	psig	40	60	58	58	58	58	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	57	
Lube Oil Temp	TE-1584	deg	150	170	148	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	
Final Discharge Temp	TE-2120	deg	110	150	85	81	79	80	77	77	78	78	78	78	78	85	88	91	94	98	98	102	99	99	97	92	92	91	91	91	
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg	226	297	267	266	266	266	265	265	265	265	265	265	265	266	266	266	266	266	266	266	266	266	266	266	266	266	266	266	
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg	258	283	244	244	246	246	246	246	246	246	246	246	246	246	247	247	247	247	247	247	247	247	247	247	247	247	247	247	
1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg	226	297	244	244	246	246	246	246	246	246	246	246	246	246	247	247	247	247	247	247	247	247	247	247	247	247	247	247	
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg	258	283	245	244	244	244	244	244	244	244	244	244	244	244	244	244	244	244	244	244	244	244	244	244	244	244	244	244	
Motor Frame Vibration	VT-1015	IPS		0.15	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	
Compressor Frame Vibration	VT-1512	IPS		0.35	0.05	0.05	0.05	0.04	0.04	0.04	0.04	0.04	0.05	0.05	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	
Take Once per Shift / at Full Load		psig		Max psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																										
Natural Gas Comp. Discharge Press.					575																										
Double Block and Bleed Pressure	AG3FGDT				8	570																									
Fuel Gas Supply Pressure	AG3FTG5T				20	558																									

DATE	APR 19 2018
SIGNATURE	C. Pacheco
Mid Shift	
Days Shift	
Notes	R. VILLO DAYS
	Williams M105718898



721624

APRIL 20 2018

U.S. GOVERNMENT
JANUARY 2018

GGTG HOURLY READING LOG

MST (M07) (Circle one)
Time Gas Introduced (Turbine Rolling):
Time of Turbine Online (Bkr Closed):Time Turbine Offline (Bkr Open):
Time No Gas Flow:

Notes:

Instrument / Air Compressor	ID	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
1. Blowerdown Dry Receiver Tank Hourly	81V-013	V				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
2. Blowerdown Wet Receiver Tank Hourly	81V-007	V				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
3. Wet Receiver Air Pressure	81-003	PSIG	90	105	120	108	105	110	111	108	118	107	105	105	109	105	110	104	108	105	103	108	110	108	111	110	106	108	✓	
4. Instrument Temperature	81-001	deg C	20	50	90	18	18	18	18	17	17	18	15	19	19	19	19	19	19	19	19	19	19	19	19	19	18	18	✓	
5. Fan Fan Cooler		Units	Low	Norm	Max																								✓	
6. Coolant Pressure	81-250	PSIG	25			19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	✓	
7. Coolant PLC Temperature	81-002	deg F	100	110	120	99	100	101	102	100	100	105	111	111	110	106	106	109	111	110	107	110	105	108	106	100	99	101	99	
8. Sight glass Level Expansion Tank	81-001	LEVEL	1/3	2/3	FULL	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	✓	
9. Coolant Return Differential from GG	81-001	in WC	60	80	80	55	55	55	55	55	55	59	59	60	63	63	65	65	65	65	65	64	63	65	65	65	65	65	✓	
10. Coolant Return Differential from	81-002	in WC	37	50	50	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	34	35	35	35	35	35	35	✓	
11. Control Room		Units	Low	Norm	Max																								✓	
12. Room Temperature		deg F	72	85	85	70	68	68	70	70	70	70	70	70	70	70	70	70	70	70	76	70	70	70	70	71	71	71	✓	
13. Combustible Gas Detector Monitor		% LEL	0%	0%	20%	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	✓	
14. WCC Log		Operation?				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
15. Operation of P55 on at 6.3MW		Yes (Y)				YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	
16. Operation of VAV Voltage Mode @ 13.5 KV		Yes (Y)				YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	
17. Fabricated Control System		Units	Low	Norm	Max																								✓	
(18-20 found on Air Diagram page)																														
18. 2000 gal Oil Water Tank Level	81-231	%			70%	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	
19. 10 gal gas TIC Drain Tank (Air Diagram page)	81-230	%			70%	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
20. Record on hard S/D trip over 4500 rpm NL Compressor (on line trip)	81-001	PSIG	35	20																									0	
21. Acknowledge Alarms Hourly		Y				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
(22-24 found on Power Management page)																														
22. Generator Current		Amps			1200	1044	1048	1050	1052	1054	1053	1079	1071	1074	1059	1055	1039	1045	1022	1038	1021	1023	1034	1044	1068	1071	1081	1088	1072	
23. New Output		MW			27	24.8	24.8	24.8	24.8	24.8	24.8	25.5	25.1	25.2	24.8	24.4	24.4	24.4	24.4	24.4	24.4	24.4	24.4	24.4	24.4	24.4	24.4	24.4	24.4	
24. 80% Base Load Minimum		MW				19.9	19.9	19.9	19.9	19.9	19.9	20.4	20.4	20.4	20.4	20.4	20.4	20.4	20.4	20.4	20.4	20.4	20.4	20.4	20.4	20.4	20.4	20.4	20.4	
25. Running Hours (unit overview)						3561	3562	3563	3564	3565	3566	3567	3568	3569	3570	3571	3572	3573	3574	3575	3576	3577	3578	3579	3580	3581	3582	3583	3584	
26. Ambient Temperature	81-001					48	48	46	46	64	74	39	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	
(27-28 found on Gas Fuel System page)																														
27. Waste Oil Tank	81-230	%			70%	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	
28. Total Fuel Flow		MMBtu/h				233	234	233	234	235	234	239	238	237	235	235	232	231	228	228	228	229	230	232	238	236	240	242	239	
Date: APRIL 20 2019																														
Signature:																														

Date: APRIL 20 2018

Signature:

APRIL 20 2018

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
1	Combustible Gas Detector	AAH-303	%	0%	20%																								
2	Packing Lubr Oil Flow Indicator Left Side	FSL-1501B	LIGHT	BLINK		B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	
3	Liquid Level Coalescing	LI-7721	LIQID	EMPTY	ANY	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	
4	Comficese Bulls eye	IC-1574	LEVEL	1/4	1/2	Y ₂	Y ₂	Y ₂	Y ₂	Y ₂	Y ₂	Y ₂	Y ₂	Y ₂	Y ₂	Y ₂	Y ₂	Y ₂	Y ₂	Y ₂	Y ₂	Y ₂	Y ₂	Y ₂	Y ₂	Y ₂	Y ₂		
5	Oil Day Tank level	LI-1562	GAL	10	FULL	47	47	47	47	47	47	47	47	47	47	47	47	47	47	47	47	47	47	47	47	47	47		
6	Lubricator Bulls eye		LEVEL	1/2	FULL	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F	F		
7	1st Stage Scrubber Liquid Level	LI-7416	LIQID	EMPTY	ANY	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E		
8	2nd Stage Scrubber Liquid Level	LI-7466	LIQID	EMPTY	ANY	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E		
9	Packing Lubr Oil Flow Indicator Right Side	FSL-1501A	LIGHT	BLINK		B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B	B		
10	1 st Stage Inlet Press.	PI-2100	PSIG		88	140	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82		
11	2 nd Stage Inlet Press	PI-2101	PSIG		238	285	251	253	252	252	252	250	251	248	250	252	251	250	250	249	249	250	250	250	250	250	250		
12	2 nd Stage Disch. Press	PI-2200	PSIG		267	285	248	248	248	248	248	248	248	248	248	248	248	248	248	248	248	248	248	248	248	248	248		
13	2 nd Stage Disch. Press	PI-2101	PSIG		600	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575		
14	Final Discharge Pressure	PI-2108	PSIG		575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575		
15	Lube Oil Pressure	PI-1572	PSIG	40	60	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574		
16	Lube Oil Temp	TE-1564	deg	150	170	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167		
17	Final Discharge Temp	TE-2120	deg	110	150	87	87	86	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85		
18	1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg	226	297	205	208	208	208	208	207	204	205	206	207	205	206	207	205	206	207	205	206	207	205	206	207		
19	1 st Stage Cylinder Disch. Temperature A	TE-2062 A	deg	258	283	216	216	216	216	215	215	209	210	210	212	210	210	212	210	210	212	210	210	212	210	210	212		
20	1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg	226	297	205	205	205	205	205	205	204	204	204	204	204	204	204	204	204	204	204	204	204	204	204	204		
21	2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg	258	283	217	217	216	216	216	215	209	210	210	212	210	210	212	210	210	212	210	210	212	210	210	212		
22	Motor Frame Vibration	VT-1015	IPS		0.15	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03			
23	Compressor Frame Vibration	VT-1512	IPS		0.35	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06		
24	Take Once per Shift / at Full Load		PSIG																										
25	Natural Gas Comp. Discharge Press.																												
26	Double Block and Bleed Pressure	A63FGDT	49-48=psid		8																								
27	Fuel Gas Supply Pressure	A63FTG5T	50-49=psid		20																								

DATE APRIL 20 2018

SIGNATURE

David Shift *James*
Days Shift

Notes


 APRIL 21 2018
 LANL-03342
 January 4 2018

CGTG HOURLY READING LOG

 Date: **APRIL 21 2018**
 MST (UTC-7) (circle one)
 Time Gas Introduced (Turbine Rolling):
 Time of Turbine Offline (Btr Closed):

 Time Turbine Offline (Btr Open):
 Time No Gas Flow:

Notes:

	ID	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24			
1. Instrument Air Compressor	897-013	V				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
2. Blowdown Dry Receiver Tank Hourly	897-007	V				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
3. Blowdown Wet Receiver Tank Hourly	897-007	V				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
4. Wet Receiver Air Pressure	897-002	psig	90	105	120	106	102	108	104	106	102	108	109	108	105	110	105	110	105	111	110	105	110	108	104	110	102	104	110			
5. Instrument Temperature	897-001	deg C	20	50	50	18	18	18	18	18	18	18	18	17	18	19	19	19	19	20	20	20	20	20	20	20	20	20	20			
6. Dry Fan Cooler	897-001	Units	Low	Norm	Max																											
7. Coolant Pressure	897-002	psig	25			19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19				
8. Coolant R/C Temperature	897-002	deg F	100	110	120	101	100	111	102	100	99	110	99	110	109	100	104	104	109	103	106	103	110	102	106	102	100	101	104			
9. Light Gas Level Expansion Tank	897-001	1/2	2/2			1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2			
10. Coolant Return Differential from CG	897-001	in WC	60	80	80	65	65	65	65	65	65	61	62	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65			
11. Coolant Return Differential from	897-002	in WC	37	50	50	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35			
12. Control Room		Units	Low	Norm	Max																											
13. Room Temperature		deg F	72	85	85	70	70	70	69	69	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70			
14. Combustible Gas Detector Monitor		% LEL	0%	0%	20%	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
15. WCC Log																																
16. Operation of P/S on at 5.3MW		Yes (Y)				Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes			
17. Operation of AMV Voltage Mode @ 3.6 KV		Yes (Y)				Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes			
18. Inertic Control System		Units	Low	Norm	Max																											
19. 2000 psi Oil Water Tank Level	U-231	%				34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34			
20. 10 gal gas TO Crank Tank (see Diagram page)	U-230	%				0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
21. Record on Hard S/D trip over 4500 rpm HL	AS-060	psig	35	20																												
22. Compressor (on line trip)	5T-011																															
23. Acknowledge Alarms Hourly		V				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓			
24. 3.6 found on Power Management panel																																
25. Generator Current		Amps				1089	1089	1089	1089	1089	1089	1089	1089	1089	1089	1089	1089	1089	1089	1089	1089	1089	1089	1089	1089	1089	1089	1089	1089			
26. MVA Output		MW				25.4	25.6	25.8	25.6	25.6	25.6	25.6	25.6	25.6	25.6	25.6	25.6	25.6	25.6	25.6	25.6	25.6	25.6	25.6	25.6	25.6	25.6	25.6	25.6			
27. 80% Base Load Minimum		MW				20.6	20.6	20.7	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1	20.1			
28. Flaming Hours (unit overvoltage)						5084	5084	5084	5084	5084	5084	5084	5084	5084	5084	5084	5084	5084	5084	5084	5084	5084	5084	5084	5084	5084	5084	5084	5084			
29. Ambient Temperature	T1 Inlet					37	37	37	37	38	38	34.9	34.7	34.1	34.1	34.1	34.1	34.1	34.1	34.1	34.1	34.1	34.1	34.1	34.1	34.1	34.1	34.1	34.1			
30. 3.6 found on Gas Fuel System panel																																
31. Waste Oil Tank	U-230	%				58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58			
32. Total Fuel Flow		Mscfh				240	240	241	240	238	240	242	241	235	232	230	239	230	225	224	225	225	224	225	226	225	225	223	232			
Date: APRIL 21 2018			Signature: <i>John</i>																													

 Date: **APRIL 21 2018**
 Signature: *John*

GGTG TURBINE

UTILITIES AND INFRASTRUCTURE

APRIL 21 2018

Natural Gas Compressor	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1st Stage Inlet Press.	psig																											
2nd Stage Inlet Press.	psig																											
1st Stage Disch. Press.	psig																											
2nd Stage Disch. Press.	psig																											
Final Discharge Pressure	psig																											
Lube Oil Pressure	psig																											
Lube Oil Temp	deg																											
1st Stage Cylinder Disch. Temperature A	deg																											
2nd Stage Cylinder Disch. Temperature A	deg																											
1st Stage Cylinder Disch. Temperature B	deg																											
2nd Stage Cylinder Disch. Temperature B	deg																											
Motor Frame Vibration	IPS																											
Compressor Frame Vibration	IPS																											
Take Once per Shift / at Full Load	psig																											
Natural Gas Comp. Discharge Press.																												
Double Block and Bled Pressure																												
Fuel Gas Supply Pressure																												

DATE APRIL 21 2018

SIGNATURE

David Shift *John*

Notes

When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer



APRIL 22 2018

LA-005-033-02
January 2018

GTG HOURLY READING LOG

Date: **APRIL 22 2018**

MST (circle one)

Time Gas Introduced (Turbine Fueling):
Time of Turbine Online (After Cooldown):1458
1452Time Turbine Offline (After Open):
Time No Gas Flow:1404
1405Notes: **1404 GTG TRIP
Turbine DES-ARCH TO BE BACK ON LINE BY 1700
19 MUNIT @ 1800 22 M UNIT.**

Instrument	Unit	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1 Blowdown Dry Recycle Tank Hourly	B-T-013	✓			✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
2 Blowdown Wet Recycle Tank Hourly	B-T-007	✓			✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
3 Wet Recycle Air Pressure	P-002	psig	90	105	106	110	100	100	108	106	100	105	100	105	103	105	100	102	106	106	111	108	106	110	106	102	110	
4 Instrument Temperature	T-001	deg C	20	50	18	18	18	18	18	18	19	19	19	19	19	19	21				22	22	22	20	20	20	19	
5 Hot Fan Cooler		Units	Low	Norm	Max																							
6 Coolant Pressure	P-250	psig	25			19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	
7 Coolant P.T. Temperature	T-002	deg F	100	110	120	100	101	102	104	102	100	105	104	103	104	105	110	111			110	102	111	110	105	103	101	
8 Sight Glass Level Expansion Tank	L-001	LEVEL	1/3	2/3	FULL	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	
9 Coolant Return Differential from EG	P-001	in WC	60	80	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65		
10 Coolant Return Differential from	P-002	in WC	37	50	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35		
11 Control Room		Units	Low	Norm	Max																							
12 Room Temperature		deg F	72	72	85	71	71	71	70	70	70	70	70	70	70	70	70	70	70	70	70	70	69	69	68	66	66	
13 Combustible Gas Detector Monitor		% LEL	0%	0%	20%	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
14 VEC Log		Operation?																										
15 Operation of PSS/ on 6.3MW		Yes (Y)			Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
16 Operation of AVR Voltage Mode @ 13.6 KV		Yes (Y)			Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
17 Electronic Control System		Units	Low	Norm	Max																							
18-20 found on Air Diagram page)																												
18 2000 gal Oil Water Tank Level	L-231	%			70%	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	
19 10 gal Gas TG Drain Tank (Air Diagram page)	L-230	%			70%	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
20 Record on hand S/D trip over 4500 rpm NL compressor (on line trip)	45000 57-01	psig	35	20																								
21 Acknowledge Alarms Hourly		✓			✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
22-24 found on Power Management page)																												
22 Generator Current		Amps			1200	1073	1077	1070	1098	1103	1102	1064	1035	1031	1017	1000	974	970			802	814	978	976	1014	1017	1016	
23 MW Output		MW			27	26.1	26.1	25.3	25.6	25.8	25.1	24.1	24.1	23.8	23.5	22.7	22.7			19.0	19.0	23.1	23.1	24.1	24.1	24.1		
24 80% Base Load Minimum		MW				28.2	28.2	28.2	28.2	28.2	28.2	28.2	28.2	28.2	28.2	28.2	28.2	28.2			18.4	18.4	19.0	19.0	19.5	19.5		
25 Running Hours (unit overview)						3408	3409	3410	3411	3412	3413	3414	3415	3416	3417	3418	3419	3420			3421	3422	3423	3424	3425	3426		
26 Ambient Temperature	T1 Inlet				44	43	43	42	40	38	45	50	51.6	55.0	59	61	63				43.2	61	59	59	58	52	52	
27-28 found on Gas Fuel System page)																												
27 Waste Oil Tank	L-120	%			70%	51	51	51	57	57	57	58	56	56	56	56	56	56	56	56	58	58	59	59	59	59	59	
28 Total Fuel Flow	Me/Fn					238	237	238	239	239	239	235	230	229	221	224	220	219			192	190	224	224	220	220	220	

Date: APRIL 22 2018Signature: [Signature]

Date: **APRIL 22 2018**Signature: *[Signature]*LA-005-033-02
January 2018

APRIL 22 2018

GGTG TURBINE 73511C

UTILITIES AND INFRASTRUCTURE

GAS COMPRESSOR START TIME		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Combustible Gas Detector	AAH-303	%		0%	20%																								
Packing Lube Oil Flow Indicator Left Side	FSJ-1501B	LIQHT		BLINK	ANY																								
Liquid Level Coalescing	LI-7721	LIQHT		EMPTY	ANY																								
Crankcase Bulb eye	LC-1574	LEVEL		1/2	FULL																								
Oil Day Tank Level	LI-1562	GAL		10	FULL																								
Lubricator Bulb eye	LI-7416	LEVEL		1/2	FULL																								
1st Stage Scrubber Liquid Level	LI-7466	LIQHT		EMPTY	ANY																								
2nd Stage Scrubber Liquid Level	LI-7466	LIQHT		EMPTY	ANY																								
Packing Lube Oil Flow Indicator Right Side	FSJ-1501A	LIQHT		BLINK	ANY																								
1st Stage Inlet Press.	PI-2100	psig		88	140																								
Stage Disch. Press	PI-2101	psig		238	285																								
2nd Stage Inlet Press	PI-2200	psig		267	285																								
2nd Stage Disch. Press	PI-2201	psig		575	600																								
Final Discharge Pressure	PI-2108	psig		575	600																								
Lube Oil Pressure	PI-1572	psig		40	60																								
Lube Oil Temp	TE-1584	deg		150	170																								
Final Discharge Temp	TE-2120	deg		110	150																								
1st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297																								
2nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283																								
1st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297																								
2nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283																								
Motor Frame Vibration	VT-1015	IPS			0.15																								
Compressor Frame Vibration	VT-1512	IPS			0.35																								
Take Once Per Shift / at Full Load		psig			Max psid																								
Natural Gas Comp. Discharge Press.	A63FGDT	49-48=psid			8																								
Double Block and Bleed Pressure																													
Fuel Gas Supply Pressure	A63FGST	50-49=psid			20																								

When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer

DATE APRIL 22 2018

735946

SIGNATURE

Mid Shift *[Signature]*

Days Shift

Notes @ 1404 GGTG TRIPPED OF. IN FORM BLANKIE. ALARM ARE IN ALARM BACK
INFORM DISPATCH TO BE BACK ON LINE BY 1700 WITH 19 MWATT@1800-22 MWATT@

U14-06-0334R2
JUNE 7 2014

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

APRIL 23 2018

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
Combustible Gas Detector	AAH-303	%		0%	20%																								
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIQUID	BLINK																										
Liquid Level Coalescing	LI-7721	LIQUID	EMPTY																										
Crackcase Bulk eye	LC-1574	LEVEL	1/4																										
Oil Day Tank Level	LI-1562	GAL	10																										
Lubricator Bulk eye	LI-7416	LEVEL	1/2																										
1st Stage Scrubber Liquid Level	LI-7466	LIQUID	EMPTY																										
2nd Stage Scrubber Liquid Level	LI-7466	LIQUID	EMPTY																										
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIQUID	EMPTY																										
1 st Stage Inlet Press.	PI-2100	PSIG	BLINK																										
Stage Disch. Press	PI-2101	PSIG	88	140	82	82	82	82	83	83	82	82	82	82	82	82	81	82	82	82	82	82	82	82	82	81	82	81	81
2nd Stage Inlet Press	PI-2200	PSIG	268	285	250	251	250	251	250	251	251	251	251	251	251	251	252	252	252	252	252	252	252	252	252	252	252	252	252
2nd Stage Disch. Press	PI-2201	PSIG	257	285	246	248	248	248	248	248	248	248	248	248	248	248	248	248	248	248	248	248	248	248	248	248	248	248	
Final Discharge Pressure	PI-2108	PSIG	575	600	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	
Lube Oil Pressure	PI-1572	PSIG	575	600	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	
Lube Oil Temp	TE-1584	deg	40	60	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	
Final Discharge Temp	TE-2120	deg	150	170	168	168	167	168	168	168	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg	110	150	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88	
2 nd Stage Cylinder Disch. Temperature A	TE-2052 A	deg	226	297	241	240	240	241	241	241	240	240	241	241	241	240	240	240	240	240	240	240	240	240	240	240	240	240	
1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg	238	283	218	218	217	216	216	215	217	217	217	217	217	217	217	217	217	217	217	217	217	217	217	217	217	217	
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg	226	297	249	249	249	249	249	249	249	249	249	249	249	249	249	249	249	249	249	249	249	249	249	249	249	249	
Motor Frame Vibration	VT-1015	IPS	238	283	217	210	210	209	208	206	214	217	217	217	217	217	217	217	217	217	217	217	217	217	217	217	217	217	
Compressor Frame Vibration	VT-1512	IPS	0.15	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3		
Take Once Per Shift / at Full Load		PSI	0.35	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	
Natural Gas Comp. Discharge Press.		Max psid																											
Double Block and Bleed Pressure	A63FGDT	49-48=psid																											
Fuel Gas Supply Pressure	A63FTGST	50-49=psid																											

DATE APRIL 23 2018

SIGNATURE

Mid Shift *AM*

Days Shift

Notes

742149 - 55666



Date: **APR 24 2018**

MST (Add/delete one)

Time Gas Introduced (Turbine Offline):
Time Turbine Offline (Bike Closed):

CGTG HOURLY READING LOG

Time Turbine Offline (Bike Open):
Time No Gas Flow:

Notes:

Instrument Air Compressor	LD	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Blowdown Dry Receiver Tank Hourly	BT-003	V																											
2. Blowdown Wet Receiver Tank Hourly	BT-007	V																											
3. Wet Receiver Air Pressure	PT-002	psig	90	105	120	105	106	106	104	108	110	108	106																
4. Instrument Temperature	TT-001	deg C	20	50	50	21	20	20	19	19	19	17	20																
5. Fin Fan Cooler		Units	Low	Norm	Max																								
6. Coolant Pressure	PT-250	psig	25			19	19	19	19	19	19	19	19																
7. Coolant P/T Temperature	TT-002	deg F	100	110	120	99	103	105	100	107	109	108	102																
8. Slight Plant Level Expansion Tank	LT-001	LEVEL	1/3	2/3	FULL	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2																
9. Coolant Return Differential from G6	PT-001	in WC	60	80	80	63	63	63	63	63	63	62	62																
10. Coolant Return Differential from	PT-002	in WC	57	90	90	36	36	36	36	36	36	35	35																
11. Control Room		Units	Low	Norm	Max																								
12. Room Temperature		deg F	72	85	85	65	68	66	69	65	69	70	70																
13. Combustible Gas Detector Monitor		% LEL	0%	0%	20%	0	0	0	0	0	0	0	0																
14. WEGC Log		Operational?																											
15. Operation of PSS on at 6.3MW		Yes (Y)			No (N)	YES	YES	YES	YES	YES	YES	YES	YES																
16. Operation of AVR Voltage Mode at 13.6 kV		Yes (Y)			No (N)	YES	YES	YES	YES	YES	YES	YES	YES																
17. Electronic Control System		Units	Low	Norm	Max																								
18. 2000 gal Oil Water Tank Level	LT-231	%			70%	34	34	34	34	34	34	34	34																
19. 10 gal gas to drain tank (see diagram page)	LT-230	%			70%	0	0	0	0	0	0	0	0																
20. Record on hand S/D trip over 4500 rpm NL Compressor (on line trip)	AS-000 ST-01	PSig	35	20																									
21. Adiabatic Ambient Hourly		V																											
22. Adiabatic Ambient Hourly																													
23. Generator Current		Amps			1200	982	992	982	997	1001	1018	997	1012																
24. 1000 Base Load Minimum	RMV	RMV			27	28.1	23.5	22.1	23.4	23.8	24.1	23.5	23.8																
25. Running Hours (unit overview)	RMV	RMV				19	19.1	19	19.3	19.2	19.5	19.2	19.3																
26. Ambient Temperature	TT Inlet					58	56	57	55	55	55	54	54																
27. Wet Oil Tank		%			70%	61	61	61	61	61	61	60	60																
28. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
29. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
30. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
31. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
32. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
33. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
34. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
35. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
36. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
37. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
38. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
39. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
40. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
41. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
42. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
43. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
44. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
45. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
46. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
47. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
48. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
49. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
50. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
51. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
52. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
53. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
54. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
55. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
56. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
57. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
58. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
59. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
60. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
61. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
62. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
63. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
64. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
65. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
66. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
67. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
68. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
69. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
70. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
71. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
72. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
73. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
74. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
75. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
76. Total Fuel Flow		Mcf/h				223	235	22	225	230	230	226	224																
77. Total Fuel Flow		Mcf/h				223	235																						

Date: **4-24-18**
Signature: *[Signature]*
0900 hrs security *[Signature]* leaving cooling water to I/O room.

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
Combustible Gas Detector	AAH-303	%		0%	20%																								
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	U/GHT	BLINK																										
Liquid Level Coalescing	LI-7721	LIQID	EMPTY	ANY																									
Crankcase Bulb eye	LC-1574	LEVEL	1/4	1/2	FULL																								
Oil Day Tank Level	LI-1562	GAL	10		FULL																								
Lubricator Bulb eye		LEVEL	1/2	FULL																									
1st Stage Scrubber Liquid Level	LI-7416	LIQID	EMPTY	ANY																									
2nd Stage Scrubber Liquid Level	LI-7466	LIQID	EMPTY	ANY																									
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	U/GHT	BLINK																										
1 st Stage Inlet Press.	PI-2100	psig	88	140																									
Stage Disch. Press.	PI-2101	psig	238	285																									
2 nd Stage Inlet Press	PI-2200	psig	267	285																									
2 nd Stage Disch. Press	PI-2201	psig	575	600																									
Final Discharge Pressure	PI-2108	psig	575	600																									
Lube Oil Pressure	PI-1572	psig	40	60																									
Lube Oil Temp	TE-1584	deg	150	170																									
Final Discharge Temp	TE-2120	deg	110	150																									
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg	226	297																									
2 nd Stage Cylinder Disch. Temperature A	TE-2052 A	deg	258	283																									
1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg	226	297																									
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg	258	283																									
Motor Frame Vibration	VT-1015	IPS		0.15																									
Compressor Frame Vibration	VT-1512	IPS		0.35																									
Take Once per Shift / at Full Load		psig		Max psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																								
Natural Gas Comp. Discharge Press.	AG3RGDT	49-48=psid		8																									
Double Block and Bleed Pressure	AG3FTGST	50-49=psid		20																									
Fuel Gas Supply Pressure																													

DATE 4-24-2018

SIGNATURE

Mid Shift

Days Shift

Notes

0900 Day security alarm, cooling water at 170 fpm.

Date: **4.25-18**
 M57 / M07 (check one)
 Time Gas Introduced (Turbine Rolling):
 Time of Turbine Online (After Closed):

Time Turbine Offline (After Open):
 Time No Gas Flow:

Notes:

CGTG HOURLY READING LOG

Instrument / Parameter	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Blower Dry Receiver Tank Hourly	BT-413	✓			✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
2. Blower Wet Receiver Tank Hourly	BT-407	✓			✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
3. Wet Receiver Air Pressure	PA-001	psig	90	105	120	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
4. Instrument Temperature	TH-001	deg C	20	50	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
5. Fan Run Cooler	FT-101	Units	Low	Norm	Max	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
6. Coolant Pressure	PI-101	psig	25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
7. Coolant Temperature	TI-001	deg F	100	110	120	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
8. Sight Glass Level Expansion Tank	UG-001	LEVEL	1/3	2/3	FULL	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
9. Coolant Return Differential from SG	PA-001	In WC	60	80	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
10. Coolant Return Differential from	PI-001	In WC	37	50	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
11. Control Room	Units	Low	Norm	Max	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
12. Room Temperature	deg F	72	85	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
13. Combustible Gas Detector Monitor	%LEL	0%	20%	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
14. Whetlogs	Operations?	Yes (Y)	No (N)	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
15. Operation of AVR Voltage Mode @ 13.6 kV	Yes (Y)	No (N)	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
16. Electronic Control System	Units	Low	Norm	Max	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
17. 100% Oil Water Tank Level	Units	Low	Norm	Max	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
18. 100% Oil Water Tank Level	Units	Low	Norm	Max	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
19. 100% Oil Water Tank Level	Units	Low	Norm	Max	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
20. Recirculation of SG Trip over 4500 ppm NL	psig	35	20	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
21. Admonitory Alarms Hourly	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
22. Generator Current	Amps	1200	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
23. MW Output	MW	27	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
24. BOP Base Load Minimum	MW	27	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
25. Running Hours (unit over/under)	hrs	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
26. Ambient Temperature	deg C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
27. 100% Oil Water Tank Level	Units	Low	Norm	Max	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
28. Total Fuel Flow	%	70%	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓

Date: **APR 25 2018** Signature: *[Signature]*

UH-0043342
 January 4 2018

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
Combustible Gas Detector	AAH-303	%		0%	20%																								
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIQHT		BUNK	ANY	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	
Liquid Level Coalescing	LI-7721	LIQUD		EMPTY	ANY	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E		
Crankcase Bulb eye	LC-1574	LEVEL	1/4	1/2	FULL	1/4	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2		
Oil Day Tank Level	LI-1562	GAL	10	FULL	FULL	29	29	29	29	29	29	29	29	29	29	29	29	29	29	29	29	29	29	29	29	29	29		
Lubricator Bulb eye		LEVEL	1/2	FULL	FULL	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E		
1st Stage Scrubber Liquid Level	LI-7416	LIQUD		EMPTY	ANY	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E		
2nd Stage Scrubber Liquid Level	LI-7466	LIQUD		EMPTY	ANY	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E	E		
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIQHT		BUNK		R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R		
1 st Stage Inlet Press.	PI-2100	psig		88	140	82	81	81	82	82	82	81	81	81	81	81	81	81	81	81	81	81	81	81	81	81	81		
Stage Disch. Press	PI-2101	psig		238	285	250	249	249	249	250	250	249	249	249	249	249	249	249	249	249	249	249	249	249	249	249	249		
2 nd Stage Inlet Press	PI-2200	psig		267	285	246	245	245	246	246	247	245	246	246	246	247	247	247	247	247	247	247	247	247	247	247	247		
2 nd Stage Disch. Press	PI-2201	psig		575	600	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579		
Final Discharge Pressure	PI-2108	psig		575	600	575	575	575	579	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575	575		
Lube Oil Pressure	PI-1572	psig	40	60	58	58	58	57	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58		
Lube Oil Temp	TE-1584	deg		150	170	169	169	170	171	170	171	171	169	169	169	167	167	168	169	169	169	169	169	169	169	169	169		
Final Discharge Temp	TE-2120	deg		110	150	82	81	81	78	77	77	77	82	85	87	87	88	88	88	88	88	88	88	88	88	88	88		
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297	269	268	268	268	268	268	269	269	269	269	269	269	269	269	269	269	269	269	269	269	269	269		
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283	215	214	213	211	210	210	212	213	216	222	223	223	223	223	223	223	223	223	223	223	223	223		
1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297	269	268	268	265	266	266	266	266	266	266	267	267	267	267	267	267	267	267	267	267	267	267		
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283	215	213	213	211	210	210	212	213	216	229	229	229	229	229	229	229	229	229	229	229	229	229		
Motor Frame Vibration	VT-1015	IPS		0.15	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04			
Compressor Frame Vibration	VT-1512	IPS		0.35	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06		
Take Once per Shift / at Full Load		psig		Max	psid																								
Natural Gas Comp Discharge Press.						575																							
Double Block and Bled Pressure	A63FGDT	49-48=psid				8	570																						
Fuel Gas Supply Pressure	A63FTGST	50-49=psid				20	157																						

DATE 4-25-2018

SIGNATURE C. Pacheco

Mid Shift

Days Shift

Notes

Date: **4-26-2018**
 MST (circle one)
 Time Gas Introduced (Turbine Rolling):
 Time of Turbine Online (After Closed):

Time Turbine Offline (After Open):
 Time No Gas Flow:

Notes:

CGTG HOURLY READING LOG

Instrument	Unit	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
1. Blowdown Dry Receiver Tank Hourly	BT-013	V																											
2. Blowdown Wet Receiver Tank Hourly	BT-007	V																											
3. Wet Receiver Air Pressure	PT-002	psig	90	105	120	110	106	108	106	102	108	112	106	114	110	108	106	108	106	110	106	109	106	105	104	108	106	104	110
4. Instrument Temperature	TT-001	deg C	30	50	50	18	18	18	18	18	18	18	18	20	20	22	22	24	24	25	25	24	24	22	21	20	19	18	
5. Oil Fan Cooler	PT-250	psig	Low	Norm	Max	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	19	
6. Coolant Pressure	TT-001	deg F	100	110	120	108	105	104	99	100	105	103	104	100	103	111	100	109	106	101	106	102	109	108	109	98	101	110	
7. Coolant P/LC Temperature	TT-002	deg F	140	150	160	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	142	
8. Sight Glass Level Expansion Tank	LEV-1	1/3	2/3	FULL	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	
9. Coolant Return Differential from GG	FT-001	in WC	60	80	80	63	63	63	63	63	62	64	64	64	63	63	63	65	65	65	65	65	63	63	63	63	63	63	
10. Coolant Return Differential from	FT-002	in WC	37	50	50	36	36	36	36	36	35	35	35	38	39	40	38	40	40	39	39	36	36	36	36	36	36	36	
11. Control Room		Units	Low	Norm	Max	67	68	71	69	66	64	70	70	70	71	71	71	72	72	72	72	72	68	69	70	66	65	66	
12. Room Temperature	deg F	72	72	85	67	68	71	69	66	64	70	70	70	70	71	71	71	72	72	72	72	72	68	69	70	66	65	66	
13. Combustible Gas Detector Monitor	% LEL	0%	0%	20%	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
14. WELC Log	Operational	Yes (Y)		No (N)	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
15. Operation of R/V Voltage Mode at 23.5 KV	Yes (Y)		No (N)	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
16. Electronic Control System	Units	Low	Norm	Max	34	34	34	34	34	34	34	34	34	34	34	34	33	33	33	33	33	33	32	33	33	33	34	34	
17. 2000 psi Oil Water Tank Level	psi	2000	2000	2000	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	
18. 2000 psi Oil Water Tank Level	psi	2000	2000	2000	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	
19. 2000 psi Oil Water Tank Level	psi	2000	2000	2000	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	1960	
20. Record on hand S/D trip over 4500 rpm ML Compressor (on line trip)	ST-01	35	20																										
21. Adverse/Alarm Hourly	Y																												
22. Generator Current	Amps			1200	1023	1032	1046	1043	1035	1044	1039	1018	969	980	962	962	943	933	933	927	930	928	949	940	1003	1016	1029	1040	1040
23. MW Output	MW			27	24.1	24.4	24.8	24.4	24.5	24.4	23.9	23.1	22.4	22.4	22.0	21.7	21.7	21.7	21.7	21.5	21.6	22.4	23.1	23.7	24.1	24.1	24.6	24.6	
24. 80% Full Load Minimum	MW				19.6	19.7	19.9	19.9	19.7	19.8	19.4	18.4	18.4	18.5	18.3	18.3	18.3	18.3	18.3	18.3	18.3	18.3	18.3	18.3	18.3	18.3	18.3	18.3	
25. Running Hours (omit overruns)	Hours				3702	3703	3704	3705	3706	3707	3708	3709	3710	3711	3712	3713	3714	3715	3716	3717	3718	3719	3720	3721	3722	3723	3724	3725	
26. Ambient Temperature	TT-001	deg C			50	50	46	46	48	46	47	53	59	60	64	65	67	69	69	70	70	70	70	65	60	56	54	52	
27. Wet Oil Tank	psi	14-150			62	62	62	62	62	62	62	61	61	60	60	60	60	60	61	61	61	61	61	61	61	61	61	61	
28. Fuel Flow	kg/hr			70%	231	232	235	234	232	234	224	224	223	219	217	215	213	213	213	212	212	212	211	226	228	230	232	234	

Date: **APR 26 2018** Signature: *[Signature]*

ULL-03-033-02
 January 4 2018

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor			Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																														
Combustible Gas Detector	AAH-303	%		0%	20%																									
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIQHT		BLINK			3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
Liquid Level Coasting	LI-7721	LIQID		EMPTY	ANY		3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
Crankcase Bulls eye	LC-1574	LEVEL	1/4	1/2	FULL		1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	
Oil Day Tank Level	LI-1562	GAL	10		FULL		2.7	2.6	2.6	2.6	2.6	2.6	2.6	2.6	2.6	2.6	2.6	2.6	2.6	2.6	2.6	2.6	2.6	2.6	2.6	2.6	2.6	2.6	2.6	
Lubricator Bulls eye		LEVEL	1/2	FULL			1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
1st Stage Scrubber Liquid Level	LI-7416	LIQID		EMPTY	ANY		3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
2nd Stage Scrubber Liquid Level	LI-7466	LIQID		EMPTY	ANY		3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIQHT		BLINK			3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
1 st Stage Inlet Press.	PI-2100	psig		88	140	82	81	81	81	81	81	81	82	81	81	81	81	81	81	81	81	81	81	81	81	81	81	81	81	81
Stage Disch. Press	PI-2101	psig		238	285	280	249	249	249	255	254	254	254	254	254	254	254	254	254	254	254	254	254	254	254	254	254	254	254	254
2nd Stage Inlet Press	PI-2200	psig		267	285	244	246	245	245	244	244	244	244	244	244	244	244	244	244	244	244	244	244	244	244	244	244	244	244	244
2 nd Stage Disch. Press	PI-2201	psig		575	600	518	579	579	574	574	578	578	574	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579	579
Final Discharge Pressure	PI-2108	psig		575	600	574	575	575	575	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574	574
Lube Oil Pressure	PI-1572	psig	40	60	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58
Lube Oil Temp	TE-1584	deg		150	170	168	169	169	169	168	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169	169
Final Discharge Temp	TE-2120	deg		110	150	88	86	86	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84	
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297	211	210	209	209	210	209	209	209	209	209	209	209	209	209	209	209	209	209	209	209	209	209	209	209	209
2 nd Stage Cylinder Disch. Temperature A	TE-2054 A	deg		228	283	229	217	216	216	218	215	215	215	215	215	215	215	215	215	215	215	215	215	215	215	215	215	215	215	215
1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297	229	228	227	227	228	227	227	227	227	227	227	227	227	227	227	227	227	227	227	227	227	227	227	227	227
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283	219	217	216	216	218	215	215	215	215	215	215	215	215	215	215	215	215	215	215	215	215	215	215	215	215
Motor Frame Vibration	VI-1015	IPS		0.15	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	
Compressor Frame Vibration	VI-1512	IPS		0.35	0.06	0.05	0.06	0.05	0.05	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	
Take Once per Shift / at Full Load		psig																												
Natural Gas Comp. Discharge Press.																														
Double Block and Bled Pressure	A63FGDT	49-48=psid					8	571																						
Fuel Gas Supply Pressure	A63FTGST	50-49=psid					20	558																						

DATE 4-26-2018

SIGNATURE

Mid Shift

Days Shift

Notes

759443-55666



Date: **APR 27, 2018**


MST (circle one)
Time Gas Introduced (Turbine Reading):
Time of Turbine Online (Bkr Closed):

Time Turbine Offline (Bkr Open):
Time No Gas Flow:

0935
0940

CGTG HOURLY READING LOG

Notes: INTERLOCKED VALVE STOP. DO TO AVE NOT REPAIRS

Instrument Air Compressor		U	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1	Blowdown Dry Receiver Tank Hourly	BT-013	V				/	/	/	/	/	/	/	/	/															
2	Blowdown Wet Receiver Tank Hourly	BT-007	V				/	/	/	/	/	/	/	/	/															
3	Wet Receiver Air Pressure	PI-002	psig	90	105	120	105	110	106	104	106	102	105	109																
4	Instrument Temperature	TT-001	deg C	20	30	50	18	18	18	17	17	17	17	19																
5	Pin Pan Cooler		Units	Low	Norm	Max																								
6	Coolant Pressure	PI-000	psig	25	35	45	19	19	19	19	19	19	19	19																
7	Coolant P/C Temperature	TT-002	deg F	100	110	120	106	104	104	105	105	102	103	105	98															
8	Sight glass level Expansion Tank	LI-001	LEVEL	1/3	2/3	FULL	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2															
9	Coolant Return Differential from GG	PI-001	in WC	60	80	100	63	63	63	63	63	63	62	63	65															
10	Coolant Return Differential from	PI-002	in WC	50	70	90	36	36	36	36	36	36	35	35	34															
11	Control Room		Units	Low	Norm	Max																								
12	Room Temperature		deg F	72	75	85	68	68	71	69	66	70	70	70	70															
13	Combustible Gas Detector Monitor		% LEL	0%	20%	20%	0	0	0	0	0	0	0	0	0															
14	WCTCC Log		Open/Close																											
15	Operation of PSS on at 6.34MW		Yes (Y)			No (N)	YES	YES	YES	YES	YES	YES	YES	YES	YES															
16	Operation of AVR Voltage Mode @ 13.6 KV		Yes (Y)			No (N)	YES	YES	YES	YES	YES	YES	YES	YES	YES															
17	Electronic Control System		Units	Low	Norm	Max																								
18	2000 gal Oil Water Tank Level	LI-001	%			70%	34	34	34	34	34	34	34	34	34															
19	10 gal gas TO Drain Tank (AV Diagram page)	LI-002	%			70%	0	0	0	0	0	0	0	0	0															
20	Record on limit S/D trip over 4500 rpm RL Compressor (on line trip)	AS5000	psig	35	20																									
21	Acknowledge Alarms Hourly	51-01	Y				/	/	/	/	/	/	/	/	/															
(22-24 found on Power Management page)																														
22	Generator Current		Amps			1200	1056	1060	1074	1074	1086	1047	1090	1069	1103															
23	Max Output		MW			27	24.8	25.1	25.1	25.5	25.5	25.5	25.5	25.1	24.5															
24	80% Base Load Minimum		MW				19.9	10	20.1	20.3	20.3	20.4	20.3	20.6	19.7															
25	Running Hours (unit over/under)						3726	3727	3728	3729	3730	3731	3732	3733	3734															
26	Ambient Temperature	TT-001					47	45	43	42	40	39	41	45.9	49.1															
(27-28 found on Gas Fuel System page)																														
27	Waste Oil Tank	LI-001	%			70%	62	62	63	63	63	63	63	63	63															
28	Total Fuel Flow		Mass/h				236	237	240	240	241	243	241	241	239															
Date: 4-27-18			Signature: 			mios																								

Date: **4-27-18**

Signature: *[Signature]*

MWS

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
Combustible Gas Detector	AAH-303	%	0%	20%																									
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIGHT	BLINK			B	B	C	B	B	B	B	B	B	B														
Liquid Level Cooling	LI-7721	LIQUID	EMPTY	ANY	E	E	E	E	E	E	E	E	E	E	E														
Crankcase Bulb eye	LC-1574	LEVEL	1/4	1/2	FULL	1/4	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2	1/2														
Oil Day Tank Level	LI-1562	GAL	10	FULL	FULL	24	24	23	23	23	23	23	22	22															
Lubricator Bulb eye		LEVEL	1/2	FULL	FULL	F	F	F	F	F	F	F	F	F															
1st Stage Scrubber Liquid Level	LI-7416	LIQUID	EMPTY	ANY	E	E	E	E	E	E	E	E	E	E															
2nd Stage Scrubber Liquid Level	LI-7466	LIQUID	EMPTY	ANY	E	E	E	E	E	E	E	E	E	E															
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIGHT	BLINK			B	B	B	B	B	B	B	B	B															
1 st Stage Inlet Press.	PI-2100	psig	88	140	81	82	82	82	81	82	81	81	80																
Stage Disch. Press	PI-2101	psig	238	285	250	249	248	248	249	249	249	249	250																
2 nd Stage Inlet Press	PI-2200	psig	267	285	246	246	245	244	245	245	245	245	246	246															
2 nd Stage Disch. Press	PI-2201	psig	575	600	579	579	579	579	579	579	579	579	579	579															
Final Discharge Pressure	PI-2108	psig	575	600	575	575	575	575	575	575	575	575	575	575															
Lube Oil Pressure	PI-1572	psig	40	60	58	58	58	58	58	57	58	58	58																
Lube Oil Temp	TE-1584	deg	150	170	168	169	170	170	170	170	170	170	170	170															
Final Discharge Temp	TE-2120	deg	110	150	86	84	83	81	80	79	79	85	89																
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg	226	297	210	209	208	208	208	207	207	209	209																
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg	258	283	216	215	213	212	212	211	211	214	219																
1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg	226	297	210	209	208	208	208	207	207	209	209																
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg	258	283	216	215	213	212	212	211	211	214	219																
Motor Frame Vibration	VI-1015	IPS	0.15	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04																
Compressor Frame Vibration	VI-1512	IPS	0.35	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05																
Take Once per Shift / at Full Load		psig		Max psid																									
Natural Gas Comp. Discharge Press.																													
Double Block and Bleed Pressure	A63FGDT	49-48-psid		8	575																								
Fuel Gas Supply Pressure	A63FTGST	50-49-psid		20	556																								

DATE APR 27 2018

SIGNATURE

Mid Shift C Pacheco [Signature] M105

Days Shift

Notes UNIT OFF LINE FOR MAINT REPAIRS

Date: 05-04-18
 MST (circle one)
 Time Gas Introduced (Turbine Refill):
 Time of Turbine Offline (Ref. Closed):
 Time Turbine Offline (Ref. Open):
 Time No Gas Flow:

0845
 0955
 1351
 1403

CGTG HOURLY READING LOG

Notes:

Instrument	Unit	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Blowdown Dry Receiver Tank Hourly	deg F	100	110	120																								
2. Blowdown Wet Receiver Tank Hourly	deg F	100	110	120																								
3. Wet Receiver Air Pressure	psi	90	105	120																								
4. Instrument Temperature	deg C	20	30	50																								
5. Pin Pin Cooler	Units	Low	Norm	Max																								
6. Coolant Pressure	psi	25																										
7. Coolant PLC Temperature	deg F	100	110	120																								
8. High Level Expansion Tank	LEVEL	1/3	2/3	FULL																								
9. Coolant Return Differential From SG	in WC	40	80																									
10. Coolant Return Differential From	in WC	37	50																									
11. Control Room	Units	Low	Norm	Max																								
12. Room Temperature	deg F	72	85																									
13. Combustible Gas Detector Monitor	% LEL	0%	0%	20%																								
14. WECC Log	Operations?																											
15. Operation of PS&G at 6.34 MW	Yes (Y)																											
16. Operation of AVR Voltage Mode @ 11.6 MV	Yes (Y)																											
17. Electronic Control System	Units	Low	Norm	Max																								
18. 2000 psi Oil Water Tank Level	%			70%																								
19. 10 psi Gas TG Drain Tank (Air Diagram page)	%			70%																								
20. Record on hand S/D trip over 4500 rpm NL Compressor (on line trip)	psi	35	20																									
21. Acknowledge Alarm Hourly	Y																											
22. Generator Current	Amps			1200																								
23. MW Output	MW			27																								
24. 100% Base Load Minimum	MW																											
25. Burner Hours (unit overview)																												
26. Ambient Temperature	°F																											
27-28 found on Gas Fuel System page																												
27. Waste Oil Tank	%			70%																								
28. Total Fuel Flow	MMBtu																											

Date: 05-04-2018 Signature: Randy Ford

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor	GAS COMPRESSOR START TIME	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Combustible Gas Detector	AAH-303	%		0%	20%										1/4														
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIQHT		BLINK											B	B	B	B											
Liquid Level Coalescing	LI-7721	LIQID		EMPTY	ANY										B	B	B	B											
Crankcase Bulb eye	LC-1574	LEVEL	1/4	1/2	FULL										1/2	1/2	1/2	1/2											
Oil Day Tank Level	LI-1562	GAL	10	FULL											20	20	20	20											
Lubricator Bulb eye		LEVEL	1/2	FULL											F	F	F	F											
1st Stage Scrubber Liquid Level	LI-7416	LIQID		EMPTY	ANY										E	E	E	E											
2nd Stage Scrubber Liquid Level	LI-7466	LIQID		EMPTY	ANY										E	E	E	E											
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIQHT		BLINK											B	B	B	B											
1 st Stage Inlet Press.	PI-2100	psig	88	140											80	81	81	81											
Stage Disch. Press	PI-2101	psig	238	285											245	249	249	249											
2nd Stage Inlet Press	PI-2200	psig	267	285											224	245	245	244											
2 nd Stage Disch. Press	PI-2201	psig	575	600											578	579	579	579											
Final Discharge Pressure	PI-2108	psig	575	600											575	575	570	578											
Lube Oil Pressure	PI-1572	psig	40	60											55	59	59	59											
Lube Oil Temp	TE-1584	deg	150	170											148	167	167	165											
Final Discharge Temp	TE-2120	deg	110	150											93	96	96	84											
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg	226	297											223	223	223	220											
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg	258	283											228	229	229	233											
1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg	226	297											221	221	224	218											
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg	258	283											228	229	229	223											
Motor Frame Vibration	VT-1015	IPS	0.15	0.35											04	04	04	04											
Compressor Frame Vibration	VT-1512	IPS	0.35	0.35											06	06	04	06											
Take Once per Shift / at Full Load		psig		Max	psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																							
Natural Gas Comp. Discharge Press.															575														
Double Block and Bleed Pressure	A63FGDT	49-48=psid			8										571														
Fuel Gas Supply Pressure	A63FTGST	50-49=psid			20										578														

DATE 05-04-2018

SIGNATURE

Mid Shift

Days Shift

Notes

Date: **05.14.18**
 MST (MST (MST one))
 Time Gas Introduced (Turbine Rollin):
 Time of Turbine Online (After Closed): **1017**
 Time Turbine Offline (After Open):
 Time No Gas Flow: **1050**
 Notes: **For test to be started for the 18**

CGTS HOURLY READING LOG

Instrument	Unit	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Blowdown Dry Receiver Tank Hourly	BT-019																								
2. Blowdown Wet Receiver Tank Hourly	BT-007																								
3. Wet Receiver Air Pressure	PI-002																								
4. Instrument Temperature	TI-001																								
5. Hot Fuel Cooler																									
6. Coolant Pressure	PI-250																								
7. Coolant PLC Temperature	TI-002																								
8. Sight glass level Expansion Tank	LI-001																								
9. Coolant Return Differential from G6	PI-001																								
10. Coolant Return Differential from	PI-002																								
11. Control Room																									
12. Room Temperature																									
13. Combustible Gas Detector Monitor																									
14. WECC Log																									
15. Operation of PSS (on at 6.3 MW)																									
16. Operation of AVR Voltage Mode @ 13.6 KV																									
17. Electronic Control System																									
18. 3000 psi Oil Water Tank Level	U-231																								
19. 10 psi gas TG Drain Tank (Air Diagram page)	U-230																								
20. Measured on hard S/O trip over 4500 rpm NL compressor (on line trip)	AS-001																								
21. Acknowledge Alarms Hourly																									
22. Generator Current																									
23. MW Output																									
24. 30% Base Load Minimum																									
25. Running Hours (unit over/low)																									
26. Ambient Temperature	TI-001																								
27. 27-28 found on Gas Fuel System page)																									
28. Total Fuel Flow	U-230																								

Date: **05-11-18**
 Signature: **[Signature]**

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor																																				
GAS COMPRESSOR START TIME	1005	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24							
Combustible Gas Detector	AAH-303	%		0%	20%																															
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIGHT		BLINK																																
Liquid Level Coalescing	LI-7721	LIQID		EMPTY	ANY																															
Crackcase Bulb eye	LC-1574	LEVEL	1/4	1/2	FULL																															
Oil Day Tank Level	LI-1562	GAL	10		FULL																															
Lubricator Bulb eye		LEVEL	1/2		FULL																															
1st Stage Scrubber Liquid Level	LI-7416	LIQID		EMPTY	ANY																															
2nd Stage Scrubber Liquid Level	LI-7466	LIQID		EMPTY	ANY																															
Packing Lube Oil Flow Indicator Right side	FSL-1501A	LIGHT		BLINK																																
1 st Stage Inlet Press.	PI-2100	psig		88	140																															
Stage Disch. Press	PI-2101	psig		238	285																															
2nd Stage Inlet Press	PI-2200	psig		267	285																															
2 nd Stage Disch. Press	PI-2201	psig		575	600																															
Final Discharge Pressure	PI-2108	psig		575	600																															
Lube Oil Pressure	PI-1572	psig	40	60																																
Lube Oil Temp	TE-1584	deg		150	170																															
Final Discharge Temp	TE-2120	deg		110	150																															
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297																															
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283																															
1st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297																															
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283																															
Motor Frame Vibration	VI-1015	IPS		0.15																																
Compressor Frame Vibration	VI-1512	IPS		0.35																																
Take Once per Shift / at Full Load		psig		Max psid		When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																														
Natural Gas Comp. Discharge Press.	A63FGDT				49-48=psid																															
Double Block and Bleed Pressure	A63FGST				50-49=psid																															
Fuel Gas Supply Pressure																																				

DATE 05-11-18

SIGNATURE (Signature)

Mid Shift

Days Shift

Notes Full GTE SAMPLES FOR SOC B.

Date: 05-14-2018

MST / MOT (circle one)

Time Gas Introduced (Turbine Rolling): 1327

Time of Turbine Online (Bkr Closed): 1327

Time Turbine Offline (Bkr Open): 1347

Time No Gas Flow: 1347

CGTG HOURLY READING LOG

Notes: 13:07 - Gas Compressor Start
Post maintenance check / Bring CGTG to start speed
4W:1 STOP

Instrument	Unit	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Blowdown Dry Receiver Tank Hourly	BT-013	V																										
2. Blowdown Wet Receiver Tank Hourly	BT-007	V																										
3. Wet Receiver Air Pressure	PI-002	psig	90	105	120																							
4. Instrument Temperature	TI-003	deg C	20	50																								
5. Fin Fan Cooler		Units	Low	Norm	Max																							
6. Coolant Pressure	PI-250	psig	25																									
7. Coolant PIC Temperature	TI-002	deg F	100	110	120																							
8. Siphon Level Expansion Tank	LI-003	LS/LE	2/3	2/3	FULL																							
9. Coolant Return Differential from GG	FI-001	In WC	60	80																								
10. Coolant Return Differential from	FI-002	In WC	37	50																								
11. Control Room		Units	Low	Norm	Max																							
12. Room Temperature		deg F	72	85																								
13. Combustible Gas Detector Monitor		% LEL	0%	0%	20%																							
14. WCC Log			Operational?																									
15. Operation of PSS for M & 3344		Yes (Y)		No (N)																								
16. Operation of AVR Voltage Mode @ 13.5 KV		Yes (Y)		No (N)																								
17. Electronic Control System		Units	Low	Norm	Max																							
18-20 found on Air Diagram page)																												
18. 2000 psi CW Water Tank Level	LI-331	%		70%																								
19. 10 psi TS Drain Tank (Air Diagram page)	LI-320	%		70%																								
20. Record on hand S/D trip over 4500 psi NL Compressor (on line trip)	AS-000	psi	35	20																								
21. Acknowledge Alarms Hourly		V																										
22-24 found on Power Management page)																												
22. Generator Current		Amps		1200																								
23. MW Output		MW		27																								
24. 100% Base Load Minimum		MW																										
25. Running Hours (unit overview)																												
26. Ambient Temperature	TI-001																											
27-28 found on Gas Fuel System page)																												
27. Waste Oil Tank	LI-320	%		70%																								
28. Total Fuel Flow		Mscfh																										

Date: 5-14-2018 Signature: _____

Date: 1-15-2018

MST / MDT (circle one)

Time Gas introduced (Turbine Rolling):

Time of Turbine Online (bkr Closed):

CGTG HOURLY READING LOG

Time Turbine Offline (bkr Open):

Time No Gas Flow:

1321

1346

Notes: Training Running C-16 up to speed

Instrument	Unit	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Instrument Air Compressor	psi																											
2. Blowdown Dry Receiver Tank Hourly	psi																											
3. Blowdown Wet Receiver Tank Hourly	psi																											
4. Wet Receiver Air Pressure	psi																											
5. Instrument Temperature	deg C																											
6. First Fan Cooler	psi																											
7. Coolant Pressure	psi																											
8. Coolant P/C Temperature	deg F																											
9. High Level Expansion Tank	LEVEL																											
10. Coolant Return Differential from C-6	in WC																											
11. Coolant Return Differential from	in WC																											
12. Control Room	Unit																											
13. Room Temperature	deg F																											
14. Combustible Gas Detector Monitor	% LEL																											
15. WCC Log	Operation																											
16. Operation of PSS on at 6.3 MW	Yes (Y)																											
17. Operation of AVR Voltage Mode @ 1.6 KV	Yes (Y)																											
18. Remote Control System	Unit																											
19. 1000 psi Oil Water Tank Level	%																											
20. 1000 psi Oil Water Tank Level	%																											
21. Record on hand S/G trip over 4500 rpm NL	pos																											
22. Compressor (on line trip)	%																											
23. Acknowledge Alarms Hourly	%																											
24. Generator Current	Amps																											
25. MW Output	MW																											
26. 100% Base Load Minimum	MW																											
27. Running Hours (unit overview)	hrs																											
28. Ambient Temperature	deg C																											
29. Waste Oil Tank	%																											
30. Total Fuel Flow	kg/hr																											

Date: _____ Signature: _____

Date: 5-24-2018
 MST (circle one)
 Time Gas Introduced (Turbine Roll-in):
 Time of Turbine Offline (Bkr Closed):
 Time Turbine Offline (Bkr Open):
 Time No Gas Flow:

0903
 0700
 0954
 1558
 0717
 1603

CGTG HOURLY READING LOG

Notes: CGTG Schedule Changed To 1000 AM
 05-24-2018

	ID	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1	Blowdown Air Receiver Tank Hourly	BWT-013	V																										
2	Blowdown Wet Receiver Tank Hourly	BWT-007	V																										
3	Wet Receiver Air Pressure	PI-002	psig	90	105	120																							
4	Instrument Temperature	TI-001	deg C	20	50																								
5	Pin Fan Cooler	Units	Low	Norm	Max																								
6	Coolant Pressure	PI-250	psig	25																									
7	Coolant PLC Temperature	TI-002	deg F	100	110	120																							
8	Sight Glass Level Expansion Tank	LI-001	L2/L3	1/3	2/3	FULL																							
9	Coolant Return Differential from SG	FI-001	In WC	60	80																								
10	Coolant Return Differential from	FI-002	In WC	37	50																								
11	Control Room	Units	Low	Norm	Max																								
12	Room Temperature	deg F	72	85																									
13	Combustible Gas Detector Monitor	% LEL	0%	0%	20%																								
14	WECT Log	Operations?																											
15	Operation of PSS on at 5.3MW	Yes (Y)			No (N)																								
16	Operation of AVR Voltage Mode @ 13.6 KV	Yes (Y)			No (N)																								
17	Electronic Control System	Units	Low	Norm	Max																								
18	3000 gal Oil Water Tank Level	U-231	%		70%																								
19	10 gal gas T6 Drain Tank (Air Diagram page)	U-230	%		70%																								
20	Record on hard S/D trip over 4500 rpm NL compressor (on line trip)	AS4660 ST-01	Prog	35	20																								
21	acknowledge Alarms Hourly	V																											
22	Generator Current	Amps			1200																								
23	Mw Output	MW			27																								
24	80% Base Load Minimum	MW																											
25	Running Hours (unit over/under)																												
26	Ambient Temperature	TI Inlet																											
27	Waste Oil Tank	U-120	%		70%																								
28	Total Fuel Flow	Mw/h																											
Date: <u>05-24-18</u>		Signature: <u>[Signature]</u>																											

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units		Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME 0639		0845																												
Combustible Gas Detector	AAH-303	%		0%	20%											11/8	005	005	005	005										
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIGHT		BLINK												13	13	13	13	13										
Liquid Level Coalescing	LI-7721	LIQUID		EMPTY	ANY											13	13	13	13	13										
Crankcase Bulb eye	LC-1574	LEVEL	1/4	1/2	FULL											11/2	1/2	1/2	1/2	1/2										
Oil Day Tank level	LI-1562	GAL	10		FULL											Full	Full	Full	Full	Full										
Lubricator Bulb eye		LEVEL	1/2	FULL												3/4	3/4	3/4	3/4	3/4										
1st Stage Scrubber Liquid Level	LI-7416	LIQUID		EMPTY	ANY											1/2	1/2	1/2	1/2	1/2										
2nd Stage Scrubber Liquid Level	LI-7466	LIQUID		EMPTY	ANY											1/2	1/2	1/2	1/2	1/2										
Packing Lube Oil Flow Indicator Right side	FSL-1501A	LIGHT		BLINK												13	13	13	13	13										
1 st Stage Inlet Press.	PI-2100	psig		88	140											219	219	219	219	219										
Stage Disch. Press	PI-2101	psig		238	285											250	250	252	252	252										
2nd Stage Inlet Press	PI-2200	psig		267	285											247	247	248	249	249										
2 nd Stage Disch. Press	PI-2201	psig		575	600											578	579	579	579	579										
Final Discharge Pressure	PI-2108	psig		575	600											575	575	575	576	575										
Lube Oil Pressure	PI-1572	psig	40	60												139	139	139	139	139										
Lube Oil Temp	TE-1584	deg		150	170											164	164	164	165	164										
Final Discharge Temp	TE-2120	deg		110	150											110	112	115	119	120										
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297											233	233	233	234	235										
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283											241	242	244	247	248										
1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297											230	230	230	231	232										
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283											240	242	244	247	247										
Motor Frame Vibration	VT-1015	IPS		0.15												0.05	0.05	0.05	0.04	0.04										
Compressor Frame Vibration	VT-1512	IPS		0.35												0.05	0.05	0.06	0.06	0.06										
Take Once per Shift / at Full Load		psig		Max	psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																								
Natural Gas Comp. Discharge Press.	A63FGDT	49-48=psid		8												576														
Double Block and Bleed Pressure	A63FTG5T	50-49=psid		20												571														
Fuel Gas Supply Pressure																561														

DATE 5-24-2018

SIGNATURE

Mid Shift
Days Shift *Robert Long*

Notes 0705 CGTG Schedule changed TO 1000 AM

Date: 5-31-18

MST (MST) (circle one)

Time Gas Introduced (Turbine holding): 0638

Time of Turbine Online (left Closed): 0754

Time Turbine Offline (left Open): 1557

Time No Gas Flow: 1604

CGTG HOURLY READING LOG

Notes:

Location / Parameter	LD	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Blowdown Dry Receiver Tank Hourly	BYV-013	V																											
2. Blowdown Wet Receiver Tank Hourly	BYV-007	V																											
3. Wet Receiver Air Pressure	PI-002	psig	90	105	120																								
4. Instrument Temperature	TI-001	deg C	20	50																									
5. Fan Fan Cooler		Units	Low	Norm	Max																								
6. Coolant Pressure	PI-520	psig	25																										
7. Coolant PLC Temperature	TI-002	deg F	100	110	120																								
8. Sight glass level Separation Tank	LI-001	LEVEL	1/3	2/3	FULL																								
9. Coolant Return Differential from GG	PI-001	in WC	60	80																									
10. Coolant Return Differential from	PI-002	in WC	37	50																									
11. Control Room		Units	Low	Norm	Max																								
12. Room Temperature		deg F	72	85																									
13. Combustible Gas Detector Monitor		% LEL	0%	0%	20%																								
14. WCC Log																													
15. Operation of PSS on at 5.3MW																													
16. Operation of AVR Voltage Mode @ 1.6 KV		Yes (Y)		No (N)																									
17. Electronic Control System		Units	Low	Norm	Max																								
18. 2000 gal Oil Water Tank Level	LI-211	%			70%																								
19. 10 gal gas TO Drain Tank (Air Diagram page)	LI-210	%			70%																								
20. Record on hard S/D trip over 4500 rpm NL Compressor (on line trip)	ASD-001	psig	35	20																									
21. Acknowledge Alarms Hourly		V																											
22. Generator Current		Amps		1200																									
23. MW Output		MW		27																									
24. 8000 Base Load Minimum		MW																											
25. Burner Hours (link error/view)																													
26. Ambient Temperature	TI-001																												
27. Waste Oil Tank	LI-210	%		70%																									
28. Total Fuel Flow		MG/H																											

Date: 5-31-18 Signature: [Signature]

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
Combustible Gas Detector	AAH-303	%		0%	20%						618		095																
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIGHT		BLINK																									
Liquid Level Coalescing	LI-7721	LIQUID		EMPTY	ANY																								
Crankcase Bulb eye	LC-1574	LEVEL	1/4	1/2	FULL																								
Oil Day Tank Level	LI-1562	GAL	10		FULL																								
Lubricator Bulb eye		LEVEL	1/2	FULL																									
1st Stage Scrubber Liquid Level	LI-7416	LIQUID		EMPTY	ANY																								
2nd Stage Scrubber Liquid Level	LI-7466	LIQUID		EMPTY	ANY																								
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIGHT		BLINK							485																		
1st Stage Inlet Press.	PI-2100	psig		88	140																								
Stage Disch. Press	PI-2101	psig		238	285																								
2nd Stage Inlet Press	PI-2200	psig		267	285																								
2nd Stage Disch. Press	PI-2201	psig		575	600																								
Final Discharge Pressure	PI-2108	psig		575	600																								
Lube Oil Pressure	PI-1572	psig	40	60																									
Lube Oil Temp	TE-1584	deg		150	170																								
Final Discharge Temp	TE-2120	deg		110	150																								
1st Stage Cylinder Disch. Temperature A	TE-2054A	deg		226	297																								
2nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283																								
1st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297																								
2nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283																								
Motor Frame Vibration	VT-1015	IPS		0.15																									
Compressor Frame Vibration	VT-1512	IPS		0.35																									
Take Once per Shift / at Full Load		psig																											
Natural Gas Comp. Discharge Press.																													
Double Block and Bled Pressure	A63FGDT	49-48-psid		8									575							535									
Fuel Gas Supply Pressure	A63FGST	50-49-psid		20									571							571									
													560							561									

5-31-18

SIGNATURE

Mid Shift

Days Shift

C. Pacheco

Notes

When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer

575
571
560

535
571
561

Date: 6-7-2018
 MST / MDT (circle one)
 Time Gas Introduced (Turbine Rolling):
 Time of Turbine Online (After Closed):
 Time Turbine Offline (After Open):
 Time No Gas Flow:

CGTG HOURLY READING LOG

Notes: 10 BE ON LINE 8/1500 DO TO CE TO REPAIRS
UNIT DID NOT UNLOAD WHEN STOP BUTTON PUSHED
TRIPPED IMMEDIATELY WITH 20 MW. SEE BELOW

Instrument Air Compressor	LD	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Blowdown Dry Receiver Tank Hourly	8V7-007	V																											
2. Wet Receiver Air Pressure	8V7-007	V																											
3. Wet Receiver Air Pressure	8V7-007	V																											
4. Instrument Temperature	8V7-007	deg C	90	105	120																								
5. Trip Fan Cooler	8V7-007	deg C	20	50	50																								
6. Coolant Pressure	8V7-007	psi	Low	Norm	Max																								
7. Coolant PLC Temperature	8V7-007	deg F	100	110	120																								
8. Sight glass level Expansion Tank	8V7-007	LEVEL	1/3	2/3	FULL																								
9. Coolant Return Differential from EG	8V7-007	in WC	60	80	80																								
10. Coolant Return Differential from	8V7-007	in WC	37	50	50																								
11. Control Room	8V7-007	Units	Low	Norm	Max																								
12. Room Temperature	8V7-007	deg F	72	85	85																								
13. Combustible Gas Detector Monitor	8V7-007	% LEL	0%	0%	20%																								
14. WCC Log	8V7-007	Operation?																											
15. Operation of PSS/ on at 6.3 MW	8V7-007	Yes (Y)																											
16. Operation of AVR Voltage Mode @ 13.5 MV	8V7-007	Yes (Y)																											
17. Electronic Control System	8V7-007	Units	Low	Norm	Max																								
18. 1000 gal Oil Water Tank Level	8V7-007	%			70%																								
19. 10 gal gas T5 Drain Tank (Air Diagram page)	8V7-007	%			70%																								
20. Recirc on hand S/D trip over 4500 ppm NL	8V7-007	psi	35	20																									
21. Compressor (on line trip)	8V7-007	psi	35	20																									
22. Acknowledge Alarms Hourly	8V7-007	Y																											
23. 24 found on Power Management page)	8V7-007	Y																											
24. Generator Current	8V7-007	amps			1200																								
25. MW Output	8V7-007	MW			27																								
26. 10% Base Load Minimum	8V7-007	MW																											
27. Running Hours (unit overview)	8V7-007	hours																											
28. Ambient Temperature	8V7-007	deg C																											
29. 24 found on Gas Fuel System page)	8V7-007	Y																											
30. Waste Oil Tank	8V7-007	%			70%																								
31. Total Fuel Flow	8V7-007	gph																											

Date: 6-7-2018 Signature: [Signature]

THERE WERE 9 FAILED STARTS OF UNIT. FUEL WAS ON FOR LESS THAN ONE MINUTE ATOT17

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
Combustible Gas Detector	AAR-303	%		0%	20%																								
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIQHT		BLINK																									
Liquid Level Coalescing	LI-7721	LIQHT		EMPTY	ANY																								
Crackcase Bulk eye	LC-1574	LEVEL	1/4	1/2	FULL																								
Oil Day Tank Level	LI-1562	GAL	10		FULL																								
Lubricator Bulk eye		LEVEL	1/2	FULL																									
1st Stage Scrubber Liquid Level	LI-7416	LIQHT		EMPTY	ANY																								
2nd Stage Scrubber Liquid Level	LI-7466	LIQHT		EMPTY	ANY																								
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIQHT		BLINK																									
1st Stage Inlet Press.	PI-2100	psig		88	140																								
Stage Disch. Press	PI-2101	psig		238	285																								
2nd Stage Inlet Press	PI-2200	psig		267	285																								
2nd Stage Disch. Press	PI-2201	psig		575	600																								
Final Discharge Pressure	PI-2108	psig		575	600																								
Lube Oil Pressure	PI-1572	psig	40	60																									
Lube Oil Temp	TE-1584	deg		150	170																								
Final Discharge Temp	TE-2120	deg		110	150																								
1st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297																								
2nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283																								
1st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297																								
2nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283																								
Motor Frame Vibration	VT-1015	IPS			0.15																								
Compressor Frame Vibration	VT-1512	IPS			0.35																								
Take Once per Shift / at Full Load		psig																											
Natural Gas Comp. Discharge Press.	A63FGDT	49-48=psid																											
Double Block and Bleed Pressure																													
Fuel Gas Supply Pressure	A63FGST	50-49=psid																											

DATE 06-7-2018

SIGNATURE

Mid Shift

Days Shift

Notes UNIT WAS ALSO STARTED AT 0837 AND 0638. THERE WERE 9 FAILED STARTS OF CGTG

Date: 6-8-18

MST / GDT (Circle one)

Time Gas Introduced (Turbine Rolling):

Time of Turbine Offline (Btr Closed):

Time Turbine Offline (Btr Open):

Time No Gas Flow:

Notes: put turbine back up to 18 MW and then shut it down

CGTG HOURLY READING LOG

Instrument / Air Compressor	LO	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Blowdown Dry Receiver Tank Hourly	BW-013	V																											
2. Blowdown Wet Receiver Tank Hourly	BW-007	V																											
3. Wet Receiver Air Pressure	PA-003	psig	90	105	120																								
4. Instrument Temperature	TI-001	deg C	20	50																									
5. Jet Fan Cooler		Units	Low	Norm	Max																								
6. Coolant Pressure	PA-250	psig	25																										
7. Coolant PLC Temperature	TT-002	deg F	100	110	120																								
8. Sight glass Level Expansion Tank	LI-001	LEVEL	1/3	2/3	FULL																								
9. Coolant Return Differential from CG	PI-001	in WC	60	80																									
10. Coolant Return Differential from	PI-002	in WC	37	50																									
11. Control Room		Units	Low	Norm	Max																								
12. Room Temperature		deg F	72	85																									
13. Combustible Gas Detector Monitor		% LEL	0%	0%	20%																								
14. WECC Log				Operational																									
15. Operation of PSS/ or 5.3 MW		Ved (V)			no (N)																								
16. Operation of AVR Voltage Mode @ 13.6 KV		Ved (V)			no (N)																								
17. Electronic Control System		Units	Low	Norm	Max																								
18. 2000 psi Oil Water Tank Level	U-231	%			70%																								
19. 10 psi TO Drain Tank (Air Diagram page)	U-230	%			70%																								
20. Record on hand S/D trip over 4500 rpm WL (compressor on line trip)	AS6660 ST-01	psig	35	20																									
21. Acknowledge Alarms Hourly		✓																											
22. Generator Current		Amps			1200																								
23. MW Output		MW			27																								
24. 80% Base Load Minimum		MW																											
25. Running Hours (unit overview)																													
26. Ambient Temperature	TA Unit																												
27. Waste Oil Tank	U-130	%			70%																								
28. Total Fuel Flow	Med/n																												

Date: 6-8-18 Signature: [Signature]

U-106-033AR2
Rev 9/2018

CGTG TURBINE		UTILITIES AND INFRASTRUCTURE																													
Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24		
GAS COMPRESSOR START TIME																															
Combustible Gas Detector	AAH-303	%		0%	20%																										
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIGHT		BLINK																											
Liquid Level Coalescing	LI-7721	LIQID		EMPTY	ANY																										
Crankcase Bulls eye	LC-1574	LEVEL	1/4	1/2	FULL																										
Oil Day Tank Level	LI-1562	GAL	10	FULL																											
Lubricator Bulls eye		LEVEL	1/2	FULL																											
1st Stage Scrubber Liquid Level	LI-7416	LIQID		EMPTY	ANY																										
2nd Stage Scrubber Liquid Level	LI-7466	LIQID		EMPTY	ANY																										
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIGHT		BLINK																											
1st Stage Inlet Press.	PI-2100	psig		88	140																										
Stage Disch. Press	PI-2101	psig		238	285																										
2nd Stage Inlet Press	PI-2200	psig		267	285																										
2nd Stage Disch. Press	PI-2201	psig		575	600																										
Final Discharge Pressure	PI-2108	psig		575	600																										
Lube Oil Pressure	PI-1572	psig	40	60																											
Lube Oil Temp	TE-1584	deg		150	170																										
Final Discharge Temp	TE-2120	deg		110	150																										
1st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297																										
2nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283																										
1st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297																										
2nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283																										
Motor Frame Vibration	VT-1015	IPS		0.15																											
Compressor Frame Vibration	VT-1512	IPS		0.35																											
Take Once per Shift / at Full Load		psig		Max psid																											
Natural Gas Comp. Discharge Press.	A63FGDT	49-48=psid		8																											
Double Block and Bleed Pressure																															
Fuel Gas Supply Pressure	A63FTGST	50-49=psid		20																											
DATE 6-8-18																															
SIGNATURE <i>[Signature]</i>																															
Mid Shift																															
Days Shift																															
Notes		Run up to speed + synchronized for testing + shut down after getting to 19 MW																													

Date: 6-11-18
 MSTR (M03) (circle one)
 Time Gas Introduced (Turbine Rolling):
 Time of Turbine Online (Bkr Closed):

Time Turbine Offline (Bkr Open):
 Time No Gas Flow:

Notes: Gas Comp Alarms Put out / Started. CGTG
CVIT Started to Burn off Gas for 600
FROM LINES

CGTG HOURLY READING LOG

Instrument Name/Compressor	LO	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Blowdown Dry Receiver Tank Hourly	BWT-013	Y																											
2. Blowdown Wet Receiver Tank Hourly	BWT-007	Y																											
3. Wet Receiver Air Pressure	PR-002	psig	90	105	120																								
4. Instrument Temperature	TT-001	deg C	20	50																									
5. Fin Fan Cooler		Units	Low	Norm	Max																								
6. Coolant Pressure	PR-250	psig	25																										
7. Coolant P/C Temperature	TT-002	deg F	100	110	120																								
8. Sight glass level Expansion Tank	LV-001	LEVEL	1/3	2/3	FULL																								
9. Coolant Return Differential from CG	PR-001	in WC	60	80																									
10. Coolant Return Differential from	PR-002	in WC	37	50																									
11. Control Room		Units	Low	Norm	Max																								
12. Room Temperature		deg F	72	85																									
13. Combustible Gas Detector Monitor		% LEL	0%	0%	20%																								
14. WTEC Log				Operational																									
15. Operation of PSS on at 6.3 MW		Yes (Y)		No (N)																									
16. Operation of MW Voltage Mode @ 13.5 KV		Yes (Y)		No (N)																									
17. Electronic Control System		Units	Low	Norm	Max																								
18. 2000 gal Oil Water Tank Level	LV-011	%			70%																								
19. 10 gal Gas TG Drain Tank (see Diagram page)	LV-010	%			70%																								
20. Record on hand S/D trip over 4500 rpm NL Compressor (see line 20)	AS5000 ST-01	psig	35	20																									
21. Acknowledge Alarms Hourly		Y																											
22. Generator Current		Amps		1200																									
23. MW Output		MW		27																									
24. 80% Base Load Minimum		MW																											
25. Running Hours (unit overview)																													
26. Ambient Temperature	TT-001																												
27. Waste Oil Tank	LV-100	%		70%																									
28. Total Fuel Flow		Med/h																											

Date: 6-11-18 Signature: [Signature]

U:\CGTG\AI856
January 2018

Date: **06-14-18**
 MST / MDT (circle one)
 Time gas introduced (Turbine Readings):
 Time of Turbine Online (Enter Clock):

1732
 1741

Time Turbine Offline (Enter Open):
 Time No Gas Flow:

1732
 1741

CGTS HOURLY READING LOG

Notes: **GAS COMPRESSOR ON AT 1340
 DID 2 WASH CYCLES AT CGTS AND 4 RINSE
 CYCLES, UNIT BROUGHT TO IDLE SPEED TO VARY**

Instrument Air Compressor	ID	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Blowdown Dry Receiver Tank Hourly	BT-013	V																											
2. Blowdown Wet Receiver Tank Hourly	BT-007	V																											
3. Wet Receiver Air Pressure	PT-002	psig	90	105	120																								
4. Instrument Temperature	TI-001	deg C	20	50																									
5. Fuel Fan Cooler		Units	Low	Norm	Max																								
6. Coolant Pressure	PT-350	psig	25																										
7. Coolant PIC Temperature	TI-002	deg F	100	110	120																								
8. Sight Glass Level Expansion Tank	LI-002	LEVEL	1/3	2/3	FULL																								
9. Coolant Return Differential from CG	FI-001	In MC	60	80																									
10. Coolant Return Differential from	FI-002	In MC	37	50																									
11. Control Room		Units	Low	Norm	Max																								
12. Room Temperature		deg F	72	85																									
13. Combustible Gas Detector Monitor		% LEL	0%	0%	20%																								
14. W/SEC Log																													
15. Operation of PSC on AI 5.2ANV		Operational?																											
16. Operation of AVM voltage Mode @ 13.6 KV		Yes (Y)																											
17. Synthetic Control System		Units	Low	Norm	Max																								
18. 2000 gal On Water Tank Level	LI-331	%			70%																								
19. 10 gal Gas IG Drain Tank (Air Diagram page)	LI-330	%			70%																								
20. Record on hard S/D trip over 4500 rpm NL Compressor (on the trip)	AEBCD	psig	35	20																									
21. Acknowledge Alarm Hourly		Y																											
22. Acknowledge Alarm Hourly		Y																											
23. Generator Current		Amps		1200																									
24. MW Output		MW		27																									
25. 80% Base Load Minimum		MW																											
26. Running Hour (unit overview)																													
27. Ambient Temperature	TI-001																												
28. Total Fuel Flow	LI-330	%		70%																									

Date: **06-14-2018** Signature: **Joe Gomez**

U/L-06-03342
 January 4, 2018

Date: **JUN 15 2018**

MST (MST Circle only)
Time Gas introduced (Turbine Rolling):
Time of Turbine Online (Bkr Closed):

Time Turbine Offline (Bkr Open):
Time No Gas Flow:

Notes: **GAS COMPRESSOR TRIPPED**

Signature: **A. Williams**

Date: **6-15-18**

Instrument Air Compressor	ID	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Blowdown Dry Receiver Tank Hourly	BYT-013	V																✓											
2. Blowdown Wet Receiver Tank Hourly	BYT-007	V																✓											
3. Wet Receiver Air Pressure	PI-002	psig	90	105	120													110											
4. Instrument Temperature	TI-001	deg C	20	50														32											
5. Fan Fan Cooler		Units	Low	Norm	Max																								
6. Coolant Pressure	PI-250	psig		25														20											
7. Coolant PLC Temperature	TI-002	deg F	100	110	120													102											
8. Sight glass Level Expansion Tank	LI-001	LEVEL	2/3	2/3	FULL													1/2											
9. Coolant Return Differential from GG	PI-001	In WC	60	80														60											
10. Coolant Return Differential from	PI-002	In WC	37	50														35											
11. Control Room		Units	Low	Norm	Max													70											
12. Room Temperature		deg F		72	85													1											
13. Combustible Gas Detector Monitor		% LEL	0%	0%	20%																								
14. WECT Log		Operational?																											
15. Operation of PSS/on at 5.3ANV		Yes (Y)			No (N)													Y											
16. Operation of AVN Voltage Mode @ 13.6 MV		Yes (Y)			No (N)													Y											
17. Operation of Control System		Units	Low	Norm	Max																								
18. 2000 gal Oil Water Tank Level	LI-231	%			70%													4											
19. 10 gal Gas TG Drain Tank (see Diagram page)	LI-230	%			70%													6											
20. Record on hard S/D info over 4500 ppm NL Compressor (on line trip)	AS-001	psig	35	20																									
21. Acknowledge Alarms Hourly		V																✓											
22. 24 Found on Power Management page)																													
23. Generator Current		Amps			1200													816											
24. MW Output		MW			27													18											
25. 80% Base Load Minimum		MW																14.3											
26. Running Hour (unit overview)																		3165											
27. Ambient Temperature	TI-001																	89											
28. 27-28 Found on Gas Fuel System page)																													
29. Waste Oil Tank	LI-120	%			70%																								
30. Total Fuel Flow	Mcf/h																												

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
Combustible Gas Detector	AAH-303	%		0%	20%													B											
Packing Tube Oil Flow Indicator Left Side	FSL-1501B	LIGHT		BLINK														E											
Liquid Level Coalescing	LI-7721	LIQID		EMPTY	ANY													1/2											
Crankcase Bulb eye	LC-1574	LEVEL	1/4	1/2	FULL													1/2											
Oil Day Tank Level	LI-1562	GAL	10		FULL													1/4											
Lubricator Bulb eye		LEVEL	1/2	FULL														3/4											
1st Stage Scrubber Liquid Level	LI-7416	LIQID		EMPTY	ANY													E											
2nd Stage Scrubber Liquid Level	LI-7466	LIQID		EMPTY	ANY													E											
Packing Tube Oil Flow Indicator Right Side	FSL-1501A	LIGHT		BLINK														B											
1 st Stage Inlet Press.	PI-2100	psig		88	140													B.5											
Stage Disch. Press	PI-2101	psig		238	285													252											
2 nd Stage Inlet Press	PI-2200	psig		267	285													249											
2 nd Stage Disch. Press	PI-2201	psig		575	600													579											
Final Discharge Pressure	PI-2108	psig		575	600													576											
Lube Oil Pressure	PI-1572	psig	40	60														60											
Lube Oil Temp	TE-1584	deg		150	170													164											
Final Discharge Temp	TE-2120	deg		110	150													121											
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297													245											
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283													252											
1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297													242											
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283													252											
Motor Frame Vibration	VT-1015	IPS		0.15														0.05											
Compressor Frame Vibration	VT-1512	IPS		0.35														0.07											
Take Once per Shift / at Full Load		psig		Max psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																								
Natural Gas Comp. Discharge Press.	A63FGDT	49-48=psid		8																									
Double Block and Bleed Pressure																													
Fuel Gas Supply Pressure	A63FTGST	50-49=psid		20																									

DATE 6-15-18

SIGNATURE

Mid Shift

Days Shift WILLIAMS

Notes

COMPRESSOR TRIP, GENERATION CANCELLED

Date: 06-19-2018
 MST / MDT (circle one)
 Time Gas Introduced (Turbine Roll-in):
 Time of Turbine Offline (After Closed):
 Time No Gas Flow:

14:30
 n/a
 14:51

Time Turbine Offline (After Open):
 Time No Gas Flow:

n/a
 14:51

Notes: 06-19-2018 - Test Gas Comp. 1 hr up
TV Switch Speed.

CGTG HOURLY READING LOG

Instrument/Parameter	Unit	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1. Blowdown Dry Receiver Tank Hourly	BYT-013	V																										
2. Blowdown Wet Receiver Tank Hourly	BYT-007	#																										
3. Wet Receiver Air Pressure	PI-002	psig	90	105	120																							
4. Instrument Temperature	TI-001	deg C	20	50																								
5. Fan Fan Cooler		Units	Low	Norm	Max																							
6. Coolant Pressure	PI-250	psig	25																									
7. Coolant P/C Temperature	TI-002	deg F	100	110	120																							
8. Sight glass level Expansion Tank	LI-001	LEVEL	1/3	2/3	FULL																							
9. Coolant Return Differential from GG	PI-001	In WC	60	80																								
10. Coolant Return Differential from	PI-002	In WC	37	50																								
11. Control Room		Units	Low	Norm	Max																							
12. Room Temperature		deg F	72	85																								
13. Combustible Gas Detector Monitor		% LEL	0%	0%	20%																							
14. WRECC Log		Operation																										
15. Operation of PSS on at 15.30V		Yes (Y)																										
16. Operation of AVR Voltage Mode @ 13.6 KV		Yes (Y)																										
17. Electronic Control System		Units	Low	Norm	Max																							
18. 2000 gal Oil Water Tank Level	LI-231	%			70%																							
19. 10 gal gas TO Drain Tank (Air Diagram page)	LI-230	%			70%																							
20. Record on hard S/D trip over 4500 rpm NL Compressor (on line trip)	A636GD ST-01	psig	35	20																								
21. Acknowledge Alarms Hourly		V																										
22. Generator Current		Amps			1200																							
23. MW Output		MW			27																							
24. 80% Base Load Minimum		MW																										
25. Running Hours (unit overview)																												
26. Ambient Temperature	TI Inlet																											
27. Waste Oil Tank	LI-120	%			70%																							
28. Total Fuel Flow		Med/h																										

Date: 06-19-2018
 Signature: David R. McIntyre

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
Combustible Gas Detector	AAH-303	%		0%	20%																								
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIGHT		BLINK																									
Liquid Level Coalescing	LI-7721	LIQID		EMPTY	ANY																								
Crankcase Bulb eye	LC-1574	LEVEL	1/4	1/2	FULL																								
Oil Day Tank Level	LI-1562	GAL	10		FULL																								
Lubricator Bulb eye		LEVEL	1/2	FULL																									
1st Stage Scrubber Liquid Level	LI-7416	LIQID		EMPTY	ANY																								
2nd Stage Scrubber Liquid Level	LI-7466	LIQID		EMPTY	ANY																								
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIGHT		BLINK																									
1 st Stage Inlet Press.	PI-2100	psig		88	140																								
Stage Disch. Press	PI-2101	psig		238	285																								
2nd Stage Inlet Press	PI-2200	psig		267	285																								
2 nd Stage Disch. Press	PI-2201	psig		575	600																								
Final Discharge Pressure	PI-2108	psig		575	600																								
Lube Oil Pressure	PI-1572	psig	40	60																									
Lube Oil Temp	TE-1584	deg		150	170																								
Final Discharge Temp	TE-2120	deg		110	150																								
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297																								
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283																								
1st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297																								
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283																								
Motor Frame Vibration	VT-1015	IPS		0.15																									
Compressor Frame Vibration	VT-1512	IPS		0.35																									
Take Once per Shift / at Full Load		psig		Max psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																								
Natural Gas Comp Discharge Press.																													
Double Block and Bled Pressure	A63FGDT	49-48=psid		8																									
Fuel Gas Supply Pressure	A63TGST	50-49=psid		20																									

DATE 6-19-2018

SIGNATURE [Signature]

Mid Shift

Days Shift

Notes Gas compressor start 09:26 / 21:45 for bring up GGT to synch speed.

On: 6-21-2018
 MST (circle one)
 Time Gas Introduced (Turbine Address):
 Time of Turbine Online (After Egress):

CGTG HOURLY READING LOG

Time Turbine Offline (After Open):
 Time No Gas Flow:

Notes: 08:15 UNIT TRIPPED DUE TO GAS
COMPRESSOR TRIPPED

Instrument Air Compressor	LD	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1 Blowdown Dry Receiver Tank Hourly	BWT-015	Y																											
2 Blowdown Wet Receiver Tank Hourly	BWT-007	Y																											
3 Wet Receiver Air Pressure	PT-002	psig	90	105	120																								
4 Instrument Temperature	TI-001	deg C	20	30																									
5 Inlet Air Cooler	PT-001	Units	Low	Norm	Max																								
6 Coolant Pressure	PT-002	psig	25																										
7 Coolant PIC Temperature	TI-002	deg F	100	110	120																								
8 Split glass Level Expansion Tank	LI-001	LVGL	1/3	2/3	FULL																								
9 Coolant Return Differential from GG	PT-001	in WC	60	80																									
10 Coolant Return Differential from	PT-002	in WC	37	50																									
11 Control Room		Units	Low	Norm	Max																								
12 Room Temperature		deg F	72	85																									
13 Combustible Gas Detector Monitor		% LEL	0%	0%	20%																								
14 WCC Log																													
15 Operation of FSD on at 5.5MW		Yes (Y)			No (N)																								
16 Operation of AVR Voltage Mode @ 12.5 KV		Yes (Y)			No (N)																								
17 Electronic Control System		Units	Low	Norm	Max																								
18-20 found on Air Diagram page)																													
18 2000 gal Oil Water Tank Level	LI-001	%			70%																								
19 10 gal gas TG Drain Tank (Air Diagram page)	LI-002	%			70%																								
20 Record on hard S/D trip over 4500 rpm VL	ASR-001	psig	35	20																									
21 Compressor (on line trip)	ST-01																												
22 Acknowledge Alarms Hourly		Y																											
23-24 found on Power Management page)																													
22 Generator Current		Amps			1200																								
23 MW Output		MW			27																								
24 50% Base Load Minimum		MW																											
25 Running Hours (unit overview)																													
26 Ambient Temperature	TI-001																												
27-28 found on Gas Fuel System page)																													
27 Waste Oil Tank	LI-001	%			70%																								
28 Fuel Flow		Med/h																											

Date: 6-21-18 Signature: [Signature]

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
Combustible Gas Detector	AAH-303	%		0%	20%																								
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIGHT		BLINK																									
Liquid Level Collecting	LI-7721	LIQUID		EMPTY	ANY																								
Crankcase Bulb eye	LC-1574	LEVEL 1/4		1/2	FULL																								
Oil Day Tank Level	LI-1562	GAL 10		FULL																									
Lubricator Bulb eye		LEVEL		1/2	FULL																								
1st Stage Scrubber Liquid Level	LI-7416	LIQUID		EMPTY	ANY																								
2nd Stage Scrubber Liquid Level	LI-7466	LIQUID		EMPTY	ANY																								
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIGHT		BLINK																									
1st Stage Inlet Press.	PI-2100	psig		88	140																								
Stage Disch. Press	PI-2101	psig		238	285																								
2nd Stage Inlet Press	PI-2200	psig		267	285																								
2nd Stage Disch. Press	PI-2201	psig		575	600																								
Final Discharge Pressure	PI-2108	psig		575	600																								
Lube Oil Pressure	PI-1572	psig		60																									
Lube Oil Temp	TE-1584	deg		150	170																								
Final Discharge Temp	TE-2120	deg		110	150																								
1st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297																								
2nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283																								
1st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297																								
2nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283																								
Motor Frame Vibration	VI-1015	IPS		0.15																									
Compressor Frame Vibration	VI-1512	IPS		0.35																									
Take Once per Shift / at Full Load		psig		Max psid																									
Natural Gas Comp. Discharge Press.	A63FGDT	49-48=psid		8																									
Double Block and Bleed Pressure	A63FTGST	50-49=psid		20																									
Fuel Gas Supply Pressure																													

DATE 6-21-2018

When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer

DATE 6-2-2018

SIGNATURE

Mid Shift

Days Shift

Notes

de 900 am. Lighted 9:00
per Robert Boyd. Station small.

Date: **6-28-18**
 MST (MDD) (circle one)
 Time Gas Introduced (Turbine Rollback):
 Time of Turbine Online (After Closed):

0823
 0835

Time Turbine Offline (After Open):
 Time No Gas Flow:

1600
 1606

CGTG HOURLY READING LOG

Notes:

Instrument Air Component	LD	Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24		
1. Blowdown Dry Receiver Tank Hourly	BT-013	V												✓	✓	✓	✓	✓	✓	✓											
2. Blowdown Wet Receiver Tank Hourly	BT-007	V												✓	✓	✓	✓	✓	✓	✓											
3. Wet Receiver Air Pressure	PT-002	psig	90	105	120									106	112	110	111	108	110	106											
4. Instrument Temperature	TI-001	deg C	20	50										32	32	32	32	32	34	36											
5. Pin Fan Cooler		Units	Low	Norm	Max																										
6. Coolant Pressure	PT-250	psig	25											19	19	19	19	19	1	19											
7. Coolant PLC Temperature	TI-002	deg F	100	110	120									106	108	104	108	106	105	111											
8. Sight Glass Level Expansion Tank	LI-001	LEVEL	1/3	2/3	FULL									1/2	1/2	1/2	1/2	1/2	1/2	1/2											
9. Coolant Return Differential from GC	PT-003	in WC	60	80										62	62	64	66	65	65	65											
10. Coolant Return Differential from	PT-003	in WC	37	50										37	37	38	38	36	38	38											
11. Control Room		Units	Low	Norm	Max																										
12. Room Temperature		deg F	72	85										74	74	75	68	66	66	66											
13. Combustible Gas Detector Monitor		% LEL	OK	OK	20%									1	1	1	1	1	1	1											
15. WCC Log				Operational																											
16. Operation of PSS on at 6.28H		Yes (Y)			No (N)									Yes	Yes	Yes	Yes	Yes	Yes	Yes											
17. Operation of AVM Voltage Mode at 13.6 RV		Yes (Y)			No (N)									Yes	Yes	Yes	Yes	Yes	Yes	Yes											
Electronic Control System		Units	Low	Norm	Max																										
(4.20 found on Air Diagram page)																															
18. 2000 gal Oil Water Tank Level	LI-251	%			70%									5	5	5	5	5	5	5											
19. 10 gal gas TG Drain Tank (Air Diagram page)	LI-250	%			70%									0	0	0	0	0	0	0											
20. Record on head STD trip over 4500 rpm NL	AE50020	psig	35	20																											
20. Compressor (on line trip)	ST-01																														
21. Acknowledge Alarms Hourly		Y												✓	✓	✓	✓	✓	✓	✓											
(2.24 found on Power Management page)																															
22. Generator Current		Amps			1200									1407	1403	1297	805	802	800	796											
23. New Output		MW			27									19.3	19.4	19.3	19.0	19.2	18.9	18.7											
24. 80% Base Load Minimum		MW												17.1	16.8	16.7	16.5	16.4	16.2	16.2											
25. Running Hours (last overview)														328	326	320	311	312	313	314											
26. Ambient Temperature	TT-101													81	85	85	90	90	91	91											
(2.28 found on Gas Feed System page)																															
27. Waste Oil Tank	LI-250	%			70%									37	36	36	36	36	38	38											
28. Total Fuel Flow	Mez/h													199	198	197	193	192	192	191											

Date: **6-28-18** Signature: **A. Wain**

CGTG TURBINE

UTILITIES AND INFRASTRUCTURE

Natural Gas Compressor		Units	Low	Norm	Max	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
GAS COMPRESSOR START TIME																													
Combustible Gas Detector	AAH-303	%		0%	20%									11/9	11														
Packing Lube Oil Flow Indicator Left Side	FSL-1501B	LIGHT		BLINK										Y	Y	Y	B	B	B	B									
Liquid Level	U-7721	LIQUID		EMPTY	ANY									E	E	E	E	E	E	C									
Crankcase Bulls eye	LC-1574	LEVEL	1/4	1/2	FULL									1/2	1/2	1/2	1/2	1/2	1/2	1/2									
Oil Day Tank Level	U-1562	GAL	10		FULL									46	46	46	46	46	46	46									
Lubricator Bulls eye		LEVEL	1/2	FULL										3/4	3/4	3/4	3/4	3/4	3/4	3/4									
1st Stage Scrubber Liquid Level	U-7416	LIQUID		EMPTY	ANY									E	E	E	E	E	E	E									
2nd Stage Scrubber Liquid Level	U-7466	LIQUID		EMPTY	ANY									E	E	E	E	E	E	E									
Packing Lube Oil Flow Indicator Right Side	FSL-1501A	LIGHT		BLINK										Y	Y	Y	B	B	B	B									
1 st Stage Inlet Press.	PI-2100	psig		88	140									82	82	83	83	83	83	84									
Stage Disch. Press	PI-2101	psig		238	285									259	259	263	264	264	264	264									
2nd Stage Inlet Press	PI-2200	psig		267	285									248	249	249	250	250	252	252									
2 nd Stage Disch. Press	PI-2201	psig		575	600									578	579	579	579	579	579	579									
Final Discharge Pressure	PI-2108	psig		575	600									578	575	575	575	575	575	575									
Lube Oil Pressure	PI-1572	psig		40	60									60	59	59	59	59	59	59									
Lube Oil Temp	TE-1584	deg		150	170									164	165	166	168	168	168	169									
Final Discharge Temp	TE-2120	deg		110	150									121	125	126	130	132	133	133									
1 st Stage Cylinder Disch. Temperature A	TE-2054 A	deg		226	297									243	244	246	248	249	251	251									
2 nd Stage Cylinder Disch. Temperature A	TE-2062 A	deg		258	283									252	254	256	261	262	264	264									
1 st Stage Cylinder Disch. Temperature B	TE-2054 B	deg		226	297									240	241	241	245	245	248	248									
2 nd Stage Cylinder Disch. Temperature B	TE-2062 B	deg		258	283									251	253	255	262	264	264	264									
Motor Frame Vibration	VT-1015	IPS			0.15									0.04	0.05	0.05	0.06	0.06	0.06	0.06									
Compressor Frame Vibration	VT-1512	IPS			0.35									0.05	0.05	0.05	0.05	0.05	0.05	0.05									
Take Once per Shift / at Full Load		psig			Max psid	When the differential pressure exceeds Max psid the filter should be changed out. Notify System Engineer																							
Natural Gas Comp. Discharge Press.	A63FGDT	49-48=psid			8									575															
Double Block and Bypass Pressure														571															
Fuel Gas Supply Pressure	A63FGST	50-49=psid			20									569															

DATE 6-28-18

SIGNATURE A. Wilson

Mid Shift

Days Shift A Unit

Notes

769005

AI 856 | Los Alamos National Laboratory

Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1–June 30, 2018

ATTACHMENT A1307.E.

TA-03 Power Plant

FGR Fan Inspection and Maintenance

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002, FGR-003)
Task Dspln : **Due Date :** 01/31/2018
Superintendent :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00595731 01

MASTER

Date: 10/17/2017**Work Order Task Written To**

Facility : F08 **Unit :** **Op Sys :**
Room : **Area :** **Sys/Cls :**
Equipment : **Component :**
Location :
Job Type : PM
Tag 1 : **Tag 2 :**
Work Item : TA03-0022 FGR **Ops Review Reqd :**

Authorization

Start Permission : **Glenn Martinez** **Start Date :** **12-18-17**
Complete Notice : **Glenn martinez** **Complete Date :** **1-2-18**

Work Order Task Instructions

DO NOT lubricate the bearings if the FGR fan is NOT in operation or in service so that proper amount of grease can be applied using headphones

You can hear when grease reaches the bearing rolling element. At this point, stop adding grease to prevent bearing damage from overheating

There are two bearings on the fan, each with its own zerk plug

Remove the shaft guard located in the middle of the drive. The two zerk plugs are located on each of the two bearings

1. Use grease gun with the Ultralube headphones to insert the correct amount of Mobilith SHC 100 grease into zerk fitting
- b. Apply grease while fan is running and stop when you hear the grease enter the running bearing

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002, FGR-003)
Task Dspln : **Due Date :** 01/31/2018
Superintendent :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00595731 01

MASTER

Date: 10/17/2017

Lubricated fan bearings on FGR-001, FGR-002 & FGR-003

4. Add grease with a hand-operated pressure gun until new grease enters the running bearing
 - a. This is accomplished by using the ultrasonic sensor and headphones to hear when the new grease enters the running bearing
 - b. Stop adding grease when the grease reaches the bearing to limit excess grease from migrating down the motor shaft and into the windings

Note: Be careful when greasing the fan end bearing of the TEFC (Totally Enclosed Fan Cooled) motors. Some motors have a spring-relief outlet grease fitting on the fan end that is not accessible. This spring-relief fitting normally does not have to be removed when regreasing. When greasing, take care in the amount of pressure you apply and verify relief is working
5. Putting in too much or too little grease can cause overheating of the motors and result in motor failure. Use this rule of thumb when adding grease to a motor that has been lubricated on a regular basis:
It is better to use a little grease more often than a lot of grease less often

Note: Watch out for motors that were shipped only with the bearings packed and not the fill tube or even the bearing housing
Apply new grease until you can hear it enter the running bearing
6. Now that greasing is complete, leave the relief plug off and run the motor for 10 minutes to expel any excess grease
7. Replace the drain plug and wipe the bearing housing clean
8. Dispose of dirty rags in accordance with Hazardous Waste Guidelines
9. Ensure correct operation of electric motors.

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002, FGR-003)
Task Dspln : **Due Date :** 01/31/2018
Superintendent :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00595731 01

MASTER

Date: 10/17/2017

--

Work Completion Signatures

Name	Function/Dept.	Date
Chris Salazar	LOG-CS/PP MAINT....	01/02/2018

Comments	
(rework?)	

Cost Accounting**Cost Center :** P2030A**Activity :** 640CL000**Percentage :** 100**Acct No :** XU5000**Sub Acct :** 7E2P0000

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002,
FGR-003)
Task Dspln : **Due Date :** 01/31/2018
Superintendant :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00595731 01

MASTER

Date: 10/17/2017



Form 2101

**Integrated Work Document (IWD) Part 2,
FOD Requirements and Approval for Entry and Area Hazards and Controls**

Non-Tenant
Activity Form

IWD No./Work Request No: _____ Revision #: _____

Facility Operation Director (FOD) must determine the facility entry and coordination requirements and identify the Environment, Safety, Health (ESH)/Security and Safeguards (S&S) hazards and controls associated with the activity location.

FOD 8	TA 3	Bldg 22	Room N/A	Other Location Power Plant Bldg - Inside
FOD Designated Facility Point-of-Contact	Name Pablo C de Vaca	Phone 699-8226	Pager N/A	Email pfc@lanl.gov

Entry and Coordination Requirements (Check one or more of the following)

- | | |
|--|---|
| <input type="checkbox"/> No Entry/Coordination Requirements | <input type="checkbox"/> FOD-designated facility Point-of-Contact must sign IWD Part 3 |
| <input checked="" type="checkbox"/> Plan of the Day/Plan of the Week (POTD/POTW) | <input checked="" type="checkbox"/> Check in at Start of Work <input checked="" type="checkbox"/> Work-Area Training Required |
| <input checked="" type="checkbox"/> Security Clearance Requirements | <input checked="" type="checkbox"/> Work must be Scheduled <input checked="" type="checkbox"/> Check in Daily |
| <input type="checkbox"/> Co-located Hazards/Concerns | <input type="checkbox"/> Other Security Requirements (ex.: Cellphone, No Foreign Nationals, etc.) |
| <input checked="" type="checkbox"/> Check out at End of Work | <input type="checkbox"/> Quality Issues <input checked="" type="checkbox"/> Check out Daily |
| <input type="checkbox"/> Escort Required | <input type="checkbox"/> Review under Authorization Basis (AB)/Safety Basis/Unreviewed Safety Question (USQ) |
| <input type="checkbox"/> Other Bounding Conditions: | |

PIC is responsible to conduct a pre-job brief for work activities to ensure that work conditions and worker communications are adequate. A pre job briefing shall be conducted at the job site. UI-OPS will determine if onsite ESH representation is required during work activities

Additional Comments (refer to Job Hazard Analysis [JHA] Tool Facility Notes)

All work must be approved by the Utilities FOD or UI-OPS. POD/POTW-contact Facility POC. No Smoking around Natural Gas Systems. Evaluate inside floor and housekeeping conditions to safely proceed with activities. Check in with Plant Operations Manager/Specialist or Operations Shift Head for final approval to proceed with tasks. Work around power plant chemical pumps and lines. Inspect for leaks before beginning any work task and pause work and report if a leak is found to operations. All personnel entering area must view the site specific training video in room 116 (Boiler Control Room), one time requirement. Observe safety signs and floor markings in all buildings and areas. No safety shoes required for visitors if escorted by Operations or UI Engineering personnel. The West end front lobby and office areas of Bldg 22 are considered a no hazard area.

Instructions: In the block below, identify work-area hazards that could potentially affect the worker(s) or others. Specify the facility controls and preventive measures that must be implemented by the worker(s) to protect against the site hazards as well as any special training required.

ESH/S&S WORK AREA HAZARDS & CONTROLS

Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
<input type="checkbox"/> No Work Area Hazards				

Form 2101 (6/12)

Page 1

Ionizing Radiation Work in posted radiological areas, work with radioactive materials, or work on or near radiation producing devices Specify Hazard:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
---	---	--	--	--

IWD No./Work Request No: _____ Revision #: _____

ESH/S&S WORK AREA HAZARDS & CONTROLS				
Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
Worker Exposure Working near non-ionizing radiation, beryllium, noise, chemicals, hazardous biological materials, lead, asbestos, temperature/humidity extremes, or high explosives. Specify Hazards:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Required PPE: Hard hat, safety shoes, safety glasses. Hearing protection (noise > 85 dba). Avoid hot surfaces and piping. Long sleeve shirt or Ansell sleeves or coveralls. Gloves when operating valves or contacting pipe/fitting openings where there is potential for hot water/steam release.</p> <p>Be aware of encapsulated asbestos. Follow LANL Asbestos program/rqmts if PACM identified outside containment.</p> <p>Be aware of chemical containers and check labeling. Be aware of piping, associated systems for any leaks. If chemical leak is noticed contact operations manager, IH&S Rep during regular working hrs. Over 100 gallons of a chemical spill leave area, and control</p>	P101-6 PPE • P101-23 Asbestos • P101-31 Hearing Conservations/Noise Program	LANL PPE or equivalent • Hearing protection • Site specific training • Asbestos awareness

		access. Call Serf Operators 667-8982 or by Radio Lanl 2 Util 6 For mitigation cleanup process. For after-hours contact the UI Duty Officer, 699-7452 to re-assess any abnormal situation		
Energized and Operative Systems Working near energized electrical parts, pressure systems, steam lines; near unprotected belts, pulleys, chains or rotating equipment; fuel fired equipment other than vehicles; or spark or flame producing operations. Specify Hazards: Energized/rotating equipment, High Temperature, High Pressure Water and Steam equipment.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Stay within established walking areas. Observe safety signage alarm lights and horns. Identify explosive hazards and follow task specific IWD if working on plant equipment or components. Note: All TA3-22 independent verification requirement will be determined by the FOD or FOD designee. If questions consult with UI system engineer, Operation Mgr, Designee, or Safety rep.	P101-13 Electrical Safety P101-3 LOTO P101-34 Pressure, Vacuum, and Cryogenic System.	Site Specific Training video. Electrical Safety LOTO if applicable to task.
Confined Spaces Entry into tanks, manholes, cooling towers, sumps, or any other area with potentially low oxygen concentration or other hazards such as toxic vapors or engulfment. Specify Hazards:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Observe confined space signs or markings and follow LANL Confined Space Requirements if task requires confined space entry.	P 101-27 Conf. Space	Confined Space Training
Elevated Work Surface Elevated work when fall protection is not provided by conventional handrail systems or required per <u>P101-20, Fall Protection Program</u>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Stay within established walking areas, stairways and paths. Observe safety signage. Follow LANL Fall Protection Requirements if task on roofs or work above 4 feet.	P101-20 Fall Protection	Fall Protection
Environmental Impact Activities conducted in areas containing potential release site, contaminated soil, sensitive species, watercourse wetlands, floodplain, historical/archeological sites, or other work area condition that can be impacted by or can impact the environment.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			

Specify Hazards:				
Security Requirements Specify:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Other Hazards Specify: Look-alike Equipment in the vicinity of work site may contain un-controlled hazardous energy	<input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Adequately barriers and controls will be established to prevent unauthorized personnel/workers from entering job site and encounter uncontrolled hazards.	IWD	Pre-job briefing emphasis. Worker confirmation of look-alike potential hazards, locations and barriers set in place to identify those potential hazards.

I have verified that the hazards identified above adequately identify the area hazards and that the IWM process has been applied appropriately.

FOD or Representative (Signature/Z #/Date) Approval Required Pablo F. CdeVaca

Digitally signed by Pablo F. CdeVaca
DN: cn=Pablo F. CdeVaca, ou=LANL, email=pf@lanl.gov, c=US
Date: 2017.09.26 11:53:41 -0600

Date Approval Expires: 09/30/2020



AP-WORK-004: Attachment 1
Maintenance & Site Services
Worker Engagement Questions

Worker engagement questions are intended to focus attention on the task and ensure uncertainties are addressed. Examples of worker engagement questions are provided below. Worker engagement questions should be tailored to the situation.

Each of the questions listed below will be discussed at each Pre-Job Brief with all affected personnel.

Topic	Completed (X)
FGR Imo Lube 01/02/18	
What permits, permissions, or support are required to safely start this work?	X
What is the most likely thing that could go wrong (not the worst thing) and what, specifically, will prevent it?	X
What can cause us to go beyond the scope of the work?	X
What hazards in the work area may not have been considered during planning of this job?	X

Pre-job by C. Salazar Z# 202847

Facility : F08 Unit : Proj :
Task Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS
W/O Type : PM W/O Group : UTIL Task Priority : 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS
Written To : TA03-0022 VARIABLE FREQUENCY DRIVES VID/VFD/FGR
Task Dspln : Due Date : 01/31/2018
Superintendant :
Hazard : MODERATE IWD Reqmt : TASK SPECIFC

Work Order Task

00595745 01

MASTER

Date: 10/17/2017

Work Order Task Written To

Facility : F08 Unit : Op Sys :
Room : Area : Sys/Cls :
Equipment : Component :
Location :
Job Type : PM
Tag 1 : Tag 2 :
Work Item : SM22VID Ops Review Reqd :

Authorization

Start Permission : Robert Simpson 1/9/2018

Complete Notice : Robert Simpson 1/26/2018

Work Order Task Instructions

CRAFT: UICS ELECTRICIANS

FURTHER INSTRUCTIONS/DETAILS

LOTO OF EACH UNIT TO CLEAN INTERNALLY THE INSIDE OF EACH VFD PANEL
TASK IS TO BE DONE THE USE OF COMPRESSED AIR AND A VACUUM CLEANER. REMOVE
ALL DUST AND DEBRIS FROM THE ENCLOSURES

Facility : F08 **Unit :** **Proj :**
Task Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS
Written To : TA03-0022 VARIABLE FREQUENCY DRIVES VID/VFD/FGR
Task Dspln : **Due Date :** 01/31/2018
Superintendent :
Hazard : MODERATE **IWD Reqmt :** TASK SPECIFC

Work Order Task

00595745 01

MASTER

Date: 10/17/2017QC Requirements / CommentsWork Completion Signatures

Name	Function/Dept.	Date
Carlos Chacon	UPES Electricians	1-25-18
Comments <input type="checkbox"/> None (rework?) <input type="checkbox"/> No		

Cost Accounting**Cost Center :** P2030A**Activity :** 640CL000**Percentage :** 100**Acct No :** XU5000**Sub Acct :** 7E2P0000

Facility : F08 Unit : Proj :
Task Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS
W/O Type : PM W/O Group : UTIL Task Priority : 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS
Written To : TA03-0022 VARIABLE FREQUENCY DRIVES VID/VFD/FGR
Task Dspln : Due Date : 01/31/2018
Superintendant :
Hazard : MODERATE IWD Reqmt : TASK SPECIFC

Work Order Task

00595745 01

MASTER

Date: 10/17/2017



Integrated Work Document (IWD) Part 3, Validation and Work Release

IWD # _____ REVISION #: _____ **WORK RELEASE**

By signing below, I verify this activity is compatible with current facility configuration and operating conditions.

FOD designated Ops Mgr or other facility point-of-contact for work area

Signature/Z#/Date (If required by FOD): _____

Note: For Standing IWD, release may be given concurrently with signatures on Part 2.

By signing below, I have verified the following:

- I have verified authorization by ensuring approval signatures of the RLM and FOD.
- I have jointly conducted a validation walkdown with workers to confirm the IWD can be performed as written, required initial conditions and other prerequisites are in-place.
- The assigned workers are authorized and are qualified to perform the work in a safe, secure, and environmentally responsible manner.
- I have conducted the pre-job briefing, and all workers (including support workers) have been briefed.
- I have ensured coordination with any required FOD work-area representatives (e.g., area work coordinators).

Primary PIC (Signature/Z#/Date) Required: _____

Alternate PIC Signatures **acknowledges** PIC authority is assumed for the first time (Note: Alternate PICs are required to sign only once, but formal handoff includes conferring with previous PIC to obtain all required information associated with the handoff).

Alternate PIC (Signature/Z#/Date) Required: _____

Alternate PIC (Signature/Z#/Date) Required: _____

Pre-Job Brief Content

- What are the critical steps or phases of this activity?
- How can we make a mistake at that point?
- What is the worst thing that can go wrong?
- What controls, preventive measures, and bounding conditions are needed?
- What work permits are required and how will we meet their requirements?
- What are the handoffs and coordination requirements among workers and multiple PICs?
- Are there hold-points including those that require sign-offs?
- What are the pause/stop work responsibilities and expectations (e.g. for unanticipated conditions or hazards)?
- How would we respond to alarms and emergencies?
- Are there lessons learned from previous similar work?
- Is other information needed to perform this activity in a safe, secure, and environmentally responsible manner?
- Does everyone agree to the work tasks/steps, hazards, and controls and commit to follow them?

Pre-Job Brief Attendance Roster

By signing below **as required**, I agree to the following:

- I agree to follow the work steps and implement the controls as written as applicable to my work assignments.
- I agree to pause/stop work when conditions or hazards change or when I encounter unexpected conditions during the execution of work, or when work cannot be performed as written, or instructions become unclear during execution.
- I confirm that I am authorized, qualified, and fit to perform the work.

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Attachment B, LO/TO Orders

Lock Coordinator Name/Z#	Phone #	Alternate Lock Coordinator Name/Z#	Phone #
---------------------------------	----------------	---	----------------

Section 1: General Information			
1. Work Document Number (i.e., Package/Procedure #):		2. LO/TO (Parent) Record #	
3. Date:			
Location			
4. TA:	5. Bldg:	6. Rm:	7. Equipment/Machinery/Name/Number:
8. Reason for LO/TO:			
9. Name of Equipment Owner/Operator:			
10. Energy Type to be Isolated (check all that apply)			
<input type="checkbox"/> Electrical <input type="checkbox"/> Mechanical <input type="checkbox"/> Hydraulic <input type="checkbox"/> Pneumatic <input type="checkbox"/> Steam <input type="checkbox"/> Capacitors <input type="checkbox"/> Compressed Energy <input type="checkbox"/> Gravity <input type="checkbox"/> Other (specify):			
11. Group LO/TO: <input type="checkbox"/> Yes <input type="checkbox"/> No		12. Group Lock Box used: <input type="checkbox"/> Yes <input type="checkbox"/> No	
If Yes, Name of Lead Authorized Worker:		If yes, enter ID# of Lock Box Lock Box ID:	
13. Sequencing Required for LO/TO <u>Installation</u>		14. Sequencing Required for LO/TO <u>Removal</u>	
If Yes, enter the required sequence in column 20 below. If No, place N/A in column 20 below.		If Yes, enter the required sequence in column 28 below. If No, place N/A in column 28 below.	
<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes <input type="checkbox"/> No	
Section 2: LO/TO Installation & Removal			
LO/TO Installation		LO/TO Removal / Return to Service	
15. Approval to Install LO/TO (signature & Z#)		24. Approval to Remove LO/TO (signature & Z#). Call #	
16. Verification required for LO/TO Installation		25. Verification required for LO/TO Removal	
<input type="checkbox"/> No <input type="checkbox"/> Peer Concurrent Dual <input type="checkbox"/> Independent Verification		<input type="checkbox"/> No <input type="checkbox"/> Peer Concurrent Dual <input type="checkbox"/> Independent Verification	
17. Verification Determination Approved by FOD/Designee (signature)		26. Verification Determination Approved by	
Z#		Z#	
Date		Date	
18. Specific Energy Isolation Device/ID	19. Location of locking Device	20. LO/TO Installation Sequence	21. Required Position/Alignment for LO/TO
22. LO/TO Installation verified By:	27. Required Position/Alignment following Removal		
	28. LO/TO Removal Sequence	29. LO/TO Removal Verified By:	30. As-Left Position
23. LO/TO Points Positioned and First Lock installed by Signature		31. LO/TO Removed, Positioned and Verified by Signature	
Z#		Z#	
Date		Date	

Attachment B, LO/TO Orders

Attachment B, LO/TO Orders (Cont.)			
1. Work Document Number (i.e., Package/Procedure #):		2. LO/TO (Parent) Record #	3. Date:
32. Zero Energy Checks have been completed <input type="checkbox"/> Yes <input type="checkbox"/> No		33. Completed by Signature Z# Date	
Section 3: Lead Authorized Worker and Authorized Workers (anyone applying a lock for this activity)			
34. Authorized Workers Name(s)	Z#	35. Date workers lock is hung	36. Date workers lock is removed
1.			
2.			
3.			
4.			
5.			
6.			
7.			
8.			
9.			
10.			
Section 4: Return of Lock(s)/Tag(s) and Locking Devices			
All Lock(s)/Tag(s) and Locking Devices have been removed and returned to the Lock Coordinator or Designee			
37. Signature of Lock Coordinator or Designee		Z#	Date

*If you have questions with regards to filling out the Attachment B, LO/TO Orders form, see the directions associated with the form.

*Take the completed forms back to the Lock Coordinator or Designee for closeout.

Continuation Page (print as needed)Rev 1. Page 3 of 5

Attachment B, LO/TO Orders

The following are directions for filling out Attachment B.

1. Enter the Work Document Number, this will be the number from the IWD or the procedure number (i.e., TA88-DOP-0001)
 2. Enter the LO/TO Parent Record number, this is obtained from the Lock Coordinator when the HEC lock(s) are issued. The Remedy LO/TO database issues this number.
 3. Enter the date of when the locks will be applied.
 4. Enter the TA where the lock(s) will be hung.
 5. Enter the Building number of where the lock(s) will be hung.
 6. Enter the Room number where the equipment is located/where work is being performed.
 7. Enter the Equipment/Machinery/Name/Number (example, HVA-001)
 8. Write a brief description of the reason for LO/TO (example, Removing and replacing belts)
 9. Enter the Name of the Equipment Owner/Operator. Each FOD is different in the assigning of Equipment Owner/Operators. There are also programmatic Equipment Owner/Operators.
 10. Check the appropriate energy type to be isolated, check all that apply. Make sure you have considered all energy sources, if other you will need to specify what "other" is.
 11. Check applicable box to identify if a group LO/TO (A LO/TO where two or more authorized workers, regardless of their occupation or craft, lock out and tag out the same equipment to perform servicing or maintenance).
 12. Check applicable box if lock box is used for the job. Enter the lock box ID#. Each organization that issues locks will be required to uniquely number and track lock boxes in their possession.
 13. When installing the lock(s)/tag(s), is there a specific sequence in which the isolation devices are to be positioned. If a specific sequence must be followed, THEN number the sequence order in column 20. If there is not a specific sequence to follow then place N/A in column 20. This needs to be an operations type person (Operator) who understands the equipment/system/component.
 14. When removing the lock(s)/tag(s), is there a specific sequence in which the isolation devices are positioned after lock/tag removal? If a specific sequence must be followed, THEN number the sequence order in column 28. If not, place N/A in the box(s).
- NOTE:** Section 2, LO/TO Installation & Removal – In some of the nuclear facilities, the operations personnel will identify the required position(s) for credited equipment/machinery depending on operational requirements for return to service. In most cases when workers remove locks, the "As-Left" Position will be different then the final position the operations personnel will place the equipment in.
15. The Equipment Owner/Operator signs and enters their Z#, authorizing the installation of the LO/TO. With some FODs this will be the maintenance coordinators.
 16. Is verification required for this LO/TO. Determine if this is Peer Verification (see P101-3, Section 3.15) or Concurrent Dual verification (see P315, Attachment 10, Section 10.3.6), or Independent Verification. For Independent Verification see P315, Attachment 10, Independent Verification, The Operations Manager (OM) prepares and maintains a facility-specific list of systems and components requiring Independent Verification.

Attachment B, LO/TO Orders

17. The FOD/Designee must sign after determining if verification is required. If Independent Verifier is identified at this time then it must be entered into the Remedy database.
18. Enter the specific Energy isolation device/ID, (example, MCC-A, A4)
19. Location of locking device, this is the location of where the lock is applied (example, MCC-A, A4 TA-XX, Bld. XXX, rm. 123)
20. If the LO/TO needs to be installed in a particular order, number the order in which the locks need to be installed. If the "No" box is checked in #13, then place N/A in this column.
21. Required Position/alignment for LO/TO, open, closed, connected, disconnected, on, off, etc.
22. LO/TO installation verified by – Has the equipment /system/component being locked out, been identified by the FOD as requiring verification, see #16. If verification is required the person who performed the verification initials here.
23. The Lead Authorized worker positions the LO/TO points and installs his/her lock and signs that this has been completed.
24. This is the person, who authorized the LO/TO to be removed, signs and places his/her Z# in this box. This signature authority may place a phone number here for the Lead Authorized worker to call for authorization to remove the LO/TO. When verbal authorization is given, it must be documented in this section. Example: John Smith per telecom, 8/13/14 and your initials. Note: It is also permissible to pre-authorize the removal of the lock by pre-signing.
25. Depending on the verification type required for LO/TO removal, check the appropriate verification type box, otherwise check the "No" box.
26. If verification is required, the FOD/Designee must sign. Independent Verifier is identified at this time and entered into the database.
27. Write the required position/alignment the system/component will be placed in following the removal of the lock(s).
28. If the isolation device needs to be positioned in a particular order/sequence, (per Post Maintenance) number the order/sequence in which the isolation device is to be position. If not, place N/A in the box(s).
29. LO/TO removal verified by Lead Authorized Worker – the lock(s) have been removed and the As-Left position is documented in column 30.
30. Enter the As-Left Position.
31. If the removal of the lock has been identified as needing to be verified, the verifier writes name and Z# after verifying the lock has been removed.
32. The authorized worker must verify that the steps utilized in the energy control procedure have effectively isolated the machine or equipment from the hazardous energy.
33. The authorized worker signs after zero energy checks have been completed.
34. All authorized workers applying a lock for this activity names/Z# and the Date must be entered.
35. Enter the date the authorized worker hangs lock.
36. Enter the date the authorized worker removes lock.
37. The Lock Coordinator or designee signs once locks, tags, and locking devices have been removed and returned. If a lock and/or tag are found to be contaminated then that will be noted by the Lock Coordinator or designee and the Lock Coordinator or designee will sign.



Form 2101

Integrated Work Document (IWD) Part 2, FOD Requirements and Approval for Entry and Area Hazards and Controls

Non-Tenant
Activity Form

IWD No./Work Request No: _____

Revision #: _____

Facility Operation Director (FOD) must determine the facility entry and coordination requirements and identify the Environment, Safety, Health (ESH)/Security and Safeguards (S&S) hazards and controls associated with the activity location.

FOD 8	TA 3	Bldg. 22	Room N/A	Other Location Power Plant Bldg - Inside
FOD Designated Facility Point-of-Contact	Name Pablo C de Vaca	Phone 699-8226	Pager N/A	Email pfc@lanl.gov

Entry and Coordination Requirements (Check one or more of the following)

- | | |
|--|---|
| <input type="checkbox"/> No Entry/Coordination Requirements | <input type="checkbox"/> FOD-designated facility Point-of-Contact must sign IWD Part 3 |
| <input checked="" type="checkbox"/> Plan of the Day/Plan of the Week (POTD/POTW) | <input checked="" type="checkbox"/> Check in at Start of Work <input checked="" type="checkbox"/> Work-Area Training Required |
| <input checked="" type="checkbox"/> Security Clearance Requirements | <input checked="" type="checkbox"/> Work must be Scheduled <input checked="" type="checkbox"/> Check in Daily |
| <input type="checkbox"/> Co-located Hazards/Concerns | <input type="checkbox"/> Other Security Requirements (ex : Cellphone, No Foreign Nationals, etc) |
| <input checked="" type="checkbox"/> Check out at End of Work | <input type="checkbox"/> Quality Issues <input checked="" type="checkbox"/> Check out Daily |
| <input type="checkbox"/> Escort Required | <input type="checkbox"/> Review under Authorization Basis (AB)/Safety Basis/Unreviewed Safety Question (USQ) |
| <input type="checkbox"/> Other Bounding Conditions: | |

PIC is responsible to conduct a pre-job brief for work activities to ensure that work conditions and worker communications are adequate. A pre job briefing shall be conducted at the job site. UI-OPS will determine if onsite ESH representation is required during work activities

Additional Comments (refer to Job Hazard Analysis [JHA] Tool Facility Notes)

All work must be approved by the Utilities FOD or UI-OPS. POD/POTW-contact Facility POC. No Smoking around Natural Gas Systems. Evaluate inside floor and housekeeping conditions to safely proceed with activities. Check in with Plant Operations Manager/Specialist or Operations Shift Head for final approval to proceed with tasks. Work around power plant chemical pumps and lines. Inspect for leaks before beginning any work task and pause work and report if a leak is found to operations. All personnel entering area must view the site specific training video in room 116 (Boiler Control Room), one time requirement. Observe safety signs and floor markings in all buildings and areas No safety shoes required for visitors if escorted by Operations or UI Engineering personnel. The West end front lobby and office areas of Bldg 22 are considered a no hazard area.

Instructions: In the block below, identify work-area hazards that could potentially affect the worker(s) or others. Specify the facility controls and preventive measures that must be implemented by the worker(s) to protect against the site hazards as well as any special training required.

ESH/S&S WORK AREA HAZARDS & CONTROLS

Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
<input type="checkbox"/> No Work Area Hazards				

Ionizing Radiation Work in posted radiological areas, work with radioactive materials, or work on or near radiation producing devices. Specify Hazard:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
--	---	--	--	--

IWD No./Work Request No: _____

Revision #: _____

ESH/S&S WORK AREA HAZARDS & CONTROLS

Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
Worker Exposure Working near non-ionizing radiation, beryllium, noise, chemicals, hazardous biological materials, lead, asbestos, temperature/humidity extremes, or high explosives. Specify Hazards:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Required PPE: Hard hat, safety shoes, safety glasses, Hearing protection (noise > 85 dba). Avoid hot surfaces and piping. Long sleeve shirt or Ansell sleeves or coveralls. Gloves when operating valves or contacting pipe/fitting openings where there is potential for hot water/steam release.</p> <p>Be aware of encapsulated asbestos. Follow LANL Asbestos program/rqmts if PACM identified outside containment.</p> <p>Be aware of chemical containers and check labeling. Be aware of piping, associated systems for any leaks. If chemical leak is noticed contact operations manager, IH&S Rep during regular working hrs. Over 100 gallons of a chemical spill leave area, and control</p>	P101-6 PPE • P101-23 Asbestos • P101-31 Hearing Conservations/Noise Program	LANL PPE or equivalent • Hearing protection • Site specific training • Asbestos awareness

		access. Call Serf Operators 667-8982 or by Radio Lanl 2 Util 6 For mitigation cleanup process. For after-hours contact the UI Duty Officer, 699-7452 to re-assess any abnormal situation		
Energized and Operative Systems Working near energized electrical parts, pressure systems, steam lines; near unprotected belts, pulleys, chains or rotating equipment; fuel fired equipment other than vehicles; or spark or flame producing operations Specify Hazards: Energized/rotating equipment, High Temperature, High Pressure Water and Steam equipment.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Stay within established walking areas. Observe safety signage alarm lights and horns. Identify explosive hazards and follow task specific IWD if working on plant equipment or components. Note: All TA3-22 independent verification requirement will be determined by the FOD or FOD designee. If questions consult with UI system engineer, Operation Mgr. Designee, or Safety rep.	P101-13 Electrical Safety P101-3 LOTO P101-34 Pressure, Vacuum, and Cryogenic System.	Site Specific Training video. Electrical Safety LOTO if applicable to task.
Confined Spaces Entry into tanks, manholes, cooling towers, sumps, or any other area with potentially low oxygen concentration or other hazards such as toxic vapors or engulfment. Specify Hazards:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Observe confined space signs or markings and follow LANL Confined Space Requirements if task requires confined space entry.	P 101-27 Conf. Space	Confined Space Training
Elevated Work Surface Elevated work when fall protection is not provided by conventional handrail systems or required per <u>P101-20, Fall Protection Program</u>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Stay within established walking areas, stairways and paths. Observe safety signage. Follow LANL Fall Protection Requirements if task on roofs or work above 4 feet.	P101-20 Fall Protection	Fall Protection
Environmental Impact Activities conducted in areas containing potential release site, contaminated soil, sensitive species, watercourse wetlands, floodplain, historical/archeological sites, or other work area condition that can be impacted by or can impact the environment.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			

Specify Hazards:				
Security Requirements Specify:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Other Hazards Specify: Look-alike Equipment in the vicinity of work site may contain un-controlled hazardous energy	<input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Adequate barriers and controls will be established to prevent unauthorized personnel/workers from entering job site and encounter uncontrolled hazards.	IWD	Pre-job briefing emphasis. Worker confirmation of look-alike potential hazards, locations and barriers set in place to identify those potential hazards.

I have verified that the hazards identified above adequately identify the area hazards and that the IWM process has been applied appropriately.

FOD or Representative (Signature/Z #/Date) Approval Required Pablo F. CdeVaca

Digitally signed by Pablo F. CdeVaca
DN: cn=Pablo F. CdeVaca, o=LANL, ou=LA, email=pfcd@lanl.gov, c=US
Date: 2017.06.16 11:52:41 -0600

Date Approval Expires: 09/30/2020




AP-WORK-004: Attachment 1 Maintenance & Site Services Worker Engagement Questions

Worker engagement questions are intended to focus attention on the task and ensure uncertainties are addressed. Examples of worker engagement questions are provided below. Worker engagement questions should be tailored to the situation.

Each of the questions listed below will be discussed at each Pre-Job Brief with all affected personnel.

Topic	Completed (X)
What permits, permissions, or support are required to safely start this work?	✓
What is the most likely thing that could go wrong (not the worst thing) and what, specifically, will prevent it?	✓
What can cause us to go beyond the scope of the work?	✓
What hazards in the work area may not have been considered during planning of this job?	✓

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0			Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD
Work Document #: (WO # / Task)			Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16
TA: 03	Building: 0022	Room:	Additional Location Description:

1.0 Work Scope

This work order task will cover the moderate hazard maintenance within the Power Plant Complex. All work will be performed in accordance with work order title and task instructions. UI Procedures will be referenced in the work order task instructions when applicable. This IWD is considered the controlling document for the work being covered.

2.0 Hazard Identification and Mitigation

2.1 Entry Conditions

- PAUSE/STOP WORK if steps cannot be completed as described, or if unforeseen situations occur. Stabilize the situation if safe, contact your supervisor or Person-In-Charge (PIC), and await further instructions before proceeding
- Ensure activity is on appropriate Plan(s) of the Day
- Check-in with ops prior to performing work
- Steps in this procedure may be worked out of sequence as directed by supervisor/PIC
- Ensure permits required for the work have been approved and posted, as required
- PIC will be available while work is being conducted
- PIC will review site specific hazards noted on IWD Part 2, Form 2101 with all workers
- All hold points will be discussed on a daily basis
- Verify all identified hazards have been eliminated, mitigated or minimized


(HAZARD ANALYSIS performed by Robert Simpson, art sparks– 9/9/2015)

2.2 Electrical

- Arc Flash: Follow PPE requirements and barricade area in accordance with the arc flash label for the specified equipment.

2.3 Mechanical

- Ensure all guards are in place before accessing equipment.
- Relieve all stored energy before performing maintenance activities.

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0			Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD
Work Document #: (WO # / Task)			Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16
TA: 03	Building: 0022	Room:	Additional Location Description:

2.4 Pneumatic

- Relieve all stored pressure.
- Ensure all fittings and hoses are inspected prior to use. Utilize safety devices on the fittings.

2.5 Elevated Work

- Ensure all scaffolding/ladders are inspected daily before use.
- Utilize fall protection equipment when required with approved tie-off points.
- Maintain 3-points of contact when utilizing a ladder
- Ensure ladder is properly oriented to work
- Scaffolding shall be erected and inspected by a competent person only

2.6 Hot Surfaces

- Wear long sleeve shirts or Ansell sleeves when working near hot surfaces.
- Utilize insulating blankets to protect against hot surfaces.

2.7 Welding, Grinding / Torch Cutting

- Use appropriate welding procedure checklist
- Keep combustible materials clear or protect surrounding
- Wear welding hood with appropriate lens for welding operation performed. Wear welding gloves.
- Ensure adequate ventilation or use welding fume extractor
- Spark and flame permit required

2.8 Chemical

- Consult IH&S for PPE requirements
- Place a catch pan under chemical and collect all residual chemicals.
- Review and follow the safety data sheets for all chemical and oil products.
- An eyewash station and safety shower must be within 10 seconds of where the chemicals are being used. Verify eyewash and safety shower have a current inspection.
- Wear chemical goggles for liquids
- PPE must be worn completely and properly

2.9 Slip, Trip & Fall:

- Be aware of ground and floor conditions

2.10 Back Strains


- Use proper lifting and bending technique at all times

2.11 Simple Hand Tools, Cuts & Abrasions:

- Inspect all tools prior to use, wear proper work gloves as determined by the job scope.
- Use of cordless power tools, power tools-electric shock.
- Use all tools properly and to safety standards. Inspect cords / batteries prior to use. GFCI protection required.

2.12 Pinching or Crushing

- Do not place body parts in the path of potential pinch points or crush points
- Hand / foot / body position awareness
- Be aware of line of fire

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0			Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD
Work Document #: (WO # / Task)			Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16
TA: 03	Building: 0022	Room:	Additional Location Description:

2.13 Asbestos Abatement Pipe and Equipment Insulation:


- Reference MSS Procedure 41-55-001-R1
- Area regulated to OSHA standards(29CFR1926.1101(e) and paragraph (j) decontamination area
- Two person rule is required during abatement
- Personal air monitoring will be required.
- Full face APR with P100 cartridges.
- Wear Tyvek coveralls with booties and hood, protection with full body coverage from head to toe.
- Wear nitrile gloves and/or leather gloves
- HEPA vacuum debris.
- Asbestos will be removed using hand tools and wet methods using amended wetting solution and wipes.
- All asbestos wastes must be kept damp enough during handling and disposal operations to prevent fibers from becoming airborne, but must not have any free liquid present during transportation.

2.14 LO/TO:

- Utilize LO/TO Attachment
- Wear Untreated Natural Fiber Shirt (long sleeve), Pants (long), Safety glasses or safety goggles, Hearing protection (ear canal inserts) and Leather gloves.

2.15 230V to 1000V Zero Voltage check requirements:

- Mode "1" Class 1.3 a,b
- Wear CAL 8+ PPE: Double-Layer switching hood.
- Class 0 Dielectric Gloves.
- AR coveralls (with an arc rating of 8 or more), hardhat, and safety glasses underneath hood.
- 2-man rule applies.
- Use NRTL approved voltage meter. Test meter on a known live circuit before and after zero voltage verification.
- No metallic objects worn.
- Voltage rated test equipment.
- Ensure no un-insulated body part enters prohibited space.
- Voltage rated tools.

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

2.16 50V to 230V Zero Voltage check requirements:

- Mode "1, Class 1.2 a,b
- Use NRTL approved calibrated voltage meter. Test meter on a known live circuit before and after zero voltage verification.
- Class "0" Dielectric Gloves
- AR clothing, minimum arc-rating of 4 cal for voltage of < 230 V (long sleeve shirt & pants of non-melting fabric or coveralls, face shield)
- AR Protective Equipment (hard hat, safety glasses or safety goggles, hearing protection).
- No metallic objects worn.
- Voltage rated test equipment.
- Ensure no un-insulated body part enters prohibited space.
- Voltage rated tools.

2.17 Cone of Safety Identification:


- The Cone of Safety as defined P101-25.0 Cranes, Hoists, Lifting Devices, and Rigging Equipment shall be identified.
- Time/distance requirements shall be assured by the LANS Hoisting/Rigging Supervisor throughout all lifts.
- Ensure lift plan is completed for all critical lifts.

2.18 General PPE Requirements for working within the Power Plant Complex:

- Safety shoes
- Safety glasses with side shields
- Hard hat
- Reflective Safety Vest
- Leather work gloves
- Hearing Protection at all times within the Power Plant. A noise evaluation shall be made by a safety engineer for other work as required.

Approach Boundaries

Voltage (VAC)	Limited Approach	Restricted Approach
50-300	3'-6"	Avoid Contact
301-750	3'-6"	1'-0"

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16	
TA: 03	Building: 0022	Room:	Additional Location Description:


3.0 Training Requirements

- 3.1 MSS Maintenance Worker, TP 10968
- 3.2 LO/TO, TP 127
- 3.3 Electrical Worker Training, Curriculum 642
- 3.4 Stationary Equipment Mechanics, Curriculum 630
- 3.5 Sheet metal Workers, Curriculum 649
- 3.6 Pipefitters, Curriculum 647
- 3.7 Carpenters, Curriculum 641
- 3.8 Insulators, Curriculum 643
- 3.9 Power Plant Operators, Curriculum 632
- 3.10 Confined space entry, supervisor and attendant (for entry)
- 3.11 Training to work with Cranes and Rigging:
 - Incidental Crane Classroom course # 20295
 - Incidental Crane Exam # 20296
- 3.12 Site Specific Training (one-time requirement)

4.0 Work Execution

4.1 Notes

- Following system conditions are configuration and conditions which have been anticipated for performance of PM activities covered under this IWD:
 - Electrical power systems are in a configuration which will support nominal steam plant operations. No major disruptions or outages are present and electrical system lineup is considered to be in a normal configuration.
 - Steam plant may either be in shutdown, standby or normal operation configuration. Mechanical components are under control of steam plant operations personnel and no major upset conditions or unanticipated outages are present within facility.
 - Power Plant operations personnel are manned to required level and sufficient support is available to support performance of maintenance activity.

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

- Permits required for this work: LO/TO Attachment, confined space.
- LO/TO devices shall be applied in accordance with P101-3. "Lockout/Tagout for Hazardous Energy Control"
- Discuss emergency evacuation procedures and muster areas
- Discuss possible error situations and mitigations

4.2 Prerequisites

- VERIFY pre-job briefing has been performed for all affected personnel including 2101 hazards

PIC:  Z#: 12093 Date: 3-19-18

- VERIFY all personnel have the appropriate PPE for job execution
- BARRICADE work area to protect against inadvertent access
- USE robust barriers and flagging to clearly define execution area
- VERIFY all required permits are approved and posted as required
- REVIEW planned activity for Life Critical Steps (to be performed by the PIC/RLM):

2101 2101	IF fall protection is to be used: <ul style="list-style-type: none"> • VERIFY that a safety system is in place (where workers understand hazard controls and required PPE) at work site. • VERIFY workers understand fall protection plan <p>PIC: <u>N/A</u> Z#: _____ Date: _____</p>
	IF aerial platform/lift is to be used: <ul style="list-style-type: none"> • VERIFY a clear travel path with all necessary clearances is defined and adequate • VERIFY geographic terrain will support execution of activity • VERIFY identification of all energized electrical systems, structure and components has occurred and their impact to activity has been accounted for and communicated to workers • VERIFY all personnel are qualified to operate aerial lift device assigned to activity. <p>PIC: <u>N/A</u> Z#: _____ Date: _____</p>


Confined Spaces: Complete confined space permit per the CSP evaluation.

Perform ventilation and air monitoring according to the evaluation.

Set up non-entry rescue equipment if required by the evaluation.

Contact pest control, as required to remove rodents and droppings.

Pest control to use 10% bleach solution and full face respirator.

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

4.3 Execution

1. **ERECT/DISMATLE** scaffolding as needed to access work area
 - INSPECT scaffold daily by competent person only
 - WEAR hard hats when working on / near scaffold
2. **PERFORM** LO/TO when required to perform maintenance

VFD:

- **VERIFY** there is not a VFD within this system. This IWD does NOT account for any stored energy that could be present in a VFD.
- **IF** VFD is present or found within system to be worked. **DO NOT** proceed with any work until UI Engineering has given approval to do so.

OK to Proceed:

 PIC: Carlos Chacon Z#: 120931 Date: 1-19-18


3. **PERFORM** zero voltage checks for maintenance involving electrical work.
4. **PERFORM** zero energy checks for mechanical maintenance. Relieve stored energy.
5. **PERFORM** maintenance in accordance with work order title and task instructions. UI Procedures will be referenced in work order task instructions when applicable. Utilize master work order equipment list when performing maintenance.
6. **REMOVE** all LO/TO
7. **REMOVE** posting or signs
8. **OPERATIONS** acknowledges work is complete and ready to place into service

 Operations: Carlos Chacon Z#: 120931 Date: 1-25-18


9. **CLEAN** up work area and properly dispose of all waste
 - **SEGREGATE** waste as required by WMC.

5.0 Close Out

- 5.1 Contact OMC (MC) and inform them work is complete.
- 5.2 Complete all required documentation and return Work Package

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task) UPPS-FY17-001		Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

<p>Insert Rows above for additional Tasks/Steps or attach pages to clearly communicate ESH&Q/S&S hazards and associated controls.</p>	<p>The RLM and FOD or FOD Representative (if required or Recommended by RLM, e.g. high hazard) approval indicates IWM has been applied appropriately, work is authorized , workers are qualified, work will be performed in accordance with ESH&Q/S&S requirements and the IWD, and facility safety basis, aggregate hazards, and collocated hazards were appropriately included in the hazard analysis and acknowledges completion of a peer review</p>	<p>RLM (Signature/Z#/Date) Required <i>Kevin M. Graham</i> 105008 4/11/16</p> <p>FOD or Representative (Signature/Z#/Date) Required Pablo F. CdeVaca <small>Digitally signed by Pablo F. CdeVaca DN: cn=Pablo F. CdeVaca, o=LANL, ou=LL, email=pc@lanl.gov, c=US Location TA 03 546 0022 Room 114 Date: 2016.04.12 10:08:25 -06'00'</small></p> <p>SME Review (Signature/Z#/Date) If Required N/A</p> <p>ESO Review (Signature/Z#/Date) If Required <i>[Signature]</i> 180602 4/11/16</p> <p>ESH Safety Review (Signature/Z#/Date) <i>[Signature]</i> 153338 4/7/16</p> <p>Peer RLM /Work Execution Manager/Maintenance Manager (Signature/Z#/Date) Required <i>Robert Lippson</i> 240725- 4/15/16</p>
<p>IWD Type</p> <p><input checked="" type="checkbox"/> Moderate-Hazard</p> <p><input type="checkbox"/> High-Hazard/Complex</p> <p><input type="checkbox"/> Standing IWD</p>	<p>Date when RLM re-approval is required _____</p> <p>Other Conditions for RE-Approval <u>Change in scope or additional hazards identified</u></p> <p>(Print) _____</p> <p>Name of Primary PIC <u>Carlos Chacon</u></p> <p>Name of Alternate PIC <u>Greg Donnelly</u></p> <p>Name of Alternate PIC _____</p>	<p>Classification review completed, if required.</p> <p>N/A</p> <p>Reviewer Signature/Z#/Date _____</p>

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Add itional Location Description:

1.0 Work Scope:

This work order task will cover the moderate hazard preventive maintenance within the Power Plant Complex. All work will be performed in accordance with work order title and task instructions. UI Procedures will be referenced in the work order task instructions when applicable. This IWD is considered the controlling document for the work being covered.

2.0 Hazard Identification and Mitigation

(HAZARD ANALYSIS performed by Robert Simpson, Kedrick Mendez– 9/9/2015)

1. Entry conditions:

- Ensure that the activity is on the Plan of the Day.
- If steps cannot be completed as described, or if unforeseen situations occur, PAUSE/STOP WORK, stabilize the situation, contact your supervisor or the Person-In-Charge (PIC), and await further instructions before proceeding.
- Certain steps in the procedure may be worked out of sequence as directed by the supervisor.
- The permits and work packages required for the project have been approved and are posted, as required.
- The PIC will be available while work is being conducted.
- PIC will review site specific hazards noted on IWD Part 2, Form 2101 with all workers.
- All hold points will be discussed on a daily basis.
- Controls needed to perform the work are identified in this IWD.

2. Electrical Hazards:

- Arc Flash: Follow PPE requirements and barricade area in accordance with the arc flash label for the specified equipment.

3. Mechanical Hazards:

- Ensure all guards are in place before accessing equipment.
- Relieve all stored energy before performing maintenance activities.

4. Pneumatic Hazards:

- Relieve all stored pressure.
- Ensure all fittings and hoses are inspected prior to use. Utilize safety devices on the fittings.

5. Elevated Work:

- Ensure all scaffolding is inspected daily before use.
- Utilize fall protection equipment when required with approved tie-off points.
- Maintain 3-points of contact when utilizing a ladder.

6. Hot Surfaces:

- Wear long sleeve shirts or Arsell sleeves when working near hot surfaces.
- Utilize insulating blankets to protect against hot surfaces.


Facilities Maintenance IWD -- (Facility Maintenance Activity Specific Information)

Revision # 0			Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD
Work Document #: (WO # / Task)			Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16
TA: 03	Building: 0022	Room:	Additional Location Description:

7. Chemical Hazards:

- Consult IH&S for PPE requirements.
- Place a catch pan under chemical and collect all residual chemicals. Deposit chemical in the day tank.
- Review the safety data sheets for all chemical and oil products.
- An eyewash station and safety shower must be within 10 seconds of where the chemicals are being used. Verify eyewash and safety shower have a current inspection.

8. Slips, Trips and Falls:

- Be aware of ground and floor conditions

9. Back strains

- Use proper lifting and bending technique at all times

10. Working with simple hand tools, cuts and abrasions:

- Inspect all tools prior to use, wear proper work gloves as determined by the job scope.
- Use of cordless power tools, power tools-electric shock.
- Use all tools properly and to safety standards. Inspect cords / batteries prior to use. GFCI protection required.

11. Pinching or crushing/hand injury:

- Do not place hands in the path of potential pinch points or crush points
- Hand/foot/ body position awareness

12. Asbestos Abatement Pipe and Equipment Insulation:

- Reference MSS Procedure 41-55-001-R1
- Area regulated to OSHA standards (29CFR1926.1101(e) and paragraph (j) decontamination area
- Two person rule is required during abatement
- Personal air monitoring will be required.
- Full face APR with P100 cartridges.
- Wear tyvek coveralls with booties and hood, protection with full body coverage from head to toe.
- Wear nitrile gloves and/or leather gloves
- HEPA vacuum debris.
- Asbestos will be removed using hand tools and wet methods using amended wetting solution and wipes.
- All asbestos wastes must be kept damp enough during handling and disposal operations to prevent fibers from becoming airborne, but must not have any free liquid present during transportation.

13. LO/TO:

- Utilize LO/TO Attachment "B"
- Wear Untreated Natural Fiber Shirt (long sleeve), Pants (long), Safety glasses or safety goggles, Hearing protection (ear canal inserts) and Leather gloves.

14. 240V to 600V Zero Voltage check requirements:

- Mode "1"
- Wear CAL 8+ PPE: Double-Layer switching hood.
- Class 0 Dielectric Gloves.
- AR coveralls (with an arc rating of 8 or more), hardhat, and safety glasses underneath hood.
- 2-man rule applies.
- Use UL approved voltage meter. Test meter on a known live circuit before and after zero voltage



Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)

Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

verification.

- No metallic objects worn.
- Voltage rated test equipment.
- Ensure no un-insulated body part enters prohibited space.
- Voltage rated tools.

15. Less than 240V Zero Voltage check requirements:

- Mode "1"
- Use UL approved voltage meter. Test meter on a known live circuit before and after zero voltage verification.
- Class "0" Dielectric Gloves
- AR clothing, minimum arc-rating of 4 cal for voltage of < 240 V (long sleeve shirt, pants or coveralls, face shield)
- AR Protective Equipment (hard hat, safety glasses or safety goggles, hearing protection).
- No metallic objects worn.
- Voltage rated test equipment.
- Ensure no un-insulated body part enters prohibited space.
- Voltage rated tools.

16. Cone of Safety Identification:

- The Cone of Safety as defined P101-25.0 Cranes, Hoists, Lifting Devices, and Rigging Equipment shall be identified.
- Time/distance requirements shall be assured by the LANS Hoisting/Rigging Supervisor throughout all lifts.
- Ensure lift plan is completed for all critical lifts.

17. General PPE Requirements for working within the Power Plant Complex:


- Safety shoes
- Safety glasses with side shields
- Hard hat
- Reflective Safety Vest
- Leather work gloves
- Hearing Protection at all times within the Power Plant. A noise evaluation shall be made by a safety engineer for other work as required.

Approach Boundaries


Voltage (VAC)	Limited Approach	Restricted Approach	Prohibited Approach
50-300	3'6"	Avoid Contact	Avoid Contact
301-750	3'6"	1'0"	0'1"

3.0 Training Requirements

- MSS Maintenance Worker, TP 10968
- LO/TO, TP 127
- Electrical Worker Training, Curriculum 642


 Facilities Main tenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0			Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD
Work Document #: (WO # / Task)			Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16
TA: 03	Building: 0022	Room:	Additional Location Description:

- Stationary Equipment Mechanics, Curriculum 630
- Sheet metal Workers, Curriculum 649
- Pipefitters, Curriculum 647
- Carpenters, Curriculum 641
- Insulators, Curriculum 643
- Power Plant Operators, Curriculum 632
- Training to work with Cranes and Rigging:
 - Incidental Crane Classroom course # 20295
 - Incidental Crane Exam # 20296
- Site Specific Training (one-time requirement)

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

4.0 Work Execution

- 1.
2. The following system conditions are the configuration and conditions which have been anticipated for performance of the PM activities covered under this standing IWD:
 - a. The electrical power systems are in a configuration which will support nominal steam plant operations. No major disruptions or outages are present and the electrical system lineup is considered to be in a normal configuration.
 - b. The steam plant may be either in a shutdown, standby or normal operation configuration. The mechanical components are under the control of the steam plant operations personnel and no major upset conditions or unanticipated outages are present within the facility.
 - c. The Power Plant operational personnel are manned to the required level and sufficient support is available to support the performance of the preventive maintenance activity.
3. Prerequisites:
 - a. **REVIEW** work package for Life Critical Steps (to be performed by the PIC/RLM).
 - I. **Fall Protection:**
 - Verify that a safety system is in place (where workers understand hazard controls and required PPE) at the work site.
 - Verify that workers understand the fall protection plan.
 - II. **Elevated Work Platforms:**
 - Verify a clear travel path with all necessary clearances has been defined and is adequate.
 - Verify the geographic terrain will support execution of the desired activity.
 - Verify the identification of all energized electrical Systems, structure and components has occurred and their impact to the activity has been accounted for and communicated to the workers.
 - Verify all personnel are qualified to operate the aerial lift device assigned to the activity.
 - b. **INSERT** Life Critical Step hold points into the work package.
 - c. **VERIFY** a daily pre-job brief has been performed with the 5 mandatory questions and 2101 has been read for site hazards and entry requirements. With all affected personnel. Perform a reverse pre-job brief and encourage all craft workers to stay involved.
 - d. **VERIFY** all personnel have appropriate PPE for job execution.
 - e. **BARRICADE** the work area in accordance with MSS-Guide-038 to protect tenants/unexpected personnel/or traffic as directed by the Supervisor or PIC. Clearly identify work zone due to look-alike equipment.




 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0			Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD
Work Document #: (WO # / Task)			Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16
TA: 03	Building: 0022	Room:	Additional Location Description:


Execution

4. **PERFORM** LO/TO, when required to perform preventive maintenance.
5. **PERFORM** zero voltage checks for maintenance involving electrical work.
6. **PERFORM** zero energy checks for mechanical maintenance. Relieve stored energy.
7. **PERFORM** preventive maintenance in accordance with work order title and task instructions. UI Procedures will be referenced in the work order task instructions when applicable. Utilize the master work order equipment list when performing preventive maintenance.
8. **REMOVE** all LO/TO.
9. **REMOVE** posting or signs.
10. **CLEAN** up work area and properly dispose of all waste.
11. **COMPLETE** all documentation.

5.0 Close Out

1. Complete closeout of the work activity in accordance with AP-WORK requirements.

<i>Insert Rows above for additional Tasks/Steps or attach pages to clearly communicate ESH&Q/S&S hazards and associated controls.</i>	The RLM and FOD or FOD Representative (if required or Recommended by RLM, e.g. high hazard) approval indicates IWM has been applied appropriately, work is authorized , workers are qualified, work will be performed in accordance with ESH&Q/S&S requirements and the IWD, and facility safety	RLM (Signature/Z#/Date) Required  190429 7-11-17
		FOD or Representative (Signature/Z#/Date) Required  090206 7-12-17
		IH&S Review (Signature/Z#/Date)  7/10/17
		Page 6 of 7

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:
		basis, aggregate hazards, and collocated hazards were appropriately included in the hazard analysis and acknowledges completion of a peer review	SME Review (Signature/Z#/Date) If Required <u>Not Required</u> ESO Review (Signature/Z#/Date) If Required _____
IWD Type <input checked="" type="checkbox"/> Moderate-Hazard <input type="checkbox"/> High-Hazard/Complex <input type="checkbox"/> Standing IWD		Date when RLM re-approval is required _____ Other Conditions for RE-Approval: <u>Scope change or additional hazards identified.</u> (Print) Name of Primary PIC _____ Name of Alternate PIC _____ Name of Alternate PIC _____	Classification review completed, if required. <u>N/A</u> Reviewer Signature/Z#/Date _____

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002, FGR-003)
Task Dspln : **Due Date :** 02/28/2018
Superintendent :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00597795 01

MASTER

Date: 11/08/2017**Work Order Task Written To**

Facility : F08 **Unit :** **Op Sys :**
Room : **Area :** **Sys/Cls :**
Equipment : **Component :**
Location :
Job Type : PM
Tag 1 : **Tag 2 :**
Work Item : TA03-0022 FGR **Ops Review Reqd :**

Authorization

Start Permission : **Start Date :**
Complete Notice : **Complete Date :**

Work Order Task Instructions

DO NOT lubricate the bearings if the FGR fan is NOT in operation or in service so that proper amount of grease can be applied using headphones
 You can hear when grease reaches the bearing rolling element. At this point, stop adding grease to prevent bearing damage from overheating

There are two bearings on the fan, each with its own zerk plug
 Remove the shaft guard located in the middle of the drive. The two zerk plugs are located on each of the two bearings

1. Use grease gun with the Ultralube headphones to insert the correct amount of Mobilith SHC 100 grease into zerk fitting
- b. Apply grease while fan is running and stop when you hear the grease enter the running bearing

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002, FGR-003)
Task Dspln : **Due Date :** 02/28/2018
Superintendant :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00597795 01

MASTER

Date: 11/08/2017

Lubricated fan bearings on FGR-001, FGR-002 & FGR-003

4. Add grease with a hand-operated pressure gun until new grease enters the running bearing
 - a. This is accomplished by using the ultrasonic sensor and headphones to hear when the new grease enters the running bearing
 - b. Stop adding grease when the grease reaches the bearing to limit excess grease from migrating down the motor shaft and into the windings

Note: Be careful when greasing the fan end bearing of the TEFC (Totally Enclosed Fan Cooled) motors. Some motors have a spring-relief outlet grease fitting on the fan end that is not accessible. This spring-relief fitting normally does not have to be removed when regreasing. When greasing, take care in the amount of pressure you apply and verify relief is working
5. Putting in too much or too little grease can cause overheating of the motors and result in motor failure. Use this rule of thumb when adding grease to a motor that has been lubricated on a regular basis:
It is better to use a little grease more often than a lot of grease less often

Note: Watch out for motors that were shipped only with the bearings packed and not the fill tube or even the bearing housing
Apply new grease until you can hear it enter the running bearing
6. Now that greasing is complete, leave the relief plug off and run the motor for 10 minutes to expel any excess grease
7. Replace the drain plug and wipe the bearing housing clean
8. Dispose of dirty rags in accordance with Hazardous Waste Guidelines
9. Ensure correct operation of electric motors.

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002, FGR-003)
Task Dspln : **Due Date :** 02/28/2018
Superintendent :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00597795 01

MASTER

Date: 11/08/2017

--

Work Completion Signatures

Name	Function/Dept.	Date
Chris Salazar	LOG-CS/PP MAINT...	02/01/2018
Comments (rework?)		

Cost Accounting**Cost Center :** P2030A**Activity :** 640CL000**Percentage :** 100**Acct No :** XU5000**Sub Acct :** 7E2P0000

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002,
FGR-003)
Task Dspln : **Due Date :** 02/28/2018
Superintendant :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00597795 01

MASTER

Date: 11/08/2017



Form 2101

**Integrated Work Document (IWD) Part 2,
FOD Requirements and Approval for Entry and Area Hazards and Controls**

**Non-Tenant
Activity Form**

IWD No /Work Request No: _____ Revision #: _____

Facility Operation Director (FOD) must determine the facility entry and coordination requirements and identify the Environment, Safety, Health (ESH)/Security and Safeguards (S&S) hazards and controls associated with the activity location.

FOD 8	TA 3	Bldg 22	Room N/A	Other Location Power Plant Bldg - Inside
FOD Designated Facility Point-of-Contact	Name Pablo C de Vaca	Phone 699-8226	Pager N/A	Email pfc@lanl.gov

Entry and Coordination Requirements (Check one or more of the following)

- | | |
|--|---|
| <input type="checkbox"/> No Entry/Coordination Requirements | <input type="checkbox"/> FOD-designated facility Point-of-Contact must sign IWD Part 3 |
| <input checked="" type="checkbox"/> Plan of the Day/Plan of the Week (POTD/POTW) | <input checked="" type="checkbox"/> Check in at Start of Work <input checked="" type="checkbox"/> Work-Area Training Required |
| <input checked="" type="checkbox"/> Security Clearance Requirements | <input checked="" type="checkbox"/> Work must be Scheduled <input checked="" type="checkbox"/> Check in Daily |
| <input type="checkbox"/> Co-located Hazards/Concerns | <input type="checkbox"/> Other Security Requirements (ex.: Cellphone, No Foreign Nationals, etc.) |
| <input checked="" type="checkbox"/> Check out at End of Work | <input type="checkbox"/> Quality Issues <input checked="" type="checkbox"/> Check out Daily |
| <input type="checkbox"/> Escort Required | <input type="checkbox"/> Review under Authorization Basis (AB)/Safety Basis/Unreviewed Safety Question (USQ) |
| <input type="checkbox"/> Other Bounding Conditions: | |

PIC is responsible to conduct a pre-job brief for work activities to ensure that work conditions and worker communications are adequate. A pre job briefing shall be conducted at the job site. UI-OPS will determine if onsite ESH representation is required during work activities

Additional Comments (refer to Job Hazard Analysis [JHA] Tool Facility Notes)

All work must be approved by the Utilities FOD or UI-OPS. POD/POTW-contact Facility POC. No Smoking around Natural Gas Systems. Evaluate inside floor and housekeeping conditions to safely proceed with activities. Check in with Plant Operations Manager/Specialist or Operations Shift Head for final approval to proceed with tasks. Work around power plant chemical pumps and lines. Inspect for leaks before beginning any work task and pause work and report if a leak is found to operations. All personnel entering area must view the site specific training video in room 116 (Boiler Control Room), one time requirement. Observe safety signs and floor markings in all buildings and areas. No safety shoes required for visitors if escorted by Operations or UI Engineering personnel. The West end front lobby and office areas of Bldg 22 are considered a no hazard area.

Instructions: In the block below, identify work-area hazards that could potentially affect the worker(s) or others. Specify the facility controls and preventive measures that must be implemented by the worker(s) to protect against the site hazards as well as any special training required.

ESH/S&S WORK AREA HAZARDS & CONTROLS

Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
<input type="checkbox"/> No Work Area Hazards				

Ionizing Radiation Work in posted radiological areas, work with radioactive materials, or work on or near radiation producing devices Specify Hazard:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
---	---	--	--	--

IWD No /Work Request No: _____

Revision #: _____

ESH/S&S WORK AREA HAZARDS & CONTROLS				
Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300. Integrated Work Management, Section 6.1)
Worker Exposure Working near non-ionizing radiation, beryllium, noise, chemicals, hazardous biological materials, lead, asbestos, temperature/humidity extremes, or high explosives. Specify Hazards:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Required PPE: Hard hat, safety shoes, safety glasses. Hearing protection (noise > 85 dba). Avoid hot surfaces and piping. Long sleeve shirt or Ansell sleeves or coveralls. Gloves when operating valves or contacting pipe/fitting openings where there is potential for hot water/steam release.</p> <p>Be aware of encapsulated asbestos. Follow LANL Asbestos program/rqmts if PACM identified outside containment.</p> <p>Be aware of chemical containers and check labeling. Be aware of piping, associated systems for any leaks. If chemical leak is noticed contact operations manager, IH&S Rep during regular working hrs. Over 100 gallons of a chemical spill leave area, and control</p>	P101-6 PPE • P101-23 Asbestos • P101-31 Hearing Conservations/Noise Program	LANL PPE or equivalent • Hearing protection • Site specific training • Asbestos awareness

		<p>access. Call Serf Operators 667-8982 or by Radio Lanl 2 Util 6 For mitigation cleanup process.</p> <p>For after-hours contact the UI Duty Officer, 699-7452 to re-assess any abnormal situation</p>		
<p>Energized and Operative Systems Working near energized electrical parts, pressure systems, steam lines; near unprotected belts, pulleys, chains or rotating equipment; fuel fired equipment other than vehicles; or spark or flame producing operations. Specify Hazards: Energized/rotating equipment, High Temperature, High Pressure Water and Steam equipment.</p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Stay within established walking areas. Observe safety signage alarm lights and horns. Identify explosive hazards and follow task specific IWD if working on plant equipment or components. Note: All TA3-22 independent verification requirement will be determined by the FOD or FOD designee. If questions consult with UI system engineer, Operation Mgr. Designee, or Safety rep.</p>	<p>P101-13 Electrical Safety</p> <p>P101-3 LOTO</p> <p>P101-34 Pressure, Vacuum, and Cryogenic System.</p>	<p>Site Specific Training video.</p> <p>Electrical Safety</p> <p>LOTO if applicable to task.</p>
<p>Confined Spaces Entry into tanks, manholes, cooling towers, sumps, or any other area with potentially low oxygen concentration or other hazards such as toxic vapors or engulfment. Specify Hazards:</p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Observe confined space signs or markings and follow LANL Confined Space Requirements if task requires confined space entry.</p>	<p>P 101-27 Conf. Space</p>	<p>Confined Space Training</p>
<p>Elevated Work Surface Elevated work when fall protection is not provided by conventional handrail systems or required per <u>P101-20, Fall Protection Program</u></p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Stay within established walking areas, stairways and paths. Observe safety signage. Follow LANL Fall Protection Requirements if task on roofs or work above 4 feet.</p>	<p>P101-20 Fall Protection</p>	<p>Fall Protection</p>
<p>Environmental Impact Activities conducted in areas containing potential release site, contaminated soil, sensitive species, watercourse wetlands, floodplain, historical/archeological sites, or other work area condition that can be impacted by or can impact the environment.</p>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			

Specify Hazards:				
Security Requirements Specify:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Other Hazards Specify: Look-alike Equipment in the vicinity of work site may contain un-controlled hazardous energy	<input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Adequate barriers and controls will be established to prevent unauthorized personnel/workers from entering job site and encounter uncontrolled hazards.	IWD	Pre-job briefing emphasis. Worker confirmation of look-alike potential hazards, locations and barriers set in place to identify those potential hazards.

I have verified that the hazards identified above adequately identify the area hazards and that the IWM process has been applied appropriately.

FOD or Representative (Signature/Z #/Date) Approval Required Pablo F. CdeVaca

Digitally signed by Pablo F. CdeVaca
DN: cn=Pablo F. CdeVaca, o=LANL, ou=US, email=pfca@lanl.gov, c=US
Date: 2017.09.26 11:53:41 -06:00

Date Approval Expires: 09/30/2020



AP-WORK-004: Attachment 1 Maintenance & Site Services Worker Engagement Questions

Worker engagement questions are intended to focus attention on the task and ensure uncertainties are addressed. Examples of worker engagement questions are provided below. Worker engagement questions should be tailored to the situation.

Each of the questions listed below will be discussed at each Pre-Job Brief with all affected personnel.

Topic	Completed (X)
Imo FGR Fan Lube 2-1-18	
What permits, permissions, or support are required to safely start this work?	X
What is the most likely thing that could go wrong (not the worst thing) and what, specifically, will prevent it?	X
What can cause us to go beyond the scope of the work?	X
What hazards in the work area may not have been considered during planning of this job?	X

Pre-job by C. Salazar #202847 2-1-18

Facility : F08 Unit : Proj :
Task Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS
W/O Type : PM W/O Group : UTIL Task Priority : 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS
Written To : TA03-0022 VARIABLE FREQUENCY DRIVES VID/VFD/FGR
Task Dspln : Due Date : 02/28/2018
Superintendent :
Hazard : MODERATE IWD Reqmt : TASK SPECIFC

Work Order Task

00597794 01

MASTER

Date: 11/08/2017

Work Order Task Written To

Facility : F08 Unit : Op Sys :
Room : Area : Sys/Cls :
Equipment : Component :
Location :
Job Type : PM
Tag 1 : Tag 2 :
Work Item : SM22VID Ops Review Reqd :

Authorization

Start Permission : Robert Simpson 2/2/2018

Complete Notice : Robert Simpson 2/28/2018

Work Order Task Instructions

CRAFT: UICS ELECTRICIANS

FURTHER INSTRUCTIONS/DETAILS

LOTO OF EACH UNIT TO CLEAN INTERNALLY THE INSIDE OF EACH VFD PANEL

TASK IS TO BE DONE THE USE OF COMPRESSED AIR AND A VACUUM CLEANER. REMOVE

ALL DUST AND DEBRIS FROM THE ENCLOSURES

Facility : F08 Unit : Proj : Task Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS W/O Type : PM W/O Group : UTIL Task Priority : 4 Planner : 189099 LOPEZ THERESA M W/O Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS Written To : TA03-0022 VARIABLE FREQUENCY DRIVES VID/VFD/FGR Task Dspln : Due Date : 02/28/2018 Superintendant : Hazard : MODERATE IWD Reqmt : TASK SPECIFC	Work Order Task 00597794 01 MASTER Date: 11/08/2017
---	--

<u>QC Requirements / Comments</u>

<u>Work Completion Signatures</u>		
Name	Function/Dept.	Date
Carlos Chacon	UPES Electricians	2-28-18
Comments <input type="checkbox"/> None (rework?) <input type="checkbox"/> No		

Cost Accounting

Cost Center : P2030A

Activity : 640CL000

Percentage : 100

Acct No : XU5000

Sub Acct : 7E2P0000

Facility : F08 **Unit :** **Proj :**
Task Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS
Written To : TA03-0022 VARIABLE FREQUENCY DRIVES VID/VFD/FGR
Task Dspln : **Due Date :** 02/28/2018
Superintendant :
Hazard : MODERATE **IWD Reqmt :** TASK SPECIFC

Work Order Task

00597794 01

MASTER

Date: 11/08/2017



Integrated Work Document (IWD) Part 3, Validation and Work Release

IWD # _____ REVISION #: _____ **WORK RELEASE**

By signing below, I verify this activity is compatible with current facility configuration and operating conditions.

FOD designated Ops Mgr or other facility point-of-contact for work area _____

Signature/Z#/Date (If required by FOD): _____

Note: For Standing IWD, release may be given concurrently with signatures on Part 2.

By signing below, I have verified the following:

- I have verified authorization by ensuring approval signatures of the RLM and FOD.
- I have jointly conducted a validation walkdown with workers to confirm the IWD can be performed as written, required initial conditions and other prerequisites are in-place.
- The assigned workers are authorized and are qualified to perform the work in a safe, secure, and environmentally responsible manner.
- I have conducted the pre-job briefing, and all workers (including support workers) have been briefed.
- I have ensured coordination with any required FOD work-area representatives (e.g., area work coordinators).

Primary PIC (Signature/Z#/Date) Required: _____

Alternate PIC Signatures **acknowledges** PIC authority is assumed for the first time (Note: Alternate PICs are required to sign only once, but formal handoff includes conferring with previous PIC to obtain all required information associated with the handoff).

Alternate PIC (Signature/Z#/Date) Required: _____

Alternate PIC (Signature/Z#/Date) Required: _____

Pre-Job Brief Content

- What are the critical steps or phases of this activity?
- How can we make a mistake at that point?
- What is the worst thing that can go wrong?
- What controls, preventive measures, and bounding conditions are needed?
- What work permits are required and how will we meet their requirements?
- What are the handoffs and coordination requirements among workers and multiple PICs?
- Are there hold-points including those that require sign-offs?
- What are the pause/stop work responsibilities and expectations (e.g. for unanticipated conditions or hazards)?
- How would we respond to alarms and emergencies?
- Are there lessons learned from previous similar work?
- Is other information needed to perform this activity in a safe, secure, and environmentally responsible manner?
- Does everyone agree to the work tasks/steps, hazards, and controls and commit to follow them?

Pre-Job Brief Attendance Roster

By signing below **as required**, I agree to the following:

- I agree to follow the work steps and implement the controls as written as applicable to my work assignments
- I agree to pause/stop work when conditions or hazards change or when I encounter unexpected conditions during the execution of work, or when work cannot be performed as written, or instructions become unclear during execution.
- I confirm that I am authorized, qualified, and fit to perform the work.

Worker (Signature/Z#/Date)

2/21/18

Worker (Signature/Z#/Date)

2/23/18

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

2/23/18

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

2/23/18

Attachment B, LO/TO Orders

Lock Coordinator Name/Z#	Phone #	Alternate Lock Coordinator Name/Z#	Phone #
---------------------------------	----------------	---	----------------

Section 1: General Information			
1. Work Document Number (i.e., Package/Procedure #):		2. LO/TO (Parent) Record #	
3. Date:			
Location			
4. TA:	5. Bldg:	6. Rm:	7. Equipment/Machinery/Name/Number:
8. Reason for LO/TO:			
9. Name of Equipment Owner/Operator:			
10. Energy Type to be Isolated (check all that apply)			
<input type="checkbox"/> Electrical <input type="checkbox"/> Mechanical <input type="checkbox"/> Hydraulic <input type="checkbox"/> Pneumatic <input type="checkbox"/> Steam <input type="checkbox"/> Capacitors <input type="checkbox"/> Compressed Energy <input type="checkbox"/> Gravity <input type="checkbox"/> Other (specify):			
11. Group LO/TO: <input type="checkbox"/> Yes <input type="checkbox"/> No		12. Group Lock Box used: <input type="checkbox"/> Yes <input type="checkbox"/> No	
If Yes, Name of Lead Authorized Worker:		If yes, enter ID# of Lock Box Lock Box ID:	
13. Sequencing Required for LO/TO <u>Installation</u>		14. Sequencing Required for LO/TO <u>Removal</u>	
If Yes, enter the required sequence in column 20 below. If No, place N/A in column 20 below.		If Yes, enter the required sequence in column 28 below. If No, place N/A in column 28 below.	
<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes <input type="checkbox"/> No	
Section 2: LO/TO Installation & Removal			
LO/TO Installation		LO/TO Removal / Return to Service	
15. Approval to Install LO/TO (signature & Z#)		24. Approval to Remove LO/TO (signature & Z#). Call #	
16. Verification required for LO/TO Installation		25. Verification required for LO/TO Removal	
<input type="checkbox"/> No <input type="checkbox"/> Peer Concurrent Dual <input type="checkbox"/> Independent Verification		<input type="checkbox"/> No <input type="checkbox"/> Peer Concurrent Dual <input type="checkbox"/> Independent Verification	
17. Verification Determination Approved by FOD/Designee (signature)		26. Verification Determination Approved by	
Z#		Z#	
Date		Date	
18. Specific Energy Isolation Device/ID	19. Location of locking Device	20. LO/TO Installation Sequence	21. Required Position/Alignment for LO/TO
22. LO/TO Installation verified By:	27. Required Position/Alignment following Removal	28. LO/TO Removal Sequence	29. LO/TO Removal Verified By:
30. As-Left Position			
23. LO/TO Points Positioned and First Lock installed by Signature		31. LO/TO Removed, Positioned and Verified by Signature	
Z#		Z#	
Date		Date	

Attachment B, LO/TO Orders

Attachment B, LO/TO Orders (Cont.)			
1. Work Document Number (i.e., Package/Procedure #):		2. LO/TO (Parent) Record #	3. Date:
32. Zero Energy Checks have been completed <input type="checkbox"/> Yes <input type="checkbox"/> No		33. Completed by Signature _____ Z# _____ Date _____	
Section 3: Lead Authorized Worker and Authorized Workers (anyone applying a lock for this activity)			
34. Authorized Workers Name(s)	Z#	35. Date workers lock is hung	36. Date workers lock is removed
1.			
2.			
3.			
4.			
5.			
6.			
7.			
8.			
9.			
10.			
Section 4: Return of Lock(s)/Tag(s) and Locking Devices			
All Lock(s)/Tag(s) and Locking Devices have been removed and returned to the Lock Coordinator or Designee			
37. Signature of Lock Coordinator or Designee _____		Z# _____	Date _____

*If you have questions with regards to filling out the Attachment B, LO/TO Orders form, see the directions associated with the form.

*Take the completed forms back to the Lock Coordinator or Designee for closeout.

Continuation Page (print as needed)[illegible]

Attachment B, LO/TO Orders

The following are directions for filling out Attachment B.

1. Enter the Work Document Number, this will be the number from the IWD or the procedure number (i.e., TA88-DOP-0001)
 2. Enter the LO/TO Parent Record number, this is obtained from the Lock Coordinator when the HEC lock(s) are issued. The Remedy LO/TO database issues this number.
 3. Enter the date of when the locks will be applied.
 4. Enter the TA where the lock(s) will be hung.
 5. Enter the Building number of where the lock(s) will be hung.
 6. Enter the Room number where the equipment is located/where work is being performed.
 7. Enter the Equipment/Machinery/Name/Number (example, HVA-001)
 8. Write a brief description of the reason for LO/TO (example, Removing and replacing belts)
 9. Enter the Name of the Equipment Owner/Operator. Each FOD is different in the assigning of Equipment Owner/Operators. There are also programmatic Equipment Owner/Operators.
 10. Check the appropriate energy type to be isolated, check all that apply. Make sure you have considered all energy sources, if other you will need to specify what "other" is.
 11. Check applicable box to identify if a group LO/TO (A LO/TO where two or more authorized workers, regardless of their occupation or craft, lock out and tag out the same equipment to perform servicing or maintenance).
 12. Check applicable box if lock box is used for the job. Enter the lock box ID#. Each organization that issues locks will be required to uniquely number and track lock boxes in their possession.
 13. When installing the lock(s)/tag(s), is there a specific sequence in which the isolation devices are to be positioned. If a specific sequence must be followed, THEN number the sequence order in column 20. If there is not a specific sequence to follow then place N/A in column 20. This needs to be an operations type person (Operator) who understands the equipment/system/component.
 14. When removing the lock(s)/tag(s), is there a specific sequence in which the isolation devices are positioned after lock/tag removal? If a specific sequence must be followed, THEN number the sequence order in column 28. If not, place N/A in the box(s).
- NOTE:** Section 2, LO/TO Installation & Removal – In some of the nuclear facilities, the operations personnel will identify the required position(s) for credited equipment/machinery depending on operational requirements for return to service. In most cases when workers remove locks, the "As-Left" Position will be different then the final position the operations personnel will place the equipment in.
15. The Equipment Owner/Operator signs and enters their Z#, authorizing the installation of the LO/TO. With some FODs this will be the maintenance coordinators.
 16. Is verification required for this LO/TO. Determine if this is Peer Verification (see P101-3, Section 3.15) or Concurrent Dual verification (see P315, Attachment 10, Section 10.3.6), or Independent Verification. For Independent Verification see P315, Attachment 10, Independent Verification, The Operations Manager (OM) prepares and maintains a facility-specific list of systems and components requiring Independent Verification.

Attachment B, LO/TO Orders

17. The FOD/Designee must sign after determining if verification is required. If Independent Verifier is identified at this time then it must be entered into the Remedy database.
18. Enter the specific Energy isolation device/ID, (example, MCC-A, A4)
19. Location of locking device, this is the location of where the lock is applied (example, MCC-A, A4 TA-XX, Bld. XXX, rm. 123)
20. If the LO/TO needs to be installed in a particular order, number the order in which the locks need to be installed. If the "No" box is checked in #13, then place N/A in this column.
21. Required Position/alignment for LO/TO, open, closed, connected, disconnected, on, off, etc.
22. LO/TO installation verified by – Has the equipment /system/component being locked out, been identified by the FOD as requiring verification, see #16. If verification is required the person who performed the verification initials here.
23. The Lead Authorized worker positions the LO/TO points and installs his/her lock and signs that this has been completed.
24. This is the person, who authorized the LO/TO to be removed, signs and places his/her Z# in this box. This signature authority may place a phone number here for the Lead Authorized worker to call for authorization to remove the LO/TO. When verbal authorization is given, it must be documented in this section. Example: John Smith per telecom, 8/13/14 and your initials. Note: It is also permissible to pre-authorize the removal of the lock by pre-signing.
25. Depending on the verification type required for LO/TO removal, check the appropriate verification type box, otherwise check the "No" box.
26. If verification is required, the FOD/Designee must sign. Independent Verifier is identified at this time and entered into the database.
27. Write the required position/alignment the system/component will be placed in following the removal of the lock(s).
28. If the isolation device needs to be positioned in a particular order/sequence, (per Post Maintenance) number the order/sequence in which the isolation device is to be position. If not, place N/A in the box(s).
29. LO/TO removal verified by Lead Authorized Worker – the lock(s) have been removed and the As-Left position is documented in column 30.
30. Enter the As-Left Position.
31. If the removal of the lock has been identified as needing to be verified, the verifier writes name and Z# after verifying the lock has been removed.
32. The authorized worker must verify that the steps utilized in the energy control procedure have effectively isolated the machine or equipment from the hazardous energy.
33. The authorized worker signs after zero energy checks have been completed.
34. All authorized workers applying a lock for this activity names/Z# and the Date must be entered.
35. Enter the date the authorized worker hangs lock.
36. Enter the date the authorized worker removes lock.
37. The Lock Coordinator or designee signs once locks, tags, and locking devices have been removed and returned. If a lock and/or tag are found to be contaminated then that will be noted by the Lock Coordinator or designee and the Lock Coordinator or designee will sign.



Form 2101

**Integrated Work Document (IWD) Part 2,
FOD Requirements and Approval for Entry and Area Hazards and Controls**

**Non-Tenant
Activity Form**

IWD No /Work Request No: _____ Revision #: _____

Facility Operation Director (FOD) must determine the facility entry and coordination requirements and identify the Environment, Safety, Health (ESH)/Security and Safeguards (S&S) hazards and controls associated with the activity location.

FOD 8	TA 3	Bldg 22	Room N/A	Other Location Power Plant Bldg - Inside
FOD Designated Facility Point-of-Contact	Name Pablo C de Vaca	Phone 699-8226	Pager N/A	Email pfc@lanl.gov

Entry and Coordination Requirements (Check one or more of the following)

- | | |
|--|---|
| <input type="checkbox"/> No Entry/Coordination Requirements | <input type="checkbox"/> FOD-designated facility Point-of-Contact must sign IWD Part 3 |
| <input checked="" type="checkbox"/> Plan of the Day/Plan of the Week (POTD/POTW) | <input checked="" type="checkbox"/> Check in at Start of Work <input checked="" type="checkbox"/> Work-Area Training Required |
| <input checked="" type="checkbox"/> Security Clearance Requirements | <input checked="" type="checkbox"/> Work must be Scheduled <input checked="" type="checkbox"/> Check in Daily |
| <input type="checkbox"/> Co-located Hazards/Concerns | <input type="checkbox"/> Other Security Requirements (ex.: Cellphone, No Foreign Nationals, etc.) |
| <input checked="" type="checkbox"/> Check out at End of Work | <input type="checkbox"/> Quality Issues <input checked="" type="checkbox"/> Check out Daily |
| <input type="checkbox"/> Escort Required | <input type="checkbox"/> Review under Authorization Basis (AB)/Safety Basis/Unreviewed Safety Question (USQ) |
| <input type="checkbox"/> Other Bounding Conditions: | |

PIC is responsible to conduct a pre-job brief for work activities to ensure that work conditions and worker communications are adequate. A pre job briefing shall be conducted at the job site. UI-OPS will determine if onsite ESH representation is required during work activities

Additional Comments (refer to Job Hazard Analysis [JHA] Tool Facility Notes)

All work must be approved by the Utilities FOD or UI-OPS. POD/POTW-contact Facility POC. No Smoking around Natural Gas Systems. Evaluate inside floor and housekeeping conditions to safely proceed with activities. Check in with Plant Operations Manager/Specialist or Operations Shift Head for final approval to proceed with tasks. Work around power plant chemical pumps and lines. Inspect for leaks before beginning any work task and pause work and report if a leak is found to operations. All personnel entering area must view the site specific training video in room 116 (Boiler Control Room), one time requirement. Observe safety signs and floor markings in all buildings and areas. No safety shoes required for visitors if escorted by Operations or UI Engineering personnel. The West end front lobby and office areas of Bldg 22 are considered a no hazard area.

Instructions: In the block below, identify work-area hazards that could potentially affect the worker(s) or others. Specify the facility controls and preventive measures that must be implemented by the worker(s) to protect against the site hazards as well as any special training required.

ESH/S&S WORK AREA HAZARDS & CONTROLS

Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
<input type="checkbox"/> No Work Area Hazards				

Form 2101 (6/12)

Page 1

Ionizing Radiation Work in posted radiological areas, work with radioactive materials, or work on or near radiation producing devices. Specify Hazard:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
--	---	--	--	--

IWD No./Work Request No: _____ Revision #: _____

ESH/S&S WORK AREA HAZARDS & CONTROLS				
Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
Worker Exposure Working near non-ionizing radiation, beryllium, noise, chemicals, hazardous biological materials, lead, asbestos, temperature/humidity extremes, or high explosives. Specify Hazards:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Required PPE: Hard hat, safety shoes, safety glasses. Hearing protection (noise > 85 dba). Avoid hot surfaces and piping. Long sleeve shirt or Ansell sleeves or coveralls. Gloves when operating valves or contacting pipe/fitting openings where there is potential for hot water/steam release.</p> <p>Be aware of encapsulated asbestos. Follow LANL Asbestos program/rqmts if PACM identified outside containment</p> <p>Be aware of chemical containers and check labeling. Be aware of piping, associated systems for any leaks. If chemical leak is noticed contact operations manager, IH&S Rep during regular working hrs. Over 100 gallons of a chemical spill leave area, and control</p>	P101-6 PPE • P101-23 Asbestos • P101-31 Hearing Conservations/Noise Program	LANL PPE or equivalent • Hearing protection • Site specific training • Asbestos awareness

		<p>access Call Serf Operators 667-8982 or by Radio Lanl 2 Util 6 For mitigation cleanup process</p> <p>For after-hours contact the UI Duty Officer, 699-7452 to re-assess any abnormal situation</p>		
<p>Energized and Operative Systems Working near energized electrical parts, pressure systems, steam lines; near unprotected belts, pulleys, chains or rotating equipment; fuel fired equipment other than vehicles; or spark or flame producing operations Specify Hazards: Energized/rotating equipment, High Temperature, High Pressure Water and Steam equipment.</p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Stay within established walking areas. Observe safety signage alarm lights and horns. Identify explosive hazards and follow task specific IWD if working on plant equipment or components. Note: All TA3-22 independent verification requirement will be determined by the FOD or FOD designee. If questions consult with UI system engineer, Operation Mgr. Designee, or Safety rep.</p>	<p>P101-13 Electrical Safety</p> <p>P101-3 LOTO</p> <p>P101-34 Pressure, Vacuum, and Cryogenic System</p>	<p>Site Specific Training video</p> <p>Electrical Safety</p> <p>LOTO if applicable to task</p>
<p>Confined Spaces Entry into tanks, manholes, cooling towers, sumps, or any other area with potentially low oxygen concentration or other hazards such as toxic vapors or engulfment. Specify Hazards:</p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Observe confined space signs or markings and follow LANL Confined Space Requirements if task requires confined space entry.</p>	<p>P 101-27 Conf. Space</p>	<p>Confined Space Training</p>
<p>Elevated Work Surface Elevated work when fall protection is not provided by conventional handrail systems or required per <u>P101-20, Fall Protection Program</u></p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Stay within established walking areas, stairways and paths. Observe safety signage. Follow LANL Fall Protection Requirements if task on roofs or work above 4 feet.</p>	<p>P101-20 Fall Protection</p>	<p>Fall Protection</p>
<p>Environmental Impact Activities conducted in areas containing potential release site, contaminated soil, sensitive species, watercourse wetlands, floodplain, historical/archeological sites, or other work area condition that can be impacted by or can impact the environment.</p>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			


Specify Hazards:				
Security Requirements Specify:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Other Hazards Specify: Look-alike Equipment in the vicinity of work site may contain un-controlled hazardous energy	<input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Adequately barriers and controls will be established to prevent unauthorized personnel/workers from entering job site and encounter uncontrolled hazards.	IWD	Pre-job briefing emphasis. Worker confirmation of look-alike potential hazards, locations and barriers set in place to identify those potential hazards.

I have verified that the hazards identified above adequately identify the area hazards and that the IWM process has been applied appropriately.

FOD or Representative (Signature/Z #/Date) Approval Required Pablo F. CdeVaca

Digitally signed by Pablo F. CdeVaca
DN: cn=Pablo F. CdeVaca, ou=LANL, ou=US, email=pcf@lanl.gov, c=US
Date: 2017.05.25 11:51:41 -0500

Date Approval Expires: 09/30/2020

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Add itional Location Description:

1.0 Work Scope:

This work order task will cover the moderate hazard preventive maintenance within the Power Plant Complex. All work will be performed in accordance with work order title and task instructions. UI Procedures will be referenced in the work order task instructions when applicable. This IWD is considered the controlling document for the work being covered.

2.0 Hazard Identification and Mitigation

(HAZARD ANALYSIS performed by Robert Simpson, Kedrick Mendez-- 9/9/2015)

1. Entry conditions:

- Ensure that the activity is on the Plan of the Day.
- If steps cannot be completed as described, or if unforeseen situations occur, PAUSE/STOP WORK, stabilize the situation, contact your supervisor or the Person-In-Charge (PIC), and await further instructions before proceeding.
- Certain steps in the procedure may be worked out of sequence as directed by the supervisor.
- The permits and work packages required for the project have been approved and are posted, as required.
- The PIC will be available while work is being conducted.
- PIC will review site specific hazards noted on IWD Part 2, Form 2101 with all workers.
- All hold points will be discussed on a daily basis.
- Controls needed to perform the work are identified in this IWD.

2. Electrical Hazards:

- Arc Flash: Follow PPE requirements and barricade area in accordance with the arc flash label for the specified equipment.

3. Mechanical Hazards:

- Ensure all guards are in place before accessing equipment.
- Relieve all stored energy before performing maintenance activities.

4. Pneumatic Hazards:


- Relieve all stored pressure.
- Ensure all fittings and hoses are inspected prior to use. Utilize safety devices on the fittings.

5. Elevated Work:

- Ensure all scaffolding is inspected daily before use.
- Utilize fall protection equipment when required with approved tie-off points.
- Maintain 3-points of contact when utilizing a ladder.

6. Hot Surfaces:

- Wear long sleeve shirts or Ansell sleeves when working near hot surfaces.
- Utilize insulating blankets to protect against hot surfaces.

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

7. Chemical Hazards:

- Consult IH&S for PPE requirements.
- Place a catch pan under chemical and collect all residual chemicals. Deposit chemical in the day tank.
- Review the safety data sheets for all chemical and oil products.
- An eyewash station and safety shower must be within 10 seconds of where the chemicals are being used. Verify eyewash and safety shower have a current inspection.

8. Slips, Trips and Falls:

- Be aware of ground and floor conditions

9. Back strains

- Use proper lifting and bending technique at all times

10. Working with simple hand tools, cuts and abrasions:

- Inspect all tools prior to use, wear proper work gloves as determined by the job scope.
- Use of cordless power tools, power tools-electric shock.
- Use all tools properly and to safety standards. Inspect cords / batteries prior to use. GFCI protection required.

11. Pinching or crushing/hand injury:

- Do not place hands in the path of potential pinch points or crush points
- Hand/foot/ body position awareness

12. Asbestos Abatement Pipe and Equipment Insulation:


- Reference MSS Procedure 41-55-001-R1
- Area regulated to OSHA standards(29CFR1926.1101(e) and paragraph (j) decontamination area
- Two person rule is required during abatement
- Personal air monitoring will be required.
- Full face APR with P100 cartridges.
- Wear tyvek coveralls with booties and hood, protection with full body coverage from head to toe.
- Wear nitrile gloves and/or leather gloves
- HEPA vacuum debris.
- Asbestos will be removed using hand tools and wet methods using amended wetting solution and wipes.
- All asbestos wastes must be kept damp enough during handling and disposal operations to prevent fibers from becoming airborne, but must not have any free liquid present during transportation.

13. LO/TO:

- Utilize LO/TO Attachment "B"
- Wear Untreated Natural Fiber Shirt (long sleeve), Pants (long), Safety glasses or safety goggles, Hearing protection (ear canal inserts) and Leather gloves.

14. 240V to 600V Zero Voltage check requirements:

- Mode "1"
- Wear CAL 8+ PPE: Double-Layer switching hood.
- Class 0 Dielectric Gloves.
- AR coveralls (with an arc rating of 8 or more), hardhat, and safety glasses underneath hood.
- 2-man rule applies.
- Use UL approved voltage meter. Test meter on a known live circuit before and after zero voltage

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:


- verification.
 - No metallic objects worn.
 - Voltage rated test equipment.
 - Ensure no un-insulated body part enters prohibited space.
 - Voltage rated tools.
15. Less than 240V Zero Voltage check requirements:
- Mode “1”
 - Use UL approved voltage meter. Test meter on a known live circuit before and after zero voltage verification.
 - Class “0” Dielectric Gloves
 - AR clothing, minimum arc-rating of 4 cal for voltage of < 240 V (long sleeve shirt, pants or coveralls, face shield)
 - AR Protective Equipment (hard hat, safety glasses or safety goggles, hearing protection).
 - No metallic objects worn.
 - Voltage rated test equipment.
 - Ensure no un-insulated body part enters prohibited space.
 - Voltage rated tools.
16. Cone of Safety Identification:
- The Cone of Safety as defined P101-25.0 Cranes, Hoists, Lifting Devices, and Rigging Equipment shall be identified.
 - Time/distance requirements shall be assured by the LANS Hoisting/Rigging Supervisor throughout all lifts.
 - Ensure lift plan is completed for all critical lifts.
17. General PPE Requirements for working within the Power Plant Complex:
- Safety shoes
 - Safety glasses with side shields
 - Hard hat
 - Reflective Safety Vest
 - Leather work gloves
 - Hearing Protection at all times within the Power Plant. A noise evaluation shall be made by a safety engineer for other work as required.

Approach Boundaries


Voltage (VAC)	Limited Approach	Restricted Approach	Prohibited Approach
50-300	3'6"	Avoid Contact	Avoid Contact
301-750	3'6"	1'0"	0'1"

3.0 Training Requirements

- MSS Maintenance Worker, TP 10968
- LO/TO, TP 127
- Electrical Worker Training, Curriculum 642


 Facilities Main tenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0			Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD
Work Document #: (WO # / Task			Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16
TA: 03	Building: 0022	Room:	Additional Location Description:

- Stationary Equipment Mechanics, Curriculum 630
- Sheet metal Workers, Curriculum 649
- Pipefitters, Curriculum 647
- Carpenters, Curriculum 641
- Insulators, Curriculum 643
- Power Plant Operators, Curriculum 632
- Training to work with Cranes and Rigging:
 - Incidental Crane Classroom course # 20295
 - Incidental Crane Exam # 20296
- Site Specific Training (one-time requirement)

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

4.0 Work Execution

- 1.
2. The following system conditions are the configuration and conditions which have been anticipated for performance of the PM activities covered under this standing IWD:
 - a. The electrical power systems are in a configuration which will support nominal steam plant operations. No major disruptions or outages are present and the electrical system lineup is considered to be in a normal configuration.
 - b. The steam plant may be either in a shutdown, standby or normal operation configuration. The mechanical components are under the control of the steam plant operations personnel and no major upset conditions or unanticipated outages are present within the facility.
 - c. The Power Plant operational personnel are manned to the required level and sufficient support is available to support the performance of the preventive maintenance activity.
3. Prerequisites:
 - a. **REVIEW** work package for Life Critical Steps (to be performed by the PIC/RLM).
 - I. **Fall Protection:**
 - Verify that a safety system is in place (where workers understand hazard controls and required PPE) at the work site.
 - Verify that workers understand the fall protection plan.
 - II. **Elevated Work Platforms:**
 - Verify a clear travel path with all necessary clearances has been defined and is adequate.
 - Verify the geographic terrain will support execution of the desired activity.
 - Verify the identification of all energized electrical Systems, structure and components has occurred and their impact to the activity has been accounted for and communicated to the workers.
 - Verify all personnel are qualified to operate the aerial lift device assigned to the activity.
 - b. **INSERT** Life Critical Step hold points into the work package.
 - c. **VERIFY** a daily pre-job brief has been performed with the 5 mandatory questions and 2101 has been read for site hazards and entry requirements. With all affected personnel. Perform a reverse pre-job brief and encourage all craft workers to stay involved.
 - d. **VERIFY** all personnel have appropriate PPE for job execution.
 - e. **BARRICADE** the work area in accordance with MSS-Guide-038 to protect tenants/unexpected personnel/or traffic as directed by the Supervisor or PIC. Clearly identify work zone due to look-alike equipment.




 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:


Execution


4. **PERFORM** LO/TO, when required to perform preventive maintenance.
5. **PERFORM** zero voltage checks for maintenance involving electrical work.
6. **PERFORM** zero energy checks for mechanical maintenance. Relieve stored energy.
7. **PERFORM** preventive maintenance in accordance with work order title and task instructions. UI Procedures will be referenced in the work order task instructions when applicable. Utilize the master work order equipment list when performing preventive maintenance.
8. **REMOVE** all LO/TO.
9. **REMOVE** posting or signs.
10. **CLEAN** up work area and properly dispose of all waste.
11. **COMPLETE** all documentation.

5.0 Close Out

1. Complete closeout of the work activity in accordance with AP-WORK requirements.

<i>Insert Rows above for additional Tasks/Steps or attach pages to clearly communicate ESH&Q/S&S hazards and associated controls.</i>	The RLM and FOD or FOD Representative (if required or Recommended by RLM, e.g. high hazard) approval indicates IWM has been applied appropriately, work is authorized , workers are qualified, work will be performed in accordance with ESH&Q/S&S requirements and the IWD, and facility safety	RLM (Signature/Z#/Date) Required  190429 7-11-17
		FOD or Representative (Signature/Z#/Date) Required  090206 7-12-17
		IH&S Review (Signature/Z#/Date)  7/10/17
		Page 6 of 7

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:
		basis, aggregate hazards, and collocated hazards were appropriately included in the hazard analysis and acknowledges completion of a peer review	SME Review (Signature/Z#/Date) If Required <u>Not Required</u> ESO Review (Signature/Z#/Date) If Required _____
IWD Type <input checked="" type="checkbox"/> Moderate-Hazard <input type="checkbox"/> High-Hazard/Complex <input type="checkbox"/> Standing IWD		Date when RLM re-approval is required _____ Other Conditions for RE-Approval: <u>Scope change or additional hazards identified.</u> (Print) Name of Primary PIC _____ Name of Alternate PIC _____ Name of Alternate PIC _____	Classification review completed, if required. <u>N/A</u> Reviewer Signature/Z#/Date _____

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0			Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD
Work Document #: (WO # / Task)			Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16
TA: 03	Building: 0022	Room:	Additional Location Description:

1.0 Work Scope

This work order task will cover the moderate hazard maintenance within the Power Plant Complex. All work will be performed in accordance with work order title and task instructions. UI Procedures will be referenced in the work order task instructions when applicable. This IWD is considered the controlling document for the work being covered.

2.0 Hazard Identification and Mitigation

2.1 Entry Conditions

- PAUSE/STOP WORK if steps cannot be completed as described, or if unforeseen situations occur. Stabilize the situation if safe, contact your supervisor or Person-In-Charge (PIC), and await further instructions before proceeding
- Ensure activity is on appropriate Plan(s) of the Day
- Check-in with ops prior to performing work
- Steps in this procedure may be worked out of sequence as directed by supervisor/PIC
- Ensure permits required for the work have been approved and posted, as required
- PIC will be available while work is being conducted
- PIC will review site specific hazards noted on IWD Part 2, Form 2101 with all workers
- All hold points will be discussed on a daily basis
- Verify all identified hazards have been eliminated, mitigated or minimized


(HAZARD ANALYSIS performed by Robert Simpson, art sparks– 9/9/2015)

2.2 Electrical

- Arc Flash: Follow PPE requirements and barricade area in accordance with the arc flash label for the specified equipment.

2.3 Mechanical

- Ensure all guards are in place before accessing equipment.
- Relieve all stored energy before performing maintenance activities.

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0			Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD
Work Document #: (WO # / Task)			Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16
TA: 03	Building: 0022	Room:	Additional Location Description:

2.4 Pneumatic

- Relieve all stored pressure.
- Ensure all fittings and hoses are inspected prior to use. Utilize safety devices on the fittings.

2.5 Elevated Work

- Ensure all scaffolding/ladders are inspected daily before use.
- Utilize fall protection equipment when required with approved tie-off points.
- Maintain 3-points of contact when utilizing a ladder
- Ensure ladder is properly oriented to work
- Scaffolding shall be erected and inspected by a competent person only

2.6 Hot Surfaces

- Wear long sleeve shirts or Ansell sleeves when working near hot surfaces.
- Utilize insulating blankets to protect against hot surfaces.

2.7 Welding, Grinding / Torch Cutting

- Use appropriate welding procedure checklist
- Keep combustible materials clear or protect surrounding
- Wear welding hood with appropriate lens for welding operation performed. Wear welding gloves.
- Ensure adequate ventilation or use welding fume extractor
- Spark and flame permit required

2.8 Chemical

- Consult IH&S for PPE requirements
- Place a catch pan under chemical and collect all residual chemicals.
- Review and follow the safety data sheets for all chemical and oil products.
- An eyewash station and safety shower must be within 10 seconds of where the chemicals are being used. Verify eyewash and safety shower have a current inspection.
- Wear chemical goggles for liquids
- PPE must be worn completely and properly

2.9 Slip, Trip & Fall:

- Be aware of ground and floor conditions

2.10 Back Strains


- Use proper lifting and bending technique at all times

2.11 Simple Hand Tools, Cuts & Abrasions:

- Inspect all tools prior to use, wear proper work gloves as determined by the job scope.
- Use of cordless power tools, power tools-electric shock.
- Use all tools properly and to safety standards. Inspect cords / batteries prior to use. GFCI protection required.

2.12 Pinching or Crushing

- Do not place body parts in the path of potential pinch points or crush points
- Hand / foot / body position awareness
- Be aware of line of fire

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0			Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD
Work Document #: (WO # / Task)			Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16
TA: 03	Building: 0022	Room:	Additional Location Description:

2.13 Asbestos Abatement Pipe and Equipment Insulation:


- Reference MSS Procedure 41-55-001-R1
- Area regulated to OSHA standards(29CFR1926.1101(e) and paragraph (j) decontamination area
- Two person rule is required during abatement
- Personal air monitoring will be required.
- Full face APR with P100 cartridges.
- Wear Tyvek coveralls with booties and hood, protection with full body coverage from head to toe.
- Wear nitrile gloves and/or leather gloves
- HEPA vacuum debris.
- Asbestos will be removed using hand tools and wet methods using amended wetting solution and wipes.
- All asbestos wastes must be kept damp enough during handling and disposal operations to prevent fibers from becoming airborne, but must not have any free liquid present during transportation.

2.14 LO/TO:

- Utilize LO/TO Attachment
- Wear Untreated Natural Fiber Shirt (long sleeve), Pants (long), Safety glasses or safety goggles, Hearing protection (ear canal inserts) and Leather gloves.

2.15 230V to 1000V Zero Voltage check requirements:

- Mode "1" Class 1.3 a,b
- Wear CAL 8+ PPE: Double-Layer switching hood.
- Class 0 Dielectric Gloves.
- AR coveralls (with an arc rating of 8 or more), hardhat, and safety glasses underneath hood.
- 2-man rule applies.
- Use NRTL approved voltage meter. Test meter on a known live circuit before and after zero voltage verification.
- No metallic objects worn.
- Voltage rated test equipment.
- Ensure no un-insulated body part enters prohibited space.
- Voltage rated tools.

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0			Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD
Work Document #: (WO # / Task)			Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16
TA: 03	Building: 0022	Room:	Additional Location Description:

2.16 50V to 230V Zero Voltage check requirements:

- Mode "1, Class 1.2 a,b
- Use NRTL approved calibrated voltage meter. Test meter on a known live circuit before and after zero voltage verification.
- Class "0" Dielectric Gloves
- AR clothing, minimum arc-rating of 4 cal for voltage of < 230 V (long sleeve shirt & pants of non-melting fabric or coveralls, face shield)
- AR Protective Equipment (hard hat, safety glasses or safety goggles, hearing protection).
- No metallic objects worn.
- Voltage rated test equipment.
- Ensure no un-insulated body part enters prohibited space.
- Voltage rated tools.

2.17 Cone of Safety Identification:


- The Cone of Safety as defined P101-25.0 Cranes, Hoists, Lifting Devices, and Rigging Equipment shall be identified.
- Time/distance requirements shall be assured by the LANS Hoisting/Rigging Supervisor throughout all lifts.
- Ensure lift plan is completed for all critical lifts.

2.18 General PPE Requirements for working within the Power Plant Complex:

- Safety shoes
- Safety glasses with side shields
- Hard hat
- Reflective Safety Vest
- Leather work gloves
- Hearing Protection at all times within the Power Plant. A noise evaluation shall be made by a safety engineer for other work as required.

Approach Boundaries

Voltage (VAC)	Limited Approach	Restricted Approach
50-300	3'-6"	Avoid Contact
301-750	3'-6"	1'-0"

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16	
TA: 03	Building: 0022	Room:	Additional Location Description:


3.0 Training Requirements

- 3.1 MSS Maintenance Worker, TP 10968
- 3.2 LO/TO, TP 127
- 3.3 Electrical Worker Training, Curriculum 642
- 3.4 Stationary Equipment Mechanics, Curriculum 630
- 3.5 Sheet metal Workers, Curriculum 649
- 3.6 Pipefitters, Curriculum 647
- 3.7 Carpenters, Curriculum 641
- 3.8 Insulators, Curriculum 643
- 3.9 Power Plant Operators, Curriculum 632
- 3.10 Confined space entry, supervisor and attendant (for entry)
- 3.11 Training to work with Cranes and Rigging:
 - Incidental Crane Classroom course # 20295
 - Incidental Crane Exam # 20296
- 3.12 Site Specific Training (one-time requirement)

4.0 Work Execution

4.1 Notes

- Following system conditions are configuration and conditions which have been anticipated for performance of PM activities covered under this IWD:
 - Electrical power systems are in a configuration which will support nominal steam plant operations. No major disruptions or outages are present and electrical system lineup is considered to be in a normal configuration.
 - Steam plant may either be in shutdown, standby or normal operation configuration. Mechanical components are under control of steam plant operations personnel and no major upset conditions or unanticipated outages are present within facility.
 - Power Plant operations personnel are manned to required level and sufficient support is available to support performance of maintenance activity.

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0			Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD
Work Document #: (WO # / Task)			Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16
TA: 03	Building: 0022	Room:	Additional Location Description:



- Permits required for this work: LO/TO Attachment, confined space.
- LO/TO devices shall be applied in accordance with P101-3. "Lockout/Tagout for Hazardous Energy Control"
- Discuss emergency evacuation procedures and muster areas
- Discuss possible error situations and mitigations

4.2 Prerequisites


- VERIFY pre-job briefing has been performed for all affected personnel including 2101 hazards

PIC:  Z#: 120936 Date: 2-24-18

- VERIFY all personnel have the appropriate PPE for job execution
- BARRICADE work area to protect against inadvertent access
- USE robust barriers and flagging to clearly define execution area
- VERIFY all required permits are approved and posted as required
- REVIEW planned activity for Life Critical Steps (to be performed by the PIC/RLM):

IO-01 IO-01	IF fall protection is to be used: <ul style="list-style-type: none"> • VERIFY that a safety system is in place (where workers understand hazard controls and required PPE) at work site. • VERIFY workers understand fall protection plan <p>PIC: <u></u> Z#: _____ Date: _____</p>
	IF aerial platform/lift is to be used: <ul style="list-style-type: none"> • VERIFY a clear travel path with all necessary clearances is defined and adequate • VERIFY geographic terrain will support execution of activity • VERIFY identification of all energized electrical systems, structure and components has occurred and their impact to activity has been accounted for and communicated to workers • VERIFY all personnel are qualified to operate aerial lift device assigned to activity <p>PIC: <u></u> Z#: _____ Date: _____</p>

Confined Spaces: Complete confined space permit per the CSP evaluation.
 Perform ventilation and air monitoring according to the evaluation.
 Set up non-entry rescue equipment if required by the evaluation.
 Contact pest control, as required to remove rodents and droppings.
 Pest control to use 10% bleach solution and full face respirator.

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

4.3 Execution


1. **ERECT/DISMATLE** scaffolding as needed to access work area
 - INSPECT scaffold daily by competent person only
 - WEAR hard hats when working on / near scaffold
2. **PERFORM** LO/TO when required to perform maintenance

VFD:

- **VERIFY** there is not a VFD within this system. This IWD does NOT account for any stored energy that could be present in a VFD.
- **IF** VFD is present or found within system to be worked. **DO NOT** proceed with any work until UI Engineering has given approval to do so.

OK to Proceed:

PIC:



Z#:

120931

Date:

2-28-18


3. **PERFORM** zero voltage checks for maintenance involving electrical work.
4. **PERFORM** zero energy checks for mechanical maintenance. Relieve stored energy.
5. **PERFORM** maintenance in accordance with work order title and task instructions. UI Procedures will be referenced in work order task instructions when applicable. Utilize master work order equipment list when performing maintenance.
6. **REMOVE** all LO/TO
7. **REMOVE** posting or signs
8. **OPERATIONS** acknowledges work is complete and ready to place into service





Operations: Carlos Chacon Type Text Here Z#: 120931 Date: 2-28-18

9. **CLEAN** up work area and properly dispose of all waste
 - **SEGREGATE** waste as required by WMC.

5.0 Close Out

- 5.1 Contact OMC (MC) and inform them work is complete.
- 5.2 Complete all required documentation and return Work Package

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task) UPPS-FY17-001		Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

<i>Insert Rows above for additional Tasks/Steps or attach pages to clearly communicate ESH&Q/S&S hazards and associated controls.</i>	The RLM and FOD or FOD Representative (if required or Recommended by RLM, e.g. high hazard) approval indicates IWM has been applied appropriately, work is authorized, workers are qualified, work will be performed in accordance with ESH&Q/S&S requirements and the IWD, and facility safety basis, aggregate hazards, and collocated hazards were appropriately included in the hazard analysis and acknowledges completion of a peer review	RLM (Signature/Z#/Date) Required  105008 4/11/16
		FOD or Representative (Signature/Z#/Date) Required Pablo F. CdeVaca <small>Digitally signed by Pablo F. CdeVaca DN: cn=Pablo F. CdeVaca, o=LANL, ou=US, email=pfcd@lanl.gov, c=US Location: 1A-011 1A-0022 Room 114 Date: 2016.04.12 10:08:25 -06:00</small>
		SME Review (Signature/Z#/Date) If Required N/A
		ESO Review (Signature/Z#/Date) If Required  180622 4/11/16
		ESH Safety Review (Signature/Z#/Date)  153338 4/7/16
Peer RLM /Work Execution Manager/Maintenance Manager (Signature/Z#/Date) Required  240725- 4/11/16		
IWD Type <input checked="" type="checkbox"/> Moderate-Hazard <input type="checkbox"/> High-Hazard/Complex <input type="checkbox"/> Standing IWD	Date when RLM re-approval is required _____ Other Conditions for RE-Approval <u>Change in</u> <u>scope or additional hazards identified</u> _____ (Print) Name of Primary PIC <u>Carlos Chacon</u> Name of Alternate PIC <u>Greg Donnelly</u> Name of Alternate PIC _____	Classification review completed, if required. N/A Reviewer Signature/Z#/Date _____



AP-WORK-004: Attachment 1 Maintenance & Site Services Worker Engagement Questions

Worker engagement questions are intended to focus attention on the task and ensure uncertainties are addressed. Examples of worker engagement questions are provided below. Worker engagement questions should be tailored to the situation.

Each of the questions listed below will be discussed at each Pre-Job Brief with all affected personnel.

Topic	Completed (X)
What permits, permissions, or support are required to safely start this work?	✓
What is the most likely thing that could go wrong (not the worst thing) and what, specifically, will prevent it?	✓
What can cause us to go beyond the scope of the work?	✓
What hazards in the work area may not have been considered during planning of this job?	✓

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002, FGR-003)
Task Dspln : **Due Date :** 03/31/2018
Superintendent :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00600283 01

MASTER

Date: 12/13/2017**Work Order Task Written To**

Facility : F08 **Unit :** **Op Sys :**
Room : **Area :** **Sys/Cls :**
Equipment : **Component :**
Location :
Job Type : PM
Tag 1 : **Tag 2 :**
Work Item : TA03-0022 FGR **Ops Review Reqd :**

Authorization

Start Permission : **Start Date :**
Complete Notice : **Complete Date :**

Work Order Task Instructions

DO NOT lubricate the bearings if the FGR fan is NOT in operation or in service so that proper amount of grease can be applied using headphones
 You can hear when grease reaches the bearing rolling element. At this point, stop adding grease to prevent bearing damage from overheating

There are two bearings on the fan, each with its own zerk plug
 Remove the shaft guard located in the middle of the drive. The two zerk plugs are located on each of the two bearings

1. Use grease gun with the Ultralube headphones to insert the correct amount of Mobilith SHC 100 grease into zerk fitting
- b. Apply grease while fan is running and stop when you hear the grease enter the running bearing

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002, FGR-003)
Task Dsplt : **Due Date :** 03/31/2018
Superintendent :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00600283 01

MASTER

Date: 12/13/2017

Lubricated fan bearings on FGR-001, FGR-002 & FGR-003

4. Add grease with a hand-operated pressure gun until new grease enters the running bearing
 - a. This is accomplished by using the ultrasonic sensor and headphones to hear when the new grease enters the running bearing
 - b. Stop adding grease when the grease reaches the bearing to limit excess grease from migrating down the motor shaft and into the windings

Note: Be careful when greasing the fan end bearing of the TEFC (Totally Enclosed Fan Cooled) motors. Some motors have a spring-relief outlet grease fitting on the fan end that is not accessible. This spring-relief fitting normally does not have to be removed when regreasing. When greasing, take care in the amount of pressure you apply and verify relief is working
5. Putting in too much or too little grease can cause overheating of the motors and result in motor failure. Use this rule of thumb when adding grease to a motor that has been lubricated on a regular basis:
 It is better to use a little grease more often than a lot of grease less often

Note: Watch out for motors that were shipped only with the bearings packed and not the fill tube or even the bearing housing
 Apply new grease until you can hear it enter the running bearing
6. Now that greasing is complete, leave the relief plug off and run the motor for 10 minutes to expel any excess grease
7. Replace the drain plug and wipe the bearing housing clean
8. Dispose of dirty rags in accordance with Hazardous Waste Guidelines
9. Ensure correct operation of electric motors.

Facility : F08 Unit : Proj :
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM W/O Group : UTIL Task Priority : 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002,
FGR-003)
Task Dspln : Due Date : 03/31/2018
Superintendant :
Hazard : LOW IWD Reqmt : N/A LOW HZRD

Work Order Task

00600283 01

MASTER

Date: 12/13/2017

Work Completion Signatures

Name	Function/Dept.	Date
Chris Salazar	LOG-CS/PP maint,.....	03/01/2018

Comments

(rework?)

Cost Accounting

Cost Center : P2030A

Activity : 640CL000

Percentage : 100

Acct No : XU5000

Sub Acct : 7E2P0000

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002,
FGR-003)
Task Dspln : **Due Date :** 03/31/2018
Superintendant :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00600283 01

MASTER

Date: 12/13/2017



Form 2101

Integrated Work Document (IWD) Part 2, FOD Requirements and Approval for Entry and Area Hazards and Controls

Non-Tenant
Activity Form

IWD No./Work Request No: _____ Revision #: _____

Facility Operation Director (FOD) must determine the facility entry and coordination requirements and identify the Environment, Safety, Health (ESH)/Security and Safeguards (S&S) hazards and controls associated with the activity location.

FOD 8	TA 3	Bldg 22	Room N/A	Other Location Power Plant Bldg - Inside
FOD Designated Facility Point-of-Contact	Name Pablo C de Vaca	Phone 699-8226	Pager N/A	Email pfc@lanl.gov

Entry and Coordination Requirements (Check one or more of the following)

- | | |
|--|---|
| <input type="checkbox"/> No Entry/Coordination Requirements | <input type="checkbox"/> FOD-designated facility Point-of-Contact must sign IWD Part 3 |
| <input checked="" type="checkbox"/> Plan of the Day/Plan of the Week (POTD/POTW) | <input checked="" type="checkbox"/> Check in at Start of Work <input checked="" type="checkbox"/> Work-Area Training Required |
| <input checked="" type="checkbox"/> Security Clearance Requirements | <input checked="" type="checkbox"/> Work must be Scheduled <input checked="" type="checkbox"/> Check in Daily |
| <input type="checkbox"/> Co-located Hazards/Concerns | <input type="checkbox"/> Other Security Requirements (ex.: Cellphone, No Foreign Nationals, etc.) |
| <input checked="" type="checkbox"/> Check out at End of Work | <input type="checkbox"/> Quality Issues <input checked="" type="checkbox"/> Check out Daily |
| <input type="checkbox"/> Escort Required | <input type="checkbox"/> Review under Authorization Basis (AB)/Safety Basis/Unreviewed Safety Question (USQ) |
| <input type="checkbox"/> Other Bounding Conditions: | |

PIC is responsible to conduct a pre-job brief for work activities to ensure that work conditions and worker communications are adequate. A pre job briefing shall be conducted at the job site. UI-OPS will determine if onsite ESH representation is required during work activities

Additional Comments (refer to Job Hazard Analysis [JHA] Tool Facility Notes)

All work must be approved by the Utilities FOD or UI-OPS. POD/POTW-contact Facility POC. No Smoking around Natural Gas Systems. Evaluate inside floor and housekeeping conditions to safely proceed with activities. Check in with Plant Operations Manager/Specialist or Operations Shift Head for final approval to proceed with tasks. Work around power plant chemical pumps and lines. Inspect for leaks before beginning any work task and pause work and report if a leak is found to operations. All personnel entering area must view the site specific training video in room 116 (Boiler Control Room), one time requirement. Observe safety signs and floor markings in all buildings and areas. No safety shoes required for visitors if escorted by Operations or UI Engineering personnel. The West end front lobby and office areas of Bldg 22 are considered a no hazard area.

Instructions: In the block below, identify work-area hazards that could potentially affect the worker(s) or others. Specify the facility controls and preventive measures that must be implemented by the worker(s) to protect against the site hazards as well as any special training required.

ESH/S&S WORK AREA HAZARDS & CONTROLS

Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300 Integrated Work Management, Section 6.1)
<input type="checkbox"/> No Work Area Hazards				

Form 2101 (6/12)

Page 1

Ionizing Radiation Work in posted radiological areas, work with radioactive materials, or work on or near radiation producing devices. Specify Hazard:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
--	---	--	--	--

IWD No./Work Request No: _____

Revision #: _____

ESH/S&S WORK AREA HAZARDS & CONTROLS				
Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
Worker Exposure Working near non-ionizing radiation, beryllium, noise, chemicals, hazardous biological materials, lead, asbestos, temperature/humidity extremes, or high explosives. Specify Hazards:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Required PPE: Hard hat, safety shoes, safety glasses, Hearing protection (noise > 85 dba), Avoid hot surfaces and piping, Long sleeve shirt or Ansell sleeves or coveralls, Gloves when operating valves or contacting pipe/fitting openings where there is potential for hot water/steam release.</p> <p>Be aware of encapsulated asbestos, Follow LANL Asbestos program/rqmts if PACM identified outside containment.</p> <p>Be aware of chemical containers and check labeling. Be aware of piping, associated systems for any leaks. If chemical leak is noticed contact operations manager, IH&S Rep during regular working hrs. Over 100 gallons of a chemical spill leave area, and control</p>	P101-6 PPE • P101-23 Asbestos • P101-31 Hearing Conservations/Noise Program	LANL PPE or equivalent • Hearing protection • Site specific training • Asbestos awareness

		access Call Serf Operators 667-8982 or by Radio Lanl 2 Util 6 For mitigation cleanup process For after-hours contact the UI Duty Officer, 699-7452 to re-assess any abnormal situation		
Energized and Operative Systems Working near energized electrical parts, pressure systems, steam lines; near unprotected belts, pulleys, chains or rotating equipment; fuel fired equipment other than vehicles; or spark or flame producing operations. Specify Hazards: Energized/rotating equipment, High Temperature, High Pressure Water and Steam equipment	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Stay within established walking areas. Observe safety signage alarm lights and horns. Identify explosive hazards and follow task specific IWD if working on plant equipment or components. Note: All TA3-22 independent verification requirement will be determined by the FOD or FOD designee. If questions consult with UI system engineer, Operation Mgr. Designee, or Safety rep.	P101-13 Electrical Safety P101-3 LOTO P101-34 Pressure, Vacuum, and Cryogenic System	Site Specific Training video Electrical Safety LOTO if applicable to task
Confined Spaces Entry into tanks, manholes, cooling towers, sumps, or any other area with potentially low oxygen concentration or other hazards such as toxic vapors or engulfment Specify Hazards:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Observe confined space signs or markings and follow LANL Confined Space Requirements if task requires confined space entry.	P 101-27 Conf. Space	Confined Space Training
Elevated Work Surface Elevated work when fall protection is not provided by conventional handrail systems or required per <u>P101-20, Fall Protection Program</u>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Stay within established walking areas, stairways and paths. Observe safety signage. Follow LANL Fall Protection Requirements if task on roofs or work above 4 feet	P101-20 Fall Protection	Fall Protection
Environmental Impact Activities conducted in areas containing potential release site, contaminated soil, sensitive species, watercourse wetlands, floodplain, historical/archeological sites, or other work area condition that can be impacted by or can impact the environment.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			

Specify Hazards:				
Security Requirements Specify:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Other Hazards Specify: Look-alike Equipment in the vicinity of work site may contain un-controlled hazardous energy	<input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Adequate barriers and controls will be established to prevent unauthorized personnel/workers from entering job site and encounter uncontrolled hazards.	IWD	Pre-job briefing emphasis. Worker confirmation of look-alike potential hazards, locations and barriers set in place to identify those potential hazards.

I have verified that the hazards identified above adequately identify the area hazards and that the IWM process has been applied appropriately.

FOD or Representative (Signature/Z #/Date) Approval Required Pablo F. CdeVaca

Digitally signed by Pablo F. CdeVaca
DN: cn=Pablo F. CdeVaca, o=LANL, ou=LL, email=pfcd@lanl.gov, c=US
Date: 2019.09.11 13:41:00-05

Date Approval Expires: 09/30/2020



AP-WORK-004: Attachment 1 Maintenance & Site Services Worker Engagement Questions

Worker engagement questions are intended to focus attention on the task and ensure uncertainties are addressed. Examples of worker engagement questions are provided below. Worker engagement questions should be tailored to the situation.

Each of the questions listed below will be discussed at each Pre-Job Brief with all affected personnel.

3/1/18

Topic	Completed (X)
IND. FGR BEARING LUBRICATION	
What permits, permissions, or support are required to safely start this work?	X
What is the most likely thing that could go wrong (not the worst thing) and what, specifically, will prevent it?	X
What can cause us to go beyond the scope of the work?	X
What hazards in the work area may not have been considered during planning of this job?	X

Briefing by J.Miller 171769

Briefing to : C.Salazar 202847

J.Lujan 217001

Facility : F08 Unit : Proj :
Task Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS
W/O Type : PM W/O Group : UTIL Task Priority : 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS
Written To : TA03-0022 VARIABLE FREQUENCY DRIVES VID/VFD/FGR
Task Dsplt : Due Date : 03/31/2018
Superintendent :
Hazard : MODERATE IWD Reqmt : TASK SPECIFC

Work Order Task

00600268 01

MASTER

Date: 12/14/2017

Work Order Task Written To

Facility : F08 Unit : Op Sys :
Room : Area : Sys/Cls :
Equipment : Component :
Location :
Job Type : PM
Tag 1 : Tag 2 :
Work Item : SM22VID Ops Review Reqd :

Authorization

Start Permission :	Robert Simpson	3/13/2018
Complete Notice :	Robert Simpson	3/23/2018

Work Order Task Instructions

CRAFT: UICS ELECTRICIANS

FURTHER INSTRUCTIONS/DETAILS

LOTO OF EACH UNIT TO CLEAN INTERNALLY THE INSIDE OF EACH VFD PANEL
TASK IS TO BE DONE THE USE OF COMPRESSED AIR AND A VACUUM CLEANER. REMOVE
ALL DUST AND DEBRIS FROM THE ENCLOSURES

Facility : F08 Unit : Proj : Task Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS W/O Type : PM W/O Group : UTIL Task Priority : 4 Planner : 189099 LOPEZ THERESA M W/O Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS Written To : TA03-0022 VARIABLE FREQUENCY DRIVES VID/VFD/FGR Task Dsplt : Due Date : 03/31/2018 Superintendent : Hazard : MODERATE IWD Reqmt : TASK SPECIFC	Work Order Task 00600268 01 MASTER Date: 12/14/2017
---	--

<u>QC Requirements / Comments</u>

<u>Work Completion Signatures</u>		
Name	Function/Dept.	Date
Carlos Chacon	UPES Controls Electricians	3-21-18
Comments (rework?)		
<input type="checkbox"/> None		
<input type="checkbox"/> No		

Cost Accounting

Cost Center : P2030A

Activity : 640CL000

Percentage : 100

Acct No : XU5000

Sub Acct : 7E2P0000

Facility : F08 Unit : Proj :
Task Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS
W/O Type : PM W/O Group : UTIL Task Priority : 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS
Written To : TA03-0022 VARIABLE FREQUENCY DRIVES VID/VFD/FGR
Task Dspln : Due Date : 03/31/2018
Superintendant :
Hazard : MODERATE IWD Reqmt : TASK SPECIFC

Work Order Task

00600268 01

MASTER

Date: 12/14/2017



Integrated Work Document (IWD) Part 3, Validation and Work Release

IWD # _____ REVISION #: _____ **WORK RELEASE**

By signing below, I verify this activity is compatible with current facility configuration and operating conditions.

FOD designated Ops Mgr or other facility point-of-contact for work area _____

Signature/Z#/Date (If required by FOD): _____

Note: For Standing IWD, release may be given concurrently with signatures on Part 2.

By signing below, I have verified the following:

- I have verified authorization by ensuring approval signatures of the RLM and FOD.
- I have jointly conducted a validation walkdown with workers to confirm the IWD can be performed as written, required initial conditions and other prerequisites are in-place.
- The assigned workers are authorized and are qualified to perform the work in a safe, secure, and environmentally responsible manner.
- I have conducted the pre-job briefing, and all workers (including support workers) have been briefed.
- I have ensured coordination with any required FOD work-area representatives (e.g., area work coordinators).

Primary PIC (Signature/Z#/Date) Required: _____

Alternate PIC Signatures **acknowledges** PIC authority is assumed for the first time (*Note: Alternate PICs are required to sign only once, but formal handoff includes conferring with previous PIC to obtain all required information associated with the handoff*)

Alternate PIC (Signature/Z#/Date) Required: _____

Alternate PIC (Signature/Z#/Date) Required: _____

Pre-Job Brief Content

- What are the critical steps or phases of this activity?
- How can we make a mistake at that point?
- What is the worst thing that can go wrong?
- What controls, preventive measures, and bounding conditions are needed?
- What work permits are required and how will we meet their requirements?
- What are the handoffs and coordination requirements among workers and multiple PICs?
- Are there hold-points including those that require sign-offs?
- What are the pause/stop work responsibilities and expectations (e.g. for unanticipated conditions or hazards)?
- How would we respond to alarms and emergencies?
- Are there lessons learned from previous similar work?
- Is other information needed to perform this activity in a safe, secure, and environmentally responsible manner?
- Does everyone agree to the work tasks/steps, hazards, and controls and commit to follow them?

Pre-Job Brief Attendance Roster

By signing below **as required**, I agree to the following:

- I agree to follow the work steps and implement the controls as written as applicable to my work assignments.
- I agree to pause/stop work when conditions or hazards change or when I encounter unexpected conditions during the execution of work, or when work cannot be performed as written, or instructions become unclear during execution.
- I confirm that I am authorized, qualified, and fit to perform the work.

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Attachment B, LO/TO Orders

Lock Coordinator Name/Z#	Phone #	Alternate Lock Coordinator Name/Z#	Phone #
---------------------------------	----------------	---	----------------

Section 1: General Information			
1. Work Document Number (i.e., Package/Procedure #):		2. LO/TO (Parent) Record #	
3. Date:			
Location			
4. TA:	5. Bldg:	6. Rm:	7. Equipment/Machinery/Name/Number:
8. Reason for LO/TO:			
9. Name of Equipment Owner/Operator:			
10. Energy Type to be Isolated (check all that apply)			
<input type="checkbox"/> Electrical <input type="checkbox"/> Mechanical <input type="checkbox"/> Hydraulic <input type="checkbox"/> Pneumatic <input type="checkbox"/> Steam <input type="checkbox"/> Capacitors <input type="checkbox"/> Compressed Energy <input type="checkbox"/> Gravity <input type="checkbox"/> Other (specify):			
11. Group LO/TO: <input type="checkbox"/> Yes <input type="checkbox"/> No		12. Group Lock Box used: <input type="checkbox"/> Yes <input type="checkbox"/> No	
If Yes, Name of Lead Authorized Worker:		If yes, enter ID# of Lock Box Lock Box ID:	
13. Sequencing Required for LO/TO <u>Installation</u>		14. Sequencing Required for LO/TO <u>Removal</u>	
If Yes, enter the required sequence in column 20 below. If No, place N/A in column 20 below.		If Yes, enter the required sequence in column 28 below. If No, place N/A in column 28 below.	
<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes <input type="checkbox"/> No	
Section 2: LO/TO Installation & Removal			
LO/TO Installation		LO/TO Removal / Return to Service	
15. Approval to Install LO/TO (signature & Z#)		24. Approval to Remove LO/TO (signature & Z#). Call #	
16. Verification required for LO/TO Installation		25. Verification required for LO/TO Removal	
<input type="checkbox"/> No <input type="checkbox"/> Peer Concurrent Dual <input type="checkbox"/> Independent Verification		<input type="checkbox"/> No <input type="checkbox"/> Peer Concurrent Dual <input type="checkbox"/> Independent Verification	
17. Verification Determination Approved by FOD/Designee (Signature)		26. Verification Determination Approved by	
Z#		Z#	
Date		Date	
18. Specific Energy Isolation Device/ID	19. Location of locking Device	20. LO/TO Installation Sequence	21. Required Position/Alignment for LO/TO
22. LO/TO Installation verified By:	27. Required Position/Alignment following Removal		
	28. LO/TO Removal Sequence	29. LO/TO Removal Verified By:	30. As-Left Position
23. LO/TO Points Positioned and First Lock installed by Signature		31. LO/TO Removed, Positioned and Verified by Signature	
Z#		Z#	
Date		Date	

Attachment B, LO/TO Orders

Attachment B, LO/TO Orders (Cont.)			
1. Work Document Number (i.e., Package/Procedure #):		2. LO/TO (Parent) Record #	3. Date:
32. Zero Energy Checks have been completed: <input type="checkbox"/> Yes <input type="checkbox"/> No		33. Completed by Signature Z# Date	
Section 3: Lead Authorized Worker and Authorized Workers (anyone applying a lock for this activity)			
34. Authorized Workers Name(s)	Z#	35. Date workers lock is hung	36. Date workers lock is removed
1.			
2.			
3.			
4.			
5.			
6.			
7.			
8.			
9.			
10.			
Section 4: Return of Lock(s)/Tag(s) and Locking Devices			
All Lock(s)/Tag(s) and Locking Devices have been removed and returned to the Lock Coordinator or Designee			
37. Signature of Lock Coordinator or Designee		Z#	Date

*If you have questions with regards to filling out the Attachment B, LO/TO Orders form, see the directions associated with the form.

*Take the completed forms back to the Lock Coordinator or Designee for closeout.

Continuation Page (print as needed)[illegible]

Attachment B, LO/TO Orders

The following are directions for filling out Attachment B.

1. Enter the Work Document Number, this will be the number from the IWD or the procedure number (i.e., TA88-DOP-0001)
 2. Enter the LO/TO Parent Record number, this is obtained from the Lock Coordinator when the HEC lock(s) are issued. The Remedy LO/TO database issues this number.
 3. Enter the date of when the locks will be applied.
 4. Enter the TA where the lock(s) will be hung.
 5. Enter the Building number of where the lock(s) will be hung.
 6. Enter the Room number where the equipment is located/where work is being performed.
 7. Enter the Equipment/Machinery/Name/Number (example, HVA-001)
 8. Write a brief description of the reason for LO/TO (example, Removing and replacing belts)
 9. Enter the Name of the Equipment Owner/Operator. Each FOD is different in the assigning of Equipment Owner/Operators. There are also programmatic Equipment Owner/Operators.
 10. Check the appropriate energy type to be isolated, check all that apply. Make sure you have considered all energy sources, if other you will need to specify what "other" is.
 11. Check applicable box to identify if a group LO/TO (A LO/TO where two or more authorized workers, regardless of their occupation or craft, lock out and tag out the same equipment to perform servicing or maintenance).
 12. Check applicable box if lock box is used for the job. Enter the lock box ID#. Each organization that issues locks will be required to uniquely number and track lock boxes in their possession.
 13. When installing the lock(s)/tag(s), is there a specific sequence in which the isolation devices are to be positioned. If a specific sequence must be followed, THEN number the sequence order in column 20. If there is not a specific sequence to follow then place N/A in column 20. This needs to be an operations type person (Operator) who understands the equipment/system/component.
 14. When removing the lock(s)/tag(s), is there a specific sequence in which the isolation devices are positioned after lock/tag removal? If a specific sequence must be followed, THEN number the sequence order in column 28. If not, place N/A in the box(s).
- NOTE:** Section 2, LO/TO Installation & Removal – In some of the nuclear facilities, the operations personnel will identify the required position(s) for credited equipment/machinery depending on operational requirements for return to service. In most cases when workers remove locks, the "As-Left" Position will be different then the final position the operations personnel will place the equipment in.
15. The Equipment Owner/Operator signs and enters their Z#, authorizing the installation of the LO/TO. With some FODs this will be the maintenance coordinators.
 16. Is verification required for this LO/TO. Determine if this is Peer Verification (see P101-3, Section 3.15) or Concurrent Dual verification (see P315, Attachment 10, Section 10.3.6), or Independent Verification. For Independent Verification see P315, Attachment 10, Independent Verification, The Operations Manager (OM) prepares and maintains a facility-specific list of systems and components requiring Independent Verification.

Attachment B, LO/TO Orders

17. The FOD/Designee must sign after determining if verification is required. If Independent Verifier is identified at this time then it must be entered into the Remedy database.
18. Enter the specific Energy isolation device/ID, (example, MCC-A, A4)
19. Location of locking device, this is the location of where the lock is applied (example, MCC-A, A4 TA-XX, Bld. XXX, rm. 123)
20. If the LO/TO needs to be installed in a particular order, number the order in which the locks need to be installed. If the "No" box is checked in #13, then place N/A in this column.
21. Required Position/alignment for LO/TO, open, closed, connected, disconnected, on, off, etc.
22. LO/TO installation verified by – Has the equipment /system/component being locked out, been identified by the FOD as requiring verification, see #16. If verification is required the person who performed the verification initials here.
23. The Lead Authorized worker positions the LO/TO points and installs his/her lock and signs that this has been completed.
24. This is the person, who authorized the LO/TO to be removed, signs and places his/her Z# in this box. This signature authority may place a phone number here for the Lead Authorized worker to call for authorization to remove the LO/TO. When verbal authorization is given, it must be documented in this section. Example: John Smith per telecom, 8/13/14 and your initials. Note: It is also permissible to pre-authorize the removal of the lock by pre-signing.
25. Depending on the verification type required for LO/TO removal, check the appropriate verification type box, otherwise check the "No" box.
26. If verification is required, the FOD/Designee must sign. Independent Verifier is identified at this time and entered into the database.
27. Write the required position/alignment the system/component will be placed in following the removal of the lock(s).
28. If the isolation device needs to be positioned in a particular order/sequence, (per Post Maintenance) number the order/sequence in which the isolation device is to be position. If not, place N/A in the box(s).
29. LO/TO removal verified by Lead Authorized Worker – the lock(s) have been removed and the As-Left position is documented in column 30.
30. Enter the As-Left Position.
31. If the removal of the lock has been identified as needing to be verified, the verifier writes name and Z# after verifying the lock has been removed.
32. The authorized worker must verify that the steps utilized in the energy control procedure have effectively isolated the machine or equipment from the hazardous energy.
33. The authorized worker signs after zero energy checks have been completed.
34. All authorized workers applying a lock for this activity names/Z# and the Date must be entered.
35. Enter the date the authorized worker hangs lock.
36. Enter the date the authorized worker removes lock.
37. The Lock Coordinator or designee signs once locks, tags, and locking devices have been removed and returned. If a lock and/or tag are found to be contaminated then that will be noted by the Lock Coordinator or designee and the Lock Coordinator or designee will sign.




AP-WORK-004: Attachment 1 Maintenance & Site Services Worker Engagement Questions

Worker engagement questions are intended to focus attention on the task and ensure uncertainties are addressed. Examples of worker engagement questions are provided below. Worker engagement questions should be tailored to the situation.

Each of the questions listed below will be discussed at each Pre-Job Brief with all affected personnel.

Topic	Completed (X)
What permits, permissions, or support are required to safely start this work?	✓
What is the most likely thing that could go wrong (not the worst thing) and what, specifically, will prevent it?	✓
What can cause us to go beyond the scope of the work?	✓
What hazards in the work area may not have been considered during planning of this job?	✓

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

1.0 Work Scope:

This work order task will cover the moderate hazard preventive maintenance within the Power Plant Complex. All work will be performed in accordance with work order title and task instructions. UI Procedures will be referenced in the work order task instructions when applicable. This IWD is considered the controlling document for the work being covered.

2.0 Hazard Identification and Mitigation

(HAZARD ANALYSIS performed by Robert Simpson, Kedrick Mendez– 9/9/2015)

1. Entry conditions:

- Ensure that the activity is on the Plan of the Day.
- If steps cannot be completed as described, or if unforeseen situations occur, PAUSE/STOP WORK, stabilize the situation, contact your supervisor or the Person-In-Charge (PIC), and await further instructions before proceeding.
- Certain steps in the procedure may be worked out of sequence as directed by the supervisor.
- The permits and work packages required for the project have been approved and are posted, as required.
- The PIC will be available while work is being conducted.
- PIC will review site specific hazards noted on IWD Part 2, Form 2101 with all workers.
- All hold points will be discussed on a daily basis.
- Controls needed to perform the work are identified in this IWD.

2. Electrical Hazards:

- Arc Flash: Follow PPE requirements and barricade area in accordance with the arc flash label for the specified equipment.

3. Mechanical Hazards:

- Ensure all guards are in place before accessing equipment.
- Relieve all stored energy before performing maintenance activities.

4. Pneumatic Hazards:


- Relieve all stored pressure.
- Ensure all fittings and hoses are inspected prior to use. Utilize safety devices on the fittings.

5. Elevated Work:

- Ensure all scaffolding is inspected daily before use.
- Utilize fall protection equipment when required with approved tie-off points.
- Maintain 3-points of contact when utilizing a ladder.

6. Hot Surfaces:

- Wear long sleeve shirts or Ansell sleeves when working near hot surfaces.
- Utilize insulating blankets to protect against hot surfaces.

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

7. Chemical Hazards:

- Consult IH&S for PPE requirements.
- Place a catch pan under chemical and collect all residual chemicals. Deposit chemical in the day tank.
- Review the safety data sheets for all chemical and oil products.
- An eyewash station and safety shower must be within 10 seconds of where the chemicals are being used. Verify eyewash and safety shower have a current inspection.

8. Slips, Trips and Falls:

- Be aware of ground and floor conditions

9. Back strains

- Use proper lifting and bending technique at all times

10. Working with simple hand tools, cuts and abrasions:

- Inspect all tools prior to use, wear proper work gloves as determined by the job scope.
- Use of cordless power tools, power tools-electric shock.
- Use all tools properly and to safety standards. Inspect cords / batteries prior to use. GFCI protection required.

11. Pinching or crushing/hand injury:

- Do not place hands in the path of potential pinch points or crush points
- Hand/foot/ body position awareness

12. Asbestos Abatement Pipe and Equipment Insulation:


- Reference MSS Procedure 41-55-001-R1
- Area regulated to OSHA standards(29CFR1926.1101(e) and paragraph (j) decontamination area
- Two person rule is required during abatement
- Personal air monitoring will be required.
- Full face APR with P100 cartridges.
- Wear tyvek coveralls with booties and hood, protection with full body coverage from head to toe.
- Wear nitrile gloves and/or leather gloves
- HEPA vacuum debris.
- Asbestos will be removed using hand tools and wet methods using amended wetting solution and wipes.
- All asbestos wastes must be kept damp enough during handling and disposal operations to prevent fibers from becoming airborne, but must not have any free liquid present during transportation.

13. LO/TO:

- Utilize LO/TO Attachment "B"
- Wear Untreated Natural Fiber Shirt (long sleeve), Pants (long), Safety glasses or safety goggles, Hearing protection (ear canal inserts) and Leather gloves.

14. 240V to 600V Zero Voltage check requirements:

- Mode "1"
- Wear CAL 8+ PPE: Double-Layer switching hood.
- Class 0 Dielectric Gloves.
- AR coveralls (with an arc rating of 8 or more), hardhat, and safety glasses underneath hood.
- 2-man rule applies.
- Use UL approved voltage meter. Test meter on a known live circuit before and after zero voltage

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

verification.

- No metallic objects worn.
- Voltage rated test equipment.
- Ensure no un-insulated body part enters prohibited space.
- Voltage rated tools.

15. Less than 240V Zero Voltage check requirements:

- Mode "I"
- Use UL approved voltage meter. Test meter on a known live circuit before and after zero voltage verification.
- Class "0" Dielectric Gloves
- AR clothing, minimum arc-rating of 4 cal for voltage of < 240 V (long sleeve shirt, pants or coveralls, face shield)
- AR Protective Equipment (hard hat, safety glasses or safety goggles, hearing protection).
- No metallic objects worn.
- Voltage rated test equipment.
- Ensure no un-insulated body part enters prohibited space.
- Voltage rated tools.

16. Cone of Safety Identification:

- The Cone of Safety as defined P101-25.0 Cranes, Hoists, Lifting Devices, and Rigging Equipment shall be identified.
- Time/distance requirements shall be assured by the LANS Hoisting/Rigging Supervisor throughout all lifts.
- Ensure lift plan is completed for all critical lifts.

17. General PPE Requirements for working within the Power Plant Complex:


- Safety shoes
- Safety glasses with side shields
- Hard hat
- Reflective Safety Vest
- Leather work gloves
- Hearing Protection at all times within the Power Plant. A noise evaluation shall be made by a safety engineer for other work as required.

Approach Boundaries


Voltage (VAC)	Limited Approach	Restricted Approach	Prohibited Approach
50-300	3'6"	Avoid Contact	Avoid Contact
301-750	3'6"	1'0"	0'1"

3.0 Training Requirements

- MSS Maintenance Worker, TP 10968
- LO/TO, TP 127
- Electrical Worker Training, Curriculum 642


 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

- Stationary Equipment Mechanics, Curriculum 630
- Sheet metal Workers, Curriculum 649
- Pipefitters, Curriculum 647
- Carpenters, Curriculum 641
- Insulators, Curriculum 643
- Power Plant Operators, Curriculum 632
- Training to work with Cranes and Rigging:
 - Incidental Crane Classroom course # 20295
 - Incidental Crane Exam # 20296
- Site Specific Training (one-time requirement)

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0			Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD
Work Document #: (WO # / Task)			Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16
TA: 03	Building: 0022	Room:	Additional Location Description:

4.0 Work Execution

- 1.
2. The following system conditions are the configuration and conditions which have been anticipated for performance of the PM activities covered under this standing IWD:
 - a. The electrical power systems are in a configuration which will support nominal steam plant operations. No major disruptions or outages are present and the electrical system lineup is considered to be in a normal configuration.
 - b. The steam plant may be either in a shutdown, standby or normal operation configuration. The mechanical components are under the control of the steam plant operations personnel and no major upset conditions or unanticipated outages are present within the facility.
 - c. The Power Plant operational personnel are manned to the required level and sufficient support is available to support the performance of the preventive maintenance activity.
3. Prerequisites:
 - a. **REVIEW** work package for Life Critical Steps (to be performed by the PIC/RLM).
 - I. **Fall Protection:**
 - Verify that a safety system is in place (where workers understand hazard controls and required PPE) at the work site.
 - Verify that workers understand the fall protection plan.
 - II. **Elevated Work Platforms:**
 - Verify a clear travel path with all necessary clearances has been defined and is adequate.
 - Verify the geographic terrain will support execution of the desired activity.
 - Verify the identification of all energized electrical Systems, structure and components has occurred and their impact to the activity has been accounted for and communicated to the workers.
 - Verify all personnel are qualified to operate the aerial lift device assigned to the activity.
 - b. **INSERT** Life Critical Step hold points into the work package.
 - c. **VERIFY** a daily pre-job brief has been performed with the 5 mandatory questions and 2101 has been read for site hazards and entry requirements. With all affected personnel. Perform a reverse pre-job brief and encourage all craft workers to stay involved.
 - d. **VERIFY** all personnel have appropriate PPE for job execution.
 - e. **BARRICADE** the work area in accordance with MSS-Guide-038 to protect tenants/unexpected personnel/or traffic as directed by the Supervisor or PIC. Clearly identify work zone due to look-alike equipment.




 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:


Execution

4. **PERFORM** LO/TO, when required to perform preventive maintenance.
5. **PERFORM** zero voltage checks for maintenance involving electrical work.
6. **PERFORM** zero energy checks for mechanical maintenance. Relieve stored energy.
7. **PERFORM** preventive maintenance in accordance with work order title and task instructions. UI Procedures will be referenced in the work order task instructions when applicable. Utilize the master work order equipment list when performing preventive maintenance.
8. **REMOVE** all LO/TO.
9. **REMOVE** posting or signs.
10. **CLEAN** up work area and properly dispose of all waste.
11. **COMPLETE** all documentation.

5.0 Close Out

1. Complete closeout of the work activity in accordance with AP-WORK requirements.

<i>Insert Rows above for additional Tasks/Steps or attach pages to clearly communicate ESH&Q/S&S hazards and associated controls.</i>	The RLM and FOD or FOD Representative (if required or Recommended by RLM, e.g. high hazard) approval indicates IWM has been applied appropriately, work is authorized , workers are qualified, work will be performed in accordance with ESH&Q/S&S requirements and the IWD, and facility safety	RLM (Signature/Z#/Date) Required  190429 7-11-17
		FOD or Representative (Signature/Z#/Date) Required 090206  7-12-17
		IH&S Review (Signature/Z#/Date)  7/10/17

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

IWD Type <input checked="" type="checkbox"/> Moderate-Hazard <input type="checkbox"/> High-Hazard/Complex <input type="checkbox"/> Standing IWD	basis, aggregate hazards, and collocated hazards were appropriately included in the hazard analysis and acknowledges completion of a peer review	SME Review (Signature/Z#/Date) If Required <u>Not Required</u>
	Date when RLM re-approval is required _____ Other Conditions for RE-Approval: <u>Scope change or additional hazards identified.</u> (Print) Carlos Chacon Name of Primary PIC _____ Name of Alternate PIC Greg Donnelly _____ Name of Alternate PIC _____	ESO Review (Signature/Z#/Date) If Required Robert Simpson 240725 1/8/2018
		Classification review completed, if required. <u>N/A</u> Reviewer Signature/Z#/Date



Form 2101

Integrated Work Document (IWD) Part 2, FOD Requirements and Approval for Entry and Area Hazards and Controls

Non-Tenant
Activity Form

IWD No./Work Request No: _____ Revision #: _____

Facility Operation Director (FOD) must determine the facility entry and coordination requirements and identify the Environment, Safety, Health (ESH)/Security and Safeguards (S&S) hazards and controls associated with the activity location.

FOD 8	TA 3	Bldg 22	Room N/A	Other Location Power Plant Bldg - Inside
FOD Designated Facility Point-of-Contact	Name Pablo C de Vaca	Phone 699-8226	Pager N/A	Email pfc@lanl.gov

Entry and Coordination Requirements (Check one or more of the following)

- | | |
|--|---|
| <input type="checkbox"/> No Entry/Coordination Requirements | <input type="checkbox"/> FOD-designated facility Point-of-Contact must sign IWD Part 3 |
| <input checked="" type="checkbox"/> Plan of the Day/Plan of the Week (POTD/POTW) | <input checked="" type="checkbox"/> Check in at Start of Work <input checked="" type="checkbox"/> Work-Area Training Required |
| <input checked="" type="checkbox"/> Security Clearance Requirements | <input checked="" type="checkbox"/> Work must be Scheduled <input checked="" type="checkbox"/> Check in Daily |
| <input type="checkbox"/> Co-located Hazards/Concerns | <input type="checkbox"/> Other Security Requirements (ex.: Cellphone, No Foreign Nationals, etc.) |
| <input checked="" type="checkbox"/> Check out at End of Work | <input type="checkbox"/> Quality Issues <input checked="" type="checkbox"/> Check out Daily |
| <input type="checkbox"/> Escort Required | <input type="checkbox"/> Review under Authorization Basis (AB)/Safety Basis/Unreviewed Safety Question (USQ) |
| <input type="checkbox"/> Other Bounding Conditions: | |

PIC is responsible to conduct a pre-job brief for work activities to ensure that work conditions and worker communications are adequate. A pre job briefing shall be conducted at the job site. UI-OPS will determine if onsite ESH representation is required during work activities

Additional Comments (refer to Job Hazard Analysis [JHA] Tool Facility Notes)

All work must be approved by the Utilities FOD or UI-OPS. POD/POTW-contact Facility POC. No Smoking around Natural Gas Systems. Evaluate inside floor and housekeeping conditions to safely proceed with activities. Check in with Plant Operations Manager/Specialist or Operations Shift Head for final approval to proceed with tasks. Work around power plant chemical pumps and lines. Inspect for leaks before beginning any work task and pause work and report if a leak is found to operations. All personnel entering area must view the site specific training video in room 116 (Boiler Control Room), one time requirement. Observe safety signs and floor markings in all buildings and areas. No safety shoes required for visitors if escorted by Operations or UI Engineering personnel. The West end front lobby and office areas of Bldg 22 are considered a no hazard area.

Instructions: In the block below, identify work-area hazards that could potentially affect the worker(s) or others. Specify the facility controls and preventive measures that must be implemented by the worker(s) to protect against the site hazards as well as any special training required.

ESH/S&S WORK AREA HAZARDS & CONTROLS

Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
<input type="checkbox"/> No Work Area Hazards				

Ionizing Radiation Work in posted radiological areas, work with radioactive materials, or work on or near radiation producing devices. Specify Hazard:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
--	---	--	--	--

IWD No./Work Request No: _____ Revision #: _____

ESH/S&S WORK AREA HAZARDS & CONTROLS				
Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
Worker Exposure Working near non-ionizing radiation, beryllium, noise, chemicals, hazardous biological materials, lead, asbestos, temperature/humidity extremes, or high explosives. Specify Hazards:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Required PPE: Hard hat, safety shoes, safety glasses. Hearing protection (noise > 85 dba). Avoid hot surfaces and piping. Long sleeve shirt or Ansell sleeves or coveralls. Gloves when operating valves or contacting pipe/fitting openings where there is potential for hot water/steam release.</p> <p>Be aware of encapsulated asbestos. Follow LANL Asbestos program/rqmts if PACM identified outside containment.</p> <p>Be aware of chemical containers and check labeling. Be aware of piping, associated systems for any leaks. If chemical leak is noticed contact operations manager, IH&S Rep during regular working hrs. Over 100 gallons of a chemical spill leave area, and control</p>	P101-6 PPE • P101-23 Asbestos • P101-31 Hearing Conservations/Noise Program	LANL PPE or equivalent • Hearing protection • Site specific training • Asbestos awareness

		<p>access. Call Serf Operators 667-8982 or by Radio Lanl 2 Util 6 For mitigation cleanup process</p> <p>For after-hours contact the UI Duty Officer, 699-7452 to re-assess any abnormal situation</p>		
<p>Energized and Operative Systems Working near energized electrical parts, pressure systems, steam lines; near unprotected belts, pulleys, chains or rotating equipment; fuel fired equipment other than vehicles; or spark or flame producing operations Specify Hazards: Energized/rotating equipment, High Temperature, High Pressure Water and Steam equipment.</p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Stay within established walking areas. Observe safety signage alarm lights and horns. Identify explosive hazards and follow task specific IWD if working on plant equipment or components. Note: All TA3-22 independent verification requirement will be determined by the FOD or FOD designee. If questions consult with UI system engineer, Operation Mgr. Designee, or Safety rep.</p>	<p>P101-13 Electrical Safety</p> <p>P101-3 LOTO</p> <p>P101-34 Pressure, Vacuum, and Cryogenic System.</p>	<p>Site Specific Training video.</p> <p>Electrical Safety</p> <p>LOTO if applicable to task.</p>
<p>Confined Spaces Entry into tanks, manholes, cooling towers, sumps, or any other area with potentially low oxygen concentration or other hazards such as toxic vapors or engulfment. Specify Hazards:</p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Observe confined space signs or markings and follow LANL Confined Space Requirements if task requires confined space entry.</p>	<p>P 101-27 Conf. Space</p>	<p>Confined Space Training</p>
<p>Elevated Work Surface Elevated work when fall protection is not provided by conventional handrail systems or required per <u>P101-20, Fall Protection Program</u></p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Stay within established walking areas, stairways and paths. Observe safety signage. Follow LANL Fall Protection Requirements if task on roofs or work above 4 feet.</p>	<p>P101-20 Fall Protection</p>	<p>Fall Protection</p>
<p>Environmental Impact Activities conducted in areas containing potential release site, contaminated soil, sensitive species, watercourse wetlands, floodplain, historical/archeological sites, or other work area condition that can be impacted by or can impact the environment.</p>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			


Specify Hazards:				
Security Requirements Specify:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Other Hazards Specify: Look-alike Equipment in the vicinity of work site may contain un-controlled hazardous energy	<input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Adequately barriers and controls will be established to prevent unauthorized personnel/workers from entering job site and encounter uncontrolled hazards.	IWD	Pre-job briefing emphasis. Worker confirmation of look-alike potential hazards, locations and barriers set in place to identify those potential hazards.

I have verified that the hazards identified above adequately identify the area hazards and that the IWM process has been applied appropriately.

FOD or Representative (Signature/Z #/Date) Approval Required Pablo F. CdeVaca

Digitally signed by Pablo F. CdeVaca
DN: cn=Pablo F. CdeVaca, o=LANL, ou=UI, email=pf@lanl.gov, c=US
Date: 2017.09.26 11:53:41 -0500

Date Approval Expires: 09/30/2020

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

1.0 Work Scope:

This work order task will cover the moderate hazard preventive maintenance within the Power Plant Complex. All work will be performed in accordance with work order title and task instructions. UI Procedures will be referenced in the work order task instructions when applicable. This IWD is considered the controlling document for the work being covered.

2.0 Hazard Identification and Mitigation

(HAZARD ANALYSIS performed by Robert Simpson, Kedrick Mendez– 9/9/2015)

1. Entry conditions:

- Ensure that the activity is on the Plan of the Day.
- If steps cannot be completed as described, or if unforeseen situations occur, PAUSE/STOP WORK, stabilize the situation, contact your supervisor or the Person-In-Charge (PIC), and await further instructions before proceeding.
- Certain steps in the procedure may be worked out of sequence as directed by the supervisor.
- The permits and work packages required for the project have been approved and are posted, as required.
- The PIC will be available while work is being conducted.
- PIC will review site specific hazards noted on IWD Part 2, Form 2101 with all workers.
- All hold points will be discussed on a daily basis.
- Controls needed to perform the work are identified in this IWD.

2. Electrical Hazards:

- Arc Flash: Follow PPE requirements and barricade area in accordance with the arc flash label for the specified equipment.

3. Mechanical Hazards:

- Ensure all guards are in place before accessing equipment.
- Relieve all stored energy before performing maintenance activities.

4. Pneumatic Hazards:


- Relieve all stored pressure.
- Ensure all fittings and hoses are inspected prior to use. Utilize safety devices on the fittings.

5. Elevated Work:

- Ensure all scaffolding is inspected daily before use.
- Utilize fall protection equipment when required with approved tie-off points.
- Maintain 3-points of contact when utilizing a ladder.

6. Hot Surfaces:

- Wear long sleeve shirts or Arsell sleeves when working near hot surfaces.
- Utilize insulating blankets to protect against hot surfaces.

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

7. Chemical Hazards:

- Consult IH&S for PPE requirements.
- Place a catch pan under chemical and collect all residual chemicals. Deposit chemical in the day tank.
- Review the safety data sheets for all chemical and oil products.
- An eyewash station and safety shower must be within 10 seconds of where the chemicals are being used. Verify eyewash and safety shower have a current inspection.

8. Slips, Trips and Falls:

- Be aware of ground and floor conditions

9. Back strains

- Use proper lifting and bending technique at all times

10. Working with simple hand tools, cuts and abrasions:

- Inspect all tools prior to use, wear proper work gloves as determined by the job scope.
- Use of cordless power tools, power tools-electric shock.
- Use all tools properly and to safety standards. Inspect cords / batteries prior to use. GFCI protection required.

11. Pinching or crushing/hand injury:

- Do not place hands in the path of potential pinch points or crush points
- Hand/foot/ body position awareness

12. Asbestos Abatement Pipe and Equipment Insulation:


- Reference MSS Procedure 41-55-001-R1
- Area regulated to OSHA standards(29CFR1926.1101(e) and paragraph (j) decontamination area
- Two person rule is required during abatement
- Personal air monitoring will be required.
- Full face APR with P100 cartridges.
- Wear tyvek coveralls with booties and hood, protection with full body coverage from head to toe.
- Wear nitrile gloves and/or leather gloves
- HEPA vacuum debris.
- Asbestos will be removed using hand tools and wet methods using amended wetting solution and wipes.
- All asbestos wastes must be kept damp enough during handling and disposal operations to prevent fibers from becoming airborne, but must not have any free liquid present during transportation.

13. LO/TO:

- Utilize LO/TO Attachment "B"
- Wear Untreated Natural Fiber Shirt (long sleeve), Pants (long), Safety glasses or safety goggles, Hearing protection (ear canal inserts) and Leather gloves.

14. 240V to 600V Zero Voltage check requirements:

- Mode "1"
- Wear CAL 8+ PPE: Double-Layer switching hood.
- Class 0 Dielectric Gloves.
- AR coveralls (with an arc rating of 8 or more), hardhat, and safety glasses underneath hood.
- 2-man rule applies.
- Use UL approved voltage meter. Test meter on a known live circuit before and after zero voltage

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

verification.

- No metallic objects worn.
- Voltage rated test equipment.
- Ensure no un-insulated body part enters prohibited space.
- Voltage rated tools.

15. Less than 240V Zero Voltage check requirements:

- Mode "1"
- Use UL approved voltage meter. Test meter on a known live circuit before and after zero voltage verification.
- Class "0" Dielectric Gloves
- AR clothing, minimum arc-rating of 4 cal for voltage of < 240 V (long sleeve shirt, pants or coveralls, face shield)
- AR Protective Equipment (hard hat, safety glasses or safety goggles, hearing protection).
- No metallic objects worn.
- Voltage rated test equipment.
- Ensure no un-insulated body part enters prohibited space.
- Voltage rated tools.

16. Cone of Safety Identification:

- The Cone of Safety as defined P101-25.0 Cranes, Hoists, Lifting Devices, and Rigging Equipment shall be identified.
- Time/distance requirements shall be assured by the LANS Hoisting/Rigging Supervisor throughout all lifts.
- Ensure lift plan is completed for all critical lifts.

17. General PPE Requirements for working within the Power Plant Complex:


- Safety shoes
- Safety glasses with side shields
- Hard hat
- Reflective Safety Vest
- Leather work gloves
- Hearing Protection at all times within the Power Plant. A noise evaluation shall be made by a safety engineer for other work as required.

Approach Boundaries


Voltage (VAC)	Limited Approach	Restricted Approach	Prohibited Approach
50-300	3'6"	Avoid Contact	Avoid Contact
301-750	3'6"	1'0"	0'1"

3.0 Training Requirements

- MSS Maintenance Worker, TP 10968
- LO/TO, TP 127
- Electrical Worker Training, Curriculum 642


 Facilities Main tenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

<ul style="list-style-type: none"> • Stationary Equipment Mechanics, Curriculum 630 • Sheet metal Workers, Curriculum 649 • Pipefitters, Curriculum 647 • Carpenters, Curriculum 641 • Insulators, Curriculum 643 • Power Plant Operators, Curriculum 632 • Training to work with Cranes and Rigging: <ul style="list-style-type: none"> ▪ Incidental Crane Classroom course # 20295 ▪ Incidental Crane Exam # 20296 • Site Specific Training (one-time requirement)

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)		
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16
TA: 03	Building: 0022	Room: Additional Location Description:

4.0 Work Execution

- 1.
2. The following system conditions are the configuration and conditions which have been anticipated for performance of the PM activities covered under this standing IWD:
 - a. The electrical power systems are in a configuration which will support nominal steam plant operations. No major disruptions or outages are present and the electrical system lineup is considered to be in a normal configuration.
 - b. The steam plant may be either in a shutdown, standby or normal operation configuration. The mechanical components are under the control of the steam plant operations personnel and no major upset conditions or unanticipated outages are present within the facility.
 - c. The Power Plant operational personnel are manned to the required level and sufficient support is available to support the performance of the preventive maintenance activity.
3. Prerequisites:
 - a. **REVIEW** work package for Life Critical Steps (to be performed by the PIC/RLM).
 - I. **Fall Protection:**
 - Verify that a safety system is in place (where workers understand hazard controls and required PPE) at the work site.
 - Verify that workers understand the fall protection plan.
 - II. **Elevated Work Platforms:**
 - Verify a clear travel path with all necessary clearances has been defined and is adequate.
 - Verify the geographic terrain will support execution of the desired activity.
 - Verify the identification of all energized electrical Systems, structure and components has occurred and their impact to the activity has been accounted for and communicated to the workers.
 - Verify all personnel are qualified to operate the aerial lift device assigned to the activity.
 - b. **INSERT** Life Critical Step hold points into the work package.
 - c. **VERIFY** a daily pre-job brief has been performed with the 5 mandatory questions and 2101 has been read for site hazards and entry requirements. With all affected personnel. Perform a reverse pre-job brief and encourage all craft workers to stay involved.
 - d. **VERIFY** all personnel have appropriate PPE for job execution.
 - e. **BARRICADE** the work area in accordance with MSS-Guide-038 to protect tenants/unexpected personnel/or traffic as directed by the Supervisor or PIC. Clearly identify work zone due to look-alike equipment.




 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:


Execution

4. **PERFORM** LO/TO, when required to perform preventive maintenance.
5. **PERFORM** zero voltage checks for maintenance involving electrical work.
6. **PERFORM** zero energy checks for mechanical maintenance. Relieve stored energy.
7. **PERFORM** preventive maintenance in accordance with work order title and task instructions. UI Procedures will be referenced in the work order task instructions when applicable. Utilize the master work order equipment list when performing preventive maintenance.
8. **REMOVE** all LO/TO.
9. **REMOVE** posting or signs.
10. **CLEAN** up work area and properly dispose of all waste.
11. **COMPLETE** all documentation.

5.0 Close Out

1. Complete closeout of the work activity in accordance with AP-WORK requirements.

<i>Insert Rows above for additional Tasks/Steps or attach pages to clearly communicate ESH&Q/S&S hazards and associated controls.</i>	The RLM and FOD or FOD Representative (if required or Recommended by RLM, e.g. high hazard) approval indicates IWM has been applied appropriately, work is authorized , workers are qualified, work will be performed in accordance with ESH&Q/S&S requirements and the IWD, and facility safety	RLM (Signature/Z#/Date) Required  190429 7-11-17 FOD or Representative (Signature/Z#/Date) Required  090206 7-12-17 IH&S Review (Signature/Z#/Date)  7/10/17
---	---	--

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:
		basis, aggregate hazards, and collocated hazards were appropriately included in the hazard analysis and acknowledges completion of a peer review	SME Review (Signature/Z#/Date) If Required <u>Not Required</u> ESO Review (Signature/Z#/Date) If Required _____
IWD Type <input checked="" type="checkbox"/> Moderate-Hazard <input type="checkbox"/> High-Hazard/Complex <input type="checkbox"/> Standing IWD		Date when RLM re-approval is required _____ Other Conditions for RE-Approval: <u>Scope change or additional hazards identified.</u> (Print) Name of Primary PIC _____ Name of Alternate PIC _____ Name of Alternate PIC _____	Classification review completed, if required. N/A Reviewer Signature/Z#/Date _____

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002, FGR-003)
Task Dspln : **Due Date :** 04/30/2018
Superintendant :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00602515 01

MASTER

Date: 01/10/2018**Work Order Task Written To**

Facility : F08 **Unit :** **Op Sys :**
Room : **Area :** **Sys/Cls :**
Equipment : **Component :**
Location :
Job Type : PM
Tag 1 : **Tag 2 :**
Work Item : TA03-0022 FGR **Ops Review Reqd :**

Authorization

Start Permission : **Start Date :**
Complete Notice : **Complete Date :**

Work Order Task Instructions

DO NOT lubricate the bearings if the FGR fan is NOT in operation or in service so that proper amount of grease can be applied using headphones
 You can hear when grease reaches the bearing rolling element. At this point, stop adding grease to prevent bearing damage from overheating

There are two bearings on the fan, each with its own zerk plug
 Remove the shaft guard located in the middle of the drive. The two zerk plugs are located on each of the two bearings

1. Use grease gun with the Ultralube headphones to insert the correct amount of Mobilith SHC 100 grease into zerk fitting
- b. Apply grease while fan is running and stop when you hear the grease enter the running bearing

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002, FGR-003)
Task Dsplt : **Due Date :** 04/30/2018
Superintendent :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00602515 01

MASTER

Date: 01/10/2018

Lubricated fan bearings on FGR-001, FGR-002 & FGR-003

4. Add grease with a hand-operated pressure gun until new grease enters the running bearing
 - a. This is accomplished by using the ultrasonic sensor and headphones to hear when the new grease enters the running bearing
 - b. Stop adding grease when the grease reaches the bearing to limit excess grease from migrating down the motor shaft and into the windings

Note: Be careful when greasing the fan end bearing of the TEFC (Totally Enclosed Fan Cooled) motors. Some motors have a spring-relief outlet grease fitting on the fan end that is not accessible. This spring-relief fitting normally does not have to be removed when regreasing. When greasing, take care in the amount of pressure you apply and verify relief is working
5. Putting in too much or too little grease can cause overheating of the motors and result in motor failure. Use this rule of thumb when adding grease to a motor that has been lubricated on a regular basis:
It is better to use a little grease more often than a lot of grease less often

Note: Watch out for motors that were shipped only with the bearings packed and not the fill tube or even the bearing housing
Apply new grease until you can hear it enter the running bearing
6. Now that greasing is complete, leave the relief plug off and run the motor for 10 minutes to expel any excess grease
7. Replace the drain plug and wipe the bearing housing clean
8. Dispose of dirty rags in accordance with Hazardous Waste Guidelines
9. Ensure correct operation of electric motors.

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002, FGR-003)
Task Dspln : **Due Date :** 04/30/2018
Superintendant :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00602515 01

MASTER

Date: 01/10/2018

--

Work Completion Signatures

Name	Function/Dept.	Date
Dennis Gutierrez	LOGCS/Maintenance	04/02/2018

Comments	
(rework?)	

Cost Accounting**Cost Center :** P2030A**Activity :** 640CL000**Percentage :** 100**Acct No :** XU5000**Sub Acct :** 7E2P0000

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002,
FGR-003)
Task Dspln : **Due Date :** 04/30/2018
Superintendant :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00602515 01

MASTER

Date: 01/10/2018



AP-WORK-004: Attachment 1
Maintenance & Site Services
Worker Engagement Questions

Worker engagement questions are intended to focus attention on the task and ensure uncertainties are addressed. Examples of worker engagement questions are provided below. Worker engagement questions should be tailored to the situation.

Each of the questions listed below will be discussed at each Pre-Job Brief with all affected personnel.

Topic	Completed (X)
Lmo FGR Fans lobe 4-2-18	
What permits, permissions, or support are required to safely start this work?	X
What is the most likely thing that could go wrong (not the worst thing) and what, specifically, will prevent it?	X
What can cause us to go beyond the scope of the work?	X
What hazards in the work area may not have been considered during planning of this job?	X

Prejob by C. Salazar 202847 4-2-18
 Jerry Lujan
 Dennis Gutierrez



Form 2101

**Integrated Work Document (IWD) Part 2,
FOD Requirements and Approval for Entry and Area Hazards and Controls**

**Non-Tenant
Activity Form**

IWD No./Work Request No: _____ Revision #: _____

Facility Operation Director (FOD) must determine the facility entry and coordination requirements and identify the Environment, Safety, Health (ESH)/Security and Safeguards (S&S) hazards and controls associated with the activity location.

FOD 8	TA 3	Bldg 22	Room N/A	Other Location Power Plant Bldg - Inside
FOD Designated Facility Point-of-Contact	Name Pablo C de Vaca	Phone 699-8226	Pager N/A	Email pfc@lanl.gov

Entry and Coordination Requirements (Check one or more of the following)

- | | |
|--|---|
| <input type="checkbox"/> No Entry/Coordination Requirements | <input type="checkbox"/> FOD-designated facility Point-of-Contact must sign IWD Part 3 |
| <input checked="" type="checkbox"/> Plan of the Day/Plan of the Week (POTD/POTW) | <input checked="" type="checkbox"/> Check in at Start of Work <input checked="" type="checkbox"/> Work-Area Training Required |
| <input checked="" type="checkbox"/> Security Clearance Requirements | <input checked="" type="checkbox"/> Work must be Scheduled <input checked="" type="checkbox"/> Check in Daily |
| <input type="checkbox"/> Co-located Hazards/Concerns | <input type="checkbox"/> Other Security Requirements (ex : Cellphone, No Foreign Nationals, etc) |
| <input checked="" type="checkbox"/> Check out at End of Work | <input type="checkbox"/> Quality Issues <input checked="" type="checkbox"/> Check out Daily |
| <input type="checkbox"/> Escort Required | <input type="checkbox"/> Review under Authorization Basis (AB)/Safety Basis/Unreviewed Safety Question (USQ) |
| <input type="checkbox"/> Other Bounding Conditions: | |

PIC is responsible to conduct a pre-job brief for work activities to ensure that work conditions and worker communications are adequate. A pre job briefing shall be conducted at the job site. UI-OPS will determine if onsite ESH representation is required during work activities

Additional Comments (refer to Job Hazard Analysis [JHA] Tool Facility Notes)

All work must be approved by the Utilities FOD or UI-OPS. POD/POTW-contact Facility POC. No Smoking around Natural Gas Systems. Evaluate inside floor and housekeeping conditions to safely proceed with activities. Check in with Plant Operations Manager/Specialist or Operations Shift Head for final approval to proceed with tasks. Work around power plant chemical pumps and lines. Inspect for leaks before beginning any work task and pause work and report if a leak is found to operations. All personnel entering area must view the site specific training video in room 116 (Boiler Control Room), one time requirement. Observe safety signs and floor markings in all buildings and areas. No safety shoes required for visitors if escorted by Operations or UI Engineering personnel. The West end front lobby and office areas of Bldg 22 are considered a no hazard area.

Instructions: In the block below, identify work-area hazards that could potentially affect the worker(s) or others. Specify the facility controls and preventive measures that must be implemented by the worker(s) to protect against the site hazards as well as any special training required.

ESH/S&S WORK AREA HAZARDS & CONTROLS

Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
<input type="checkbox"/> No Work Area Hazards				

Form 2101 (6/12)

Page 1

Ionizing Radiation Work in posted radiological areas, work with radioactive materials, or work on or near radiation producing devices. Specify Hazard:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
--	---	--	--	--

IWD No./Work Request No: _____ Revision #: _____

ESH/S&S WORK AREA HAZARDS & CONTROLS				
Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
Worker Exposure Working near non-ionizing radiation, beryllium, noise, chemicals, hazardous biological materials, lead, asbestos, temperature/humidity extremes, or high explosives. Specify Hazards:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Required PPE: Hard hat, safety shoes, safety glasses. Hearing protection (noise > 85 dba). Avoid hot surfaces and piping. Long sleeve shirt or Ansell sleeves or coveralls. Gloves when operating valves or contacting pipe/fitting openings where there is potential for hot water/steam release.</p> <p>Be aware of encapsulated asbestos. Follow LANL Asbestos program/rqmts if PACM identified outside containment.</p> <p>Be aware of chemical containers and check labeling. Be aware of piping, associated systems for any leaks. If chemical leak is noticed contact operations manager, IH&S Rep during regular working hrs. Over 100 gallons of a chemical spill leave area, and control</p>	P101-6 PPE • P101-23 Asbestos • P101-31 Hearing Conservations/Noise Program	LANL PPE or equivalent • Hearing protection • Site specific training • Asbestos awareness

		<p>access Call Serf Operators 667-8982 or by Radio Lanl 2 Util 6 For mitigation cleanup process.</p> <p>For after-hours contact the UI Duty Officer, 699-7452 to re-assess any abnormal situation</p>		
<p>Energized and Operative Systems Working near energized electrical parts, pressure systems, steam lines; near unprotected belts, pulleys, chains or rotating equipment; fuel fired equipment other than vehicles; or spark or flame producing operations. Specify Hazards: Energized/rotating equipment, High Temperature, High Pressure Water and Steam equipment.</p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Stay within established walking areas. Observe safety signage alarm lights and horns. Identify explosive hazards and follow task specific IWD if working on plant equipment or components. Note: All TA3-22 independent verification requirement will be determined by the FOD or FOD designee. If questions consult with UI system engineer, Operation Mgr. Designee, or Safety rep.</p>	<p>P101-13 Electrical Safety</p> <p>P101-3 LOTO</p> <p>P101-34 Pressure, Vacuum, and Cryogenic System.</p>	<p>Site Specific Training video.</p> <p>Electrical Safety</p> <p>LOTO if applicable to task</p>
<p>Confined Spaces Entry into tanks, manholes, cooling towers, sumps, or any other area with potentially low oxygen concentration or other hazards such as toxic vapors or engulfment. Specify Hazards:</p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Observe confined space signs or markings and follow LANL Confined Space Requirements if task requires confined space entry</p>	<p>P 101-27 Conf. Space</p>	<p>Confined Space Training</p>
<p>Elevated Work Surface Elevated work when fall protection is not provided by conventional handrail systems or required per <u>P101-20, Fall Protection Program</u></p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Stay within established walking areas, stairways and paths. Observe safety signage. Follow LANL Fall Protection Requirements if task on roofs or work above 4 feet.</p>	<p>P101-20 Fall Protection</p>	<p>Fall Protection</p>
<p>Environmental Impact Activities conducted in areas containing potential release site, contaminated soil, sensitive species, watercourse wetlands, floodplain, historical/archeological sites, or other work area condition that can be impacted by or can impact the environment.</p>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			

Specify Hazards:				
Security Requirements Specify:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Other Hazards Specify: Look-alike Equipment in the vicinity of work site may contain un-controlled hazardous energy	<input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Adequate barriers and controls will be established to prevent unauthorized personnel/workers from entering job site and encounter uncontrolled hazards.	IWD	Pre-job briefing emphasis. Worker confirmation of look-alike potential hazards, locations and barriers set in place to identify those potential hazards.

I have verified that the hazards identified above adequately identify the area hazards and that the IWM process has been applied appropriately.

FOD or Representative (Signature/Z #/Date) Approval Required Pablo F. CdeVaca

Digitally signed by Pablo F. CdeVaca
DN: cn=Pablo F. CdeVaca, o=LANL, ou=LA, email=pf@lanl.gov, c=US
Date: 2017.06.26 11:53:41 -0600

Date Approval Expires: 09/30/2020

Facility : F08	Unit :	Proj :	Work Order Task 00602501 01 MASTER Date: 01/10/2018
Task Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS			
W/O Type : PM	W/O Group : UTIL	Task Priority : 4	
Planner : 189099 LOPEZ THERESA M			
W/O Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS			
Written To : TA03-0022 VARIABLE FREQUENCY DRIVES VID/VFD/FGR			
Task Dspln :	Due Date : 04/30/2018		
Superintendent :			
Hazard : MODERATE	IWD Reqmt : TASK SPECIFC		

<u>Work Order Task Written To</u>		
Facility : F08	Unit :	Op Sys :
Room :	Area :	Sys/Cls :
Equipment :	Component :	
Location :		
Job Type : PM		
Tag 1 :	Tag 2 :	
Work Item : SM22VID	Ops Review Reqd :	

<u>Authorization</u>		
Start Permission :	<input type="text" value="Robert Simpson"/>	<input type="text" value="4/10/2018"/>
Complete Notice :	<input type="text" value="Robert Simpson"/>	<input type="text" value="4/26/2018"/>

<u>Work Order Task Instructions</u>
 CRAFT: UICS ELECTRICIANS FURTHER INSTRUCTIONS/DETAILS LOTO OF EACH UNIT TO CLEAN INTERNALLY THE INSIDE OF EACH VFD PANEL TASK IS TO BE DONE THE USE OF COMPRESSED AIR AND A VACUUM CLEANER. REMOVE ALL DUST AND DEBRIS FROM THE ENCLOSURES .

Facility : F08 **Unit :** **Proj :**
Task Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS
Written To : TA03-0022 VARIABLE FREQUENCY DRIVES VID/VFD/FGR
Task Dspln : **Due Date :** 04/30/2018
Superintendent :
Hazard : MODERATE **IWD Reqmt :** TASK SPECIFC

Work Order Task

00602501 01

MASTER

Date: 01/10/2018QC Requirements / CommentsWork Completion Signatures

Name	Function/Dept.	Date
Carlos Chacon	UPES Controls Electricians	4-26-18
Comments <input type="checkbox"/> None (rework?) <input type="checkbox"/> No		

Cost Accounting**Cost Center :** P2030A**Activity :** 640CL000**Percentage :** 100**Acct No :** XU5000**Sub Acct :** 7E2P0000

Facility : F08 Unit : Proj :
Task Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS
W/O Type : PM W/O Group : UTIL Task Priority : 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP (E) 1M TA3-22 VID/VFD/FGR FILTERS
Written To : TA03-0022 VARIABLE FREQUENCY DRIVES VID/VFD/FGR
Task Dspln : Due Date : 04/30/2018
Superintendant :
Hazard : MODERATE IWD Reqmt : TASK SPECIFC

Work Order Task

00602501 01

MASTER

Date: 01/10/2018



Integrated Work Document (IWD) Part 3, Validation and Work Release

IWD # _____ REVISION #: _____ **WORK RELEASE**

By signing below, I verify this activity is compatible with current facility configuration and operating conditions.

FOD designated Ops Mgr or other facility point-of-contact for work area

Signature/Z#/Date (If required by FOD): _____

Note: For Standing IWD, release may be given concurrently with signatures on Part 2

By signing below, I have verified the following:

- I have verified authorization by ensuring approval signatures of the RLM and FOD.
- I have jointly conducted a validation walkdown with workers to confirm the IWD can be performed as written, required initial conditions and other prerequisites are in-place.
- The assigned workers are authorized and are qualified to perform the work in a safe, secure, and environmentally responsible manner.
- I have conducted the pre-job briefing, and all workers (including support workers) have been briefed.
- I have ensured coordination with any required FOD work area representatives (e.g., area work coordinators).

Primary PIC (Signature/Z#/Date) Required: _____

Alternate PIC Signatures **acknowledges** PIC authority is assumed for the first time (Note: Alternate PICs are required to sign only once, but formal handoff includes conferring with previous PIC to obtain all required information associated with the handoff)

Alternate PIC (Signature/Z#/Date) Required: _____

Alternate PIC (Signature/Z#/Date) Required: _____

Pre-Job Brief Content

- What are the critical steps or phases of this activity?
- How can we make a mistake at that point?
- What is the worst thing that can go wrong?
- What controls, preventive measures, and bounding conditions are needed?
- What work permits are required and how will we meet their requirements?
- What are the handoffs and coordination requirements among workers and multiple PICs?
- Are there hold-points including those that require sign-offs?
- What are the pause/stop work responsibilities and expectations (e.g. for unanticipated conditions or hazards)?
- How would we respond to alarms and emergencies?
- Are there lessons learned from previous similar work?
- Is other information needed to perform this activity in a safe, secure, and environmentally responsible manner?
- Does everyone agree to the work tasks/steps, hazards, and controls and commit to follow them?

Pre-Job Brief Attendance Roster

By signing below **as required**, I agree to the following:

- I agree to follow the work steps and implement the controls as written as applicable to my work assignments.
- I agree to pause/stop work when conditions or hazards change or when I encounter unexpected conditions during the execution of work, or when work cannot be performed as written, or instructions become unclear during execution.
- I confirm that I am authorized, qualified, and fit to perform the work.

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Worker (Signature/Z#/Date)

Attachment B, LO/TO Orders

Lock Coordinator Name/Z#	Phone #	Alternate Lock Coordinator Name/Z#	Phone #
Section 1: General Information			
1. Work Document Number (i.e., Package/Procedure #):		2. LO/TO (Parent) Record #	3. Date:
Location			
4. TA:	5. Bldg:	6. Rm:	7. Equipment/Machinery/Name/Number:
8. Reason for LO/TO:			
9. Name of Equipment Owner/Operator:			
10. Energy Type to be Isolated (check all that apply)			
<input type="checkbox"/> Electrical <input type="checkbox"/> Mechanical <input type="checkbox"/> Hydraulic <input type="checkbox"/> Pneumatic <input type="checkbox"/> Steam <input type="checkbox"/> Capacitors <input type="checkbox"/> Compressed Energy <input type="checkbox"/> Gravity <input type="checkbox"/> Other (specify):			
11. Group LO/TO: <input type="checkbox"/> Yes <input type="checkbox"/> No		12. Group Lock Box used: <input type="checkbox"/> Yes <input type="checkbox"/> No	
If Yes, Name of Lead Authorized Worker:		If yes, enter ID# of Lock Box	
		Lock Box ID:	
13. Sequencing Required for LO/TO <u>Installation</u>		14. Sequencing Required for LO/TO <u>Removal</u>	
If Yes, enter the required sequence in column 20 below. If No, place N/A in column 20 below.		If Yes, enter the required sequence in column 28 below. If No, place N/A in column 28 below.	
<input type="checkbox"/> Yes <input type="checkbox"/> No		<input type="checkbox"/> Yes <input type="checkbox"/> No	
Section 2: LO/TO Installation & Removal			
LO/TO Installation		LO/TO Removal / Return to Service	
15. Approval to Install LO/TO (signature & Z#)		24. Approval to Remove LO/TO (signature & Z#), Call #	
16. Verification required for LO/TO Installation		25. Verification required for LO/TO Removal	
<input type="checkbox"/> No <input type="checkbox"/> Peer Concurrent Dual <input type="checkbox"/> Independent Verification		<input type="checkbox"/> No <input type="checkbox"/> Peer Concurrent Dual <input type="checkbox"/> Independent Verification	
17. Verification Determination Approved by		26. Verification Determination Approved by	
FOD/Designee (signature)		Z#	
Date		Date	
18. Specific Energy Isolation Device/ID	19. Location of locking Device	20. LO/TO Installation Sequence	21. Required Position/Alignment for LO/TO
22. LO/TO Installation verified By:	27. Required Position/Alignment following Removal	28. LO/TO Removal Sequence	29. LO/TO Removal Verified By:
30. As-Left Position			
23. LO/TO Points Positioned and First Lock installed by Signature	Z#	Date	31. LO/TO Removed, Positioned and Verified by Signature

Attachment B, LO/TO Orders

Attachment B, LO/TO Orders (Cont.)			
1. Work Document Number (i.e., Package/Procedure #):		2. LO/TO (Parent) Record #	3. Date:
32. Zero Energy Checks have been completed <input type="checkbox"/> Yes <input type="checkbox"/> No		33. Completed by Signature _____ Z# _____ Date _____	
Section 3: Lead Authorized Worker and Authorized Workers (anyone applying a lock for this activity)			
34. Authorized Workers Name(s)	Z#	35. Date workers lock is hung	36. Date workers lock is removed
1.			
2.			
3.			
4.			
5.			
6.			
7.			
8.			
9.			
10.			
Section 4: Return of Lock(s)/Tag(s) and Locking Devices			
All Lock(s)/Tag(s) and Locking Devices have been removed and returned to the Lock Coordinator or Designee			
37. Signature of Lock Coordinator or Designee		Z#	Date

*If you have questions with regards to filling out the Attachment B, LO/TO Orders form, see the directions associated with the form.

*Take the completed forms back to the Lock Coordinator or Designee for closeout.

Continuation Page (print as needed)[illegible]

Attachment B, LO/TO Orders

The following are directions for filling out Attachment B.

1. Enter the Work Document Number, this will be the number from the IWD or the procedure number (i.e., TA88-DOP-0001)
 2. Enter the LO/TO Parent Record number, this is obtained from the Lock Coordinator when the HEC lock(s) are issued. The Remedy LO/TO database issues this number.
 3. Enter the date of when the locks will be applied.
 4. Enter the TA where the lock(s) will be hung.
 5. Enter the Building number of where the lock(s) will be hung.
 6. Enter the Room number where the equipment is located/where work is being performed.
 7. Enter the Equipment/Machinery/Name/Number (example, HVA-001)
 8. Write a brief description of the reason for LO/TO (example, Removing and replacing belts)
 9. Enter the Name of the Equipment Owner/Operator. Each FOD is different in the assigning of Equipment Owner/Operators. There are also programmatic Equipment Owner/Operators.
 10. Check the appropriate energy type to be isolated, check all that apply. Make sure you have considered all energy sources, if other you will need to specify what "other" is.
 11. Check applicable box to identify if a group LO/TO (A LO/TO where two or more authorized workers, regardless of their occupation or craft, lock out and tag out the same equipment to perform servicing or maintenance).
 12. Check applicable box if lock box is used for the job. Enter the lock box ID#. Each organization that issues locks will be required to uniquely number and track lock boxes in their possession.
 13. When installing the lock(s)/tag(s), is there a specific sequence in which the isolation devices are to be positioned. If a specific sequence must be followed, THEN number the sequence order in column 20. If there is not a specific sequence to follow then place N/A in column 20. This needs to be an operations type person (Operator) who understands the equipment/system/component.
 14. When removing the lock(s)/tag(s), is there a specific sequence in which the isolation devices are positioned after lock/tag removal? If a specific sequence must be followed, THEN number the sequence order in column 28. If not, place N/A in the box(s).
- NOTE:** Section 2, LO/TO Installation & Removal – In some of the nuclear facilities, the operations personnel will identify the required position(s) for credited equipment/machinery depending on operational requirements for return to service. In most cases when workers remove locks, the "As-Left" Position will be different then the final position the operations personnel will place the equipment in.
15. The Equipment Owner/Operator signs and enters their Z#, authorizing the installation of the LO/TO. With some FODs this will be the maintenance coordinators.
 16. Is verification required for this LO/TO. Determine if this is Peer Verification (see P101-3, Section 3.15) or Concurrent Dual verification (see P315, Attachment 10, Section 10.3.6), or Independent Verification. For Independent Verification see P315, Attachment 10, Independent Verification, The Operations Manager (OM) prepares and maintains a facility-specific list of systems and components requiring Independent Verification.

Attachment B, LO/TO Orders

17. The FOD/Designee must sign after determining if verification is required. If Independent Verifier is identified at this time then it must be entered into the Remedy database.
18. Enter the specific Energy isolation device/ID, (example, MCC-A, A4)
19. Location of locking device, this is the location of where the lock is applied (example, MCC-A, A4 TA-XX, Bld. XXX, rm. 123)
20. If the LO/TO needs to be installed in a particular order, number the order in which the locks need to be installed. If the "No" box is checked in #13, then place N/A in this column.
21. Required Position/alignment for LO/TO, open, closed, connected, disconnected, on, off, etc.
22. LO/TO installation verified by – Has the equipment /system/component being locked out, been identified by the FOD as requiring verification, see #16. If verification is required the person who performed the verification initials here.
23. The Lead Authorized worker positions the LO/TO points and installs his/her lock and signs that this has been completed.
24. This is the person, who authorized the LO/TO to be removed, signs and places his/her Z# in this box. This signature authority may place a phone number here for the Lead Authorized worker to call for authorization to remove the LO/TO. When verbal authorization is given, it must be documented in this section. Example: John Smith per telecom, 8/13/14 and your initials. Note: It is also permissible to pre-authorize the removal of the lock by pre-signing.
25. Depending on the verification type required for LO/TO removal, check the appropriate verification type box, otherwise check the "No" box.
26. If verification is required, the FOD/Designee must sign. Independent Verifier is identified at this time and entered into the database.
27. Write the required position/alignment the system/component will be placed in following the removal of the lock(s).
28. If the isolation device needs to be positioned in a particular order/sequence, (per Post Maintenance) number the order/sequence in which the isolation device is to be position. If not, place N/A in the box(s).
29. LO/TO removal verified by Lead Authorized Worker – the lock(s) have been removed and the As-Left position is documented in column 30.
30. Enter the As-Left Position.
31. If the removal of the lock has been identified as needing to be verified, the verifier writes name and Z# after verifying the lock has been removed.
32. The authorized worker must verify that the steps utilized in the energy control procedure have effectively isolated the machine or equipment from the hazardous energy.
33. The authorized worker signs after zero energy checks have been completed.
34. All authorized workers applying a lock for this activity names/Z# and the Date must be entered.
35. Enter the date the authorized worker hangs lock.
36. Enter the date the authorized worker removes lock.
37. The Lock Coordinator or designee signs once locks, tags, and locking devices have been removed and returned. If a lock and/or tag are found to be contaminated then that will be noted by the Lock Coordinator or designee and the Lock Coordinator or designee will sign.



Form 2101

Integrated Work Document (IWD) Part 2, FOD Requirements and Approval for Entry and Area Hazards and Controls

Non-Tenant
Activity Form

IWD No./Work Request No: _____

Revision #: _____

Facility Operation Director (FOD) must determine the facility entry and coordination requirements and identify the Environment, Safety, Health (ESH)/Security and Safeguards (S&S) hazards and controls associated with the activity location.

FOD 8	TA 3	Bldg 22	Room N/A	Other Location Power Plant Bldg - Inside
FOD Designated Facility Point-of-Contact	Name Pablo C de Vaca	Phone 699-8226	Pager N/A	Email pfc@lanl.gov

Entry and Coordination Requirements (Check one or more of the following)

- | | |
|--|---|
| <input type="checkbox"/> No Entry/Coordination Requirements | <input type="checkbox"/> FOD-designated facility Point-of-Contact must sign IWD Part 3 |
| <input checked="" type="checkbox"/> Plan of the Day/Plan of the Week (POTD/POTW) | <input checked="" type="checkbox"/> Check in at Start of Work <input checked="" type="checkbox"/> Work-Area Training Required |
| <input checked="" type="checkbox"/> Security Clearance Requirements | <input checked="" type="checkbox"/> Work must be Scheduled <input checked="" type="checkbox"/> Check in Daily |
| <input type="checkbox"/> Co-located Hazards/Concerns | <input type="checkbox"/> Other Security Requirements (ex.: Cellphone, No Foreign Nationals, etc.) |
| <input checked="" type="checkbox"/> Check out at End of Work | <input type="checkbox"/> Quality Issues <input checked="" type="checkbox"/> Check out Daily |
| <input type="checkbox"/> Escort Required | <input type="checkbox"/> Review under Authorization Basis (AB)/Safety Basis/Unreviewed Safety Question (USQ) |
| <input type="checkbox"/> Other Bounding Conditions: | |

PIC is responsible to conduct a pre-job brief for work activities to ensure that work conditions and worker communications are adequate. A pre job briefing shall be conducted at the job site. UI-OPS will determine if onsite ESH representation is required during work activities

Additional Comments (refer to Job Hazard Analysis [JHA] Tool Facility Notes)

All work must be approved by the Utilities FOD or UI-OPS. POD/POTW-contact Facility POC. No Smoking around Natural Gas Systems. Evaluate inside floor and housekeeping conditions to safely proceed with activities. Check in with Plant Operations Manager/Specialist or Operations Shift Head for final approval to proceed with tasks. Work around power plant chemical pumps and lines. Inspect for leaks before beginning any work task and pause work and report if a leak is found to operations. All personnel entering area must view the site specific training video in room 116 (Boiler Control Room), one time requirement. Observe safety signs and floor markings in all buildings and areas. No safety shoes required for visitors if escorted by Operations or UI Engineering personnel. The West end front lobby and office areas of Bldg 22 are considered a no hazard area.

Instructions: In the block below, identify work-area hazards that could potentially affect the worker(s) or others. Specify the facility controls and preventive measures that must be implemented by the worker(s) to protect against the site hazards as well as any special training required.

ESH/S&S WORK AREA HAZARDS & CONTROLS

Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
<input type="checkbox"/> No Work Area Hazards				

Form 2101 (6/12)

Page 1

Ionizing Radiation Work in posted radiological areas, work with radioactive materials, or work on or near radiation producing devices. Specify Hazard:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
--	---	--	--	--

IWD No./Work Request No: _____ Revision #: _____

ESH/S&S WORK AREA HAZARDS & CONTROLS				
Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
Worker Exposure Working near non-ionizing radiation, beryllium, noise, chemicals, hazardous biological materials, lead, asbestos, temperature/humidity extremes, or high explosives. Specify Hazards:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Required PPE: Hard hat, safety shoes, safety glasses. Hearing protection (noise > 85 dba). Avoid hot surfaces and piping. Long sleeve shirt or Ansell sleeves or coveralls. Gloves when operating valves or contacting pipe/fitting openings where there is potential for hot water/steam release.</p> <p>Be aware of encapsulated asbestos. Follow LANL Asbestos program/rqmts if PACM identified outside containment.</p> <p>Be aware of chemical containers and check labeling. Be aware of piping, associated systems for any leaks. If chemical leak is noticed contact operations manager, IH&S Rep during regular working hrs. Over 100 gallons of a chemical spill leave area, and control</p>	P101-6 PPE • P101-23 Asbestos • P101-31 Hearing Conservations/Noise Program	LANL PPE or equivalent • Hearing protection • Site specific training • Asbestos awareness

		<p>access Call Serf Operators 667-8982 or by Radio Lanl 2 Util 6 For mitigation cleanup process</p> <p>For after-hours contact the UI Duty Officer, 699-7452 to re-assess any abnormal situation</p>		
<p>Energized and Operative Systems Working near energized electrical parts, pressure systems, steam lines; near unprotected belts, pulleys, chains or rotating equipment; fuel fired equipment other than vehicles; or spark or flame producing operations Specify Hazards: Energized/rotating equipment, High Temperature, High Pressure Water and Steam equipment</p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Stay within established walking areas. Observe safety signage alarm lights and horns. Identify explosive hazards and follow task specific IWD if working on plant equipment or components. Note: All TA3-22 independent verification requirement will be determined by the FOD or FOD designee. If questions consult with UI system engineer, Operation Mgr. Designee, or Safety rep.</p>	<p>P101-13 Electrical Safety</p> <p>P101-3 LOTO</p> <p>P101-34 Pressure, Vacuum, and Cryogenic System</p>	<p>Site Specific Training video</p> <p>Electrical Safety</p> <p>LOTO if applicable to task</p>
<p>Confined Spaces Entry into tanks, manholes, cooling towers, sumps, or any other area with potentially low oxygen concentration or other hazards such as toxic vapors or engulfment. Specify Hazards:</p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Observe confined space signs or markings and follow LANL Confined Space Requirements if task requires confined space entry.</p>	<p>P 101-27 Conf. Space</p>	<p>Confined Space Training</p>
<p>Elevated Work Surface Elevated work when fall protection is not provided by conventional handrail systems or required per <u>P101-20, Fall Protection Program</u></p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Stay within established walking areas, stairways and paths. Observe safety signage. Follow LANL Fall Protection Requirements if task on roofs or work above 4 feet.</p>	<p>P101-20 Fall Protection</p>	<p>Fall Protection</p>
<p>Environmental Impact Activities conducted in areas containing potential release site, contaminated soil, sensitive species, watercourse wetlands, floodplain, historical/archeological sites, or other work area condition that can be impacted by or can impact the environment.</p>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			

Specify Hazards:				
Security Requirements Specify:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Other Hazards Specify: Look-alike Equipment in the vicinity of work site may contain un-controlled hazardous energy	<input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Adequately barriers and controls will be established to prevent unauthorized personnel/workers from entering job site and encounter uncontrolled hazards.	IWD	Pre-job briefing emphasis. Worker confirmation of look-alike potential hazards, locations and barriers set in place to identify those potential hazards.

I have verified that the hazards identified above adequately identify the area hazards and that the IWM process has been applied appropriately.

FOD or Representative (Signature/Z #/Date) Approval Required Pablo F. CdeVaca

Digitally signed by Pablo F. CdeVaca
DN: cn=Pablo F. CdeVaca, o=LANL, ou=LA, email=pfcd@lanl.gov, c=US
Date: 2017.06.16 11:51:41 -0600

Date Approval Expires: 09/30/2020



AP-WORK-004: Attachment 1


Maintenance & Site Services

Worker Engagement Questions

Worker engagement questions are intended to focus attention on the task and ensure uncertainties are addressed. Examples of worker engagement questions are provided below. Worker engagement questions should be tailored to the situation.

Each of the questions listed below will be discussed at each Pre-Job Brief with all affected personnel.

Topic	Completed (X)
What permits, permissions, or support are required to safely start this work?	✓
What is the most likely thing that could go wrong (not the worst thing) and what, specifically, will prevent it?	✓
What can cause us to go beyond the scope of the work?	✓
What hazards in the work area may not have been considered during planning of this job?	✓

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

1.0 Work Scope

This work order task will cover the moderate hazard maintenance within the Power Plant Complex. All work will be performed in accordance with work order title and task instructions. UI Procedures will be referenced in the work order task instructions when applicable. This IWD is considered the controlling document for the work being covered.

2.0 Hazard Identification and Mitigation

2.1 Entry Conditions

- PAUSE/STOP WORK if steps cannot be completed as described, or if unforeseen situations occur. Stabilize the situation if safe, contact your supervisor or Person-In-Charge (PIC), and await further instructions before proceeding
- Ensure activity is on appropriate Plan(s) of the Day
- Check-in with ops prior to performing work
- Steps in this procedure may be worked out of sequence as directed by supervisor/PIC
- Ensure permits required for the work have been approved and posted, as required
- PIC will be available while work is being conducted
- PIC will review site specific hazards noted on IWD Part 2, Form 2101 with all workers
- All hold points will be discussed on a daily basis
- Verify all identified hazards have been eliminated, mitigated or minimized


(HAZARD ANALYSIS performed by Robert Simpson, art sparks– 9/9/2015)

2.2 Electrical

- Arc Flash: Follow PPE requirements and barricade area in accordance with the arc flash label for the specified equipment.

2.3 Mechanical

- Ensure all guards are in place before accessing equipment.
- Relieve all stored energy before performing maintenance activities.

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0			Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD
Work Document #: (WO # / Task)			Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16
TA: 03	Building: 0022	Room:	Additional Location Description:

2.4 Pneumatic

- Relieve all stored pressure.
- Ensure all fittings and hoses are inspected prior to use. Utilize safety devices on the fittings.

2.5 Elevated Work

- Ensure all scaffolding/ladders are inspected daily before use.
- Utilize fall protection equipment when required with approved tie-off points.
- Maintain 3-points of contact when utilizing a ladder
- Ensure ladder is properly oriented to work
- Scaffolding shall be erected and inspected by a competent person only

2.6 Hot Surfaces

- Wear long sleeve shirts or Ansell sleeves when working near hot surfaces.
- Utilize insulating blankets to protect against hot surfaces.

2.7 Welding, Grinding / Torch Cutting

- Use appropriate welding procedure checklist
- Keep combustible materials clear or protect surrounding
- Wear welding hood with appropriate lens for welding operation performed. Wear welding gloves.
- Ensure adequate ventilation or use welding fume extractor
- Spark and flame permit required

2.8 Chemical

- Consult IH&S for PPE requirements
- Place a catch pan under chemical and collect all residual chemicals.
- Review and follow the safety data sheets for all chemical and oil products.
- An eyewash station and safety shower must be within 10 seconds of where the chemicals are being used. Verify eyewash and safety shower have a current inspection.
- Wear chemical goggles for liquids
- PPE must be worn completely and properly

2.9 Slip, Trip & Fall:

- Be aware of ground and floor conditions

2.10 Back Strains


- Use proper lifting and bending technique at all times

2.11 Simple Hand Tools, Cuts & Abrasions:

- Inspect all tools prior to use, wear proper work gloves as determined by the job scope.
- Use of cordless power tools, power tools-electric shock.
- Use all tools properly and to safety standards. Inspect cords / batteries prior to use. GFCI protection required.

2.12 Pinching or Crushing

- Do not place body parts in the path of potential pinch points or crush points
- Hand / foot / body position awareness
- Be aware of line of fire

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

2.13 Asbestos Abatement Pipe and Equipment Insulation:


- Reference MSS Procedure 41-55-001-R1
- Area regulated to OSHA standards(29CFR1926.1101(e) and paragraph (j) decontamination area
- Two person rule is required during abatement
- Personal air monitoring will be required.
- Full face APR with P100 cartridges.
- Wear Tyvek coveralls with booties and hood, protection with full body coverage from head to toe.
- Wear nitrile gloves and/or leather gloves
- HEPA vacuum debris.
- Asbestos will be removed using hand tools and wet methods using amended wetting solution and wipes.
- All asbestos wastes must be kept damp enough during handling and disposal operations to prevent fibers from becoming airborne, but must not have any free liquid present during transportation.

2.14 LO/TO:

- Utilize LO/TO Attachment
- Wear Untreated Natural Fiber Shirt (long sleeve), Pants (long), Safety glasses or safety goggles, Hearing protection (ear canal inserts) and Leather gloves.

2.15 230V to 1000V Zero Voltage check requirements:

- Mode "1" Class 1.3 a,b
- Wear CAL 8+ PPE: Double-Layer switching hood.
- Class 0 Dielectric Gloves.
- AR coveralls (with an arc rating of 8 or more), hardhat, and safety glasses underneath hood.
- 2-man rule applies.
- Use NRTL approved voltage meter. Test meter on a known live circuit before and after zero voltage verification.
- No metallic objects worn.
- Voltage rated test equipment.
- Ensure no un-insulated body part enters prohibited space.
- Voltage rated tools.

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

2.16 50V to 230V Zero Voltage check requirements:

- Mode "1, Class 1.2 a,b
- Use NRTL approved calibrated voltage meter. Test meter on a known live circuit before and after zero voltage verification.
- Class "0" Dielectric Gloves
- AR clothing, minimum arc-rating of 4 cal for voltage of < 230 V (long sleeve shirt & pants of non-melting fabric or coveralls, face shield)
- AR Protective Equipment (hard hat, safety glasses or safety goggles, hearing protection).
- No metallic objects worn.
- Voltage rated test equipment.
- Ensure no un-insulated body part enters prohibited space.
- Voltage rated tools.

2.17 Cone of Safety Identification:


- The Cone of Safety as defined P101-25.0 Cranes, Hoists, Lifting Devices, and Rigging Equipment shall be identified.
- Time/distance requirements shall be assured by the LANS Hoisting/Rigging Supervisor throughout all lifts.
- Ensure lift plan is completed for all critical lifts.

2.18 General PPE Requirements for working within the Power Plant Complex:

- Safety shoes
- Safety glasses with side shields
- Hard hat
- Reflective Safety Vest
- Leather work gloves
- Hearing Protection at all times within the Power Plant. A noise evaluation shall be made by a safety engineer for other work as required.

Approach Boundaries

Voltage (VAC)	Limited Approach	Restricted Approach
50-300	3'-6"	Avoid Contact
301-750	3'-6"	1'-0"

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16	
TA: 03	Building: 0022	Room:	Additional Location Description:


3.0 Training Requirements

- 3.1 MSS Maintenance Worker, TP 10968
- 3.2 LO/TO, TP 127
- 3.3 Electrical Worker Training, Curriculum 642
- 3.4 Stationary Equipment Mechanics, Curriculum 630
- 3.5 Sheet metal Workers, Curriculum 649
- 3.6 Pipefitters, Curriculum 647
- 3.7 Carpenters, Curriculum 641
- 3.8 Insulators, Curriculum 643
- 3.9 Power Plant Operators, Curriculum 632
- 3.10 Confined space entry, supervisor and attendant (for entry)
- 3.11 Training to work with Cranes and Rigging:
 - Incidental Crane Classroom course # 20295
 - Incidental Crane Exam # 20296
- 3.12 Site Specific Training (one-time requirement)

4.0 Work Execution

4.1 Notes

- Following system conditions are configuration and conditions which have been anticipated for performance of PM activities covered under this IWD:
 - Electrical power systems are in a configuration which will support nominal steam plant operations. No major disruptions or outages are present and electrical system lineup is considered to be in a normal configuration.
 - Steam plant may either be in shutdown, standby or normal operation configuration. Mechanical components are under control of steam plant operations personnel and no major upset conditions or unanticipated outages are present within facility.
 - Power Plant operations personnel are manned to required level and sufficient support is available to support performance of maintenance activity.

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

- Permits required for this work: LO/TO Attachment, confined space.
- LO/TO devices shall be applied in accordance with P101-3. "Lockout/Tagout for Hazardous Energy Control"
- Discuss emergency evacuation procedures and muster areas
- Discuss possible error situations and mitigations

4.2 Prerequisites

- VERIFY pre-job briefing has been performed for all affected personnel including 2101 hazards

PIC : 4 Z#: 170951 Date: 4.16.18

- VERIFY all personnel have the appropriate PPE for job execution
- BARRICADE work area to protect against inadvertent access
- USE robust barriers and flagging to clearly define execution area
- VERIFY all required permits are approved and posted as required
- REVIEW planned activity for Life Critical Steps (to be performed by the PIC/RLM):

LO/TO	IF fall protection is to be used: <ul style="list-style-type: none"> • VERIFY that a safety system is in place (where workers understand hazard controls and required PPE) at work site. • VERIFY workers understand fall protection plan <p>PIC : <u>N/A</u> Z#: _____ Date: _____</p>
	IF aerial platform/lift is to be used: <ul style="list-style-type: none"> • VERIFY a clear travel path with all necessary clearances is defined and adequate • VERIFY geographic terrain will support execution of activity • VERIFY identification of all energized electrical systems, structure and components has occurred and their impact to activity has been accounted for and communicated to workers • VERIFY all personnel are qualified to operate aerial lift device assigned to activity. <p>PIC : <u>N/A</u> Z#: _____ Date: _____</p>


Confined Spaces: Complete confined space permit per the CSP evaluation.

Perform ventilation and air monitoring according to the evaluation.

Set up non-entry rescue equipment if required by the evaluation.

Contact pest control, as required to remove rodents and droppings.

Pest control to use 10% bleach solution and full face respirator.

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

4.3 Execution

1. **ERECT/DISMATLE** scaffolding as needed to access work area
 - INSPECT scaffold daily by competent person only
 - WEAR hard hats when working on / near scaffold
2. **PERFORM** LO/TO when required to perform maintenance

DO NOT	VFD: <i>(VFD)'s accounted for with zero voltage checks.</i> • VERIFY there is not a VFD within this system. This IWD does NOT account for any stored energy that could be present in a VFD. • IF VFD is present or found within system to be worked. DO NOT proceed with any work until UI Engineering has given approval to do so. OK to Proceed:
	PIC : _____ Z#: _____ Date: _____


3. **PERFORM** zero voltage checks for maintenance involving electrical work.
4. **PERFORM** zero energy checks for mechanical maintenance. Relieve stored energy.
5. **PERFORM** maintenance in accordance with work order title and task instructions. UI Procedures will be referenced in work order task instructions when applicable. Utilize master work order equipment list when performing maintenance.
6. **REMOVE** all LO/TO
7. **REMOVE** posting or signs
8. **OPERATIONS** acknowledges work is complete and ready to place into service





Operations: Carlos Chacon **Z#:** 120931 **Date:** 4-26-18


9. **CLEAN** up work area and properly dispose of all waste
 - SEGREGATE waste as required by WMC.

5.0 Close Out

- 5.1 Contact OMC (MC) and inform them work is complete.
- 5.2 Complete all required documentation and return Work Package

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task) UPPS-FY17-001		Planner/Preparer (Name/Z#/Date) Justin Maestas 177550 3/28/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

<p><i>Insert Rows above for additional Tasks/Steps or attach pages to clearly communicate ESH&Q/S&S hazards and associated controls.</i></p>	<p>The RLM and FOD or FOD Representative (if required or Recommended by RLM, e.g. high hazard) approval indicates IWM has been applied appropriately, work is authorized , workers are qualified, work will be performed in accordance with ESH&Q/S&S requirements and the IWD, and facility safety basis, aggregate hazards, and collocated hazards were appropriately included in the hazard analysis and acknowledges completion of a peer review</p>	RLM (Signature/Z#/Date) Required  105008 4/11/16
		FOD or Representative (Signature/Z#/Date) Required Pablo F. CdeVaca <small>Digitally signed by Pablo F. CdeVaca DN: cn=Pablo F. CdeVaca, o=LANL, ou=UL, email=pf@cpl.lanl.gov, c=US Location: TA-03 550-0022 Room 114 Date: 2016.04.12 10:00:25 -0600</small>
		SME Review (Signature/Z#/Date) If Required N/A
		ESO Review (Signature/Z#/Date) If Required  180622 4/11/16
		ESH Safety Review (Signature/Z#/Date)  153338 4/7/16
		Peer RLM /Work Execution Manager/Maintenance Manager (Signature/Z#/Date) Required  240725 4/11/16
IWD Type <input checked="" type="checkbox"/> Moderate-Hazard <input type="checkbox"/> High-Hazard/Complex <input type="checkbox"/> Standing IWD	Date when RLM re-approval is required _____ Other Conditions for RE-Approval <u>Change in scope or additional hazards identified</u> _____ (Print) Name of Primary PIC <u>Carlos Chacon</u> Name of Alternate PIC <u>Greg Donnelly</u> Name of Alternate PIC _____	Classification review completed, if required. N/A Reviewer Signature/Z#/Date _____

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

1.0 Work Scope:

This work order task will cover the moderate hazard preventive maintenance within the Power Plant Complex. All work will be performed in accordance with work order title and task instructions. UI Procedures will be referenced in the work order task instructions when applicable. This IWD is considered the controlling document for the work being covered.

2.0 Hazard Identification and Mitigation

(HAZARD ANALYSIS performed by Robert Simpson, Kedrick Mendez-- 9/9/2015)

1. Entry conditions:

- Ensure that the activity is on the Plan of the Day.
- If steps cannot be completed as described, or if unforeseen situations occur, PAUSE/STOP WORK, stabilize the situation, contact your supervisor or the Person-In-Charge (PIC), and await further instructions before proceeding.
- Certain steps in the procedure may be worked out of sequence as directed by the supervisor.
- The permits and work packages required for the project have been approved and are posted, as required.
- The PIC will be available while work is being conducted.
- PIC will review site specific hazards noted on IWD Part 2, Form 2101 with all workers.
- All hold points will be discussed on a daily basis.
- Controls needed to perform the work are identified in this IWD.

2. Electrical Hazards:

- Arc Flash: Follow PPE requirements and barricade area in accordance with the arc flash label for the specified equipment.

3. Mechanical Hazards:

- Ensure all guards are in place before accessing equipment.
- Relieve all stored energy before performing maintenance activities.

4. Pneumatic Hazards:


- Relieve all stored pressure.
- Ensure all fittings and hoses are inspected prior to use. Utilize safety devices on the fittings.

5. Elevated Work:

- Ensure all scaffolding is inspected daily before use.
- Utilize fall protection equipment when required with approved tie-off points.
- Maintain 3-points of contact when utilizing a ladder.

6. Hot Surfaces:

- Wear long sleeve shirts or Arsell sleeves when working near hot surfaces.
- Utilize insulating blankets to protect against hot surfaces.

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

7. Chemical Hazards:

- Consult IH&S for PPE requirements.
- Place a catch pan under chemical and collect all residual chemicals. Deposit chemical in the day tank.
- Review the safety data sheets for all chemical and oil products.
- An eyewash station and safety shower must be within 10 seconds of where the chemicals are being used. Verify eyewash and safety shower have a current inspection.

8. Slips, Trips and Falls:

- Be aware of ground and floor conditions

9. Back strains

- Use proper lifting and bending technique at all times

10. Working with simple hand tools, cuts and abrasions:

- Inspect all tools prior to use, wear proper work gloves as determined by the job scope.
- Use of cordless power tools, power tools-electric shock.
- Use all tools properly and to safety standards. Inspect cords / batteries prior to use. GFCI protection required.

11. Pinching or crushing/hand injury:

- Do not place hands in the path of potential pinch points or crush points
- Hand/foot/ body position awareness

12. Asbestos Abatement Pipe and Equipment Insulation:

- Reference MSS Procedure 41-55-001-R1
- Area regulated to OSHA standards (29CFR1926.1101(e) and paragraph (j) decontamination area
- Two person rule is required during abatement
- Personal air monitoring will be required.
- Full face APR with P100 cartridges.
- Wear tyvek coveralls with booties and hood, protection with full body coverage from head to toe.
- Wear nitrile gloves and/or leather gloves
- HEPA vacuum debris.
- Asbestos will be removed using hand tools and wet methods using amended wetting solution and wipes.
- All asbestos wastes must be kept damp enough during handling and disposal operations to prevent fibers from becoming airborne, but must not have any free liquid present during transportation.

13. LO/TO:

- Utilize LO/TO Attachment "B"
- Wear Untreated Natural Fiber Shirt (long sleeve), Pants (long), Safety glasses or safety goggles, Hearing protection (ear canal inserts) and Leather gloves.

14. 240V to 600V Zero Voltage check requirements:

- Mode "1"
- Wear CAL 8+ PPE: Double-Layer switching hood.
- Class 0 Dielectric Gloves.
- AR coveralls (with an arc rating of 8 or more), hardhat, and safety glasses underneath hood.
- 2-man rule applies.
- Use UL approved voltage meter. Test meter on a known live circuit before and after zero voltage



Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)

Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

verification.

- No metallic objects worn.
- Voltage rated test equipment.
- Ensure no un-insulated body part enters prohibited space.
- Voltage rated tools.

15. Less than 240V Zero Voltage check requirements:

- Mode "1"
- Use UL approved voltage meter. Test meter on a known live circuit before and after zero voltage verification.
- Class "0" Dielectric Gloves
- AR clothing, minimum arc-rating of 4 cal for voltage of < 240 V (long sleeve shirt, pants or coveralls, face shield)
- AR Protective Equipment (hard hat, safety glasses or safety goggles, hearing protection).
- No metallic objects worn.
- Voltage rated test equipment.
- Ensure no un-insulated body part enters prohibited space.
- Voltage rated tools.

16. Cone of Safety Identification:

- The Cone of Safety as defined P101-25.0 Cranes, Hoists, Lifting Devices, and Rigging Equipment shall be identified.
- Time/distance requirements shall be assured by the LANS Hoisting/Rigging Supervisor throughout all lifts.
- Ensure lift plan is completed for all critical lifts.

17. General PPE Requirements for working within the Power Plant Complex:


- Safety shoes
- Safety glasses with side shields
- Hard hat
- Reflective Safety Vest
- Leather work gloves
- Hearing Protection at all times within the Power Plant. A noise evaluation shall be made by a safety engineer for other work as required.

Approach Boundaries


Voltage (VAC)	Limited Approach	Restricted Approach	Prohibited Approach
50-300	3'6"	Avoid Contact	Avoid Contact
301-750	3'6"	1'0"	0'1"

3.0 Training Requirements

- MSS Maintenance Worker, TP 10968
- LO/TO, TP 127
- Electrical Worker Training, Curriculum 642


 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

- Stationary Equipment Mechanics, Curriculum 630
- Sheet metal Workers, Curriculum 649
- Pipefitters, Curriculum 647
- Carpenters, Curriculum 641
- Insulators, Curriculum 643
- Power Plant Operators, Curriculum 632
- Training to work with Cranes and Rigging:
 - Incidental Crane Classroom course # 20295
 - Incidental Crane Exam # 20296
- Site Specific Training (one-time requirement)

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

4.0 Work Execution

- 1.
2. The following system conditions are the configuration and conditions which have been anticipated for performance of the PM activities covered under this standing IWD:
 - a. The electrical power systems are in a configuration which will support nominal steam plant operations. No major disruptions or outages are present and the electrical system lineup is considered to be in a normal configuration.
 - b. The steam plant may be either in a shutdown, standby or normal operation configuration. The mechanical components are under the control of the steam plant operations personnel and no major upset conditions or unanticipated outages are present within the facility.
 - c. The Power Plant operational personnel are manned to the required level and sufficient support is available to support the performance of the preventive maintenance activity.
3. Prerequisites:
 - a. **REVIEW** work package for Life Critical Steps (to be performed by the PIC/RLM).
 - I. **Fall Protection:**
 - Verify that a safety system is in place (where workers understand hazard controls and required PPE) at the work site.
 - Verify that workers understand the fall protection plan.
 - II. **Elevated Work Platforms:**
 - Verify a clear travel path with all necessary clearances has been defined and is adequate.
 - Verify the geographic terrain will support execution of the desired activity.
 - Verify the identification of all energized electrical Systems, structure and components has occurred and their impact to the activity has been accounted for and communicated to the workers.
 - Verify all personnel are qualified to operate the aerial lift device assigned to the activity.
 - b. **INSERT** Life Critical Step hold points into the work package.
 - c. **VERIFY** a daily pre-job brief has been performed with the 5 mandatory questions and 2101 has been read for site hazards and entry requirements. With all affected personnel. Perform a reverse pre-job brief and encourage all craft workers to stay involved.
 - d. **VERIFY** all personnel have appropriate PPE for job execution.
 - e. **BARRICADE** the work area in accordance with MSS-Guide-038 to protect tenants/unexpected personnel/or traffic as directed by the Supervisor or PIC. Clearly identify work zone due to look-alike equipment.




 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:


Execution

4. **PERFORM** LO/TO, when required to perform preventive maintenance.
5. **PERFORM** zero voltage checks for maintenance involving electrical work.
6. **PERFORM** zero energy checks for mechanical maintenance. Relieve stored energy.
7. **PERFORM** preventive maintenance in accordance with work order title and task instructions. UI Procedures will be referenced in the work order task instructions when applicable. Utilize the master work order equipment list when performing preventive maintenance.
8. **REMOVE** all LO/TO.
9. **REMOVE** posting or signs.
10. **CLEAN** up work area and properly dispose of all waste.
11. **COMPLETE** all documentation.

5.0 Close Out

1. Complete closeout of the work activity in accordance with AP-WORK requirements.

<i>Insert Rows above for additional Tasks/Steps or attach pages to clearly communicate ESH&Q/S&S hazards and associated controls.</i>	The RLM and FOD or FOD Representative (if required or Recommended by RLM, e.g. high hazard) approval indicates IWM has been applied appropriately, work is authorized , workers are qualified, work will be performed in accordance with ESH&Q/S&S requirements and the IWD, and facility safety	RLM (Signature/Z#/Date) Required  190429 7-11-17
		FOD or Representative (Signature/Z#/Date) Required  090206 7-12-17
		IH&S Review (Signature/Z#/Date)  7/10/17

 Facilities Maintenance IWD – (Facility Maintenance Activity Specific Information)			
Revision # 0		Activity/Task Title: POWER PLANT COMPLEX-MODERATE HAZARD STANDING IWD	
Work Document #: (WO # / Task)		Planner/Preparer (Name/Z#/Date) Kedrick Mendez 180622 9/30/16	
TA: 03	Building: 0022	Room:	Additional Location Description:

	basis, aggregate hazards, and collocated hazards were appropriately included in the hazard analysis and acknowledges completion of a peer review	SME Review (Signature/Z#/Date) If Required Not Required _____
		ESO Review (Signature/Z#/Date) If Required _____
IWD Type <input checked="" type="checkbox"/> Moderate-Hazard <input type="checkbox"/> High-Hazard/Complex <input type="checkbox"/> Standing IWD	Date when RLM re-approval is required _____ Other Conditions for RE-Approval: <u>Scope change or additional hazards identified.</u> (Print) Name of Primary PIC _____ Name of Alternate PIC _____ Name of Alternate PIC _____	Classification review completed, if required. N/A Reviewer Signature/Z#/Date _____

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002, FGR-003)
Task Dspln : **Due Date :** 05/31/2018
Superintendent :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00605131 01

MASTER

Date: 02/15/2018**Work Order Task Written To**

Facility : F08 **Unit :** **Op Sys :**
Room : **Area :** **Sys/Cls :**
Equipment : **Component :**
Location :
Job Type : PM
Tag 1 : **Tag 2 :**
Work Item : TA03-0022 FGR **Ops Review Reqd :**

Authorization

Start Permission : Herman Madrid Jr **Start Date :** 4-27-2018
Complete Notice : Herman Madrid Jr **Complete Date :** 5-10-2018

Work Order Task Instructions

DO NOT lubricate the bearings if the FGR fan is NOT in operation or in service so that proper amount of grease can be applied using headphones
 You can hear when grease reaches the bearing rolling element. At this point, stop adding grease to prevent bearing damage from overheating

There are two bearings on the fan, each with its own zerk plug
 Remove the shaft guard located in the middle of the drive. The two zerk plugs are located on each of the two bearings

1. Use grease gun with the Ultralube headphones to insert the correct amount of Mobilith SHC 100 grease into zerk fitting
- b. Apply grease while fan is running and stop when you hear the grease enter the running bearing

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002, FGR-003)
Task Dspln : **Due Date :** 05/31/2018
Superintendent :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00605131 01

MASTER

Date: 02/15/2018

Lubricated fan bearings on FGR-001, FGR-002 & FGR-003

4. Add grease with a hand-operated pressure gun until new grease enters the running bearing
 - a. This is accomplished by using the ultrasonic sensor and headphones to hear when the new grease enters the running bearing
 - b. Stop adding grease when the grease reaches the bearing to limit excess grease from migrating down the motor shaft and into the windings

Note: Be careful when greasing the fan end bearing of the TEFC (Totally Enclosed Fan Cooled) motors. Some motors have a spring-relief outlet grease fitting on the fan end that is not accessible. This spring-relief fitting normally does not have to be removed when regreasing. When greasing, take care in the amount of pressure you apply and verify relief is working
5. Putting in too much or too little grease can cause overheating of the motors and result in motor failure. Use this rule of thumb when adding grease to a motor that has been lubricated on a regular basis:
It is better to use a little grease more often than a lot of grease less often

Note: Watch out for motors that were shipped only with the bearings packed and not the fill tube or even the bearing housing
Apply new grease until you can hear it enter the running bearing
6. Now that greasing is complete, leave the relief plug off and run the motor for 10 minutes to expel any excess grease
7. Replace the drain plug and wipe the bearing housing clean
8. Dispose of dirty rags in accordance with Hazardous Waste Guidelines
9. Ensure correct operation of electric motors.

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002, FGR-003)
Task Dspln : **Due Date :** 05/31/2018
Superintendent :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00605131 01

MASTER

Date: 02/15/2018

--

Work Completion Signatures

Name	Function/Dept.	Date
Chris Salazar	LOG-CS/PP MAINT....	05/01/2018

Comments

(rework?)

Cost Accounting**Cost Center :** P2030A**Activity :** 640CL000**Percentage :** 100**Acct No :** XU5000**Sub Acct :** 7E2P0000

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002,
FGR-003)
Task Dspln : **Due Date :** 05/31/2018
Superintendant :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00605131 01

MASTER

Date: 02/15/2018



Form 2101

Integrated Work Document (IWD) Part 2, FOD Requirements and Approval for Entry and Area Hazards and Controls

Non-Tenant
Activity Form

IWD No./Work Request No: _____ Revision #: _____

Facility Operation Director (FOD) must determine the facility entry and coordination requirements and identify the Environment, Safety, Health (ESH)/Security and Safeguards (S&S) hazards and controls associated with the activity location.

FOD 8	TA 3	Bldg 22	Room N/A	Other Location Power Plant Bldg - Inside
FOD Designated Facility Point-of-Contact	Name Pablo C de Vaca	Phone 699-8226	Pager N/A	Email pfc@lanl.gov

Entry and Coordination Requirements (Check one or more of the following)

- | | |
|--|---|
| <input type="checkbox"/> No Entry/Coordination Requirements | <input type="checkbox"/> FOD-designated facility Point-of-Contact must sign IWD Part 3 |
| <input checked="" type="checkbox"/> Plan of the Day/Plan of the Week (POTD/POTW) | <input checked="" type="checkbox"/> Check in at Start of Work <input checked="" type="checkbox"/> Work-Area Training Required |
| <input checked="" type="checkbox"/> Security Clearance Requirements | <input checked="" type="checkbox"/> Work must be Scheduled <input checked="" type="checkbox"/> Check in Daily |
| <input type="checkbox"/> Co-located Hazards/Concerns | <input type="checkbox"/> Other Security Requirements (ex.: Cellphone, No Foreign Nationals, etc.) |
| <input checked="" type="checkbox"/> Check out at End of Work | <input type="checkbox"/> Quality Issues <input checked="" type="checkbox"/> Check out Daily |
| <input type="checkbox"/> Escort Required | <input type="checkbox"/> Review under Authorization Basis (AB)/Safety Basis/Unreviewed Safety Question (USQ) |
| <input type="checkbox"/> Other Bounding Conditions: | |

PIC is responsible to conduct a pre-job brief for work activities to ensure that work conditions and worker communications are adequate. A pre job briefing shall be conducted at the job site. UI-OPS will determine if onsite ESH representation is required during work activities

Additional Comments (refer to Job Hazard Analysis [JHA] Tool Facility Notes)

All work must be approved by the Utilities FOD or UI-OPS. POD/POTW-contact Facility POC. No Smoking around Natural Gas Systems. Evaluate inside floor and housekeeping conditions to safely proceed with activities. Check in with Plant Operations Manager/Specialist or Operations Shift Head for final approval to proceed with tasks. Work around power plant chemical pumps and lines. Inspect for leaks before beginning any work task and pause work and report if a leak is found to operations. All personnel entering area must view the site specific training video in room 116 (Boiler Control Room), one time requirement. Observe safety signs and floor markings in all buildings and areas. No safety shoes required for visitors if escorted by Operations or UI Engineering personnel. The West end front lobby and office areas of Bldg 22 are considered a no hazard area.

Instructions: In the block below, identify work-area hazards that could potentially affect the worker(s) or others. Specify the facility controls and preventive measures that must be implemented by the worker(s) to protect against the site hazards as well as any special training required.

ESH/S&S WORK AREA HAZARDS & CONTROLS

Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
<input type="checkbox"/> No Work Area Hazards				

Form 2101 (6/12)

Page 1

Ionizing Radiation Work in posted radiological areas, work with radioactive materials, or work on or near radiation producing devices Specify Hazard:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
---	---	--	--	--

IWD No./Work Request No: _____

Revision #: _____

ESH/S&S WORK AREA HAZARDS & CONTROLS				
Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
Worker Exposure Working near non-ionizing radiation, beryllium, noise, chemicals, hazardous biological materials, lead, asbestos, temperature/humidity extremes, or high explosives Specify Hazards:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Required PPE: Hard hat, safety shoes, safety glasses. Hearing protection (noise > 85 dba). Avoid hot surfaces and piping. Long sleeve shirt or Ansell sleeves or coveralls. Gloves when operating valves or contacting pipe/fitting openings where there is potential for hot water/steam release. Be aware of encapsulated asbestos. Follow LANL Asbestos program/rqmts if PACM identified outside containment. Be aware of chemical containers and check labeling. Be aware of piping, associated systems for any leaks. If chemical leak is noticed contact operations manager, IH&S Rep during regular working hrs. Over 100 gallons of a chemical spill leave area, and control.	P101-6 PPE • P101-23 Asbestos • P101-31 Hearing Conservations/Noise Program	LANL PPE or equivalent • Hearing protection • Site specific training • Asbestos awareness

		<p>access. Call Serf Operators 667-8982 or by Radio Lanl 2 Util 6 For mitigation cleanup process.</p> <p>For after-hours contact the UI Duty Officer, 699-7452 to re-assess any abnormal situation</p>		
<p>Energized and Operative Systems Working near energized electrical parts, pressure systems, steam lines; near unprotected belts, pulleys, chains or rotating equipment; fuel fired equipment other than vehicles; or spark or flame producing operations. Specify Hazards: Energized/rotating equipment, High Temperature, High Pressure Water and Steam equipment.</p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Stay within established walking areas. Observe safety signage alarm lights and horns. Identify explosive hazards and follow task specific IWD if working on plant equipment or components. Note: All TA3-22 independent verification requirement will be determined by the FOD or FOD designee. If questions consult with UI system engineer, Operation Mgr. Designee, or Safety rep.</p>	<p>P101-13 Electrical Safety</p> <p>P101-3 LOTO</p> <p>P101-34 Pressure, Vacuum, and Cryogenic System.</p>	<p>Site Specific Training video.</p> <p>Electrical Safety</p> <p>LOTO if applicable to task.</p>
<p>Confined Spaces Entry into tanks, manholes, cooling towers, sumps, or any other area with potentially low oxygen concentration or other hazards such as toxic vapors or engulfment. Specify Hazards:</p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Observe confined space signs or markings and follow LANL Confined Space Requirements if task requires confined space entry.</p>	<p>P 101-27 Conf. Space</p>	<p>Confined Space Training</p>
<p>Elevated Work Surface Elevated work when fall protection is not provided by conventional handrail systems or required per <u>P101-20, Fall Protection Program</u></p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Stay within established walking areas, stairways and paths. Observe safety signage. Follow LANL Fall Protection Requirements if task on roofs or work above 4 feet.</p>	<p>P101-20 Fall Protection</p>	<p>Fall Protection</p>
<p>Environmental Impact Activities conducted in areas containing potential release site, contaminated soil, sensitive species, watercourse wetlands, floodplain, historical/archeological sites, or other work area condition that can be impacted by or can impact the environment.</p>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			

Specify Hazards:				
Security Requirements Specify:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Other Hazards Specify: Look-alike Equipment in the vicinity of work site may contain un-controlled hazardous energy	<input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Adequately barriers and controls will be established to prevent unauthorized personnel/workers from entering job site and encounter uncontrolled hazards.	IWD	Pre-job briefing emphasis. Worker confirmation of look-alike potential hazards, locations and barriers set in place to identify those potential hazards.

I have verified that the hazards identified above adequately identify the area hazards and that the IWM process has been applied appropriately.

FOD or Representative (Signature/Z #/Date) Approval Required **Pablo F. CdeVaca**

Digitally signed by Pablo F. CdeVaca
DN: cn=Pablo F. CdeVaca, o=LANL, email=pfcdevaca@lanl.gov, c=US
Date: 2019.09.28 11:53:43 -0600

Date Approval Expires: 09/30/2020



AP-WORK-004: Attachment 1 Maintenance & Site Services Worker Engagement Questions

Worker engagement questions are intended to focus attention on the task and ensure uncertainties are addressed. Examples of worker engagement questions are provided below. Worker engagement questions should be tailored to the situation.

Each of the questions listed below will be discussed at each Pre-Job Brief with all affected personnel.

3/1/18

Topic	Completed (X)
FGR BEARINGS LUBRICATE	
What permits, permissions, or support are required to safely start this work?	X
What is the most likely thing that could go wrong (not the worst thing) and what, specifically, will prevent it?	X
What can cause us to go beyond the scope of the work?	X
What hazards in the work area may not have been considered during planning of this job?	X

The job by J. M. Bell 171769
 Given to: C. Salazar 202897
 J. Trujillo 217001

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002, FGR-003)
Task Dsplt : **Due Date :** 06/30/2018
Superintendent :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00607483 01

MASTER

Date: 03/07/2018**Work Order Task Written To**

Facility : F08 **Unit :** **Op Sys :**
Room : **Area :** **Sys/Cls :**
Equipment : **Component :**
Location :
Job Type : PM
Tag 1 : **Tag 2 :**
Work Item : TA03-0022 FGR **Ops Review Reqd :**

Authorization

Start Permission : **Start Date :**
Complete Notice : **Complete Date :**

Work Order Task Instructions

DO NOT lubricate the bearings if the FGR fan is NOT in operation or in service so that proper amount of grease can be applied using headphones
 You can hear when grease reaches the bearing rolling element. At this point, stop adding grease to prevent bearing damage from overheating

There are two bearings on the fan, each with its own zerk plug
 Remove the shaft guard located in the middle of the drive. The two zerk plugs are located on each of the two bearings

1. Use grease gun with the Ultralube headphones to insert the correct amount of Mobilith SHC 100 grease into zerk fitting
- b. Apply grease while fan is running and stop when you hear the grease enter the running bearing

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002, FGR-003)
Task Dsplt : **Due Date :** 06/30/2018
Superintendent :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00607483 01

MASTER

Date: 03/07/2018

Lubricated fan bearings on FGR-001, FGR-002 & FGR-003

4. Add grease with a hand-operated pressure gun until new grease enters the running bearing
 - a. This is accomplished by using the ultrasonic sensor and headphones to hear when the new grease enters the running bearing
 - b. Stop adding grease when the grease reaches the bearing to limit excess grease from migrating down the motor shaft and into the windings

Note: Be careful when greasing the fan end bearing of the TEFC (Totally Enclosed Fan Cooled) motors. Some motors have a spring-relief outlet grease fitting on the fan end that is not accessible. This spring-relief fitting normally does not have to be removed when regreasing. When greasing, take care in the amount of pressure you apply and verify relief is working
5. Putting in too much or too little grease can cause overheating of the motors and result in motor failure. Use this rule of thumb when adding grease to a motor that has been lubricated on a regular basis:

It is better to use a little grease more often than a lot of grease less often

Note: Watch out for motors that were shipped only with the bearings packed and not the fill tube or even the bearing housing

Apply new grease until you can hear it enter the running bearing
6. Now that greasing is complete, leave the relief plug off and run the motor for 10 minutes to expel any excess grease
7. Replace the drain plug and wipe the bearing housing clean
8. Dispose of dirty rags in accordance with Hazardous Waste Guidelines
9. Ensure correct operation of electric motors.

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002, FGR-003)
Task Dsplt : **Due Date :** 06/30/2018
Superintendent :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00607483 01

MASTER

Date: 03/07/2018**Work Completion Signatures**

Name

Function/Dept.

Date

John M. Miller

Maint.Foreman/LOG-CS

6/4/18

Comments**(rework?)****Cost Accounting****Cost Center :** P2030A**Activity :** 640CL000**Percentage :** 100**Acct No :** XU5000**Sub Acct :** 7E2P0000

Facility : F08 **Unit :** **Proj :**
Task Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
W/O Type : PM **W/O Group :** UTIL **Task Priority :** 4
Planner : 189099 LOPEZ THERESA M
W/O Title : PP 1M TA3-22 FGR BEARINGS, LUBRICATE
Written To : TA03-0022 FAN, FLUE GAS RECIRCULING (FGR-001, FGR-002,
FGR-003)
Task Dspln : **Due Date :** 06/30/2018
Superintendent :
Hazard : LOW **IWD Reqmt :** N/A LOW HZRD

Work Order Task

00607483 01

MASTER

Date: 03/07/2018



AP-WORK-004: Attachment 1 Maintenance & Site Services Worker Engagement Questions

Worker engagement questions are intended to focus attention on the task and ensure uncertainties are addressed. Examples of worker engagement questions are provided below. Worker engagement questions should be tailored to the situation.

Each of the questions listed below will be discussed at each Pre-Job Brief with all affected personnel.

6/4/2018

Tonic 1MO. FGR Fan Shaft Lubrication	Completed (X)
What permits, permissions, or support are required to safely start this work?	X
What is the most likely thing that could go wrong (not the worst thing) and what, specifically, will prevent it?	X
What can cause us to go beyond the scope of the work?	X
What hazards in the work area may not have been considered during planning of this job?	X



Form 2101

Integrated Work Document (IWD) Part 2, FOD Requirements and Approval for Entry and Area Hazards and Controls

Non-Tenant
Activity Form

IWD No./Work Request No: _____

Revision #: _____

Facility Operation Director (FOD) must determine the facility entry and coordination requirements and identify the Environment, Safety, Health (ESH)/Security and Safeguards (S&S) hazards and controls associated with the activity location.

FOD 8	TA 3	Bldg 22	Room N/A	Other Location Power Plant Bldg - Inside
FOD Designated Facility Point-of-Contact	Name Pablo C de Vaca	Phone 699-8226	Pager N/A	Email pfc@lanl.gov

Entry and Coordination Requirements (Check one or more of the following)

- | | |
|--|--|
| <input type="checkbox"/> No Entry/Coordination Requirements | <input type="checkbox"/> FOD-designated facility Point-of-Contact must sign IWD Part 3 |
| <input checked="" type="checkbox"/> Plan of the Day/Plan of the Week (POTD/POTW) | <input checked="" type="checkbox"/> Check in at Start of Work |
| <input checked="" type="checkbox"/> Security Clearance Requirements | <input checked="" type="checkbox"/> Work-Area Training Required |
| <input type="checkbox"/> Co-located Hazards/Concerns | <input checked="" type="checkbox"/> Work must be Scheduled |
| <input checked="" type="checkbox"/> Check out at End of Work | <input checked="" type="checkbox"/> Check in Daily |
| <input type="checkbox"/> Escort Required | <input type="checkbox"/> Other Security Requirements (ex : Cellphone, No Foreign Nationals, etc.) |
| <input type="checkbox"/> Other Bounding Conditions: | <input type="checkbox"/> Quality Issues |
| | <input checked="" type="checkbox"/> Check out Daily |
| | <input type="checkbox"/> Review under Authorization Basis (AB)/Safety Basis/Unreviewed Safety Question (USQ) |

PIC is responsible to conduct a pre-job brief for work activities to ensure that work conditions and worker communications are adequate. A pre job briefing shall be conducted at the job site. UI-OPS will determine if onsite ESH representation is required during work activities

Additional Comments (refer to Job Hazard Analysis [JHA] Tool Facility Notes)

All work must be approved by the Utilities FOD or UI-OPS. POD/POTW-contact Facility POC. No Smoking around Natural Gas Systems. Evaluate inside floor and housekeeping conditions to safely proceed with activities. Check in with Plant Operations Manager/Specialist or Operations Shift Head for final approval to proceed with tasks. Work around power plant chemical pumps and lines. Inspect for leaks before beginning any work task and pause work and report if a leak is found to operations. All personnel entering area must view the site specific training video in room 116 (Boiler Control Room), one time requirement. Observe safety signs and floor markings in all buildings and areas. No safety shoes required for visitors if escorted by Operations or UI Engineering personnel. The West end front lobby and office areas of Bldg 22 are considered a no hazard area.

Instructions: In the block below, identify work-area hazards that could potentially affect the worker(s) or others. Specify the facility controls and preventive measures that must be implemented by the worker(s) to protect against the site hazards as well as any special training required.

ESH/S&S WORK AREA HAZARDS & CONTROLS

Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
<input type="checkbox"/> No Work Area Hazards				

Form 2101 (6/12)

Page 1

Ionizing Radiation Work in posted radiological areas, work with radioactive materials, or work on or near radiation producing devices. Specify Hazard:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
--	---	--	--	--

IWD No /Work Request No: _____ Revision #: _____

ESH/S&S WORK AREA HAZARDS & CONTROLS				
Work Area Hazards/Concerns Identify site hazards and concerns that could potentially affect the worker(s) or others.	Work Area Hazard Present	Facility Controls/ Preventive Measures/ Bounding Conditions Specify preventive measures, controls and bounding conditions for each site hazard	Reference Documents List permits, operating manuals, and other reference procedures	Training and Qualification List training requirements (P300, Integrated Work Management, Section 6.1)
Worker Exposure Working near non-ionizing radiation, beryllium, noise, chemicals, hazardous biological materials, lead, asbestos, temperature/humidity extremes, or high explosives. Specify Hazards:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Required PPE: Hard hat, safety shoes, safety glasses. Hearing protection (noise > 85 dba). Avoid hot surfaces and piping. Long sleeve shirt or Ansell sleeves or coveralls. Gloves when operating valves or contacting pipe/fitting openings where there is potential for hot water/steam release.</p> <p>Be aware of encapsulated asbestos. Follow LANL Asbestos program/rqmts if PACM identified outside containment.</p> <p>Be aware of chemical containers and check labeling. Be aware of piping, associated systems for any leaks. If chemical leak is noticed contact operations manager, IH&S Rep during regular working hrs. Over 100 gallons of a chemical spill leave area, and control.</p>	P101-6 PPE • P101-23 Asbestos • P101-31 Hearing Conservations/Noise Program	LANL PPE or equivalent • Hearing protection • Site specific training • Asbestos awareness

		<p>access. Call Serf Operators 667-8982 or by Radio Lanl 2 Util 6 For mitigation cleanup process.</p> <p>For after-hours contact the UI Duty Officer, 699-7452 to re-assess any abnormal situation</p>		
<p>Energized and Operative Systems Working near energized electrical parts, pressure systems, steam lines; near unprotected belts, pulleys, chains or rotating equipment; fuel fired equipment other than vehicles; or spark or flame producing operations Specify Hazards: Energized/rotating equipment, High Temperature, High Pressure Water and Steam equipment</p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Stay within established walking areas. Observe safety signage alarm lights and horns. Identify explosive hazards and follow task specific IWD if working on plant equipment or components. Note: All TA3-22 independent verification requirement will be determined by the FOD or FOD designee. If questions consult with UI system engineer, Operation Mgr. Designee, or Safety rep.</p>	<p>P101-13 Electrical Safety</p> <p>P101-3 LOTO</p> <p>P101-34 Pressure, Vacuum, and Cryogenic System</p>	<p>Site Specific Training video.</p> <p>Electrical Safety</p> <p>LOTO if applicable to task</p>
<p>Confined Spaces Entry into tanks, manholes, cooling towers, sumps, or any other area with potentially low oxygen concentration or other hazards such as toxic vapors or engulfment. Specify Hazards:</p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Observe confined space signs or markings and follow LANL Confined Space Requirements if task requires confined space entry.</p>	<p>P 101-27 Conf. Space</p>	<p>Confined Space Training</p>
<p>Elevated Work Surface Elevated work when fall protection is not provided by conventional handrail systems or required per <u>P101-20, Fall Protection Program</u></p>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<p>Stay within established walking areas, stairways and paths. Observe safety signage. Follow LANL Fall Protection Requirements if task on roofs or work above 4 feet</p>	<p>P101-20 Fall Protection</p>	<p>Fall Protection</p>
<p>Environmental Impact Activities conducted in areas containing potential release site, contaminated soil, sensitive species, watercourse wetlands, floodplain, historical/archeological sites, or other work area condition that can be impacted by or can impact the environment.</p>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			

Specify Hazards:				
Security Requirements Specify:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Other Hazards Specify: Look-alike Equipment in the vicinity of work site may contain un-controlled hazardous energy	<input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Adequate barriers and controls will be established to prevent unauthorized personnel/workers from entering job site and encounter uncontrolled hazards.	IWD	Pre-job briefing emphasis. Worker confirmation of look-alike potential hazards, locations and barriers set in place to identify those potential hazards.

I have verified that the hazards identified above adequately identify the area hazards and that the IWM process has been applied appropriately.

FOD or Representative (Signature/Z #/Date) Approval Required Pablo F. CdeVaca

Digitally signed by Pablo F. CdeVaca
DN: cn=Pablo F. CdeVaca, o=LANL, ou=LA, email=pfc@lanl.gov, c=US
Date: 2019.09.11 15:58:11 -0500

Date Approval Expires: 09/30/2020

AI 856 | Los Alamos National Laboratory

LANL Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1 – June 30, 2018

Attachment A1307.H. – TA-3 Power Plant Combustion Turbine Emission Stack Test Report

The most recent annual emission stack test for the TA-3 Combustion Turbine was conducted on December 16, 2014. An emission stack test is not required during this reporting period because the combustion turbine operated less than 25% of the monitoring period (January 1 – June 30, 2018).

AI 856 | Los Alamos National Laboratory

Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1 – June 30, 2018

Attachment A1407.A. – Open Burning

There was no open burning conducted during this reporting period.

AI 856 | Los Alamos National Laboratory

Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1 – June 30, 2018

Attachment A1507.A.a.

Evaporative Sprayers

Analytical Data for Basin Water

The monitoring requirement for analysis of the evaporative sprayer basin water is required to be completed every two years beginning no later than calendar year 2018. Water sampling is scheduled for summer 2018.

AI 856 | Los Alamos National Laboratory

Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1–June 30, 2018

ATTACHMENT A1507.A.b

Evaporative Sprayers Hours of Operation

2018 Operational Data for SERF Spray Evaporators - Data entry

	Evap Sprayer #1 (SN 0053)		Evap Sprayer #2 (SN 0054)		Evap Sprayer #3 (SN 0055)		Evap Sprayer 4 (not installed)	Evap Sprayer 5 (not installed)
	Hrs of Op	Gallons Sprayed	Hrs of Op	Gallons Sprayed	Hrs of Op	Gallons Sprayed		
Jan	311	112,174	296	70,408	-	-		
Feb	374	134,402	147	88,946	-	-		
Mar	536	193,376	304	109,614	-	-		
Apr	620	227,150	383	139,812	-	-		
May	704	267,490	442	168,198	-	-		
Jun	711	306,734	397	147,074				
Jul								
Aug								
Sep								
Oct								
Nov								
Dec								
Annual Totals	3,256	1,241,326	1,969	724,052	-	-		

AI 856 | Los Alamos National Laboratory



Operating Permit P100-R2M1 & P100-R2M2

Monitoring Period January 1–June 30, 2018

ATTACHMENT A1507.B.

Evaporative Sprayers

Work Practice Standards—Maintenance and Repair Requirements


	
UI-PROC-81-00-027-R1	

Operations Procedure


SERF Sigma Basin SMI 120F Evaporator Inspections

Review frequency 1 yr ☐ 2 yr ☐ 3 yr ☒
 Issue date 6/18/18 Next review 6/18/21


Process Owner

Jared Hornberger	SERF Lead Operator	
	Z-# 281223	Date <u>6/13/18</u>


Reviewed by

Joshua Begay	SERF System Engineer	
	Z-# 304395	Date <u>6/13/2018</u>


ESH Review

Russell Stone	ESH Manager	
	Z-# 117365	Date <u>6/14/2018</u>

Approved by

Lawrence Chavez	Operations Manager	
	Z-# 186199 090206	Date <u>6-18-18</u>

Derivative Classifier Review

Michael E. Gallegos	VERIFIED UNCLASSIFIED	
	Z-# 089711 120179	Date <u>14 June 18</u>

Utilities & Institutional Facilities Operations Procedure
SERF Sigma Basin SMI 120F Evaporator Inspections

UI-PROC-81-00-027-R1

History of Revisions

Document Number	Issue Date	Action
UI-PROC-81-00-027-R1	6/18/18	Review and reissue. Minor changes.
UI-PROC-81-00-027-R0	06/01/18	New procedure.

Table of Contents

1	Purpose	5
2	Scope/Applicability	5
3	Prerequisites	5
4	Precautions and Limitations	5
5	Equipment, Supplies, etc.....	6
6	Responsibilities	6
7	Work Steps	6
7.1	General Items	6
7.2	Perform Inspections.....	7
8	Records	7
9	Abbreviations, Acronyms, and Terms	8
10	References	8
11	Appendices and Attachments.....	8

This page intentionally left blank.

Utilities & Institutional Facilities Operations Procedure

SERF Sigma Basin SMI 120F Evaporator Inspections

1 Purpose

The purpose of this procedure is to provide instructions for inspecting and removing scale and debris from SMI Evaporative Solutions Model 120F Floating Mechanical Evaporators used at SERF evaporation ponds at TA-60-0221/0222 on Sigma Mesa.

2 Scope/Applicability

1. The procedure includes inspecting evaporator housings and pump sleeves for scale, inspecting fan blades for wear, removing scale, removing obstructions, and cleaning evaporator pump static inlet filters.
2. Affected personnel: SERF Operations and other personnel

3 Prerequisites

1. Required training and qualifications:
 - a. Utilities & Institutional Facilities (UI) procedures and work control processes
 - b. The current procedure, equipment, supplies, etc.
 - c. P101-3, Lockout/Tagout for Hazardous Energy Control
2. Pre-job briefing

4 Precautions and Limitations

1. Required Personal Protective Equipment (PPE)
 - Steel-toe safety shoes
 - Safety glasses with side shields
 - Personal floatation device
2. All procedure hazards, both task and site, must be addressed in accordance with UI work control processes.
3. Refer to Integrated Work Document (IWD) for specific task and site hazards.
4. Lockout/tagout (LO/TO) must be performed per P101-3, Lockout/Tagout for Hazardous Energy Control.

5 Equipment, Supplies, etc.

1. Equipment, tools, instruments:
 - Pressure washer
 - Power generator
 - Pump
 - Flat and/or combination screwdriver
 - Hand tools
 - Flashlight

6 Responsibilities

1. Persons performing this procedure are responsible for –
 - Complying with its requirements
 - Notifying appropriate supervisory personnel of equipment damage or other conditions that could require corrective action
 - Issuing a PAUSE/STOP WORK order whenever warranted by conditions related to health or safety in accordance with P101-18, Procedure for Pause/Stop Work
2. Managers are responsible for ensuring procedure compliance.

7 Work Steps

7.1 General Items

1. Schedule performance of the procedure in coordination with SERF Operations.
 - Inform affected personnel when the inspection process is about to begin.
2. Make sure evaporators are operational.

If an evaporator is out of service, record the following information in SERF Operator Log:

- Reason out of service
- Submitted Work Order/FSR number
(if MSS repair)

7.2 Perform Inspections

Perform inspections yearly.

1. Turn evaporators OFF.
2. Apply LO/TO per P101-3, Lockout/Tagout for Hazardous Energy Control.
3. Remove evaporators from ponds using tethering cable.
 - Inspect cables for tear or excessive jacket wear.
4. Inspect exterior of evaporators for scale build-up.
 - Use pressure washer to remove scale.
5. Inspect fan blades for wear.
 - Note that the blades are not sharp.
 - Notify appropriate personnel of excessive wear.
6. Inspect pump sleeves through viewing port for obstructions and scale build-up.
 - Remove any obstructions.
 - Use pressure washer to remove scale.
7. Remove static inlet filters from pumps and clean them.
8. Reinstall cleaned static inlet filters.
9. Return evaporators and tethering cables where they came from in pond.
10. Remove LO/TO.
11. Turn evaporators ON and check for normal operation.
12. If a problem is found, immediately notify appropriate personnel so corrective action can be taken.

8 Records

Records generated as a result of implementing this procedure are maintained in accordance with the UI records program.

9 Abbreviations, Acronyms, and Terms

Abbreviation, Acronym, or Term	Definition
ESH	Environment, Safety, and Health
IWD	Integrated Work Document
LO/TO	Lockout/tagout
PPE	Personal Protective Equipment
SERF	Sanitary Effluent Reclamation Facility
UI	Utilities & Institutional Facilities

10 References

P101-3, Lockout/Tagout for Hazardous Energy Control

11 Appendices and Attachments

None