

LA-UR-18-30768

Approved for public release; distribution is unlimited.

Title:	Emissions Inventory Report Summary for Los Alamos National Laboratory for Calendar Year 2017
Author(s):	Whetham, Walter Wiley
Intended for:	Report Environmental Regulatory Document
Issued:	2018-11-28 (rev.2)

Disclaimer:

Los Alamos National Laboratory, an affirmative action/equal opportunity employer, is operated by Triad National Security, LLC for the National Nuclear Security Administration of U.S. Department of Energy under contract 89233218CNA000001. By approving this article, the publisher recognizes that the U.S. Government retains nonexclusive, royalty-free license to publish or reproduce the published form of this contribution, or to allow others to do so, for U.S. Government purposes. Los Alamos National Laboratory requests that the publisher identify this article as work performed under the auspices of the U.S. Department of Energy. Los Alamos National Laboratory strongly supports academic freedom and a researcher's right to publish; as an institution, however, the Laboratory does not endorse the viewpoint of a publication or guarantee its technical correctness.

LA-UR-18-30768

November 2018

Emissions Inventory Report Summary for Los Alamos National Laboratory for Calendar Year 2017

Prepared by the Environmental Protection Division

Los Alamos National Laboratory, an affirmative action/equal opportunity employer, is operated by the Los Alamos National Security, LLC, for the National Nuclear Security Administration of the U.S. Department of Energy under contract DE-AC52-06NA25396. By acceptance of this article, the publisher recognizes that the U.S. Government retains a nonexclusive, royalty-free license to publish or reproduce the published form of this contribution, or to allow others to do so, for U.S. Government purposes. Los Alamos National Laboratory requests that the publisher identify this article as work performed under the auspices of the U.S. Department of Energy. Los Alamos National Laboratory strongly supports academic freedom and a researcher's right to publish; as an institution, however, the Laboratory does not endorse the viewpoint of a publication or guarantee its technical correctness.

CONTENTS

ABSTRACT.....	1
1.1 Regulatory Basis.....	1
1.2 Contents of Annual Emissions Inventory Submittal.....	2
1.3 Contents of the Semi-annual Title V Operating Permit Emissions Reports.....	3
2.0 REPORTED EMISSION SOURCES.....	3
2.1 Power Plant.....	4
2.2 Small Boilers and Heaters	5
2.3 Asphalt Plant.....	6
2.4 Data Disintegrator.....	6
2.5 Degreasers	6
2.6 Permitted Beryllium-Machining Operations	7
2.7 Generators.....	7
2.8 Combustion Turbine	8
2.9 Emissions from Chemical Use Activities	8
2.9.1 VOC Emissions.....	8
2.9.2 HAP Emissions	10
2.10 Evaporative Sprayers	
2.11 Emissions Summary by Source	10
3.0 REPORTING EXEMPTIONS.....	12
3.1 Boilers.....	12
3.2 Generators.....	13
3.3 VOC Emissions	13
3.4 HAP Emissions.....	15
3.5 Paint.....	15
4.0 EMISSIONS SUMMARY	16
4.1 2017 Emissions Summary	16
REFERENCES.....	20
ATTACHMENT A: <i>Emission Calculation Worksheets for Individual Emission Units</i>	22
ATTACHMENT B: <i>2017 Annual Emissions Inventory Submittal to NMED</i>.....	35
ATTACHMENT C: <i>2017 Semi-annual Emissions Reports Submitted Under Title V Operating Permit Requirements</i>.....	91

Figures

Figure 2.1-1.	TA-3 power plant.....	5
Figure 2.9-1.	Example of a laboratory fume hood at LANL	8
Figure 4.1-1.	Emissions of criteria pollutants by source in 2017	17
Figure 4.1-2.	Comparison of facility-wide annual reported emissions from 2007 to 2017.....	18
Figure 4.1-3.	VOC and HAP emissions from chemical use from 2007 to 2017	19

Tables

Table 2.0-1.	Sources Included in LANL’s 2017 Annual Emissions Inventory and Semi-annual Emissions Reports.....	4
Table 2.10-1.	Summary of LANL 2017 Reported Emissions for Annual Emissions Inventory	11
Table 2.10-2.	Summary of LANL 2017 Semi-annual Emissions as Reported Under Title V Operating Permit Requirements.....	12
Table 4.1-1.	LANL Facility-Wide Criteria Pollutant Emissions for 2017	16
Table 4.1-2.	LANL HAP Emissions from Top Five Chemicals Used in 2017	16

Acronyms and Terms

AIRS	Aerometric Information Retrieval System
AQB	Air Quality Bureau
CAS	Chemical Abstracts Service
CFR	Code of Federal Regulations
CMRR	Chemistry and Metallurgy Research Replacement (Facility)
CO	carbon monoxide
EPA	United States Environmental Protection Agency
FGR	flue gas recirculation
gal.	gallon
HAP	hazardous air pollutant
LANL	Los Alamos National Laboratory
lb	pound
MMBTU/hr	1,000,000 British thermal units per hour
mmHg	millimeter of mercury
MSDS	material safety data sheet
NMAC	New Mexico Administrative Code
NMED	New Mexico Environment Department
NO _x	nitrogen oxides
oz.	ounce
PM	particulate matter
PM _{2.5}	particulate matter with diameter less than 2.5 micrometers
PM ₁₀	particulate matter with diameter less than 10 micrometers
PSD	Prevention of Significant Deterioration
R&D	research and development
RLUOB	Radiological Laboratory/Utility/Office Building
SO _x	sulfur oxides
SO ₂	sulfur dioxide
TA	Technical Area
TSP	total suspended particulates
µm	micrometer
VOC	volatile organic compound
yr	year

This page intentionally left blank.

EMISSIONS INVENTORY REPORT SUMMARY FOR LOS ALAMOS NATIONAL LABORATORY FOR CALENDAR YEAR 2017

by
Environmental Compliance Programs Group

ABSTRACT

Los Alamos National Laboratory (LANL) is subject to annual emissions reporting requirements for regulated air pollutants under Title 20 of the New Mexico Administrative Code, Chapter 2, Part 73 (20.2.73 NMAC), Notice of Intent and Emissions Inventory Requirements. The applicability of the requirements is based on LANL's potential to emit 100 tons per year of suspended particulate matter, nitrogen oxides, carbon monoxide, sulfur oxides, or volatile organic compounds. Additionally, on April 30, 2004, LANL was issued a Title V Operating Permit from the New Mexico Environment Department/Air Quality Bureau, under 20.2.70 NMAC and the permit was revised on February 3, 2017. This Title V Operating Permit (Permit No. P100-R2M1) includes emission limits and operating limits for all regulated sources of air pollution at LANL. The Title V Operating Permit also requires semi-annual emissions reporting for all sources included in the permit. This report summarizes both the annual emissions inventory reporting and the semi-annual emissions reporting for LANL for calendar year 2017. LANL's 2017 emissions are well below the emission limits in the Title V Operating Permit.

1.0 INTRODUCTION

1.1 Regulatory Basis

Los Alamos National Laboratory (LANL or the Laboratory) has reported on air pollutants generated from its operations since the 1970s when Air Quality Control Regulation 703, Registration of Air Contaminant Sources, was promulgated. According to the regulation, the Laboratory was required to register air pollutant sources that emitted more than 2,000 lbs per year of any air contaminant. This regulatory requirement later evolved into Title 20 of the New Mexico Administrative Code, Chapter 2, Part 73 (20.2.73 NMAC), Notice of Intent and Emissions Inventory Requirements. The objective of the reporting requirement is to provide emissions data to the New Mexico Environment Department (NMED)/Air Quality Bureau (AQB) so its staff can determine whether LANL meets state and federal air pollutant standards.

Annual emissions inventory reporting requirements under 20.2.73 NMAC apply to any stationary source that

- has been issued a construction permit under 20.2.72 NMAC;
- has been required to file a Notice of Intent under 20.2.73.200 NMAC; or
- emits in excess of
 - 1 ton per year of lead or
 - 10 tons per year of

- total suspended particulates (TSP),
- particulate matter (PM) with diameter less than 10 micrometers (PM₁₀),
- PM with diameter less than 2.5 micrometers (PM_{2.5}),
- sulfur dioxide (SO₂),
- nitrogen oxides (NO_x),
- carbon monoxide (CO), or
- volatile organic compounds (VOCs).

The annual emissions inventory must be submitted to NMED/AQB by April 1 of each year. The NMED/AQB enters the data into the Aerometric Information Retrieval System (AIRS). This nationwide system, administered by the United States Environmental Protection Agency (EPA), is used to help ensure that ambient air quality standards are maintained and to track the state's air pollutant emissions. AIRS is a large air pollution database that contains information, requirements, and data on air pollution and air quality in the United States and various World Health Organization member countries. The program is operated by the EPA and state/local air pollution control agencies. The AIRS database tracks each state's progress towards achieving and maintaining National Ambient Air Quality Standards for criteria pollutants. The database is also used as a tool to help improve each state's air quality programs by enabling program members to access and compare past data and view data from other states.

Additionally, on April 30, 2004, LANL was issued a Title V Operating Permit from the NMED/AQB, under 20.2.70 NMAC. The NMED/ABQ issued a revised permit (P100-R2M1; NMED 2017) on February 3, 2017 (NMED 2017a). A condition of the Title V Operating Permit is that LANL must submit semi-annual emissions reports to NMED documenting that emissions from all permitted sources are below permitted emission levels. Section A109.B of the permit states:

“A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emissions estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table106.B.”

In 2004, the Laboratory began submitting the semi-annual emissions reports as well as the annual emissions inventory. There are a few differences in which sources are included in the two emissions reports. These differences are explained in the following sections.

1.2 Contents of Annual Emissions Inventory Submittal

NMED requested that LANL submit annual emissions inventory data for 2017 via online reporting tool, AEIR, for entry into AIRS. The information required for submittal includes the following:

- facility name, organization name, and agency ID;
- facility contact information;
- signed certification statement by a responsible facility official; and
- specific information for each emission unit such as fuel type, materials processed, materials consumed, fuel heating value, percent sulfur of fuel, percent ash of fuel, percent carbon content, and details of operating schedule.

This annual emissions inventory submittal includes air pollutant data for PM, PM₁₀, PM_{2.5}, CO, NO_x, sulfur oxides (SO_x), VOCs, and hazardous air pollutants (HAPs).

1.3 Contents of the Semi-annual Title V Operating Permit Emissions Reports

The semi-annual Title V Operating Permit emissions reports include actual estimated emissions for the reporting period for each emission source or source category included in the Title V Operating Permit. For each source category, the actual emissions are compared with emission limits listed in the permit.

The emissions are calculated using operating data from logbooks and records maintained on site.

All emission calculations are consistent with calculation methods used for the annual emissions inventory.

The semi-annual emissions reports include a few source categories not included in the annual emissions inventory. For the first Title V permit, the Laboratory requested emission limits in their Title V Operating Permit for two source categories that are considered insignificant sources for the annual emissions inventory. These source categories are 1) small boilers and heaters and 2) stationary standby generators. LANL requested emission limits for these source categories to obtain federally enforceable limits that would keep the Laboratory under the major source threshold for Prevention of Significant Deterioration (PSD) applicability (20.2.74 NMAC). LANL's actual emissions from these insignificant sources have historically been very low; however, without federally enforceable limits on their operation, the potential to emit from these sources was quite high. To demonstrate that LANL is below the PSD applicability and is in compliance with the emission limits placed on these emission sources for the original Title V Operating Permit, LANL included these emissions in the semi-annual emissions reports. NMED removed the stationary standby generators starting with the P100-R2 permit.

2.0 REPORTED EMISSION SOURCES

Table 2.0-1 shows the emission sources included in the Laboratory's 2017 annual emissions inventory (LANL 2017a) and the 2017 semi-annual emissions reports (LANL 2017b and 2017c). The source categories and the methodology used to calculate emissions are described in the following sections.

The following subsections describe emission sources included in the 2017 emissions inventory and semi-annual emissions reports and emission calculation methodology for each source type. A summary table of actual reported emissions by source is included in Section 2.12. Attachment A includes worksheets showing detailed emission calculations for individual emissions sources. A copy of the 2017 emissions inventory as submitted to NMED is presented in Attachment B. The 2017 semi-annual emissions reports are included as Attachment C.

Table 2.0-1. Sources Included in LANL's 2017 Annual Emissions Inventory and Semi-annual Emissions Reports

Included in Annual Emissions Inventory	Included in Semi-annual Emissions Reports	Comment
Power Plant (TA-3)	Power Plant (TA-3)	n/a ^a
Boilers greater than 5 MMBTU/hr ^b (14 units)	All small and large boilers and heaters (approximately 175 units)	Small boilers less than 5 MMBTU/hr are exempt from annual emissions inventory requirements (see Section 3.1).
Asphalt Plant	Asphalt Plant	n/a
Degreasers	Degreasers	n/a
Data Disintegrator	Data Disintegrator	n/a
Permitted Beryllium Sources	Permitted Beryllium Sources	n/a
Facility-wide Chemical Use	Facility-wide Chemical Use	The semi-annual emissions reports also include separate emission data for the CMRR-RLUOB building.
Process Generators and Stationary Standby Generators	Process Generators	n/a
TA-3 Turbine	TA-3 Turbine	n/a
Evaporative Sprayers	Evaporative Sprayers	n/a

^a n/a = not applicable.^b one million British thermals units per hour.

2.1 Power Plant

The Laboratory operates a power plant at Technical Area (TA) 3. The power plant produces steam for heating and electricity for much of the Laboratory when sufficient power from outside sources is not available. The heat produced from the power plant is used for comfort heat and hot water and to support facility processes. The power plant has three boilers that are fueled primarily with natural gas with No. 2 fuel oil as a backup. The Laboratory operated a second power plant at TA-21 that was shut down in 2007.

For the 2017 emissions inventory, NMED requested that emissions from natural gas and No. 2 fuel oil be reported separately for the boilers located at each of the power plants. The TA-3 power plant was originally included in LANL's emissions inventory as a single unit. When a modification to the plant was made in 2001, the TA-3 power plant was separated into three separate units for emissions reporting purposes. Because each of the three boilers has the capability of burning either natural gas or No. 2 fuel oil, the TA-3 power plant is now reported as six units (EQPT-24, EQPT-25, and EQPT-26 for the natural gas and EQPT-137, EQPT-138, and EQPT-141 for the No. 2 fuel oil).

Actual estimated emissions are calculated on the basis of metered fuel consumption and emission factors. The primary source of emission factors is AP-42, the EPA's Compilation of Air Pollutant Emission Factors (EPA 1998). However, emission factors from stack tests conducted at the TA-3 power plant when burning natural gas were also used, as appropriate.

The TA-3 power plant has historically been the largest source of NO_x emissions at the Laboratory. In 2002, a voluntary project to install pollution control equipment on the three boilers at the TA-3 power plant was completed. The three boilers were fitted with flue gas recirculation (FGR) equipment to reduce NO_x emissions. Stack testing for NO_x and CO was conducted before FGR equipment was installed and again after it was operational. Based on these stack test results, FGR reduced NO_x emissions by approximately 64%. Figure 2.1-1 shows a picture of the TA-3 power plant building and stacks.



Figure 2.1-1. TA-3 power plant

2.2 Small Boilers and Heaters

The Laboratory operates approximately 175 small boilers and heaters, used primarily for seasonal comfort heat. Most of the boilers are exempt from permitting requirements because of their small size and use as comfort boilers and are not included in the annual emissions inventory. The exemption analysis applied to boilers is discussed in Section 3.1 of this report.

The boilers that are not exempt and reported in the 2017 annual emissions inventory include:

- two boilers at TA-53 (EQPT-11 and EQPT-12),
- two boilers at TA-55 (EQPT-29 and EQPT-30),
- five boilers at the Chemistry and Metallurgy Research Replacement (CMRR) Facility (EQPT-90, EQPT-104, EQPT-105, EQPT-106, and EQPT-107), and
- two boilers at TA-16 (EQPT-53 and EQPT-134).

All of the reported boilers burn natural gas. Operating logs of actual fuel used for the TA-55 and the CMRR boilers were used to quantify emissions from these units. Fuel use for all other boilers was estimated based on the total amount of natural gas used by the Laboratory minus the amount supplied to metered sources. The amount of natural gas left after subtracting out metered sources was apportioned to the various boilers based on their size. Since virtually all of the small boilers are seasonal boilers used for building heating, it was assumed they would all operate approximately the same amount of time over the course of the year. Some emission factors were available from stack tests (TA-55), some were provided by the boiler manufacturer (Sellers Engineering Company), and the rest were taken from AP-42

(EPA 1998). Copies of spreadsheets showing fuel use and emission factors for each boiler are included in Attachment A.

For the semi-annual emissions reports, emissions from small boilers are included as a source category. These boilers include TA-16-1484-BS-1, TA-16-1484-BS-2, TA-53-365-BHW-1, TA-53-365-BHW-2, TA-55-6-BHW-1, TA-55-6-BHW-2, CMRR-BWH-1, CMRR-BWH-2, CMRR-BWH-3, and CMRR-BWH-4. Additionally, emissions from each of the CMRR boilers are included as separate source categories. To estimate emissions, all unmetered fuel use was multiplied by AP-42 emission factors for small boilers burning natural gas (EPA 1998). Total emissions of each pollutant from all boilers and heaters in this source category were then summed and reported on the semi-annual emissions reports.

2.3 Asphalt Plant

The TA-60 asphalt plant (EQPT-116) began operations in July 2005. This unit replaced the TA-3 asphalt plant, which was dismantled and removed in September 2003. Information on the amount of asphalt produced and the duration of daily operation at the TA-60 asphalt plant was provided as part of a monthly site support contractor data deliverable. The total asphalt produced in 2017 was 712 tons.

The emissions from the asphalt plant include criteria pollutants, NO_x, and CO. None of the emissions were significant in regard to the overall Laboratory emissions. The largest pollutant emitted from the asphalt plant was CO at 0.15 tons per year.

2.4 Data Disintegrator

The data disintegrator is included in the 2017 emissions inventory as EQPT-89. Operation of this source started in August 2004. Emissions are calculated using the methodology described in the original permit application dated June 23, 2003. Emissions of PM, PM₁₀, and PM_{2.5} are calculated based on the number of boxes shredded, the amount of dust estimated to enter the exhaust (provided by the manufacturer), and the control efficiency of the cyclone and baghouse (also provided by the manufacturer). The permit application included PM_{2.5} emission estimates. Therefore, an emission methodology had to be developed for the emission inventory reporting. No specific PM size distribution data were available. However, the manufacturer reported that dust into the exhaust would be in the size range of 5 to 20 μm. Based on visual observation and engineering judgment, a particle size distribution in the exhaust was estimated as follows:

- PM_{2.5} 15%
- PM₁₀ 90%
- TSP 100%

The number of boxes of material shredded is provided in a monthly data deliverable from the site support contractor. The total number of boxes shredded at the data disintegrator in 2017 was 10,067.

2.5 Degreasers

The halogenated solvent cleaning machine at TA-55 has a capacity of 18 liters and is registered with NMED/AQB as required under the National Emissions Standards for Hazardous Air Pollutants, 40 Code of Federal Regulations (CFR) 63 Subpart T, Halogenated Solvent Cleaning. The solvent used in the machine, trichloroethylene (Chemical Abstracts Service [CAS] No. 79-01-6), is a VOC and a HAP. This

emission unit is included in the annual emissions inventory as EQPT-21. LANL uses a mass balance approach to estimate emissions. Logbooks are kept on the amount of solvent added and removed from the machine. Additionally, solvent levels in the machine are logged monthly. LANL has two additional halogenated solvent cleaning machines registered with NMED which were not operational in 2017. The emissions from the TA-55 degreaser for this reporting period are 3.16 lbs or 0.0016 tons per year. This source category is reported in both the annual emissions inventory and the semi-annual emissions reports.

2.6 Permitted Beryllium-Machining Operations

The Laboratory operates five permitted beryllium-machining operations that are subject to 40 CFR 61, Subpart C, and National Emission Standards for Beryllium. Emissions reported for the Beryllium Test Facility (ACT-3) are from actual stack emissions measurements. Emissions for the Target Fabrication Facility (ACT-2) are from initial compliance stack testing and are reported as permitted emission levels. In addition, emissions from the Plutonium Facility (ACT-6) are reported at permitted emission levels. Foundry operations within the Plutonium Facility did not occur during this reporting period. The Sigma Facility (ACT-41) includes emissions from electroplating, chemical milling, and metallographic operations. Total emissions from all permitted beryllium operations are included in the semi-annual emissions reports.

2.7 Generators

LANL has 11 permitted internal combustion engines including: four generators located at TA-33, three generators located at CMRR Radiological Laboratory/Utility/Office Building (RLUOB), three generators located at TA-55, and one generator located at TA-48. The original TA-33 generator was installed in May 2006 and replaced in December 2014 by a Cummins Portable Diesel Generator. The new generator (EQPT-146) operated for 0.4 hours in 2017. Permit No. 2195-P was issued in August 2007 for three more units at TA-33 (EQPT-119, EQPT-120, EQPT-135); the three units operated for a total of 3.5 hours in 2017.

LANL has three permitted generators (EQPT-128, EQPT-153, EQPT-154) located at the RLUOB facility, which began operating in 2012. The generators were added to the newest Title V Operating Permit and included in both the semi-annual emissions report and emissions inventory report. The three generators operated for a total of 17.7 hours in 2017.

The other four permitted generators at LANL are located at TA-55 (EQPT-143, EQPT-155, EQPT-156) and TA-48 (EQPT-147). The TA-55 generators operated for a total of 13.3 hours in 2017 and the TA-48 generator did not operate.

The Laboratory maintains approximately 37 stationary standby generators that are considered exempt sources under the Construction Permit regulations (20.2.72.202.b NMAC). These sources are included in LANL's annual emissions inventory report, but not in the semi-annual emissions report. All stationary standby generators at LANL are tested on a routine schedule to ensure they are operational and will function properly if needed. All units are equipped with hour meters to document how many hours they are used. The Laboratory maintains records on a semi-annual basis to document hour meter readings. The number of hours each generator is used in a reporting period is multiplied by AP-42 emission factors for diesel-fired internal combustion engines or natural-gas-fired internal combustion engines (EPA 1996).

Emissions are then summed for each pollutant and reported on the semi-annual emissions reports for this source category.

2.8 Combustion Turbine

LANL has one combustion turbine located at the TA-3 power plant (EQPT-112). A revised construction permit was issued by NMED July 2004 to add the TA-3 combustion turbine as a new permitted source. This unit started operations in September 2007. Emission calculations are based on the initial stack compliance tests performed in 2007, AP-42 Tables 3.1-2a and 3.1-3, and information provided by the manufacturer. In 2017, this combustion turbine operated for 206.1 hours.

2.9 Emissions from Chemical Use Activities

A significant amount of the Laboratory's work is devoted to research and development (R&D) activities. Varying operating parameters, as well as amounts and types of chemicals, are used in these activities. R&D activities occur at virtually all technical areas within the Laboratory, typically in small quantities in laboratory settings. Figure 2.9-1 shows a typical laboratory at LANL where chemicals are used.



Figure 2.9-1. Example of a laboratory fume hood at LANL

For the purposes of annual emissions inventory reporting, one equipment number has been assigned for all R&D chemical use (ACT-7). Facility-wide chemical use emissions are reported on both the annual emissions inventory and the semi-annual emissions reports. The methods used to quantify emissions of VOC and HAPs from R&D activities are discussed below.

2.9.1 VOC Emissions

The Laboratory tracks chemical purchases through a facility-wide chemical tracking system called ChemDB. A download from the ChemDB inventory system was created that included all chemical containers added to LANL's inventory between January 1, 2017, and December 31, 2017. This dataset included 47,425 separate line items of chemicals purchased.

The dataset was reviewed electronically to identify all VOCs purchased and received at LANL in 2017. With the exception of specific listed chemicals, VOCs are any compounds of carbon that participate in atmospheric photochemical reactions. VOCs include commonly used chemicals such as ethanol, methanol, trichloroethylene, and isopropanol. The general assumption used in estimating VOC emissions from chemical use is

$$\text{Purchasing} = \text{Use} = \text{Emissions}$$

From the dataset of chemicals purchased in 2017, certain categories of chemicals were separated and eliminated from the analysis. The classifications assigned and corresponding reasons (noted in parentheses) for exclusion of chemicals from inventory records are noted below.

- Solid materials (not a significant source of air emissions based on their low vapor pressure)
- Non-VOC materials as defined by 40 CFR 51.100 (specific chemicals in 40 CFR 51.100 are listed as having negligible photochemical reactivity and are exempt from the definition of VOC)
- Paints (paints were evaluated separately—see Section 3.5)
- Inorganic chemicals (inorganics are not compounds of carbon)
- Oils (not a significant source of air emissions based on low vapor pressure and primarily used for maintenance)
- Fuels used for combustion purposes (emissions from fuel combustion are reported for each combustion unit)

The following categories of chemicals were eliminated based on guidance from NMED (NMED 2001).

- Container sizes of 1 lb or less
- Chemicals with vapor pressures less than 10 mmHg
- Chemicals used to calibrate equipment
- Maintenance chemicals
- Use of office equipment and products
- Chemicals used for boiler water treatment operations
- Chemicals used for oxygen scavenging (deaeration) of water
- Chemicals used in bench-scale chemical analysis¹

After the elimination of chemicals and categories of chemicals listed above, the remaining chemical inventory records were matched with a list of known VOCs by CAS number. For mixtures (chemicals without CAS numbers), material safety data sheets (MSDSs) were reviewed to determine if any VOCs were present and, if so, to determine the associated percent volatile. As a conservative estimate, VOCs identified in ChemDB records were assumed to be 100% emitted to air. Estimated emissions of VOCs from chemical use in 2017 totaled 10.32 tons.

¹ This exemption was applied only to biological research solutions. Otherwise, this exemption was not applied (see Table 3.3-1).

2.9.2 HAP Emissions

Section 112(b) of the 1990 Clean Air Act Amendments listed 188 unique HAPs identified for potential regulation by the EPA. In 1995, caprolactam was delisted as a HAP, and methyl ethyl ketone was delisted in 2005. Of the remaining 187 listed HAPs, 17 are classes of compounds (e.g., nickel compounds). Use of the 187 listed chemicals in activities at the Laboratory was evaluated and quantified for the annual emissions inventory submittal to NMED.

The ChemDB inventory system 2017 dataset was analyzed to identify HAPs. The identification process was similar to that used for VOCs. Pure chemicals (i.e., chemicals with CAS numbers), classes of compounds, and mixtures were evaluated to determine if the chemicals themselves were HAPs or if they contained HAP constituents. For mixtures, MSDSs were reviewed to determine if any HAPs were present and, if so, to determine the associated HAP percentages. Listed below are certain chemical types or categories that were identified and removed from this analysis (refer to Section 2.9.1 and Table 3.3-1 for explanations on removal of these chemicals).

- Paints
- Oils
- Maintenance chemicals
- Chemicals used to calibrate equipment
- Container sizes of 1 lb or less
- Chemicals used in bench-scale chemical analysis
- Use of office equipment and products
- Chemicals used for boiler water treatment operations
- Chemicals used for oxygen scavenging (deaeration) of water

Total HAP emissions were estimated by summing 1) pure HAP chemicals, 2) classes of compounds that are HAPs, and 3) the HAP constituents from mixtures. The resulting total amount of HAPs from chemical use reported for 2017 was 5.16 tons.

The HAP emissions reported generally reflect quantities procured in the calendar year. In a few cases, procurement values and operational processes were further evaluated so that actual air emissions could be reported instead of procurement quantities. Additional analyses for certain metals and acids were performed and are described below.

2.10 Evaporative Sprayers

The Laboratory is permitted to operate five spray evaporators at the Sanitary Effluent Treatment Facility or SERF. However, only three of the sprayers have been installed. The spray evaporators are intended to reduce water volume in the existing Sigma Mesa evaporation basins. These synthetically-lined evaporation basins are located within TA-60. The basins are intended for use to evaporate a specific treated waste water discharge from SERF which processes treated sanitary wastewater effluent for beneficial reuse, and is intended to conserve potable water and reduce wastewater discharges to the environment. The stored treated waste water is a concentrated salt solution from reverse osmosis treatment at the SERF facility. Operation of the

SERF facility is crucial in reducing water usage at LANL, achieving compliance with discharges to an NPDES outfall, and providing clean water for cooling tower use at LANL.

Actual estimated emissions are calculated from hours of operation and emission factors based on analytical results from sampling the basin water.

2.11 Emissions Summary by Source

Table 2.10-1 provides a summary of LANL's 2017 actual emissions, as submitted for the annual emissions inventory. The table presents emissions by pollutant and by source, with a facility total at the bottom of the table. Attachment A provides detailed information on how emissions were calculated for each emission unit.

Table 2.10-1. Summary of LANL 2017 Reported Emissions for Annual Emissions Inventory

	NO _x (tons/yr)	SO _x (tons/yr)	PM ₁₀ (tons/yr)	PM _{2.5} (tons/yr)	CO (tons/yr)	VOC (tons/yr)	HAPs (tons/yr)
TA-3 Power Plant Boilers	9.83	0.11	1.29	1.29	6.78	0.93	0.32
TA-55-6 Boilers	1.53	0.007	0.16	0.16	0.42	0.066	0.021
TA-53 Boilers	0.95	0.006	0.072	0.072	0.80	0.052	0.018
TA-16 Boilers	0.31	0.005	0.064	0.064	0.31	0.047	0.16
RLUOB Boilers	0.034	0.001	0.006	0.006	0.044	0.030	0.002
Asphalt Plant	0.004	0.002	0.002	n/a	0.155	0.003	0.003
Data Disintegrator	n/a	n/a	0.38	n/a	n/a	n/a	n/a
Degreaser	n/a	n/a	n/a	n/a	n/a	0.002	0.002
R&D Chemical Use	n/a	n/a	n/a	n/a	n/a	10.32	5.16
TA-33 Generators	0.006	0.0002	0.0002	n/a	0.001	0.0004	1.6E-06
RLUOB Generators	0.30	0.008	0.015	n/a	0.37	0.042	7.7E-05
TA-55 Generators	0.18	0.0002	0.0002	n/a	0.001	0.0004	1.6E-06
TA-48 Generator	0	0	0	n/a	0	0	0
Stationary Standby Generators	4.34	0.17	0.20	n/a	1.13	0.21	0.003
TA-3 Turbine	1.29	0.09	0.17	0.17	0.27	0.06	0.04
Evaporative Sprayers	n/a	n/a	n/a	n/a	n/a	n/a	0.0003
TOTAL	18.77	0.40	2.36	1.76	10.28	11.76	5.73

* n/a = not applicable.

Table 2.10-2 provides a summary of 2017 emissions as reported on the semi-annual emissions reports required by the Title V Operating Permit. Attachment A provides detailed information on how emissions were calculated for each emission source category.

Table 2.10-2. Summary of LANL 2017 Semi-annual Emissions as Reported Under Title V Operating Permit Requirements

	NO _x (tons/yr)	SO _x (tons/yr)	PM ₁₀ (tons/yr)	PM _{2.5} (tons/yr)	CO (tons/yr)	VOC (tons/yr)	HAPs (tons/yr)
TA-3 Power Plant Boilers	9.83	0.11	1.29	1.29	6.78	0.93	0.32
Small Boilers	19.25	0.12	1.55	n/a*	15.38	1.10	0.37
RLUOB Boilers	0.034	0.001	0.006	0.006	0.044	0.030	0.002
Asphalt Plant	0.004	0.002	0.002	n/a	0.155	0.003	0.003
Data Disintegrator	n/a	n/a	0.38	n/a	n/a	n/a	n/a
Degreaser	n/a	n/a	n/a	n/a	n/a	0.003	0.003
R&D Chemical Use	n/a	n/a	n/a	n/a	n/a	10.32	5.16
TA-33 Generators	0.006	0.0002	0.0002	n/a	0.001	0.0004	1.6E-06
RLUOB Generators	0.30	0.008	0.015	n/a	0.37	0.042	7.7E-05
TA-55 Generators	0.18	0.0002	0.0002	n/a	0.001	0.0004	1.6E-06
TA-48 Generator	0	0	0	n/a	0	0	0
TA-3 Turbine	1.29	0.09	0.17	0.17	0.27	0.06	0.04
Evaporative Sprayers	n/a	n/a	n/a	n/a	n/a	n/a	0.0003
TOTAL	30.89	0.33	3.41	1.47	23.00	12.49	5.90

* n/a = not applicable.

3.0 REPORTING EXEMPTIONS

Specific activities that are determined to be insignificant under NMED's Operating Permit program (20.2.70 NMAC) are exempt from reporting under the emissions inventory requirements (20.2.73.300 NMAC). NMED has designated exempt sources, activities, or thresholds in the following lists:

- List of Insignificant Activities, March 25, 2005 (NMED 2005)
- List of Trivial Activities, January 10, 1996 (NMED 1996).

Laboratory sources and activities that qualify as insignificant or trivial as specified in these lists are not included in the annual emissions inventory. The following subsections of this report provide information and examples of the Laboratory's exempt activities as well as analyses performed to determine exempt status.

3.1 Boilers

The Laboratory's boiler inventory was evaluated against the List of Insignificant Activities (NMED 2005). Specifically, boilers were exempted from emissions inventory reporting requirements if they met one of the following requirements:

- Fuel-burning equipment that uses gaseous fuel has a design rate less than or equal to 5 MMBTU/hr, and is used solely for heating buildings for personal comfort or for producing hot water for personal use, or
- Any emissions unit . . . that has the potential to emit no more than 1 ton/yr of any regulated pollutant

Any boiler that was not used exclusively for comfort heating or hot water was evaluated for the 1 ton per year exemption. For purposes of determining exemptions, boiler design ratings were used to estimate potential to emit. Any boiler not qualifying for one of these two exemptions is included in the annual emissions inventory with its own unique equipment number.

For the semi-annual emissions reports, emissions from all boilers and heaters were summed and reported for the entire source category.

3.2 Generators

The Laboratory maintains an inventory of approximately 73 portable generators. Portable generators are used at the Laboratory for temporary operations requiring remote power or to provide emergency backup power during power outages at various sites. The portable generators are fueled by gasoline and/or diesel fuel.

In addition to portable generators, the Laboratory maintains and operates approximately 45 stationary standby generators. Stationary generators are used on standby (emergency) status to provide power to critical systems at the Laboratory during power outages. The stationary generators are fueled by natural gas, propane, gasoline, or diesel.

The insignificant activity exemptions applicable to the Laboratory's generators are for:

- Portable engines and portable turbines that have a design capacity . . . less than or equal to a
 - 200-horsepower engine if fueled by diesel or natural gas and a
 - 500-horsepower engine if fueled by gasoline.
- Emergency generators that on a temporary basis replace equipment used in normal operation, and which either have an allowable emission rate or potential to emit for each pollutant that is equal to or less than the equipment replaced, or which do not operate for a period exceeding 500 hours per calendar year.

On the basis of size, portable generators used for temporary power at remote locations are exempt from emissions inventory reporting requirements. Further, LANL's small portable generators are considered trivial activities and are not included in the Title V Operating Permit or semi-annual emissions reports. All stationary generators are designated as standby equipment under the Operating Permit Program and are used solely to provide emergency backup power for less than 500 hours per year. Therefore, they are considered insignificant sources and are also exempt from annual emissions inventory reporting requirements. However, the stationary standby generators were voluntarily included as a source category in the Title V Operating Permit and are included in the semi-annual emissions reports.

3.3 VOC Emissions

A number of insignificant and trivial activities were applicable for exempting materials from the VOC chemical use total in the emissions inventory. The basis of the exemptions and corresponding insignificant or trivial activities are explained in Table 3.3-1.

Fuels such as propane, kerosene, and acetylene were analyzed separately and are not listed in Table 3.3-1. When fuels are burned in an open flame, almost all of the fuels are consumed and VOC emissions are

minimal. Emissions from fuel combustion are accounted for by using emission factors for each fuel-burning unit.

Table 3.3-1. Exemptions Applied for Chemical Use Activities

Basis of Exemption	Activity Type	Activity
Container sizes of 1 lb or less	Trivial	Paint or nonpaint materials dispensed from prepackaged aerosol cans of 16-oz. capacity or less.
Chemicals with vapor pressures less than 10 mmHg	Insignificant	Any emissions unit, operation, or activity that handles or stores a liquid with vapor pressure less than 10 mmHg or in quantities less than 500 gal.
Calibration chemicals	Trivial	Routine calibration and maintenance of laboratory equipment or other analytical instruments, including gases used as part of those processes.
Maintenance chemicals and oils	Trivial	Activities that occur strictly for maintenance of grounds or buildings, including lawn care; pest control; grinding; cutting; welding; painting; woodworking; sweeping; general repairs; janitorial activities; plumbing; re-tarring roofs; installing insulation; steam-cleaning and water-washing activities; and paving of roads, parking lots, and other areas. Activities for maintenance and repair of equipment, pollution-control equipment, or motor vehicles either inside or outside of a building.
Use of office equipment and products	Trivial	Use of office equipment and products, not including printers or businesses primarily involved in photographic reproduction.
Chemicals used for boiler water treatment	Trivial	Boiler water treatment operations, not including cooling towers.
Chemicals used for oxygen scavenging	Trivial	Oxygen scavenging (deaeration of water).
Chemicals used in bench-scale chemical analysis	Trivial	Bench-scale laboratory equipment used for physical or chemical analysis but not lab fume hoods or vents. Note: This exemption was applied only to biological research solutions. Otherwise, this exemption was not applied.

3.4 HAP Emissions

The HAP chemical use exemption analysis, similar to the VOC chemical use exemption analysis, resulted in application of several of the same exemptions from NMED/AQB List of Insignificant Activities (NMED 2005) and List of Trivial Activities (NMED 1996) (refer to Table 3.3-1).

3.5 Paints

An analysis of VOC and HAP emissions resulting from painting activities at the Laboratory was performed to determine if certain exemptions apply. Paint information for 2017 was gathered from the ChemDB chemical inventory system. These records were evaluated for applicability of exemptions for trivial and insignificant activities.

The following exemptions from NMED/AQB Operating Permit Program List of Trivial Activities (NMED 1996) were used in the paint analysis:

- Activities that occur strictly for maintenance of grounds or buildings, including the following: lawn care; pest control; grinding; cutting; welding; painting; woodworking; sweeping; general repairs; janitorial activities; plumbing; re-tarring roofs; installing insulation; steam-cleaning and water-washing activities; and paving of roads, parking lots, and other areas.

- Activities for maintenance and repair of equipment, pollution control equipment, or motor vehicles either inside or outside of a building.
- Paint or nonpaint materials dispensed from prepackaged aerosol cans of 16 oz. or less capacity. The amount of paint that did not qualify for a Trivial Activity totaled to 3,019 lbs (1.51 tons), which is less than the 2-ton emission limit for insignificant activities.
- Surface coating of equipment, including spray painting and roll coating, for sources with facility-wide total cleanup solvent and coating actual emissions of less than 2 tons per year.

4.0 EMISSIONS SUMMARY

4.1 2017 Emissions Summary

Table 4.1-1 presents facility-wide estimated actual emissions of criteria pollutants for 2017 as reported in the annual emissions inventory and the semi-annual emissions reports. In addition, the Title V Operating Permit emissions limits are included. Table 4.1-2 presents estimated actual emissions for HAPs from chemical use. Emission unit information and detailed emissions calculations are included in Attachment A. The 2017 emissions inventory report as submitted to NMED is presented in Attachment B. Attachment C includes semi-annual emissions reports for 2017.

Table 4.1-1. LANL Facility-Wide Criteria Pollutant Emissions for 2017

Pollutant	Estimated actual Emissions for Annual Emissions Inventory Reporting (tons/yr)	Estimated actual Emissions for Semi-annual Title V Operating Permit Reporting (tons/yr)	Title V Operating Permit Facility-Wide Emission Limits (tons/yr)
NO _x	18.77	30.89	245
SO _x	0.40	0.33	150
CO	10.28	23.00	225
PM	2.36	3.41	120
PM ₁₀	2.36	3.41	120
PM _{2.5}	1.76	1.47	120
VOC	11.76	12.49	200

Table 4.1-2. LANL HAP Emissions from Top Five Chemicals Used in 2017

Pollutant	Chemical Use HAP Emissions (tons/yr)
Methanol	1.28
Hydrochloric Acid	1.14
Cyanide Compounds	0.60
Methylene Chloride	0.42
Hexane	0.37
All other HAPs from Chemical Use	1.35
Total HAPs	5.16

HAP emissions from combustion sources are included in the emissions reports; however, they are negligible and do not contribute significantly to facility-wide HAP emissions.

Figure 4.1-1 shows criteria air pollutant emissions by source for 2017, excluding the very small emissions sources such as the data disintegrator, asphalt plant, degreasers, and evaporative sprayers. As the figure shows, the TA-3 power plant and the sum of emissions from small boilers and were the largest sources of CO and NO_x emissions in 2017. R&D chemical use was the largest source of VOC emissions.




Figure 4.1-1. Emissions of criteria pollutants by source in 2017

Emission Trends and Title V Permit Limits

A comparison of historical emissions to the facility-wide emission limits in the Title V Operating Permit is provided in this section. It should be noted that the facility-wide emission limits in the Operating Permit include emissions from some sources that are not included in the annual emissions inventory, most notably small (insignificant) boilers and emergency standby generators. However, historical data are only available for emission sources that were included in the annual emissions inventory submittals.

Figure 4.1-2 provides a comparison of the past 10 years' facility-wide emissions for criteria air pollutants as reported to NMED in the annual emissions inventory submittal. The facility-wide emission limits included in LANL's Title V Operating Permit are also shown on the graph.




Figure 4.1-2. Comparison of facility-wide annual reported emissions from 2007 to 2017

Figure 4.1-3 presents VOC and HAP emissions from chemical use activities for the last 10 years. The continued fluctuation in both VOC and HAP emissions is due to both variations in actual chemical purchases and improvements the Laboratory has made to the chemical tracking system.




Figure 4.1-3. VOC and HAP emissions from chemical use from 2008 to 2017

REFERENCES

- EPA (U.S. Environmental Protection Agency), 1998. "Compilation of Air Pollutant Emission Factors," AP-42, Fifth Edition, Section 1.4–Natural Gas Combustion, July 1998, and Section 1.3–Fuel Oil Combustion, <http://www.epa.gov/ttn/chief/ap42/> (September 1998).
- EPA (U.S. Environmental Protection Agency), 1996. "Compilation of Air Pollutant Emission Factors," AP-42, Fifth Edition, Section 3.3–Gasoline and Diesel Industrial Engines, and Section 3.4–Large Stationary Diesel and All Stationary Dual-Fuel Engines, <http://www.epa.gov/ttn/chief/ap42/> (October 1996).
- LANL (Los Alamos National Laboratory), 2017a. "2017 Emissions Inventory Report Submittal to the New Mexico Environment Department," Los Alamos National Laboratory document LA-UR-18-22329 (March 2017).
- LANL (Los Alamos National Laboratory), 2017b. "Semi-Annual Emissions Report, July–December 2017," submitted to the New Mexico Environment Department, Los Alamos National Laboratory document LA-UR-18-22248 (March 2017).
- LANL (Los Alamos National Laboratory), 2017c. "Semi-Annual Emissions Report, January–June 2017," submitted to the New Mexico Environment Department, Los Alamos National Laboratory document LA-UR-17-27818 (September 2017).
- NMED (New Mexico Environment Department, Air Quality Bureau, Operating Permit Program), 2005. "List of Insignificant Activities under Title V Operating Permits," <http://www.nmenv.state.nm.us/aqb/forms/InsignificantListTitleV.pdf> (March 2005).
- NMED (New Mexico Environment Department, Air Quality Bureau), 2001. Letter from Mary Uhl, NMED/AQB to LANL, dated January 30, 2001.
- NMED (New Mexico Environment Department, Air Quality Bureau, Operating Permit Program), 1996. "List of Trivial Activities under Title V Operating Permits," <http://www.nmenv.state.nm.us/aqb/forms/TrivialListTitleV.pdf> (January 1996).

This page intentionally left blank.

ATTACHMENT A:

Emission Calculation Worksheets for Individual Emission Units

2017 Emission Inventory | AI856 LANL - Asphalt Batch Plant Emissions Calculations

Year 2017
 Type Asphalt Drum/Burner
 NMED ID EQPT-116
 Title V Designation TA-60-BDM
 Description Asphalt Plant Dryer

Annual Asphalt Production 712.0 ton/year

Equation for Calculations

Annual Emissions (ton/year)= Emission Factor (lb/ton) X Annual Asphalt Production (ton/year) / 2000 (lb/ton)

Pollutant	Emission Factor (lb/ton)	Annual Emissions (ton/year)	Calculation Basis
NOx	0.012	0.0044	(b)
CO	0.434	0.1545	(b)
PM	0.007	0.0026	(b)
PM-10	0.006	0.0021	(c)
PM-2.5	0.006	0.0021	(c)
SOx	0.0046	0.0016	(a)
VOC	0.0082	0.0029	(a)
Hazardous Air Pollutants	Emission Factor (lb/ton)	Annual Emissions (ton/year)	Calculation Basis
EthylBenzene	0.0022	0.0008	(d)
Formaldehyde	0.00074	0.0003	(d)
Xylene	0.0027	0.0010	(d)

Reference

(a) AP-42, Sec. 11.1, *Hot Mix Asphalt Plants*, Table 11.1-5 & 11.1-6, Updated 4/2004

(b) Calculated using stack test results performed on May 18, 2009 by TRC Air Measurements.

(c) PM-10 emission factor is calculated as 64% of the PM emission factor (from stack test), using the same ratio of PM to PM-10 as provided in AP-42 Table 11.1-1. No data provided for PM-2.5, assume same as PM-10.

(d) AP-42, Table 11.1-9, *Hot Mix Asphalt Plants*, Updated 4/2004

2017 Emission Inventory | AI856 LANL - Beryllium Emissions Calculations

Year	2017
Type	Beryllium Work
NMED ID	ACT-2
Title V Designation	TA-35-213
Description	Be Target Fabrication Facility - Machining TA-35-213

Emission Calculation Description -

Emissions for the Target Fabrication Facility are from initial compliance testing of that source and calculated based on a conservative assumption of 8 hour work days. Log books were checked to verify that work days were much less than 8 hours.

Year	2017
Type	Beryllium Work
NMED ID	ACT-3
Title V Designation	TA-3-141
Description	Be Test Facility - Machining TA-3-141

Emission Calculation Description -

Emission values shown for the Beryllium Test Facility are from actual stack emission measurements which are submitted to NMED quarterly.

Year	2017
Type	Beryllium Work
NMED ID	ACT-6
Title V Designation	TA-55-PF-4
Description	Plutonium Facility Beryllium machining, weld cutting/dressing and metallography

Emission Calculation Description -

Emissions for the Plutonium Facility are calculated based on permitted throughputs. Log books were checked to verify that throughputs were much less than permitted values. The Plutonium Facility foundry operations did not operate during 2017.

Year	2017
Type	Beryllium Work
NMED ID	ACT-41
Title V Designation	TA-3-66
Description	Sigma Facility - electroplating, metallography, and chemical milling

Emission Calculation Description -

Emission Factors for the Sigma Facility are based on currently permitted similar processes (see Sections 4 and 6 of Sep 1997 application for permit 634-M2, and permit 1081-M1-R3).

2017 Emission Inventory | AI856 LANL - Boilers Emissions Calculations

Year 2017
 Type Boilers except those at the power plant
 NMED ID multiple (see emission table below)
 Title V Designation EQPT 11, EQPT 12, EQPT 29, EQPT 30, EQPT 53, EQPT 90, EQPT 104, EQPT 105, EQPT 134
 Description Boilers located at various locations not including the power plant

Emission Factors (lb/MMscf)

Emission Factors (lb/MMscf)				
Emission Sources	Small Uncontrolled Boilers ¹	TA-16 Low NOx Boilers ⁴	TA-55-6 Boilers ³	RLUOB Boilers
Pollutant				
NOx	100	37.08	138	29.9
SOx	0.6	0.6	0.6	0.6
PM ²	7.6	7.6	14.2	4.9
PM-10 ²	7.6	7.6	14.2	4.9
PM-2.5 ²	7.6	7.6	14.2	4.9
CO	84	37.08	38.2	38.1
VOC	5.5	5.5	5.98	25.8
Formaldehyde ⁵	0.075	0.075	0.075	0.075
Hexane ⁵	1.8	1.8	1.8	1.8

References for Emission Factors

- (1) AP-42, 7/98, Section 1.4, Natural Gas Combustion, Small Boilers.
- (2) Emission factors for natural gas of PM-10 and PM-2.5 are roughly equal to those of PM, Natural Gas Combustion, Table 1.4-2.
- (3) AP-42, 7/98, Section 1.4, Natural Gas Combustion, Small Boilers for SOx. Stack test on 3/00 for NOx. Otherwise, Emission factors from Sellers Engineering Co.
- (4) AP-42, 7/98, Section 1.4, Natural Gas Combustion, Small Boilers; Emission factors for NOx and CO from Sellers Engineering Co (low-NOx boilers).
- (5) All HAP emission factors from AP-42 7/98, Section 1.4, Natural Gas Combustion, Tables 1.4-3, 1.4-4.

2017 Natural Gas Use

Permit Designation	TA-16-1484 BS-1	TA-16-1484 BS-2	TA-53-365 BHW-1	TA-53-365 BHW-2	TA-55-6 BHW-1	TA-55-6 BHW-2	B-1 CMRR	B-2 CMRR	B-3 CMRR
NG Use (MMscf/yr)	8.481	8.481	9.502	9.502	17.313	4.813	0.767	0.767	0.767

2017 Emission Inventory | AI856 LANL - Boilers Emissions Calculations

Year 2017
Type Boilers except those at the power plant

Equation for Emissions Calculation

Annual Emissions (ton/year) = Emission Factor (lb/MMscf) X Annual natural gas consumption (MMscf/year) / 2000 (lb/ton)

2017 Boiler Emissions for Annual EI Reporting (tons/year)

NMED Unit ID	134	53	11	12	29	30	90	104	105
Pollutant	TA-16-1484-BS-1	TA-16-1484-BS-2	TA-53-365-BHW-1	TA-53-365-BHW-2	TA-55-6-BHW-1	TA-55-6-BHW-2	RLUOB-BHW-1	RLUOB-BHW-2	RLUOB-BHW-3
NOx	0.157	0.157	0.475	0.475	1.195	0.332	0.011	0.011	0.011
SOx	0.0025	0.0025	0.0029	0.0029	0.0052	0.0014	0.0002	0.0002	0.0002
PM	0.032	0.032	0.036	0.036	0.123	0.034	0.002	0.002	0.002
PM-10	0.032	0.032	0.036	0.036	0.123	0.034	0.002	0.002	0.002
PM-2.5	0.032	0.032	0.036	0.036	0.123	0.034	0.002	0.002	0.002
CO	0.157	0.157	0.399	0.399	0.331	0.092	0.015	0.015	0.015
VOC	0.023	0.023	0.026	0.026	0.052	0.014	0.010	0.010	0.010
Formaldehyde	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000
Hexane	0.008	0.008	0.009	0.009	0.016	0.004	0.001	0.001	0.001

2017 Emission Inventory | AI856 LANL - Degreaser

Year 2017
 Type Parts Washer
 NMED ID EQPT-21
 Title V Designation TA-55-DG-1
 Description Degreaser - Ultrasonic Cold batch TA-55-4

Solvent Trichloroethylene

Degreaser Emissions January-June 2017 (lbs)	
Jan-17	0.00
Feb-17	0.00
Mar-17	3.16
Apr-17	0.00
May-17	0.00
Jun-17	0.00
Total lbs:	3.16
Total tons:	0.00158

Degreaser Emissions July-December 2017 (lbs)	
Jul-17	0.00
Aug-17	0.00
Sep-17	0.00
Oct-17	0.00
Nov-17	0.00
Dec-17	0.00
Total lbs:	0
Total tons:	0

Total lbs 2017:	3.16
Total tons 2017:	0.00158

2017 Emission Inventory | A1856 LANL - Internal Combustion Engine

Year 2017
 Type Internal Combustion Engine
 NMED ID EQPT-119, EQPT-120, EQPT-128, EQPT-135, EQPT-143, EQPT-146, EQPT-147, EQPT-153, EQPT-154, EQPT-155, EQPT-156
 Title V Designation Four TA-33-Generators; Three RLUOB Generators; Three TA-55 Generators; One TA-48 Generator
 Description Multiple genertors located at TA-33; 3 generators located at TA-55 CMRR; 3 generators TA-55, and 1 at TA-48

EMISSION FACTORS (EF)	NO _x lb/kw-hr	CO lb/kw-hr	SO _x lb/kw-hr	PM lb/kw-hr	PM ₁₀ lb/kw-hr	VOC lb/kw-hr	EF References
TA-33-G-1P	2.01E-02	2.01E-03	5.36E-04	6.17E-04	6.17E-04	1.48E-03	(a)
TA-33-G-2	4.17E-02	1.21E-02	2.87E-03	2.87E-03	2.87E-03	3.31E-03	(b)
TA-33-G-3	4.17E-02	1.21E-02	2.87E-03	2.87E-03	2.87E-03	3.31E-03	(b)
TA-33-G-4	4.17E-02	2.51E-02	2.87E-03	2.87E-03	2.87E-03	3.31E-03	(b)
RLUOB-GEN-1	2.03E-02	2.51E-02	5.29E-04	1.19E-03	9.92E-04	2.87E-03	(c)
RLUOB-GEN-2	2.03E-02	2.51E-02	5.29E-04	1.19E-03	9.92E-04	2.87E-03	(c)
RLUOB-GEN-3	2.03E-02	2.51E-02	5.29E-04	1.19E-03	9.92E-04	2.87E-03	(c)
TA-48-GEN-1	8.82E-03	7.72E-03	6.61E-06	4.41E-04	3.00E-03	8.82E-03	(d)
TA-55-GEN-1	4.20E-02	9.00E-03	3.00E-03	3.00E-03	3.00E-03	3.00E-03	(e)
TA-55-GEN-2	4.20E-02	9.00E-03	3.00E-03	3.00E-03	3.00E-03	3.00E-03	(e)
TA-55-GEN-3	3.20E-02	7.00E-03	5.40E-04	1.00E-03	1.00E-03	1.00E-03	(e)

References:

447 kw is the size limit for determining large vs. small diesel fired generator. This information was taken from the operating permit application.
(a) TA-33-G-1P NO _x , CO, PM, VOC emission rates are from manufacturer's data; the values were given in gm/HP-hr; The following conversion factors were used to obtain lb/kW-hr; 453.6 g/lb and 1.341 hp-hr/kWh to convert emission factor units to lb/kWh; total HC was used as VOC; actual VOC would be much lower; SO ₂ from Table 3.4-1 AP-42 based on 0.05% S in fuel
(b) TA-33 G2, G3, G4 CO emission rate are from EPA Tier 1 nonroad standards; all others from AP-42, Section 3.3 (see TV permit renewal app calcs from 2013)
(c) RLUOB-GEN-1, GEN-2, GEN-3 emission rates for NO _x , CO, PM and VOC from applicable Tier 1 standards (see TV renewal app 2013); Emission factors for SO _x and PM ₁₀ from AP-42
(d) TA-48 NO _x , CO, VOC and PM factors from Tier 3 engine standards (see TV renewal app); EF for SO _x , PM ₁₀ and HAPs from AP-42.
(e) Emission factors for generators at TA-55 are from AP-42. Emission factors for small diesel fired engines were taken from AP-42 (fifth edition) Tables 3.3-1 and 3.3-2. Large generators emission factors were taken from AP-42 (fifth edition) Tables 3.4-1, 3.4-2, 3.4-3, and 3.4-4.

2017 Emission Inventory | A1856 LANL - Internal Combustion Engine

Year 2017
Type Internal Combustion Engine

Equation for Calculations

Emission Rate in tons/year = EF (lb/kW-hour) X Equip. Rating (kW-hr) X Number of hours (hour/year)/2000 (lb/ton)

Permit ID	NMED ID	kW rating	No of hours per year	NOx ton/yr	CO ton/yr	SOx ton/yr	PM ton/yr	PM ₁₀ ton/yr	VOC ton/yr
TA-33-G-1P	EQPT-146	1000	0.4	0.004	0.000	0.000	0.000	0.000	0.000
TA-33-G-2	EQPT-119	20	2.3	0.001	0.000	0.000	0.000	0.000	0.000
TA-33-G-3	EQPT-120	20	1.2	0.001	0.000	0.000	0.000	0.000	0.000
TA-33-G-4	EQPT-135	225	0.0	0.000	0.000	0.000	0.000	0.000	0.000
RLUOB-Gen-1	EQPT-128	1656.1	5.9	0.099	0.123	0.003	0.006	0.005	0.014
RLUOB-Gen-2	EQPT-153	1656.1	7.7	0.129	0.160	0.003	0.008	0.006	0.018
RLUOB-Gen-3	EQPT-154	1656.1	4.1	0.069	0.085	0.002	0.004	0.003	0.010
TA-48-Gen-1	EQPT-147	186	0.0	0.000	0.000	0.000	0.000	0.000	0.000
TA-55-Gen-1	EQPT-156	40.2	1.2	0.001	0.000	0.000	0.000	0.000	0.000
TA-55-Gen-2	EQPT-155	40.2	0.0	0.000	0.000	0.000	0.000	0.000	0.000
TA-55-Gen-3	EQPT-143	900	12.1	0.174	0.038	0.003	0.005	0.005	0.005
Total Emission (ton/year)				0.478	0.369	0.008	0.018	0.015	0.042

2017 Emission Inventory | AI856 LANL - Data Disintegrator

Year 2017
 Type Shredder
 NMED ID 89
 Title V Designation TA-52-11
 Description Data Disintegrator/Industrial Shredder

Total Boxes Shredded ^(c)	10,067
-------------------------------------	--------

Emission Calculations

	Percent Material in Exhaust ^(b)	% in Exhaust ^(e)	Control ^(d) Efficiency (Cyclone)	Control ^(d) Efficiency (Baghouse)
PM 2.5	15%	15%	0%	95.0%
PM 10	15%	90%	75%	95.0%
TSP	15%	100%	75%	95.0%

Average Box Weight ^(a)
45 Pounds

TA-52-11	Amount Processed (pounds)	PM-2.5 Emissions (pounds)	PM-2.5 Emissions (tons)	PM-10 Emissions (pounds)	PM-10 Emissions (tons)	TSP Emissions (pounds)	TSP Emissions (tons)
CY Annual Total	453,015	509.6	0.25	764.5	0.38	849.4	0.42

Reference				
(a). Estimated maximum box weight is 45 pounds. Information provided by shredding operations. Full box weight of tightly packed paper.	(b). Emission Factor (percentage of material shredded that will enter into the exhaust) obtained from the manufacturer of the air handling system, AGET Manufacturing Co. 15% is also listed in the construction permit application.	(c). Information provided by the shredding operations personnel.	(d). Information on control equipment efficiencies was provided by the manufacturer (SEM) of the Data Disintegrator. Those values not given were extrapolated using manufacturer data. Efficiencies of 75% for the Cyclone and 95% for the bag house are listed in the construction permit application. (see cyclone efficiency tab for more info.)	(e). Manufacturer provided info that the dust into the exhaust would be in the size range of 5-20 um. Conservative assumption that 15% is PM2.5, and 90% is PM10.

Maximum Annual emission rate is 9.9 tpy or 2.3 lb/hr of Total Suspended Particulate (TSP) per year.
9.9 tpy or 2.3 lb/hr of Particulate Matter <10µm (PM-10) per year.

2017 Emission Inventory | AI856 LANL - Power Plant Boilers

Year 2017
 Type Boilers - Power Plant
 NMED ID EQPT-24; EQPT-25; EQPT-26 (pph, Natural Gas); EQPT-137, EQPT-138, EQPT-141 (pph; No. 2 fuel oil)
 Designation TA-3-22-1; TA3-22-2; TA-3-22-3
 Description Power Plant Boiler (pph, Natural Gas)
 Power Plant Boiler (pph, No. 2 fuel oil)

Pollutant	Emission Factor (EF)	
	Natural ^(a) Gas (lb/MMscf)	Fuel Oil ^(f) lbs/ 1000 gal
NOx^(c)	58	8.64
SOx^(g)	0.6	7.4
PM^(d)	7.6	3.3
PM-10^(d)	7.6	2.3
PM-2.5^(d)	7.6	1.55
CO^(e)	40	5.0
VOC	5.5	0.2
Formaldehyde	0.075	0.048
Hexane	1.8	-

Reference
(a) AP-42, 7/98, Section. 1.4, <i>Natural Gas Combustion</i> , Tables 1.4-1, 1.4-2
(b) Fuel usage obtained from utilities on a monthly basis
(c) Average of source tests conducted on all 3 boilers September 2002 burning natural gas after FGR installed. Assumed FGR resulted in similar Nox reduction for oil.
(d) All PM from natural gas is assumed <1μ, so PM-10, PM-2.5 and total PM have equal EFs, AP-42, Natural Gas Combustion, Table 1.4-2. The PM emission factor for fuel oil is the sum of filterable and condensable PM.
(e) AP-42, 1/95, Section. 1.4, Natural Gas Combustion, Table 1.4-2. Consistent with previous stack tests.
(f) AP-42, 9/98, Section. 1.3, <i>Fuel Oil Combustion</i> , Table 1.3-1 with Errata, Table 1.3-3, and Table 1.3-6.
(g) Boilers>100 MMBtu/hr: SOx Emission Factor (SO ₂ {142S} + SO ₃ {5.7S}) = 147.7 * S (from AP-42, Table 1.3-1 w/Errata) (S = weight % sulfur in oil)(Sulfur content per analysis on oil in tanks in August 01', no new oil delivered in 02'/03')

Permit Designation	Boiler TA-3-22-1		Boiler TA-3-22-2		Boiler TA-3-22-3	
Boiler ID	EQPT-24	EQPT-141	EQPT-25	EQPT-137	EQPT-26	EQPT-138
Type of fuel	Natural Gas	#2 Fuel oil	Natural Gas	#2 Fuel oil	Natural Gas	#2 Fuel oil
Units	mscf	gallons	mscf	gallons	mscf	gallons
Annual Use	53,129	0	184,560	0	101,089	1,469

Equation for Emissions Calculations

Annual Emissions for NG Use (ton/year) = NG Use (MSCF/year) / 1 MMscf/1000 Mscf X EF (lb/MMscf) X 1 (ton)/2000 (lb)

Pollutant	Boiler TA-3-22-1		Boiler TA-3-22-2		Boiler TA-3-22-3	
	EQPT-24	EQPT-141	EQPT-25	EQPT-137	EQPT-26	EQPT-138
	Annual Emissions (NG) (tons)	Annual Emissions Fuel Oil (tons)	Annual Emissions (NG) (tons)	Annual Emissions Fuel Oil (tons)	Annual Emissions (NG) (tons)	Annual Emissions Fuel Oil (tons)
NO _x ^(c)	1.541	0.000	5.352	0.000	2.932	0.006
SO _x ^(g)	0.016	0.000	0.055	0.000	0.030	0.005
PM ^(d)	0.202	0.000	0.701	0.000	0.384	0.002
PM-10 ^(d)	0.202	0.000	0.701	0.000	0.384	0.002
PM-2.5 ^(d)	0.202	0.000	0.701	0.000	0.384	0.001
CO ^(e)	1.063	0.000	3.691	0.000	2.022	0.004
VOC	0.146	0.000	0.508	0.000	0.278	0.000
Formaldehyde	0.002	0.000	0.007	0.000	0.004	0.000
Hexane	0.048	0.000	0.166	0.000	0.091	0.000

2017 Emission Inventory | AI856 LANL - Power Plant Combustion Turbine

Year 2017
 Type Turbine
 NMED ID EQPT-112
 Title V Designation TA-3-22-CT-1
 Description Combustion Turbine
 Annual Gas Use 51.2 MMscf

Equation for Emission Calculation = Annual Gas Use (MMscf) X EF (lb/MMscf) X 1 ton/2000 lb

Pollutant Criteria	Emission Factors (lb/MMscf)	Annual Emissions (Tons) TA-3-2422 Combustion Turbine	Calculation Basis
NOx	50.5	1.293	a
SOx	3.5	0.090	b
PM	6.8	0.174	c
PM ₁₀	6.8	0.174	c
PM _{2.5}	6.8	0.174	c
CO	10.5	0.269	a
VOC	2.2	0.056	d
Acetaldehyde	4.12E-02	0.001	e, f, g
Copper	7.11E-02	0.002	f, h
Ethylbenzene	3.30E-02	0.001	e, f, g
Formaldehyde	7.31E-01	0.019	e, f, g
Manganese	8.24E-02	0.002	f, h
Nickel	1.18E-01	0.003	f, h
Propylene Oxide	2.99E-02	0.001	e, f, g
Toluene	1.34E-01	0.003	e, f, g
Xylenes (isomers)	6.59E-02	0.002	e, f, g

References:
(a) Values are from the initial compliance test (TRC - October 22, 2007). Test shows average NOx as 11.29 lbs/hr and CO as 2.35 lbs/hr. These were divided by the gas flow rate of 0.223620 MMscf/hr to get 50.48 lb/MMscf (rounded to 50.5) for NOx and 10.5 lb/MMscf for CO. The SCFH value (fuel flow rate) from the compliance test report (223620 SCFH or 223.6 MSCFH)
(b) The SOx emission factor was taken from AP-42 Table 3.1-2a. The default value is used when percent sulfur is unknown (0.0034 lb/mmbtu). This is equivalent to converting the 2 grains per 100 scf to percent. The 0.0034 lb/mmbtu was converted to lb/mmcsf by multiplying by 1030 btu/scf (the heat value of natural gas), to provide 3.5 lb/mmcsf.
(c) PM was calculated by taking the AP-42, Table 3.1-2a, EF of 6.6E-3 lb/MMBtu and multiplying it by 1030 BTU/scf to get 6.8 lb/MMscf. PM10 was calculated the same as PM, as most PM from natural gas combustion is less than 1 micrometer.
(d) The VOC emission factor was taken from AP-42 Table 3.1-2a. The factor, 2.1 E-03 lb/mmbtu, was converted to lb/mmcsf by multiplying by 1030 giving 2.2 lbs/mmcsf.
(e) These chemicals are HAPs
(f) These chemicals are EPCRA 313 listed chemicals.
(g) Emission factor from AP-42, table 3.1-3 (lb/mmbtu). This was multiplied by 1030 Btu/scf to provide the lb./mmcsf factor.
(h) Emission factors from EPA FIRE database (SCC: 20300202 & 20200201). These values were also converted from lb/mmbtu to lb/mmcsf. Retrieved 4-14-08.

2017 Emission Inventory | AI856 LANL - Evaporative Sprayers

Year 2017
 Type Fugitives
 NMED ID RPNT-35, RPNT-36, RPNT-37
 Title V Designation TA-60-EVAP-1, TA-60-EVAP-2, TA-60-EVAP-3
 Description Water Spray Evaporators

Emission Factors

HAP	PPM ¹	Weight Fraction
Total PCB	3.94E-07	3.94E-13
Chloroform	0.00181	1.81E-09
Chloromethane	0.00124	1.24E-09
Bromoform	0.0016	1.60E-09
Cyanide (Total)	0.00368	3.68E-09
Manganese	0.0133	1.33E-08
Antimony	0.00629	6.29E-09

References for Emission Factors
¹ Values from pond sampling laboratory results for GC Semivolatile Herbicide, GC Semivolatile Pesticide, GC/MS Semivolatile, GC/MS Volatile, General Chemistry, Metals and Radiochemistry, GEL Laboratories, December 9, 2015.
² Water Density = 8.34 lb/gallon
³ Max Pump Rate Per Sprayer = 7.51 gallons/minute
⁴ Evaporation Rate = 42.5 Percent

2017 Hours of Operation

Permit Designation	TA-60-EVAP-1	TA-60-EVAP-2	TA-60-EVAP-3
Hours	5,810	4,016	3,690

Equation for Emissions Calculation

Annual Emissions (ton/year) = $\frac{\text{Water Density (lb/gal)} \times \text{Max Pump Rate (g/min)} \times (60 \text{ min/hr}) \times \text{Hours of Operation (hr)} \times \text{Evaporation Rate}}{100 \times \text{Weight Fraction} / 2000 \text{ (lb/ton)}}$

2017 Evaporative Sprayers Emissions for Annual EI Reporting (tons/year)

Polutant	RPNT-35 TA-60-EVAP-1	RPNT-36 TA-60-EVAP-2	RPNT-37 TA-60-EVAP-3
Total PCB	1.83E-09	1.26E-09	1.16E-09
Chloroform	8.40E-06	5.80E-06	5.33E-06
Chloromethane	5.75E-06	3.98E-06	3.65E-06
Bromoform	7.42E-06	5.13E-06	4.71E-06
Cyanide (Total)	1.71E-05	1.18E-05	1.08E-05
Manganese	6.17E-05	4.27E-05	3.92E-05
Antimony	2.92E-05	2.02E-05	1.85E-05
Total HAPs	1.30E-04	8.95E-05	8.23E-05

ATTACHMENT B:

2017 Annual Emissions Inventory Submittal to NMED



memorandum

*Environmental Protection & Compliance Division
Los Alamos National Laboratory*

To/MS: 2017 Emissions Inventory File
Thru/MS: Steve Story, EPC-CP, MS J978 *SS*
From/MS: Walt Whetham, EPC-CP, MS J978 *WW*
Phone: 505-665-8885
Symbol: EPC-DO: 18-126
Date: **MAR 27 2018**

Subject: 2017 Emissions Inventory Electronic Submittal

Los Alamos National Laboratory (LANL) submitted their 2017 Emissions Inventory Report to New Mexico Environmental Department (NMED) via online reporting tool, AEIR. This report is required by Title 20, Chapter 2, Part 73 of the New Mexico Administrative Code (20.2.73 NMAC), Notice of Intent and Emissions Inventory Requirements. The report was submitted on March 27, 2018, and meets New Mexico Environmental Department's deadline of April 1st.

Should you have any questions or comments regarding the information provided in this report, please contact Steve Story at (505) 665-2169 or story@lanl.gov.

SLS/WW: am

Copy: Adrienne L. Nash, LASO-NS-LP, (E-File)
Hai Shen, EM-SG, (E-File)
Annette E. Russell, EM-LA, (E-File)
Cindy Byerly, EM-LA, (E-File)
Richard M. Kacich, DIR, (E-File)
Craig S. Leasure, PADOPS, (E-File)
William R. Mairson, ADESH (E-File)
John Bretzke, ADESH, (E-File)
Ben Roberts, EPC-DO, (E-File)
Taunia Van Valkenburg, EPC-CP, (E-File)
Saundra Martinez, ADEM-PO, (E-File)
Steven L. Story, EPC-CP, (E-File)
Walter W. Whetham, EPC-CP, (E-File)
Ellena I. Martinez, EPC-CP, (E-File)
Timothy A. Dolan, LC-ESH, (E-File)
locatesteam@lanl.gov, (E-File)
adesh@lanl.gov, (E-File)
epc-correspondence@lanl.gov, (E-File)
EPC-CP Emissions Inventory File, J978

Enclosure 1

2017 Emissions Inventory Report

EPC-DO: 18-126

Electronic Submittal

Date: MAR 27 2018



Subject Item List

[Home](#) [Admin Tools](#) [About AEIR](#)
[Logout](#)

Facility Annual Emissions - Subject Item List

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item/Equipment (51 Subject Items)

Type	ID	Designation	Description	Status	Complete
<input checked="" type="radio"/> Federal Agency	AI -856	2195R71	Los Alamos National Security, LLC	Active 06/12/17	
<input checked="" type="radio"/> Asphalt Drum/Burner	EQPT-116	TA-60-BDM	Asphalt Plant Dryer - Natural Gas	Active 07/19/05	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Beryllium Work	ACT -2	TA-35-213	Beryllium Activity-Be Target Fabrication Facility - Machining TA-35-213	Active 05/10/00	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Beryllium Work	ACT -3	TA-3-141	Beryllium Activity-Be Test Facility - Machining TA-3-141	Active 05/10/00	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Beryllium Work	ACT -6	TA-55-PF4 (a)	Beryllium Activity-Plutonium Facility Beryllium machining, weld cutting / dressing and metallography	Active 04/14/06	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Beryllium Work	ACT -41	TA-3-66	Beryllium Activity-Sigma Facility-electroplating/metallography	Active 05/24/10	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Boiler	EQPT-11	TA-53-365-BHW-1	Boiler TA-53-365-BHW-1	Active 05/31/01	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Boiler	EQPT-12	TA-53-365-BHW-2	Boiler TA-53-365-BHW-2	Active 05/31/01	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Boiler	EQPT-24	TA-3-22-1 (gas)	Power Plant Boiler (pph, Natural Gas)	Active 03/05/09	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Boiler	EQPT-25	TA-3-22-2 (gas)	Power Plant Boiler (pph, Natural Gas)	Active 03/05/09	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Boiler	EQPT-26	TA-3-22-3 (gas)	Power Plant Boiler (pph, Natural Gas)	Active 03/05/09	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Boiler	EQPT-29	TA-55-6-BHW-1	Sellers Boiler TA-55-6-BHW-1	Active 12/17/01	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Boiler	EQPT-30	TA-55-6-BHW-2	Sellers Boiler TA-55-6-BHW-2	Active 12/17/01	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Boiler	EQPT-53	TA-16-1484-BS-2	Low NOx Boiler TA-16-1484-BS-2	Active 11/27/96	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Boiler	EQPT-90	RLUOB-BHW-1 (gas)	Boiler-CMRR-BHW-1	Active 03/01/05	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Boiler	EQPT-104	RLUOB-BHW-2 (gas)	Boiler-CMRR-BHW-2	Active 03/01/05	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Boiler	EQPT-105	RLUOB-BHW-3 (gas)	Boiler-CMRR-BHW-3	Active 03/01/05	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Boiler	EQPT-106	RLUOB-BHW-4 (gas)	Boiler-CMRR-BHW-4	Active 03/01/05	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Boiler	EQPT-107	B-5	Boiler-CMRR	Active 03/01/05	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Boiler	EQPT-134	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Active 11/27/96	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Boiler	EQPT-137	TA-3-22-2	Power Plant Boiler (pph, No. 2 fuel oil)	Active 03/05/09	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Boiler	EQPT-138	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Active 03/05/09	<input checked="" type="checkbox"/>
<input checked="" type="radio"/> Boiler	EQPT-141	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Active 03/05/09	<input checked="" type="checkbox"/>

<input type="radio"/>	Boiler	EQPT-144	Boiler combined emissions	TA-16-1484-Bs-1,2; TA -53-365-BHW-1,2; TA-55-6-BHW-1,2; RLUOB-BHW-1,2,3,4	Active 03/05/09	<input checked="" type="checkbox"/>
<input type="radio"/>	Boiler	EQPT-149	RLUOB-BHW-1 (oil)	Boiler-CMRR-BHW-1	Active 03/01/05	<input checked="" type="checkbox"/>
<input type="radio"/>	Boiler	EQPT-150	RLUOB-BHW-2 (oil)	Boiler-CMRR-BHW-2	Active 03/01/05	<input checked="" type="checkbox"/>
<input type="radio"/>	Boiler	EQPT-151	RLUOB-BHW-3 (oil)	Boiler-CMRR-BHW-3	Active 03/01/05	<input checked="" type="checkbox"/>
<input type="radio"/>	Boiler	EQPT-152	RLUOB-BHW-4 (oil)	Boiler-CMRR-BHW-4	Active 03/01/05	<input checked="" type="checkbox"/>
<input type="radio"/>	Fugitives	RPNT-34	Facilitywide Open Burning	Fugitives - Open Burning	Active 02/27/15	<input checked="" type="checkbox"/>
<input type="radio"/>	Fugitives	RPNT-35	TA-60-EVAP-1	Evaporative Sprayer for basin water	Active 02/03/17	<input checked="" type="checkbox"/>
<input type="radio"/>	Fugitives	RPNT-36	TA-60-EVAP-2	Evaporative Sprayer for basin water	Active 02/03/17	<input checked="" type="checkbox"/>
<input type="radio"/>	Fugitives	RPNT-37	TA-60-EVAP-3	Evaporative Sprayer for basin water	Active 02/03/17	<input checked="" type="checkbox"/>
<input type="radio"/>	Fugitives	RPNT-38	TA-60-EVAP-4	Evaporative Sprayer for basin water	Active 02/03/17	<input checked="" type="checkbox"/>
<input type="radio"/>	Fugitives	RPNT-39	TA-60-EVAP-5	Evaporative Sprayer for basin water	Active 02/03/17	<input checked="" type="checkbox"/>
<input type="radio"/>	Internal combustion engine	EQPT-96	Standby-Generators	Diesel Generators	Active 03/01/05	<input checked="" type="checkbox"/>
<input type="radio"/>	Internal combustion engine	EQPT-119	TA-33-G-2	Kohler Diesel Generator TA-33, TA-36, TA-39	Active 04/22/08	<input checked="" type="checkbox"/>
<input type="radio"/>	Internal combustion engine	EQPT-120	TA-33-G-3	Kohler Diesel Generator TA-33, TA-36, TA-39	Active 09/18/06	<input checked="" type="checkbox"/>
<input type="radio"/>	Internal combustion engine	EQPT-128	RLUOB-GEN 1	Cummins Diesel Powered Generator and Engine - CMRR	Active 12/11/07	<input checked="" type="checkbox"/>
<input type="radio"/>	Internal combustion engine	EQPT-135	TA-33-G-4	Caterpillar Diesel Generator TA-33, TA-36, TA-39	Active 04/22/08	<input checked="" type="checkbox"/>
<input type="radio"/>	Internal combustion engine	EQPT-143	TA-55-GEN-3	CI-RICE Stationary Generator - Caterpillar 1335 hp	Active 11/30/10	<input checked="" type="checkbox"/>
<input type="radio"/>	Internal combustion engine	EQPT-146	TA-33-G-1P	Cummins Portable Diesel Generator	Active 12/12/13	<input checked="" type="checkbox"/>
<input type="radio"/>	Internal combustion engine	EQPT-147	TA-48-GEN-1	Cummins Diesel Powered Generator and Engine	Active 02/27/15	<input checked="" type="checkbox"/>
<input type="radio"/>	Internal combustion engine	EQPT-153	RLUOB-GEN 2	Cummins Diesel Powered Generator and Engine - CMRR	Active 12/11/07	<input checked="" type="checkbox"/>
<input type="radio"/>	Internal combustion engine	EQPT-154	RLUOB-GEN 3	Cummins Diesel Powered Generator and Engine - CMRR	Active 12/11/07	<input checked="" type="checkbox"/>
<input type="radio"/>	Internal combustion engine	EQPT-155	TA-55-GEN-2	CI-RICE Stationary Generator - Whisper Watt 40.2 hp	Active 02/27/15	<input checked="" type="checkbox"/>
<input type="radio"/>	Internal combustion engine	EQPT-156	TA-55-GEN-1	CI-RICE Stationary Generator - Whisper Watt 40.2 hp	Active 02/27/15	<input checked="" type="checkbox"/>
<input type="radio"/>	Parts Washer	EQPT-21	TA-55-DG-1	Degreaser - Ultrasonic Cold Batch TA-55-4	Active 05/31/01	<input checked="" type="checkbox"/>
<input type="radio"/>	Research/Testing	ACT -7	LANL-FW-CHEM	R & D Activities - Labwide (031)	Active 05/31/01	<input checked="" type="checkbox"/>
<input type="radio"/>	Research/Testing	ACT -42	RLUOB-CHEM	Chemical Usage, Bldg. TA-55-400 (lab portion of RLUOB Bldg.)	Active 05/31/01	<input checked="" type="checkbox"/>
<input type="radio"/>	Shredder	EQPT-89	TA-52-11	Data Disintegrator/Industrial Shredder	Active 10/22/03	<input checked="" type="checkbox"/>
<input type="radio"/>	Turbine	EQPT-112	TA-3-22-CT-1	Combustion Turbine	Active 07/29/06	<input checked="" type="checkbox"/>

Add an unpermitted source for EPA GHG calculations

Detail	Emissions	Print	Export	Total Emissions	Review for Submittal
--------	-----------	-------	--------	-----------------	----------------------

Submittal Comments

2000 character maximum

Save Comments

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-116

Designation: TA-60-BDM

Description: Asphalt Plant Dryer - Natural Gas

Type: Asphalt Drum/Burner

SCC: Industrial Processes, Mineral Products, Asphalt Concrete, Drum Mix Plant: Rotary Drum Dryer / Mixer, Natural Gas - Fired

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Asphalt (INPUT)	
Materials Consumed:	2.27	MM SCF
Fuel Heating Value:	1020.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	8
Operating Time in Days per Week:	5
Operating Time in Weeks per Year:	26
Operating Time in Hours per Year:	67
Percent of Operation During Winter:	10
Percent of Operation During Spring:	30
Percent of Operation During Summer:	30
Percent of Operation During Fall:	30

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.155	tons/y	EPA emission factors (e.g., AP-42)
Ethylbenzene:	0.001	tons/y	EPA emission factors (e.g., AP-42)
Lead:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.004	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.002	tons/y	Manufacturer Specification
Particulate Matter (2.5 microns or less):	0.002	tons/y	Manufacturer Specification

Particulate Matter (total suspended):	0.003	tons/y	Manufacturer Specification
Sulfur Dioxide:	0.002	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.003	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: ACT -2

Designation: TA-35-213

Beryllium Activity-Be Target

Description: Fabrication Facility - Machining
TA-35-213

Type: Beryllium Work

SCC: Industrial Processes, Fabricated
Metal Products, Machining
Operations, Specify Material**

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Input Materials Processed: Metal (INPUT)

Operating Detail

	Value
Operating Time in Hours per Day:	5
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	1820
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Beryllium:	0.0	tons/y	Estimate
Particulate Matter (total suspended):	0.0	tons/y	Estimate

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: ACT -3

Designation: TA-3-141

Description: Beryllium Activity-Be Test
Facility - Machining TA-3-141

Type: Beryllium Work

SCC: Industrial Processes, Fabricated
Metal Products, Machining
Operations, Specify Material**

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Input Materials Processed: Metal (INPUT)

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Beryllium:	0.0	tons/y	Field measurement
Particulate Matter (total suspended):	0.0	tons/y	Field measurement

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: ACT -6

Designation: TA-55-PF4 (a)

Description: Beryllium Activity-Plutonium
Facility Beryllium machining,
weld cutting / dressing and
metallography

Type: Beryllium Work

SCC: Industrial Processes, Fabricated
Metal Products, Machining
Operations, Specify Material**

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Input Materials Processed: Metal (INPUT)

Operating Detail

	Value
Operating Time in Hours per Day:	5
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	1820
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Beryllium:	0.0	tons/y	Estimate

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: ACT -41
Designation: TA-3-66
Beryllium Activity-Sigma
Description: Facility-
electroplating/metallography
Type: Beryllium Work
SCC: Industrial Processes, Fabricated
Metal Products, Abrasive
Cleaning of Metal Parts,
Polishing
GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Input Materials Processed: Metal (INPUT)

Operating Detail

	Value
Operating Time in Hours per Day:	8
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Beryllium:	0.0	tons/y	Estimate

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-11

Designation: TA-53-365-BHW-1

Description: Boiler TA-53-365-BHW-1

Type: Boiler

SCC: External Combustion Boilers,
Electric Generation, Natural Gas,
Boilers < 100 Million Btu/hr
except Tangential

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	9.502	MM SCF
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	15
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	33
Operating Time in Hours per Year:	3465
Percent of Operation During Winter:	40
Percent of Operation During Spring:	20
Percent of Operation During Summer:	0
Percent of Operation During Fall:	40

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.399	tons/y	EPA emission factors (e.g., AP-42)
Formaldehyde:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.009	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.475	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.036	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.036	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.036	tons/y	EPA emission factors (e.g., AP-42)

Sulfur Dioxide:	0.003	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.026	tons/y	EPA emission factors (e.g., AP-42)
<i>Subject Item Comments</i>			

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-12

Designation: TA-53-365-BHW-2

Description: Boiler TA-53-365-BHW-2

Type: Boiler

SCC: External Combustion Boilers,
Electric Generation, Natural Gas,
Boilers < 100 Million Btu/hr
except Tangential

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	9.502	MM SCF
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	15
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	33
Operating Time in Hours per Year:	3465
Percent of Operation During Winter:	40
Percent of Operation During Spring:	20
Percent of Operation During Summer:	0
Percent of Operation During Fall:	40

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.399	tons/y	EPA emission factors (e.g., AP-42)
Formaldehyde:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.009	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.475	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.036	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.036	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.036	tons/y	EPA emission factors (e.g., AP-42)

Sulfur Dioxide:	0.003	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.026	tons/y	EPA emission factors (e.g., AP-42)
<i>Subject Item Comments</i>			

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-24

Designation: TA-3-22-1 (gas)

Description: Power Plant Boiler (pph, Natural Gas)

Type: Boiler

SCC: External Combustion Boilers, Electric Generation, Natural Gas, Boilers > 100 Million Btu/hr except Tangential

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	53.129	MM SCF
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	1.063	tons/y	EPA emission factors (e.g., AP-42)
Formaldehyde:	0.002	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.048	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	1.541	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.202	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.202	tons/y	EPA emission factors (e.g., AP-42)

Particulate Matter (total suspended):	0.202	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.016	tons/y	EPA emission factors (e.g., AP-42)
Toluene; (Methyl benzene):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.146	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856**Facility Name:** Los Alamos National Security, LLC**Organization Name:** U.S. Department of Energy National Nuclear Security Administration**Submittal Status:** 2017 Submittal (In Process)**Subject Item ID:** EQPT-25**Designation:** TA-3-22-2 (gas)**Description:** Power Plant Boiler (pph, Natural Gas)**Type:** Boiler**SCC:** External Combustion Boilers,
Electric Generation, Natural Gas,
Boilers > 100 Million Btu/hr
except Tangential**GHG Reporting:** Reports GHG to EPA**Supplemental Parameters**

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	184.56	MM SCF
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	3.691	tons/y	EPA emission factors (e.g., AP-42)
Formaldehyde:	0.007	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.166	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	5.352	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.701	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.701	tons/y	EPA emission factors (e.g., AP-42)

Particulate Matter (total suspended):	0.701	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.055	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.508	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-26

Designation: TA-3-22-3 (gas)

Description: Power Plant Boiler (pph, Natural Gas)

Type: Boiler

SCC: External Combustion Boilers, Electric Generation, Natural Gas, Boilers > 100 Million Btu/hr except Tangential

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	101.089	MM SCF
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	2.022	tons/y	EPA emission factors (e.g., AP-42)
Formaldehyde:	0.004	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.091	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	2.932	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.384	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.384	tons/y	EPA emission factors (e.g., AP-42)

Particulate Matter (total suspended):	0.384	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.03	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.278	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856**Facility Name:** Los Alamos National Security, LLC**Organization Name:** U.S. Department of Energy National Nuclear Security Administration**Submittal Status:** 2017 Submittal (In Process)**Subject Item ID:** EQPT-29**Designation:** TA-55-6-BHW-1**Description:** Sellers Boiler TA-55-6-BHW-1**Type:** Boiler**SCC:** External Combustion Boilers,
Electric Generation, Natural Gas,
Boilers < 100 Million Btu/hr
except Tangential**GHG Reporting:** Reports GHG to EPA**Supplemental Parameters**

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	17.313	MM SCF
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent

Operating Detail

	Value
Operating Time in Hours per Day:	15
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	33
Operating Time in Hours per Year:	3465
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.331	tons/y	EPA emission factors (e.g., AP-42)
Formaldehyde:	0.001	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.016	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	1.195	tons/y	Actual stack test
Particulate Matter (10 microns or less):	0.123	tons/y	Manufacturer Specification
Particulate Matter (2.5 microns or less):	0.123	tons/y	Manufacturer Specification
Particulate Matter (total suspended):	0.123	tons/y	Manufacturer Specification
Sulfur Dioxide:	0.005	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.052	tons/y	Manufacturer Specification

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856**Facility Name:** Los Alamos National Security, LLC**Organization Name:** U.S. Department of Energy National Nuclear Security Administration**Submittal Status:** 2017 Submittal (In Process)**Subject Item ID:** EQPT-30**Designation:** TA-55-6-BHW-2**Description:** Sellers Boiler TA-55-6-BHW-2**Type:** Boiler**SCC:** External Combustion Boilers,
Electric Generation, Natural Gas,
Boilers < 100 Million Btu/hr
except Tangential**GHG Reporting:** Reports GHG to EPA**Supplemental Parameters**

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	4.813	MM SCF
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	15
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	33
Operating Time in Hours per Year:	3465
Percent of Operation During Winter:	40
Percent of Operation During Spring:	10
Percent of Operation During Summer:	10
Percent of Operation During Fall:	40

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.092	tons/y	EPA emission factors (e.g., AP-42)
Formaldehyde:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.004	tons/y	EPA emission factors (e.g., AP-42)
Lead:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.332	tons/y	Actual stack test
Particulate Matter (10 microns or less):	0.034	tons/y	Manufacturer Specification
Particulate Matter (2.5 microns or less):	0.034	tons/y	Manufacturer Specification
Particulate Matter (total suspended):	0.034	tons/y	Manufacturer Specification

Sulfur Dioxide:	0.001	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.014	tons/y	Manufacturer Specification

Subject Item Comments

Print	Close
-------	-------

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856**Facility Name:** Los Alamos National Security, LLC**Organization Name:** U.S. Department of Energy National Nuclear Security Administration**Submittal Status:** 2017 Submittal (In Process)**Subject Item ID:** EQPT-53**Designation:** TA-16-1484-BS-2**Description:** Low NOx Boiler
TA-16-1484-BS-2**Type:** Boiler**SCC:** External Combustion Boilers,
Commercial/Institutional,
Natural Gas, < 10 Million Btu/hr**GHG Reporting:** Reports GHG to EPA**Supplemental Parameters**

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	8.481	MM SCF
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Ash of Fuel:	0.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.157	tons/y	Design calculation
Hexane:	0.008	tons/y	Design calculation
Lead:	0.0	tons/y	Design calculation
Nitrogen Dioxide:	0.157	tons/y	Design calculation
Particulate Matter (10 microns or less):	0.032	tons/y	Design calculation
Particulate Matter (2.5 microns or less):	0.032	tons/y	Design calculation
Particulate Matter (total suspended):	0.032	tons/y	Design calculation
Sulfur Dioxide:	0.003	tons/y	Design calculation
Volatile Organic Compounds (VOC):	0.023	tons/y	Design calculation

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856**Facility Name:** Los Alamos National Security, LLC**Organization Name:** U.S. Department of Energy National Nuclear Security Administration**Submittal Status:** 2017 Submittal (In Process)**Subject Item ID:** EQPT-90**Designation:** RLUOB-BHW-1 (gas)**Description:** Boiler-CMRR-BHW-1**Type:** Boiler**SCC:** External Combustion Boilers,
Commercial/Institutional,
Natural Gas, < 10 Million Btu/hr**GHG Reporting:** Reports GHG to EPA**Supplemental Parameters**

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	0.767	MM SCF
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.015	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.001	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.011	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.002	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.002	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.002	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.01	tons/y	EPA emission factors (e.g., AP-42)

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-104

Designation: RLUOB-BHW-2 (gas)

Description: Boiler-CMRR-BHW-2

Type: Boiler

SCC: External Combustion Boilers,
Commercial/Institutional,
Natural Gas, < 10 Million Btu/hr

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	0.767	MM SCF
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.015	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.001	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.011	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.002	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.002	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.002	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.01	tons/y	EPA emission factors (e.g., AP-42)

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856**Facility Name:** Los Alamos National Security, LLC**Organization Name:** U.S. Department of Energy National Nuclear Security Administration**Submittal Status:** 2017 Submittal (In Process)**Subject Item ID:** EQPT-105**Designation:** RLUOB-BHW-3 (gas)**Description:** Boiler-CMRR-BHW-3**Type:** Boiler**SCC:** External Combustion Boilers,
Commercial/Institutional,
Natural Gas, < 10 Million Btu/hr**GHG Reporting:** Reports GHG to EPA**Supplemental Parameters**

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	0.767	MM SCF
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.015	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.001	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.011	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.002	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.002	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.002	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.01	tons/y	EPA emission factors (e.g., AP-42)

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-106

Designation: RLUOB-BHW-4 (gas)

Description: Boiler-CMRR-BHW-4

Type: Boiler

SCC: External Combustion Boilers,
Commercial/Institutional,
Natural Gas, < 10 Million Btu/hr

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	0.0	MM SCF
Fuel Heating Value:	0.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.0	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	0.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	0
Operating Time in Days per Week:	0
Operating Time in Weeks per Year:	0
Operating Time in Hours per Year:	0
Percent of Operation During Winter:	0
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

This unit has not been built.

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-107

Designation: B-5

Description: Boiler-CMRR

Type: Boiler

SCC: External Combustion Boilers,
Commercial/Institutional,
Natural Gas, < 10 Million Btu/hr

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	0.0	MM SCF
Fuel Heating Value:	0.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.0	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	0.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	0
Operating Time in Days per Week:	0
Operating Time in Weeks per Year:	0
Operating Time in Hours per Year:	0
Percent of Operation During Winter:	0
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

This unit has not been built.

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-134

Designation: TA-16-1484-BS-1

Description: Low NOx Boiler
TA-16-1484-BS-1

Type: Boiler

SCC: External Combustion Boilers,
Commercial/Institutional,
Natural Gas, < 10 Million Btu/hr

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	8.481	MM SCF
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.157	tons/y	Design calculation
Hexane:	0.008	tons/y	Design calculation
Lead:	0.0	tons/y	Design calculation
Nitrogen Dioxide:	0.157	tons/y	Design calculation
Particulate Matter (10 microns or less):	0.032	tons/y	Design calculation
Particulate Matter (2.5 microns or less):	0.032	tons/y	Design calculation
Particulate Matter (total suspended):	0.032	tons/y	Design calculation

Sulfur Dioxide:	0.003	tons/y	Design calculation
Volatile Organic Compounds (VOC):	0.023	tons/y	Design calculation

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-137

Designation: TA-3-22-2

Description: Power Plant Boiler (pph, No. 2 fuel oil)

Type: Boiler

SCC: External Combustion Boilers, Electric Generation, Distillate Oil, Grades 1 and 2 Oil

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Materials Consumed:	0.0	gal
Fuel Heating Value:	138.0	MM BTU/M gal
Percent Sulfur of Fuel:	0.05	percent

Operating Detail

	Value
Operating Time in Hours per Day:	0
Operating Time in Days per Week:	0
Operating Time in Weeks per Year:	0
Operating Time in Hours per Year:	0
Percent of Operation During Winter:	0
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Formaldehyde:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

This unit did not run on diesel in 2017.

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-138

Designation: TA-3-22-3

Description: Power Plant Boiler (pph, No. 2 fuel oil)

Type: Boiler

SCC: External Combustion Boilers, Electric Generation, Distillate Oil, Grades 1 and 2 Oil

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Materials Consumed:	1469.0	gal
Fuel Heating Value:	138.0	MM BTU/M gal
Percent Sulfur of Fuel:	0.05	percent

Operating Detail

	Value
Operating Time in Hours per Day:	8
Operating Time in Days per Week:	2
Operating Time in Weeks per Year:	5
Operating Time in Hours per Year:	80
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.004	tons/y	EPA emission factors (e.g., AP-42)
Formaldehyde:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.006	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.002	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.001	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.002	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.005	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-141

Designation: TA-3-22-1

Description: Power Plant Boiler (pph, No. 2 fuel oil)

Type: Boiler

SCC: External Combustion Boilers, Electric Generation, Natural Gas, Boilers > 100 Million Btu/hr except Tangential

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Materials Consumed:	0.0	gal
Fuel Heating Value:	138.0	MM BTU/M gal

Operating Detail

	Value
Operating Time in Hours per Day:	0
Operating Time in Days per Week:	0
Operating Time in Weeks per Year:	0
Operating Time in Hours per Year:	0
Percent of Operation During Winter:	0
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

This unit did not run on diesel in 2017.

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-144

Designation: Boiler combined emissions

TA-16-1484-Bs-1,2; TA

Description: -53-365-BHW-1,2; TA-55-6-BHW-1,2; RLUOB-BHW-1,2,3,4

Type: Boiler

SCC: External Combustion Boilers, Electric Generation, Natural Gas, Boilers > 100 Million Btu/hr except Tangential

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	0.0	MM SCF
Fuel Heating Value:	0.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.0	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	0.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	0
Operating Time in Days per Week:	0
Operating Time in Weeks per Year:	0
Operating Time in Hours per Year:	0
Percent of Operation During Winter:	0
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)

Volatile Organic Compounds (VOC): 0.0 tons/y EPA emission factors (e.g., AP-42)

Subject Item Comments

This Facility ID represents the total from the two TA-16 boilers, the two TA-53 boilers, the two TA-55 boilers, and the four RLUOB boilers. However, these emissions are already captured in other facility IDs. In order to avoid counting the emissions twice, NMED has asked us to enter zeros for this Facility ID.

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-149

Designation: RLUOB-BHW-1 (oil)

Description: Boiler-CMRR-BHW-1

Type: Boiler

SCC: External Combustion Boilers,
Commercial/Institutional,
Natural Gas, < 10 Million Btu/hr

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Materials Consumed:	0.0	gal
Fuel Heating Value:	0.0	MM BTU/M gal

Operating Detail

	Value
Operating Time in Hours per Day:	0
Operating Time in Days per Week:	0
Operating Time in Weeks per Year:	0
Operating Time in Hours per Year:	0
Percent of Operation During Winter:	0
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

The RLUOB boilers did not operate on fuel oil in 2017.

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856**Facility Name:** Los Alamos National Security, LLC**Organization Name:** U.S. Department of Energy National Nuclear Security Administration**Submittal Status:** 2017 Submittal (In Process)**Subject Item ID:** EQPT-150**Designation:** RLUOB-BHW-2 (oil)**Description:** Boiler-CMRR-BHW-2**Type:** Boiler**SCC:** External Combustion Boilers,
Commercial/Institutional,
Natural Gas, < 10 Million Btu/hr**GHG Reporting:** Reports GHG to EPA**Supplemental Parameters**

	Amount	Unit of Measure
Fuel Type:	Diesel	
Materials Consumed:	0.0	gal
Fuel Heating Value:	0.0	MM BTU/M gal

Operating Detail

	Value
Operating Time in Hours per Day:	0
Operating Time in Days per Week:	0
Operating Time in Weeks per Year:	0
Operating Time in Hours per Year:	0
Percent of Operation During Winter:	0
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

The RLUOB boilers did not operate on fuel oil in 2017.

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856**Facility Name:** Los Alamos National Security, LLC**Organization Name:** U.S. Department of Energy National Nuclear Security Administration**Submittal Status:** 2017 Submittal (In Process)**Subject Item ID:** EQPT-151**Designation:** RLUOB-BHW-3 (oil)**Description:** Boiler-CMRR-BHW-3**Type:** Boiler**SCC:** External Combustion Boilers,
Commercial/Institutional,
Natural Gas, < 10 Million Btu/hr**GHG Reporting:** Reports GHG to EPA**Supplemental Parameters**

	Amount	Unit of Measure
Fuel Type:	Diesel	
Materials Consumed:	0.0	gal
Fuel Heating Value:	0.0	MM BTU/M gal

Operating Detail

	Value
Operating Time in Hours per Day:	0
Operating Time in Days per Week:	0
Operating Time in Weeks per Year:	0
Operating Time in Hours per Year:	0
Percent of Operation During Winter:	0
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

The RLUOB boilers, did not operate on fuel oil in 2017.

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856
Facility Name: Los Alamos National Security, LLC
Organization Name: U.S. Department of Energy National Nuclear Security Administration
Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-152
Designation: RLUOB-BHW-4 (oil)
Description: Boiler-CMRR-BHW-4
Type: Boiler
SCC: External Combustion Boilers,
Commercial/Institutional,
Natural Gas, < 10 Million Btu/hr
GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Materials Consumed:	0.0	gal
Fuel Heating Value:	0.0	MM BTU/M gal

Operating Detail

	Value
Operating Time in Hours per Day:	0
Operating Time in Days per Week:	0
Operating Time in Weeks per Year:	0
Operating Time in Hours per Year:	0
Percent of Operation During Winter:	0
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

This unit has not been built.

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: RPNT-34
Designation: Facilitywide Open Burning
Description: Fugitives - Open Burning
Type: Fugitives
SCC: Industrial Processes, Oil and Gas
Production, Fugitive Emissions,
Fugitive Emissions
GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Operating Detail

	Value
Operating Time in Hours per Day:	0
Operating Time in Days per Week:	0
Operating Time in Weeks per Year:	0
Operating Time in Hours per Year:	0
Percent of Operation During Winter:	0
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Individual HAP:	0.0	tons/y	Engineer Calculation
Total HAP:	0.0	tons/y	Engineer Calculation

Subject Item Comments

No opening burning activities took place in 2017.

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: RPNT-35

Designation: TA-60-EVAP-1

Description: Evaporative Sprayer for basin water

Type: Fugitives

SCC: Industrial Processes, Oil and Gas Production, Fugitive Emissions, Fugitive Emissions

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Total HAP:	0.0	tons/y	Design calculation

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: RPNT-36

Designation: TA-60-EVAP-2

Description: Evaporative Sprayer for basin water

Type: Fugitives

SCC: Industrial Processes, Oil and Gas Production, Fugitive Emissions, Fugitive Emissions

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Total HAP:	0.0	tons/y	Design calculation

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: RPNT-37

Designation: TA-60-EVAP-3

Description: Evaporative Sprayer for basin water

Type: Fugitives

SCC: Industrial Processes, Oil and Gas Production, Fugitive Emissions, Fugitive Emissions

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Total HAP:	0.0	tons/y	Design calculation

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: RPNT-38

Designation: TA-60-EVAP-4

Description: Evaporative Sprayer for basin water

Type: Fugitives

SCC: Industrial Processes, Oil and Gas Production, Fugitive Emissions, Fugitive Emissions

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Operating Detail

	Value
Operating Time in Hours per Day:	0
Operating Time in Days per Week:	0
Operating Time in Weeks per Year:	0
Operating Time in Hours per Year:	0
Percent of Operation During Winter:	0
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Total HAP:	0.0	tons/y	Design calculation

Subject Item Comments

This sprayer has not been installed.

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: RPNT-39

Designation: TA-60-EVAP-5

Description: Evaporative Sprayer for basin water

Type: Fugitives

SCC: Industrial Processes, Oil and Gas Production, Fugitive Emissions, Fugitive Emissions

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Operating Detail

	Value
Operating Time in Hours per Day:	0
Operating Time in Days per Week:	0
Operating Time in Weeks per Year:	0
Operating Time in Hours per Year:	0
Percent of Operation During Winter:	0
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Total HAP:	0.0	tons/y	Design calculation

Subject Item Comments

This sprayer has not been installed.

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-96

Designation: Standby-Generators

Description: Diesel Generators

Type: Internal combustion engine

SCC: Internal Combustion Engines,
Industrial, Natural Gas,
Reciprocating

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Fuel Heating Value:	138.0	MM BTU/M gal

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	1.13	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	4.34	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.2	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.2	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.17	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.21	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856**Facility Name:** Los Alamos National Security, LLC**Organization Name:** U.S. Department of Energy National Nuclear Security Administration**Submittal Status:** 2017 Submittal (In Process)**Subject Item ID:** EQPT-119**Designation:** TA-33-G-2**Description:** Kohler Diesel Generator TA-33,
TA-36, TA-39**Type:** Internal combustion engine**SCC:** Internal Combustion Engines,
Electric Generation, Distillate Oil
(Diesel), Reciprocating**GHG Reporting:** Reports GHG to EPA**Supplemental Parameters**

	Amount	Unit of Measure
Fuel Type:	Diesel	
Input Materials Processed:	Diesel (INPUT)	
Materials Consumed:	3.91	gal
Fuel Heating Value:	138.0	MM BTU/M gal
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.01	percent
Percent Carbon Content:	83.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	2
Operating Time in Days per Week:	1
Operating Time in Weeks per Year:	2
Operating Time in Hours per Year:	4
Percent of Operation During Winter:	50
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	50

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	Design calculation
Nitrogen Dioxide:	0.001	tons/y	Design calculation
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856**Facility Name:** Los Alamos National Security, LLC**Organization Name:** U.S. Department of Energy National Nuclear Security Administration**Submittal Status:** 2017 Submittal (In Process)**Subject Item ID:** EQPT-120**Designation:** TA-33-G-3**Description:** Kohler Diesel Generator TA-33,
TA-36, TA-39**Type:** Internal combustion engine**SCC:** Internal Combustion Engines,
Industrial, Natural Gas,
Reciprocating**GHG Reporting:** Reports GHG to EPA**Supplemental Parameters**

	Amount	Unit of Measure
Fuel Type:	Diesel	
Input Materials Processed:	Diesel (INPUT)	
Materials Consumed:	2.04	gal
Fuel Heating Value:	138.0	MM BTU/M gal
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.01	percent
Percent Carbon Content:	83.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	1
Operating Time in Days per Week:	1
Operating Time in Weeks per Year:	2
Operating Time in Hours per Year:	2
Percent of Operation During Winter:	0
Percent of Operation During Spring:	50
Percent of Operation During Summer:	0
Percent of Operation During Fall:	50

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	Design calculation
Nitrogen Dioxide:	0.001	tons/y	Design calculation
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856**Facility Name:** Los Alamos National Security, LLC**Organization Name:** U.S. Department of Energy National Nuclear Security Administration**Submittal Status:** 2017 Submittal (In Process)**Subject Item ID:** EQPT-128**Designation:** RLUOB-GEN 1**Description:** Cummins Diesel Powered
Generator and Engine - CMRR**Type:** Internal combustion engine**SCC:** Internal Combustion Engines,
Industrial, Distillate Oil (Diesel),
Reciprocating: Cogeneration**GHG Reporting:** Reports GHG to EPA**Supplemental Parameters**

	Amount	Unit of Measure
Fuel Type:	Diesel	
Materials Consumed:	611.2	gal
Fuel Heating Value:	138.0	MM BTU/M gal

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.123	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.099	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.005	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.005	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.006	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.003	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.014	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-135

Designation: TA-33-G-4

Description: Caterpillar Diesel Generator
TA-33, TA-36, TA-39

Type: Internal combustion engine

SCC: Internal Combustion Engines,
Industrial, Natural Gas, 4-cycle
Rich Burn

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Input Materials Processed:	Diesel (INPUT)	
Materials Consumed:	0.0	gal
Fuel Heating Value:	138.0	MM BTU/M gal
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.01	percent
Percent Carbon Content:	83.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	Design calculation
Nitrogen Dioxide:	0.0	tons/y	Design calculation
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856
Facility Name: Los Alamos National Security, LLC
Organization Name: U.S. Department of Energy National Nuclear Security Administration
Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-143
Designation: TA-55-GEN-3
Description: CI-RICE Stationary Generator -
Caterpillar 1335 hp
Type: Internal combustion engine
SCC: Internal Combustion Engines,
Industrial, Natural Gas,
Reciprocating
GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Operating Detail

	Value
Operating Time in Hours per Day:	8
Operating Time in Days per Week:	5
Operating Time in Weeks per Year:	20
Operating Time in Hours per Year:	200
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.046	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.209	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.007	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.007	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.004	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.008	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856
Facility Name: Los Alamos National Security, LLC
Organization Name: U.S. Department of Energy National Nuclear Security Administration
Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-146
Designation: TA-33-G-1P
Description: Cummins Portable Diesel Generator
Type: Internal combustion engine
SCC: Internal Combustion Engines, Electric Generation, Distillate Oil (Diesel), Reciprocating
GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Operating Detail

	Value
Operating Time in Hours per Day:	2
Operating Time in Days per Week:	2
Operating Time in Weeks per Year:	8
Operating Time in Hours per Year:	16
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.004	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856
Facility Name: Los Alamos National Security, LLC
Organization Name: U.S. Department of Energy National Nuclear Security Administration
Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-147
Designation: TA-48-GEN-1
Description: Cummins Diesel Powered Generator and Engine
Type: Internal combustion engine
SCC: Internal Combustion Engines, Industrial, Natural Gas, Reciprocating
GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Materials Consumed:	0.0	gal
Fuel Heating Value:	138.0	MM BTU/M gal

Operating Detail

	Value
Operating Time in Hours per Day:	0
Operating Time in Days per Week:	0
Operating Time in Weeks per Year:	0
Operating Time in Hours per Year:	0
Percent of Operation During Winter:	0
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
-----------	--------	-----------------	--------------------

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-153

Designation: RLUOB-GEN 2

Description: Cummins Diesel Powered
Generator and Engine - CMRR

Type: Internal combustion engine

SCC: Internal Combustion Engines,
Industrial, Distillate Oil (Diesel),
Reciprocating: Cogeneration

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Materials Consumed:	797.7	gal
Fuel Heating Value:	138.0	MM BTU/M gal

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.16	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.129	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.006	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.008	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.003	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.018	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-154

Designation: RLUOB-GEN 3

Description: Cummins Diesel Powered
Generator and Engine - CMRR

Type: Internal combustion engine

SCC: Internal Combustion Engines,
Industrial, Distillate Oil (Diesel),
Reciprocating: Cogeneration

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Materials Consumed:	424.8	gal
Fuel Heating Value:	138.0	MM BTU/M gal

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.085	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.069	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.003	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.004	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.002	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.01	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856**Facility Name:** Los Alamos National Security, LLC**Organization Name:** U.S. Department of Energy National Nuclear Security Administration**Submittal Status:** 2017 Submittal (In Process)**Subject Item ID:** EQPT-155**Designation:** TA-55-GEN-2**Description:** CI-RICE Stationary Generator -
Whisper Watt 40.2 hp**Type:** Internal combustion engine**SCC:** Internal Combustion Engines,
Industrial, Natural Gas,
Reciprocating**GHG Reporting:** Reports GHG to EPA**Supplemental Parameters****Operating Detail**

	Value
Operating Time in Hours per Day:	0
Operating Time in Days per Week:	0
Operating Time in Weeks per Year:	0
Operating Time in Hours per Year:	0
Percent of Operation During Winter:	0
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856
Facility Name: Los Alamos National Security, LLC
Organization Name: U.S. Department of Energy National Nuclear Security Administration
Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-156
Designation: TA-55-GEN-1
Description: CI-RICE Stationary Generator -
Whisper Watt 40.2 hp
Type: Internal combustion engine
SCC: Internal Combustion Engines,
Industrial, Natural Gas,
Reciprocating
GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Operating Detail

	Value
Operating Time in Hours per Day:	1
Operating Time in Days per Week:	1
Operating Time in Weeks per Year:	1
Operating Time in Hours per Year:	1
Percent of Operation During Winter:	0
Percent of Operation During Spring:	100
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.001	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-21

Designation: TA-55-DG-1

Description: Degreaser - Ultrasonic Cold
Batch TA-55-4

Type: Parts Washer

SCC: Petroleum and Solvent
Evaporation, Organic Solvent
Evaporation, Degreasing,
Trichloroethylene: General
Degreasing Units

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Input Materials Processed: Solvent (INPUT)

Operating Detail

	Value
Operating Time in Hours per Day:	4
Operating Time in Days per Week:	1
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	208
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
TCE; (Trichloroethylene); (Trichloroethene):	0.002	tons/y	Material balance

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: ACT -7

Designation: LANL-FW-CHEM

Description: R & D Activities - Labwide (031)

Type: Research/Testing

SCC: Industrial Processes,
Photographic Equipment/Health
Care/Laboratories, Laboratories,
Bench Scale Reagents: Research

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Acetaldehyde; (Ethyl aldehyde):	0.002	tons/y	Material balance
Acetonitrile; (Methyl cyanide):	0.112	tons/y	Material balance
Acetophenone:	0.001	tons/y	Material balance
Acrylamide:	0.0	tons/y	Material balance
Acrylic acid:	0.004	tons/y	Material balance
Acrylonitrile:	0.002	tons/y	Material balance
Ammonia:	0.0	tons/y	Material balance
Aniline:	0.025	tons/y	Material balance
Antimony:	0.0	tons/y	Material balance
Antimony compounds:	0.002	tons/y	Material balance
Arsenic Compounds:	0.001	tons/y	Material balance
Benzene:	0.011	tons/y	Material balance
Benzyl Chloride:	0.0	tons/y	Material balance
Beryllium Compounds:	0.001	tons/y	Material balance
Biphenyl:	0.0	tons/y	Material balance
Bromoform; (Tribromomethane):	0.0	tons/y	Material balance
Butadiene(1,3-):	0.001	tons/y	Material balance
Cadmium:	0.0	tons/y	Material balance

Cadmium compounds:	0.006	tons/y	Material balance
Carbon Disulfide:	0.003	tons/y	Material balance
Carbon tetrachloride; (Tetrachloromethane):	0.003	tons/y	Material balance
Carbonyl sulfide:	0.0	tons/y	Material balance
Catechol (Pyrocatechol):	0.0	tons/y	Material balance
Chlorine:	0.023	tons/y	Material balance
Chloroacetic Acid:	0.0	tons/y	Material balance
Chlorobenzene(Phenyl Chloride):	0.002	tons/y	Material balance
Chloroform; (Trichloromethane):	0.199	tons/y	Material balance
Chromium:	0.0	tons/y	Material balance
Chromium VI compounds:	0.007	tons/y	Material balance
Cobalt Compounds:	0.004	tons/y	Material balance
Cresol(m-); (Methylphenol, 3-):	0.001	tons/y	Material balance
Cumene:	0.0	tons/y	Material balance
Cyanide compounds:	0.598	tons/y	Material balance
Dibutylphthalate; (Di-n-butyl phthalate):	0.0	tons/y	Material balance
Dichloroethane (1,2-); (EDC); (Ethylene dichloride):	0.002	tons/y	Material balance
Dichlorofluoromethane:	0.0	tons/y	Material balance
Diethanolamine:	0.001	tons/y	Material balance
Dimethyl Sulfate:	0.0	tons/y	Material balance
Dimethyl formamide:	0.038	tons/y	Material balance
Dimethylhydrazine(1,1-):	0.0	tons/y	Material balance
Dioxane(1,4-) (1,4-Diethyleneoxide):	0.005	tons/y	Material balance
Epichlorohydrin; (1-Chloro-2,3-epoxypropane):	0.002	tons/y	Material balance
Epoxybutane(1,2-) (1,2-Butylene oxide):	0.0	tons/y	Material balance
Ethyl Acrylate:	0.001	tons/y	Material balance
Ethyl chloride; (Chloroethane):	0.0	tons/y	Material balance
Ethylbenzene:	0.001	tons/y	Material balance
Ethylene Glycol:	0.37	tons/y	Material balance
Ethylene dibromide; (EDB); (1,2-Dibromoethane):	0.001	tons/y	Material balance
Formaldehyde:	0.0	tons/y	Material balance
Glycol Ethers:	0.066	tons/y	Material balance
Hexachlorocyclopentadiene:	0.0	tons/y	Material balance
Hexamethylphosphoramide:	0.0	tons/y	Material balance
Hexane:	0.37	tons/y	Material balance
Hydrazine:	0.0	tons/y	Material balance
Hydrochloric acid (HCl):	1.141	tons/y	Material balance
Hydrofluoric Acid; (Hydrogen fluoride):	0.013	tons/y	Material balance
Hydroquinone:	0.037	tons/y	Material balance
Iodomethane (Methyl iodide):	0.002	tons/y	Material balance
Lead Compounds:	0.003	tons/y	Material balance
Maleic anhydride:	0.0	tons/y	Material balance
Manganese:	0.0	tons/y	Material balance
Manganese compounds:	0.01	tons/y	Material balance
Mercury compounds:	0.002	tons/y	Material balance
Methanol; (Methyl alcohol):	1.279	tons/y	Material balance
Methyl Ethyl Ketone; (MEK); (2-Butanone):	0.0	tons/y	Material balance
Methyl Methacrylate:	0.002	tons/y	Material balance

Methyl bromide; (Bromomethane):	0.0	tons/y	Material balance
Methyl chloride; (Chloromethane):	0.0	tons/y	Material balance
Methyl isobutyl ketone; (Hexone); (4-Methyl-2-pentanone):	0.004	tons/y	Material balance
Methyl tert butyl ether:	0.013	tons/y	Material balance
Methylene chloride; (Dichloromethane):	0.421	tons/y	Material balance
Methylenebiphenyl isocyanate; (MDI); (Diphenylmethane diisocyanate):	0.073	tons/y	Material balance
Mineral Fibers:	0.003	tons/y	Material balance
Naphthalene:	0.008	tons/y	Material balance
Nickel:	0.0	tons/y	Material balance
Nickel compounds:	0.009	tons/y	Material balance
Nitrobenzene; (nitro-Benzene):	0.005	tons/y	Material balance
Nitrophenol(4-); (p-Nitrophenol):	0.0	tons/y	Material balance
PCE; (Perchloroethylene); (Tetrachloroethylene); (Tetrachloroethene):	0.004	tons/y	Material balance
Phenol:	0.0	tons/y	Material balance
Phenylenediamine(p-); (Phenylenediamine):	0.0	tons/y	Material balance
Phosphine:	0.0	tons/y	Material balance
Phosphorus:	0.001	tons/y	Material balance
Phthalic anhydride:	0.0	tons/y	Material balance
Polycyclic Organic Matter:	0.045	tons/y	Material balance
Propylene Dichloride (1,2-Dichloropropane):	0.0	tons/y	Material balance
Propylene oxide:	0.0	tons/y	Material balance
Selenium:	0.0	tons/y	Material balance
Selenium compounds:	0.0	tons/y	Material balance
Styrene:	0.002	tons/y	Material balance
TCE; (Trichloroethylene); (Trichloroethene):	0.013	tons/y	Material balance
Tetrachloroethane(1,1,2,2-):	0.0	tons/y	Material balance
Titanium tetrachloride:	0.0	tons/y	Material balance
Toluene diisocyanate(2,4-):	0.0	tons/y	Material balance
Toluene; (Methyl benzene):	0.134	tons/y	Material balance
Total HAP:	5.16	tons/y	Material balance
Trichloroethane(1,1,1-) (Methyl Chloroform):	0.002	tons/y	Material balance
Trichloroethane(1,1,2-):	0.0	tons/y	Material balance
Triethylamine:	0.009	tons/y	Material balance
Trimethylpentane(2,2,4-):	0.001	tons/y	Material balance
Urethane; (Ethyl carbamate):	0.0	tons/y	Material balance
Vinyl acetate; (Vinyl acetate monomer):	0.0	tons/y	Material balance
Volatile Organic Compounds (VOC):	10.32	tons/y	Material balance
Xylene(m-); (1,3-Dimethylbenzene); (meta-Xylene):	0.0	tons/y	Material balance
Xylene(o-); (1,2-Dimethylbenzene); (ortho-Xylene):	0.001	tons/y	Material balance
Xylene(p-); (1,4-Dimethylbenzene); (para-Xylene):	0.0	tons/y	Material balance
Xylenes (total); (Xylol):	0.057	tons/y	Material balance
bis(2-ethylhexyl) phthalate; (Di-2-ethylhexyl phthalate); (DEHP):	0.0	tons/y	Material balance

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: ACT -42
Designation: RLUOB-CHEM
Chemical Usage, Bldg.
Description: TA-55-400 (lab portion of RLUOB Bldg.)
Type: Research/Testing
SCC: Industrial Processes, Photographic Equipment/Health Care/Laboratories, Laboratories, Bench Scale Reagents: Research
GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Total HAP:	0.006	tons/y	Material balance
Volatile Organic Compounds (VOC):	0.0	tons/y	Material balance

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856
Facility Name: Los Alamos National Security, LLC
Organization Name: U.S. Department of Energy National Nuclear Security Administration
Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-89
Designation: TA-52-11
Description: Data Disintegrator/Industrial Shredder
Type: Shredder
SCC: Industrial Processes, Pulp and Paper and Wood Products, Miscellaneous Paper Products, Other Not Classified
GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Input Materials Processed: Paper (INPUT)

Operating Detail

	Value
Operating Time in Hours per Day:	7
Operating Time in Days per Week:	5
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	1820
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Particulate Matter (10 microns or less):	0.38	tons/y	Manufacturer Specification
Particulate Matter (2.5 microns or less):	0.25	tons/y	Manufacturer Specification
Particulate Matter (total suspended):	0.42	tons/y	Manufacturer Specification

Subject Item Comments

PrintClose

Facility Annual Emissions - Subject Item Submittal Review

Tuesday, March 20, 2018

Agency ID: 856

Facility Name: Los Alamos National Security, LLC

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2017 Submittal (In Process)

Subject Item ID: EQPT-112

Designation: TA-3-22-CT-1

Description: Combustion Turbine

Type: Turbine

SCC: Internal Combustion Engines,
Electric Generation, Natural Gas,
Turbine

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Input Materials Processed:	Diesel (INPUT)	
Materials Consumed:	51.2	gal
Fuel Heating Value:	1020.0	MM BTU/M gal
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	7
Operating Time in Days per Week:	4
Operating Time in Weeks per Year:	12
Operating Time in Hours per Year:	500
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Acetaldehyde; (Ethyl aldehyde):	0.001	tons/y	EPA emission factors (e.g., AP-42)
Carbon Monoxide:	0.269	tons/y	EPA emission factors (e.g., AP-42)
Copper:	0.002	tons/y	EPA emission factors (e.g., AP-42)
Ethylbenzene:	0.001	tons/y	EPA emission factors (e.g., AP-42)
Formaldehyde:	0.019	tons/y	EPA emission factors (e.g., AP-42)
Lead:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Manganese:	0.002	tons/y	EPA emission factors (e.g., AP-42)
Nickel:	0.003	tons/y	EPA emission factors (e.g., AP-42)

Nitrogen Dioxide:	1.293	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.174	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.174	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.174	tons/y	EPA emission factors (e.g., AP-42)
Propylene oxide:	0.001	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.09	tons/y	EPA emission factors (e.g., AP-42)
Toluene; (Methyl benzene):	0.003	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.056	tons/y	EPA emission factors (e.g., AP-42)
Xylenes (total); (Xylol):	0.002	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Print

Close

ATTACHMENT C:

2017 Semi-annual Emissions Reports

Submitted Under Title V Operating Permit Requirements



Environment Safety & Health

P.O. Box 1663, K491

Los Alamos, New Mexico 87545

(505) 667-4218

Date: **SEP 18 2017**

Symbol: ADESH-17-066

LA-UR: 17-27818

Locates Action No.: N/A

Mr. Ralph Gruebel
Compliance & Enforcement Section Chief
New Mexico Environment Department
Air Quality Bureau
525 Camino de los Marquez, Suite 1
Santa Fe, New Mexico 87505-1816

Subject: Title V Semi-Annual Emissions Report for Permit P100-R2M1, January 1, 2017 – June 30, 2017 AI No. 856 – Los Alamos National Laboratory (LANL)

Dear Mr. Gruebel:

Attached please find Los Alamos National Laboratory's (LANL) Semi-Annual Emissions report for Permit P100-R2M1 for the period January 1, 2017 through June 30, 2017. This report is required by permit condition A109.B and is submitted within 90 days from the end of the reporting period as required by that condition.

The semi-annual emissions report includes actual emissions from permitted sources included in LANL's Operating Permit. In this report, the actual emissions are listed along with the emission limits for ease in comparing and verifying compliance. No annual emission limits were exceeded during this reporting period.

Please contact Steven L. Story at (505) 665-2169 or story@lanl.gov of the Environmental Compliance Programs group (EPC-CP) if you have questions.

Sincerely,

Michael T. Brandt, DrPH, CIH
Associate Director
MTB/SLS/WW:sj

Enclosure 1: Title V Semi-Annual Emissions Report for Permit P100-R2M1, Jan 1, 2017 – June 30, 2017

Copy: Adrienne L. Nash, LASO-NS-LP, (E-FILE)
Hai Shen, EM-SG, (E-FILE)
Annette E. Russell, EM-LA, (E-FILE)
Kirsten M. Laskey, EM-LA (E-FILE)
Richard M. Kacich, DIR, (E-FILE)
Craig S. Leasure, PADOPS, (E-FILE)
William R. Mairson, PADOPS, (E-FILE)
Michael Brandt, ADESH (E-FILE)
Raeanna R. Sharp-Geiger, ADESH, (E-FILE)
Steven L. Story, EPC-CP, (E-FILE)
Walter W. Whetham, EPC-CP, (E-FILE)
Ellena I. Martinez, EPC-CP, (E-FILE)
Timothy A. Dolan, LC-ESH, (E-FILE)
Saundra Martinez, OIO-DO, (E-FILE)
lasomailbox@nnsa.doe.gov, (E-FILE)
locatetesteam@lanl.gov, (E-FILE)
adesh@lanl.gov, (E-FILE)
emla.docs@em.doe.gov
epc-correspondence@lanl.gov, (E-FILE)
EPC-CP Title V Emissions Report File, J978

Title V Semi-Annual Emissions Report for Permit P100-R2M1

January 1, 2017 – June 30, 2017

Identifying Information

Source Name: Los Alamos National Laboratory County: Los Alamos

Source Address:

City: Los Alamos State: NM Zip Code: 87545

Responsible Official: Michael T. Brandt Ph No. (505) 667-4218 Fax No. (505) 665-3811

Technical Contact: Steven L. Story Ph No. (505) 665-2169 Fax No. (505) 665-8858


Principal Company Product or Business: National Security and Nuclear Weapons Research Primary SIC Code: 8733

Permit No. P100-R2M1, January 1, 2017 – June 30, 2017 {IDEA/Tempo ID No. 856} Permit Issued Date: Feb. 3, 2017

Certification of Truth, Accuracy, and Completeness

I, Michael T. Brandt certify that, based on information and belief formed after reasonable inquiry, the statements and information in the attached semi-annual emission report are true, accurate, and complete.

Signature



Date:

9/18/17

Title: Associate Director Environmental, Safety, and Health

ENCLOSURE 1

**Title V Semi-Annual Emissions Report
for Permit P100-R2M1
January 1, 2017 – June 30, 2017**

ADESH-17-066

LA-UR-17-27818

Date: SEP 18 2017

Title V Semi-Annual Emissions Report
Permit P100-R2M1, January 1, 2017 - June 30, 2017

Emission Reporting Requirements

A109 Facility: Reporting Schedules

- A. A Semi-Annual Report of monitoring activities is due within 45 days following the end of every 6-month reporting period. The six month reporting periods start on January 1st and July 1st of each year.
- B. A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Specific Emissions Reports:

A600 Asphalt Production

A602 Emission Limits - Asphalt Production

Unit No.	Nox tpy	SO ₂ tpy	PM tpy	CO tpy	VOC tpy
TA-60-BDM	50.0	50.0	50.0	30.0	50.0

Reporting Requirement

A607 F The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NOx, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No

Provide comments and identify any supporting documentation as an attachment.

Comments:

Asphalt Plant TA-60-BDM	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A602 A) (tons per year)
NOx	0.0019			50.0
SO ₂	0.0007			50.0
PM	0.0011			50.0
CO	0.0662			30.0
VOC	0.0013			50.0
HAPs	0.0012			No Source Permit Limit

A700 Beryllium Activities

A702 Emission Limits - Beryllium Activities

Source	Beryllium Particulate Matter	Aluminum Particulate Matter
Sigma Facility TA-3-66	10 gm/24 hr	N/A
Beryllium Technology Facility TA-3-141	3.5 gm/yr	N/A
Target Fabrication Facility TA-35-213	0.36 gm/yr	N/A
Plutonium Facility TA-55-PF-4 Machining Operation	2.99 gm/yr	2.99 gm/yr
Plutonium Facility TA-55-PF-4 Foundry Operation	8.73×10^{-04} gm/yr	8.73×10^{-04} gm/yr

Reporting Requirement

A707 D The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No

Provide comments and identify any supporting documentation as an attachment.

Comments: Continued on the next page

A700 Beryllium Activities - continued

Comments:

Source	Pollutant	January - June Emissions	July - December Emissions	Annual Emissions	Permit Limits (Condition A702 A)
Sigma Facility TA-3-66 ⁽¹⁾	Beryllium (grams)	0.012			10 gm/24 hr
Beryllium Technology Facility TA-3-141 ⁽²⁾	Beryllium (grams)	< 0.00407			3.5 gm/yr
Target Fabrication Facility TA-35-213 ⁽³⁾	Beryllium (grams)	< 0.00944			0.36 gm/yr
Plutonium Facility TA-55-PF4 Machining Operation ⁽⁴⁾	Beryllium (grams)	< 1.495			2.99 gm/yr
	Aluminum (grams)	< 1.495			2.99 gm/yr
Plutonium Facility TA-55-PF4 Foundry Operation ⁽⁵⁾	Beryllium (grams)	0			8.73×10^{-4} gm/yr
	Aluminum (grams)	0			8.73×10^{-4} gm/yr
Beryllium Total⁽⁵⁾ (tons) =		< 1.66E-06			
Aluminum Total (tons) =		< 1.65E-06			

Notes: (1) Emissions from the Sigma Facility are from electroplating, chemical milling, and metallographic operations. (2) Emission values shown for the Beryllium Technology Facility are from actual stack emission measurements which are submitted to NMED quarterly. (3) Emissions for the Target Fabrication Facility are from initial compliance testing of that source and calculated based on a conservative assumption of 8 hour work days. Log books were checked to verify that work days were much less than 8 hours. (4) Emissions for the Plutonium Facility are calculated based on permitted throughputs. Log books were checked to verify that throughputs were much less than permitted values. (5) The Plutonium Facility foundry operations did not operate during the first 6 months of 2017.

A800 External Combustion

A802 Emission Limits - External Combustion

Unit No.	NOx tpy	CO tpy	VOC tpy	SO ₂ tpy	TSP tpy	PM ₁₀ tpy
All Boilers	80.0	80.0	50.0	50.0	50.0	50.0

Unit No.	NOx tpy	CO tpy	SO ₂ tpy	TSP tpy	PM ₁₀ tpy	PM _{2.5} tpy
RLUOB-BHW-1 (gas)	2.9	4.8	0.3	0.4	0.4	0.4
RLUOB-BHW-2 (gas)	2.9	4.8	0.3	0.4	0.4	0.4
RLUOB-BHW-3 (gas)	2.9	4.8	0.3	0.4	0.4	0.4
RLUOB-BHW-4 (gas)	2.9	4.8	0.3	0.4	0.4	0.4
RLUOB Boilers (oil)	2.9	0.9	10.4	0.5	0.3	0.3
RLUOB Boilers Total	14.5	20.1	11.6	2.1	1.9	1.9

Reporting Requirement

A807 B The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NOx, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No Provide comments and identify any supporting documentation as an attachment.

Comments:

Boilers	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 A) (tons per year)
NOx	11.18			80
SO ₂	0.07			50
TSP	0.90			50
PM-10	0.90			50
CO	8.97			80
VOCs	0.64			50
HAPs	0.21			No Source Limit

Note: The emissions shown in this table includes all exempt, non-exempt, metered, and non-metered boilers at LANL except for the TA-3-22 Power Plant boilers. The Power Plant boilers can be found under Section A1300 of this report.

Continued on the next page

A800 External Combustion - continued

RLUOB-BHW-1 (Gas)	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 B) (tons per year)
NOx	0.0062			2.9
SO ₂	0.0001			0.3
TSP	0.0010			0.4
PM-10	0.0010			0.4
PM-2.5	0.0010			0.4
CO	0.0079			4.8
VOCs	0.0053			No Source Limit
HAPs	3.92E-04			No Source Limit

RLUOB-BHW-2 (Gas)	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 B) (tons per year)
NOx	0.0062			2.9
SO ₂	0.0001			0.3
TSP	0.0010			0.4
PM-10	0.0010			0.4
PM-2.5	0.0010			0.4
CO	0.0079			4.8
VOCs	0.0053			No Source Limit
HAPs	3.92E-04			No Source Limit

RLUOB-BHW-3 (Gas)	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 B) (tons per year)
NOx	0.0062			2.9
SO ₂	0.0001			0.3
TSP	0.0010			0.4
PM-10	0.0010			0.4
PM-2.5	0.0010			0.4
CO	0.0079			4.8
VOCs	0.0053			No Source Limit
HAPs	3.92E-04			No Source Limit

RLUOB-BHW-4 (Gas)	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 B) (tons per year)
NOx	0.000			2.9
SO ₂	0.000			0.3
TSP	0.000			0.4
PM-10	0.000			0.4
PM-2.5	0.000			0.4
CO	0.000			4.8
VOCs	0.000			No Source Limit
HAPs	0.000			No Source Limit

Note: The RLUOB-BHW-4 boiler has not been installed.

Continued on the next page.

A800 External Combustion - continued

RLUOB Boilers Totals (Oil)	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 B) (tons per year)
NOx	0.000			2.9
SO ₂	0.000			10.4
TSP	0.000			0.5
PM-10	0.000			0.3
PM-2.5	0.000			0.3
CO	0.000			0.9
VOCs	0.000			No Source Limit
HAPs	0.000			No Source Limit

Note: The RLUOB boilers did not operate on fuel oil during the first 6 months of 2017.

RLUOB Boilers Totals (Gas and Oil)	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 B) (tons per year)
NOx	0.0186			14.5
SO ₂	0.0004			11.6
TSP	0.0031			2.1
PM-10	0.0031			1.9
PM-2.5	0.0031			1.9
CO	0.0237			20.1
VOCs	0.0160			No Source Limit
HAPs	1.18E-03			No Source Limit

A900 Chemical Usage

A902 Emission Limits - Chemical Usage

Unit No.	VOC/HAPs tpy
LANL-FW-CHEM	3.75 ¹
CMRR-CHEM	3.75 ¹

¹ The VOC emissions from this source category are included in the facility-wide allowable emissions limit established in Table 106.B: 200 tpy VOC, 8.0 tpy per individual HAP, and 24.0 tpy of combined total HAPs. Any VHAPs that are also defined as a VOC shall be included in the VOC total.

Reporting Requirement

A907 A The permittee shall submit reports described in Section A109 and in accordance with B110. With respect to individual HAPs, reports shall include any HAP emitted in quantity greater than 0.5 tons per year.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No Provide comments and identify any supporting documentation as an attachment.

Comments:

Chemical Usage LANL-FW-CHEM		January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A902 B)
VOCs		3.94			Source limits refer to facility-wide limits.
HAPs		2.52			
Individual HAPs greater than 0.5 tons	Hydrochloric Acid	0.76			
	Cyanide Compounds	0.51			
	Methanol	0.50			

Chemical Usage CMRR-CHEM		January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A902 B)
HAPs		0.0029			3.75
VOCs		0.0000			3.75
TAPs		0.0128			No Source Limit

A1000 Degreasers

A1002 Emission Limits - Degreasers

Unit No.	VOC/HAPs tpy
TA-55-DG-1	--

1 The VOC emissions from this source category are included in the facility-wide allowable emissions limit established in Table 106.B: 200 tpy VOC, 8.0 tpy per individual HAP, and 24.0 tpy of combined total HAPs. Any VHAPs that are also defined as a VOC shall be included in the VOC total.

Reporting Requirement

A1007 A The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No Provide comments and identify any supporting documentation as an attachment.

Comments:

Degreaser TA-55-DG-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1002 A) (tons per year)
VOCs	0.0016			Source limits refer to facility-wide limits.
HAPs	0.0016			

A1100 Internal Combustion

A1102 Emission Limits - Internal Combustion

Unit No.	NO _x tpy	CO tpy	VOC tpy	SO ₂ tpy	TSP tpy	PM ₁₀ tpy
TA-33-G-1P	18.1	15.2	0.3	2.5	0.6	0.6
TA-33-G-2	0.21	0.1	-- ¹	--	--	--
TA-33-G-3	0.21	0.1	-- ¹	--	--	--
TA-33-G-4	2.33	1.4	0.2	0.16	--	--

¹ The VOC emissions from this source category are included in the facility-wide allowable emissions limit established in condition 106.B: 200 tpy VOC, 8.0 tpy per individual HAP, and 24.0 tpy of combined total HAPs.

Reporting Requirement

A1107 A The permittee shall comply with all applicable reporting requirements of 40 CFR 60, Subpart A as required in 60.4218 and in accordance with Section B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No Provide comments and identify any supporting documentation as an attachment.

Comments:

Generator TA-33-G-1P	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1102 A) (tons per year)
NO _x	0.0040			18.1
SO ₂	0.0001			2.5
TSP	0.0001			0.6
PM ₁₀	0.0001			0.6
CO	0.0004			15.2
VOC	0.0003			0.3
HAPs	1.16E-06			No Source Limit

Generator TA-33-G-2	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1102 A) (tons per year)
NO _x	0.0084			0.21
SO ₂	0.0006			Not Required
TSP	0.0006			Not Required
PM ₁₀	0.0006			Not Required
CO	0.0024			0.1
VOC	0.0007			Not Required
HAPs	2.72E-06			No Source Limit

Continued on the next page.

A1100 Internal Combustion- continued

Generator TA-33-G-3	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1102 A) (tons per year)
NOx	0.0004			0.21
SO ₂	0.0000			Not Required
TSP	0.0000			Not Required
PM ₁₀	0.0000			Not Required
CO	0.0001			0.1
VOC	0.0000			Not Required
HAPs	1.35E-07			No Source Limit

Generator TA-33-G-4	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1102 A) (tons per year)
NOx	0.0000			2.33
SO ₂	0.0000			0.16
TSP	0.0000			Not Required
PM ₁₀	0.0000			Not Required
CO	0.0000			1.4
VOC	0.0000			0.2
HAPs	0.00E+00			No Source Limit

Note: The TA-33-G-4 generator did not operate during the first 6 months of 2017.

Generator RLUOB-GEN-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NOx	0.035			No Source Specific Emission Limits for the CMRR Generators
SO ₂	0.001			
TSP	0.002			
PM ₁₀	0.002			
CO	0.044			
VOC	0.005			
HAPs	9.17E-06			

Generator RLUOB-GEN-2	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NOx	0.045			No Source Specific Emission Limits for the CMRR Generators
SO ₂	0.001			
TSP	0.003			
PM ₁₀	0.002			
CO	0.056			
VOC	0.006			
HAPs	1.18E-05			

Continued on the next page.

A1100 Internal Combustion- continued

Generator RLUOB-GEN-3	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NOx	0.034			No Source Specific Emission Limits for the CMRR Generators
SO ₂	0.001			
TSP	0.002			
PM ₁₀	0.002			
CO	0.042			
VOC	0.005			
HAPs	8.73E-06			

Generator TA-48-GEN-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NOx	0.000			No Source Specific Emission Limits for the TA-48 Generator
SO ₂	0.000			
TSP	0.000			
PM ₁₀	0.000			
CO	0.000			
VOC	0.000			
HAPs	0.00E+00			

Note: The TA-48-GEN-1 generator did not operate during the first six months of 2017.

Generator TA-55-GEN-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NOx	0.0000			No Source Specific Emission Limits for the TA-55 Generators
SO ₂	0.0000			
TSP	0.0000			
PM ₁₀	0.0000			
CO	0.0000			
VOC	0.0000			
HAPs	0.00E+00			

Note: The TA-55-GEN-1 generator did not operate during the first six months of 2017.

Generator TA-55-GEN-2	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NOx	0.0000			No Source Specific Emission Limits for the TA-55 Generators
SO ₂	0.0000			
TSP	0.0000			
PM ₁₀	0.0000			
CO	0.0000			
VOC	0.0000			
HAPs	0.00E+00			

Note: The TA-55-GEN-2 generator did not operate during the first six months of 2017.

Continued on the next page.

A1100 Internal Combustion- continued

Generator TA-55-GEN-3	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NOx	0.1022			No Source Specific Emission Limits for the TA-55 Generators
SO ₂	0.0017			
TSP	0.0032			
PM ₁₀	0.0032			
CO	0.0224			
VOC	0.0047			
HAPs	1.86E-05			

A1200 Data Disintegrator

A1202 Emission Limits - Data Disintegrator

Unit No.	TSP tpy	PM10 tpy
TA-52-11	9.9	9.9

Reporting Requirement

A1207 A The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No

Provide comments and identify any supporting documentation as an attachment.

Comments:

Data Disintegrator TA-52-11	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1202 A) (tons per year)
TSP	0.22			9.9
PM10	0.20			9.9

A1300 TA-3 Power Plant

A1302 Emission Limits - TA-3 Power Plant

All TA-3 Power Plant Boilers Combined (TA-33-1, TA-33-2, TA-33-3)

NOx tpy	CO tpy	VOC tpy	SOx tpy	TSP tpy	PM ₁₀ tpy	PM2.5 tpy
31.5	21.5	2.8	4.9	4.7	4.4	4.2

TA-3 Power Plant Turbine (TA-3-22-CT-1)

NOx tpy	CO tpy	VOC tpy	SOx tpy	TSP tpy	PM ₁₀ tpy	PM2.5 tpy
59.4	72.3	1.5	4.2	4.8	4.8	4.8

Reporting Requirement

A1307 A The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NOx, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No Provide comments and identify any supporting documentation as an attachment.

Comments:

Boilers TA-3-22-1, TA-3-22-2, TA-3-22-3	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limit (Condition A1302 A) (tons per year)
NOx	5.62			31.5
SO ₂	0.06			4.9
TSP	0.74			4.7
PM ₁₀	0.74			4.4
PM _{2.5}	0.74			4.2
CO	3.88			21.5
VOC	0.53			2.8
HAPs	0.18			No Source Limit

Combustion Turbine TA-3-22 CT-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limit (Condition A1302 A) (tons per year)
NOx	0.864			59.4
SOx	0.060			4.2
TSP	0.116			4.8
PM ₁₀	0.116			4.8
PM _{2.5}	0.116			4.8
CO	0.180			72.3
VOC	0.038			1.5
HAPs	0.024			No Source Limit

A1400 Open Burning

A1402 Emission Limits - Open Burning

Unit No.	Individual HAP ¹ (tpy)	Total HAPs ¹ (tpy)
Facility-Wide Open Burning	8.0	24.0

¹ Individual and Total HAPs emitted by Open Burning are included in facility-wide HAP emission limits at Table 106.B.

Reporting Requirement

A1407 A The permittee shall submit reports as outlined in the Condition 1407.A Requirements, as described in Section A109, and in accordance with Section B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No Provide comments and identify any supporting documentation as an attachment.

Comments:

No open burning activities took place during the first six months of 2017.

A1500 Evaporative Sprayers

A1502 Emission Limits - Evaporative Sprayers

Unit No.	HAPs tpy
TA-60-EVAP-1	-- ¹
TA-60-EVAP-2	-- ¹
TA-60-EVAP-3	-- ¹
TA-60-EVAP-4	-- ¹
TA-60-EVAP-5	-- ¹

¹ Hazardous air pollutants (HAPs) from the evaporative coolers are included in and subject to the individual and total HAP facility-wide emission limits in Table 106.B: 8.0 tpy per individual HAP, and 24.0 tpy of combined total HAPs.

Reporting Requirement

A1507 A The permittee shall submit reports described in Section A109 and in accordance with B111.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No

Provide comments and identify any supporting documentation as an attachment.

Comments:

Evaporative Sprayer TA-60-EVAP-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1502 A) (tons per year)
Polychlorinated biphenyls	7.14E-10			Source limits refer to facility-wide limits.
Chloroform	3.28E-06			
Chloromethane	2.25E-06			
Bromoform	2.90E-06			
Cyanide Compounds	6.67E-06			
Manganese Compounds	2.41E-05			
Antimony Compounds	1.14E-05			
TOTAL HAPs	5.06E-05			

Evaporative Sprayer TA-60-EVAP-2	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1502 A) (tons per year)
Polychlorinated biphenyls	3.26E-10			Source limits refer to facility-wide limits.
Chloroform	1.50E-06			
Chloromethane	1.03E-06			
Bromoform	1.32E-06			
Cyanide Compounds	3.04E-06			
Manganese Compounds	1.10E-05			
Antimony Compounds	5.20E-06			
TOTAL HAPs	2.31E-05			

Continued on the next page.

A1500 Evaporative Sprayers - continued

Evaporative Sprayer TA-60-EVAP-3	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1502 A) (tons per year)
Polychlorinated biphenyls	6.61E-10			Source limits refer to facility-wide limits.
Chloroform	3.04E-06			
Chloromethane	2.08E-06			
Bromoform	2.69E-06			
Cyanide Compounds	6.18E-06			
Manganese Compounds	2.23E-05			
Antimony Compounds	1.06E-05			
TOTAL HAPs	4.69E-05			

Evaporative Sprayer TA-60-EVAP-4	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1502 A) (tons per year)
Polychlorinated biphenyls	0.000			Source limits refer to facility-wide limits.
Chloroform	0.000			
Chloromethane	0.000			
Bromoform	0.000			
Cyanide Compounds	0.000			
Manganese Compounds	0.000			
Antimony Compounds	0.000			
TOTAL HAPs	0.000			

Note: The TA-60-EVAP-4 evaporative sprayer has not been installed.

Evaporative Sprayer TA-60-EVAP-5	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1502 A) (tons per year)
Polychlorinated biphenyls	0.000			Source limits refer to facility-wide limits.
Chloroform	0.000			
Chloromethane	0.000			
Bromoform	0.000			
Cyanide Compounds	0.000			
Manganese Compounds	0.000			
Antimony Compounds	0.000			
TOTAL HAPs	0.000			

Note: The TA-60-EVAP-5 evaporative sprayer has not been installed.

A102 Facility Wide Emission Limits

Table 102.A: Total Potential Criteria Pollutant Emissions from Entire Facility

Pollutant	Emissions (tons per year)
Nitrogen Oxides (NOx)	245.0
Carbon Monoxide (CO)	225.0
Volatile Organic Carbons (VOC)	200.0
Sulfur Dioxide (SO ₂)	150.0
Total Particulate Matter (TSP)	120.0
Particulate Matter less than 10 microns (PM ₁₀)	120.0
Particulate Matter less than 2.5 microns (PM _{2.5})	120.0

Table 102.B: Total Potential HAPs that exceed 1.0 tons per year

Pollutant	Emissions (tons per year)
Individual HAP	8.0
Total HAPs	24.0

Reporting Requirement

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NOx, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No

Provide comments and identify any supporting documentation as an attachment.

Comments:

Pollutant	January - June Emissions (tons)	July - December Emissions (tons)	2017 Annual Emissions (tons)	Facility Wide Permit Limits (Condition A102) (tons per year)
Nitrogen Oxides	17.89			245
Carbon Monoxide	13.26			225
Volatile Organic Carbons	5.17			200
Sulfur Dioxide	0.19			150
Total Particulate Matter	1.98			120
Particulate Matter less than 10 microns	1.96			120
Particulate Matter less than 2.5 microns	0.86			120
Hazardous Air Pollutants	2.94			24



Environmental Safety & Health
Los Alamos National Laboratory
PO Box 1663, K491
Los Alamos, New Mexico 87545
(505) 667-4218

Environmental Management
Los Alamos Field Office
3747 West Jemez Road, A316
Los Alamos, New Mexico, 87544
(505) 667-5105/ Fax (505) 667-5948

Symbol: ADESH-18: 020

Date:

LA-UR: **MAR 26 2018**
18-22248

Locates Action No.: N/A

Mr. Ralph Grubel
Compliance & Enforcement Section Chief
New Mexico Environment Department
Air Quality Bureau
525 Camino de los Marquez, Suite 1
Santa Fe, New Mexico 87505-1816

Subject: Title V Semi-Annual Emissions Report for Permit P100-R2M1, July 1, 2017 – December 31, 2017 AI No. 856 – Los Alamos National Laboratory (LANL)

Dear Mr. Grubel:

Please find Los Alamos National Laboratory's (LANL) Semi-Annual Emissions report for Permit P100-R2M1 for the period July 1, 2017 through December 31, 2017 (*Enclosure 1*). This report is required by permit condition A109.B and is submitted within 90 days from the end of the reporting period as required by that condition.

The semi-annual emissions report includes actual emissions from permitted sources included in LANL's Operating Permit. In this report, the actual emissions are listed along with the emission limits for ease in comparing and verifying compliance. No annual emission limits were exceeded during this reporting period.

Please contact Steven L. Story at (505) 665-2169 or story@lanl.gov of the Environmental Compliance Programs group (EPC-CP) if you have questions.

Sincerely,

William R. Mairson
Associate Director

WRM/SLS/WW:am

Enclosure(s) Enclosure 1 Title V Semi-Annual Emissions Report for Permit P100-R2M1, Jul 1, 2017 –
Dec 31, 2017

Copy: Adrienne L. Nash, LASO-NS-LP, (E-File)
Hai Shen, EM-SG, (E-File)
Annette E. Russell, EM-LA, (E-File)
Richard M. Kacich, DIR, (E-File)
Craig S. Leasure, PADOPS, (E-File)
John Bretzke, ADESH, (E-File)
Ben Roberts, EPC-DO, (E-File)
Taunia Van Valkenburg, EPC-CP, (E-File)
Steven L. Story, EPC-CP, (E-File)
Walter W. Whetham, EPC-CP, (E-File)
Ellena I. Martinez, EPC-CP, (E-File)
Timothy A. Dolan, LC-ESH, (E-File)
locatesteam@lanl.gov, (E-File)
adesh@lanl.gov, (E-File)
epc-correspondence@lanl.gov, (E-File)
EPC-CP Title V Emissions Report File, J978

Title V Semi-Annual Emission Report for Permit P100-R2M1

July 1, 2017 – December 31, 2017

Identifying Information

Source Name: Los Alamos National Laboratory County: Los Alamos

Source Address:

City: Los Alamos State: NM Zip Code: 87545

Responsible Official: William R. Mairson Ph No. (505) 667-4218 Fax No. (505) 665-3811

Technical Contact: Steven L. Story Ph No. (505) 665-2169 Fax No. (505) 665-8858

Principal Company Product or Business: National Security and Nuclear Weapons Research Primary SIC Code: 8733

Permit No. P100-R2M1, July 1, 2017 – Dec. 31, 2017 {IDEA/Tempo ID No. 856} Permit Issued Date: Feb. 3, 2017

Certification of Truth, Accuracy, and Completeness

I, William R. Mairson certify that, based on information and belief formed after reasonable inquiry, the statements and information in the attached semi-annual emission report are true, accurate, and complete.

Signature



Date: 3-26-18

Title: Associate Director Environmental, Safety, and Health

ENCLOSURE 1

**Title V Semi-Annual Emissions Report
For Permit P100-R2M1
July 1, 2017 – December 31, 2017**

ADESH-18: 020

LA-UR-18-22248

MAR 26 2018

Date: _____

Title V Semi-Annual Emissions Report
Permit P100-R2M1, July 1, 2017 - December 31, 2017

Emission Reporting Requirements

A109 Facility: Reporting Schedules

- A. A Semi-Annual Report of monitoring activities is due within 45 days following the end of every 6-month reporting period. The six month reporting periods start on January 1st and July 1st of each year.
- B. A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Specific Emissions Reports:

A600 Asphalt Production

A602 Emission Limits - Asphalt Production

Unit No.	Nox tpy	SO ₂ tpy	PM tpy	CO tpy	VOC tpy
TA-60-BDM	50.0	50.0	50.0	30.0	50.0

Reporting Requirement

A607 F The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No

Provide comments and identify any supporting documentation as an attachment.

Comments:

Asphalt Plant TA-60-BDM	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A602 A) (tons per year)
NO _x	0.0019	0.0025	0.004	50.0
SO ₂	0.0007	0.0009	0.002	50.0
PM	0.0011	0.0015	0.003	50.0
CO	0.0662	0.0883	0.155	30.0
VOC	0.0013	0.0017	0.003	50.0
HAPs	0.0012	0.0016	0.003	No Source Permit Limit

A700 Beryllium Activities

A702 Emission Limits - Beryllium Activities

Source	Beryllium Particulate Matter	Aluminum Particulate Matter
Sigma Facility TA-3-66	10 gm/24 hr	N/A
Beryllium Technology Facility TA-3-141	3.5 gm/yr	N/A
Target Fabrication Facility TA-35-213	0.36 gm/yr	N/A
Plutonium Facility TA-55-PF-4 Machining Operation	2.99 gm/yr	2.99 gm/yr
Plutonium Facility TA-55-PF-4 Foundry Operation	8.73×10^{-04} gm/yr	8.73×10^{-04} gm/yr

Reporting Requirement

A707 D The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No Provide comments and identify any supporting documentation as an attachment.

Comments: Continued on the next page

A700 Beryllium Activities - continued

Comments:

Source	Pollutant	January - June Emissions	July - December Emissions	Annual Emissions	Permit Limits (Condition A702 A)
Sigma Facility TA-3-66 ⁽¹⁾	Beryllium (grams)	0.012	0.007	0.019	10 gm/24 hr
Beryllium Technology Facility TA-3-141 ⁽²⁾	Beryllium (grams)	< 0.00407	< 0.00293	< 0.007	3.5 gm/yr
Target Fabrication Facility TA-35-213 ⁽³⁾	Beryllium (grams)	< 0.00944	< 0.009	< 0.018	0.36 gm/yr
Plutonium Facility TA-55-PF4 Machining Operation ⁽⁴⁾	Beryllium (grams)	< 1.495	< 1.41	< 2.91	2.99 gm/yr
	Aluminum (grams)	< 1.495	< 1.41	< 2.91	2.99 gm/yr
Plutonium Facility TA-55-PF4 Foundry Operation ⁽⁵⁾	Beryllium (grams)	0	0	0.00	8.73 x 10 ⁻⁴ gm/yr
	Aluminum (grams)	0	0	0.00	8.73 x 10 ⁻⁴ gm/yr
Beryllium Total⁽⁵⁾ (tons) =		< 1.66E-06	< 1.57E-06	< 3.23E-06	
Aluminum Total (tons) =		< 1.65E-06	< 1.55E-06	< 3.30E-06	

Notes: (1) Emissions from the Sigma Facility are from electroplating, chemical milling, and metallographic operations. (2) Emission values shown for the Beryllium Technology Facility are from actual stack emission measurements which are submitted to NMED quarterly. (3) Emissions for the Target Fabrication Facility are from initial compliance testing of that source and calculated based on a conservative assumption of 8 hour work days. Log books were checked to verify that work days were much less than 8 hours. (4) Emissions for the Plutonium Facility are calculated based on permitted throughputs. Log books were checked to verify that throughputs were much less than permitted values. (5) The Plutonium Facility foundry operations did not operate during the last 6 months of 2017.

A800 External Combustion

A802 Emission Limits - External Combustion

Unit No.	NOx tpy	CO tpy	VOC tpy	SO ₂ tpy	TSP tpy	PM ₁₀ tpy
All Boilers	80.0	80.0	50.0	50.0	50.0	50.0

Unit No.	NOx tpy	CO tpy	SO ₂ tpy	TSP tpy	PM ₁₀ tpy	PM _{2.5} tpy
RLUOB-BHW-1 (gas)	2.9	4.8	0.3	0.4	0.4	0.4
RLUOB-BHW-2 (gas)	2.9	4.8	0.3	0.4	0.4	0.4
RLUOB-BHW-3 (gas)	2.9	4.8	0.3	0.4	0.4	0.4
RLUOB-BHW-4 (gas)	2.9	4.8	0.3	0.4	0.4	0.4
RLUOB Boilers (oil)	2.9	0.9	10.4	0.5	0.3	0.3
RLUOB Boilers Total	14.5	20.1	11.6	2.1	1.9	1.9

Reporting Requirement

A807 B The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NOx, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No Provide comments and identify any supporting documentation as an attachment.

Comments:

Boilers	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 A) (tons per year)
NOx	11.18	8.08	19.3	80
SO ₂	0.07	0.05	0.1	50
TSP	0.90	0.65	1.5	50
PM-10	0.90	0.65	1.5	50
CO	8.97	6.41	15.4	80
VOCs	0.64	0.46	1.1	50
HAPs	0.21	0.15	0.4	No Source Limit

Note: The emissions shown in this table includes all exempt, non-exempt, metered, and non-metered boilers at LANL except for the TA-3-22 Power Plant boilers. The Power Plant boilers can be found under Section A1300 of this report.

Continued on the next page

A800 External Combustion - continued

RLUOB-BHW-1 (Gas)	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 B) (tons per year)
NOx	0.0062	0.0053	0.011	2.9
SO ₂	0.0001	0.0001	0.0002	0.3
TSP	0.0010	0.0009	0.002	0.4
PM-10	0.0010	0.0009	0.002	0.4
PM-2.5	0.0010	0.0009	0.002	0.4
CO	0.0079	0.0067	0.015	4.8
VOCs	0.0053	0.0045	0.010	No Source Limit
HAPs	3.92E-04	3.32E-04	0.001	No Source Limit

RLUOB-BHW-2 (Gas)	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 B) (tons per year)
NOx	0.0062	0.0053	0.011	2.9
SO ₂	0.0001	0.0001	0.0002	0.3
TSP	0.0010	0.0009	0.002	0.4
PM-10	0.0010	0.0009	0.002	0.4
PM-2.5	0.0010	0.0009	0.002	0.4
CO	0.0079	0.0067	0.015	4.8
VOCs	0.0053	0.0045	0.010	No Source Limit
HAPs	3.92E-04	3.32E-04	0.001	No Source Limit

RLUOB-BHW-3 (Gas)	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 B) (tons per year)
NOx	0.0062	0.0053	0.011	2.9
SO ₂	0.0001	0.0001	0.0002	0.3
TSP	0.0010	0.0009	0.002	0.4
PM-10	0.0010	0.0009	0.002	0.4
PM-2.5	0.0010	0.0009	0.002	0.4
CO	0.0079	0.0067	0.015	4.8
VOCs	0.0053	0.0045	0.010	No Source Limit
HAPs	3.92E-04	3.32E-04	0.001	No Source Limit

RLUOB-BHW-4 (Gas)	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 B) (tons per year)
NOx	0.000	0.000	0.000	2.9
SO ₂	0.000	0.000	0.000	0.3
TSP	0.000	0.000	0.000	0.4
PM-10	0.000	0.000	0.000	0.4
PM-2.5	0.000	0.000	0.000	0.4
CO	0.000	0.000	0.000	4.8
VOCs	0.000	0.000	0.000	No Source Limit
HAPs	0.000	0.000	0.000	No Source Limit

Note: The RLUOB-BHW-4 boiler has not been installed.

Continued on the next page.

A800 External Combustion - continued

RLUOB Boilers Totals (Oil)	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 B) (tons per year)
NOx	0.000	0.000	0.000	2.9
SO ₂	0.000	0.000	0.000	10.4
TSP	0.000	0.000	0.000	0.5
PM-10	0.000	0.000	0.000	0.3
PM-2.5	0.000	0.000	0.000	0.3
CO	0.000	0.000	0.000	0.9
VOCs	0.000	0.000	0.000	No Source Limit
HAPs	0.000	0.000	0.000	No Source Limit

Note: The RLUOB boilers did not operate on fuel oil during 2017.

RLUOB Boilers Totals (Gas and Oil)	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 B) (tons per year)
NOx	0.0186	0.0158	0.034	14.5
SO ₂	0.0004	0.0003	0.001	11.6
TSP	0.0031	0.0026	0.006	2.1
PM-10	0.0031	0.0026	0.006	1.9
PM-2.5	0.0031	0.0026	0.006	1.9
CO	0.0237	0.0201	0.044	20.1
VOCs	0.0160	0.0136	0.030	No Source Limit
HAPs	1.18E-03	9.96E-04	0.002	No Source Limit

A900 Chemical Usage

A902 Emission Limits - Chemical Usage

Unit No.	VOC/HAPs tpy
LANL-FW-CHEM	3.75 ¹
CMRR-CHEM	3.75 ¹

¹ The VOC emissions from this source category are included in the facility-wide allowable emissions limit established in Table 106.B: 200 tpy VOC, 8.0 tpy per individual HAP, and 24.0 tpy of combined total HAPs. Any VHAPs that are also defined as a VOC shall be included in the VOC total.

Reporting Requirement

A907 A The permittee shall submit reports described in Section A109 and in accordance with B110. With respect to individual HAPs, reports shall include any HAP emitted in quantity greater than 0.5 tons per year.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No Provide comments and identify any supporting documentation as an attachment.

Comments:

Chemical Usage LANL-FW-CHEM		January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A902 B)
VOCs		3.94	6.38	10.32	Source limits refer to facility-wide limits.
HAPs		2.53	2.63	5.16	
Individual HAPs greater than 0.5 tons	Methanol	0.504	0.774	1.28	
	Hydrochloric Acid	0.764	0.377	1.14	
	Cyanide Compounds	0.510	0.092	0.60	

Chemical Usage CMRR-CHEM		January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A902 B)
HAPs		0.0029	0.0035	0.0064	3.75
VOCs		0.0000	0.0000	0.0000	3.75
TAPs		0.0128	0.0067	0.0195	No Source Limit

A1000 Degreasers

A1002 Emission Limits - Degreasers

Unit No.	VOC/HAPs tpy
TA-55-DG-1	-- 3.

1 The VOC emissions from this source category are included in the facility-wide allowable emissions limit established in Table 106.B: 200 tpy VOC, 8.0 tpy per individual HAP, and 24.0 tpy of combined total HAPs. Any VHAPs that are also defined as a VOC shall be included in the VOC total.

Reporting Requirement

A1007 A The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No Provide comments and identify any supporting documentation as an attachment.

Comments:

Degreaser TA-55-DG-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1002 A) (tons per year)
VOCs	0.0016	0.000	0.0016	Source limits refer to facility-wide limits.
HAPs	0.0016	0.000	0.0016	

A1100 Internal Combustion

A1102 Emission Limits - Internal Combustion

Unit No.	NOx tpy	CO tpy	VOC tpy	SO ₂ tpy	TSP tpy	PM ₁₀ tpy
TA-33-G-1P	18.1	15.2	0.3	2.5	0.6	0.6
TA-33-G-2	0.21	0.1	-- ¹	--	--	--
TA-33-G-3	0.21	0.1	-- ¹	--	--	--
TA-33-G-4	2.33	1.4	0.2	0.16	--	--

¹ The VOC emissions from this source category are included in the facility-wide allowable emissions limit established in condition 106.B: 200 tpy VOC, 8.0 tpy per individual HAP, and 24.0 tpy of combined total HAPs.

Reporting Requirement

A1107 A The permittee shall comply with all applicable reporting requirements of 40 CFR 60, Subpart A as required in 60.4218 and in accordance with Section B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NOx, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No Provide comments and identify any supporting documentation as an attachment.

Comments:

Generator TA-33-G-1P	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1102 A) (tons per year)
NOx	0.0040	0.000	0.0040	18.1
SO ₂	0.0001	0.000	0.0001	2.5
TSP	0.0001	0.000	0.0001	0.6
PM ₁₀	0.0001	0.000	0.0001	0.6
CO	0.0004	0.000	0.0004	15.2
VOC	0.0003	0.000	0.0003	0.3
HAPs	1.16E-06	0.000	1.16E-06	No Source Limit

Note: The TA-33-G-1P generator did not operate during the second six months of 2017.

Generator TA-33-G-2	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1102 A) (tons per year)
NOx	0.0009	0.0001	0.0010	0.21
SO ₂	0.0001	0.0000	0.0001	Not Required
TSP	0.0001	0.0000	0.0001	Not Required
PM ₁₀	0.0001	0.0000	0.0001	Not Required
CO	0.0003	0.0000	0.0003	0.1
VOC	0.0001	0.0000	0.0001	Not Required
HAPs	2.84E-07	2.70E-08	3.11E-07	No Source Limit

Continued on the next page.

A1100 Internal Combustion- continued

Generator TA-33-G-3	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1102 A) (tons per year)
NOx	0.0004	0.0001	0.0005	0.21
SO ₂	0.0000	0.0000	0.0000	Not Required
TSP	0.0000	0.0000	0.0000	Not Required
PM ₁₀	0.0000	0.0000	0.0000	Not Required
CO	0.0001	0.0000	0.0001	0.1
VOC	0.0000	0.0000	0.0000	Not Required
HAPs	1.35E-07	2.70E-08	1.62E-07	No Source Limit

Generator TA-33-G-4	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1102 A) (tons per year)
NOx	0.000	0.000	0.000	2.33
SO ₂	0.000	0.000	0.000	0.16
TSP	0.000	0.000	0.000	Not Required
PM ₁₀	0.000	0.000	0.000	Not Required
CO	0.000	0.000	0.000	1.4
VOC	0.000	0.000	0.000	0.2
HAPs	0.000	0.000	0.000	No Source Limit

Note: The TA-33-G-4 generator did not operate during 2017.

Generator RLUOB-GEN-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NOx	0.035	0.064	0.099	No Source Specific Emission Limits for the CMRR Generators
SO ₂	0.001	0.002	0.003	
TSP	0.002	0.004	0.006	
PM ₁₀	0.002	0.003	0.005	
CO	0.044	0.079	0.123	
VOC	0.005	0.009	0.014	
HAPs	9.17E-06	1.66E-05	2.58E-05	

Generator RLUOB-GEN-2	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NOx	0.045	0.084	0.129	No Source Specific Emission Limits for the CMRR Generators
SO ₂	0.001	0.002	0.003	
TSP	0.003	0.005	0.008	
PM ₁₀	0.002	0.004	0.006	
CO	0.056	0.104	0.160	
VOC	0.006	0.012	0.018	
HAPs	1.18E-05	2.18E-05	0.000	

Continued on the next page.

A1100 Internal Combustion- continued

Generator RLUOB-GEN-3	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NO _x	0.034	0.035	0.069	No Source Specific Emission Limits for the CMRR Generators
SO ₂	0.001	0.001	0.002	
TSP	0.002	0.002	0.004	
PM ₁₀	0.002	0.002	0.004	
CO	0.042	0.044	0.086	
VOC	0.005	0.005	0.010	
HAPs	8.73E-06	9.17E-06	1.79E-05	

Generator TA-48-GEN-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NO _x	0.000	0.000	0.000	No Source Specific Emission Limits for the TA-48 Generator
SO ₂	0.000	0.000	0.000	
TSP	0.000	0.000	0.000	
PM ₁₀	0.000	0.000	0.000	
CO	0.000	0.000	0.000	
VOC	0.000	0.000	0.000	
HAPs	0.000	0.000	0.000	

Note: The TA-48-GEN-1 generator did not operate during 2017.

Generator TA-55-GEN-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NO _x	0.000	0.0010	0.0010	No Source Specific Emission Limits for the TA-55 Generators
SO ₂	0.000	0.0001	0.0001	
TSP	0.000	0.0001	0.0001	
PM ₁₀	0.000	0.0001	0.0001	
CO	0.000	0.0002	0.0002	
VOC	0.000	0.0001	0.0001	
HAPs	0.000	2.43E-07	2.43E-07	

Note: The TA-55-GEN-1 generator did not operate during the first six months of 2017.

Generator TA-55-GEN-2	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NO _x	0.000	0.000	0.000	No Source Specific Emission Limits for the TA-55 Generators
SO ₂	0.000	0.000	0.000	
TSP	0.000	0.000	0.000	
PM ₁₀	0.000	0.000	0.000	
CO	0.000	0.000	0.000	
VOC	0.000	0.000	0.000	
HAPs	0.000	0.000	0.000	

Note: The TA-55-GEN-2 generator did not operate during 2017.

Continued on the next page.

A1100 Internal Combustion- continued

Generator TA-55-GEN-3	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NOx	0.102	0.072	0.17	No Source Specific Emission Limits for the TA-55 Generators
SO ₂	0.002	0.001	0.003	
TSP	0.003	0.002	0.01	
PM ₁₀	0.003	0.002	0.01	
CO	0.022	0.016	0.04	
VOC	0.005	0.002	0.01	
HAPs	1.86E-05	1.31E-05	3.17E-05	

A1200 Data Disintegrator

A1202 Emission Limits - Data Disintegrator

Unit No.	TSP tpy	PM10 tpy
TA-52-11	9.9	9.9

Reporting Requirement

A1207 A The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No

Provide comments and identify any supporting documentation as an attachment.

Comments:

Data Disintegrator TA-52-11	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1202 A) (tons per year)
TSP	0.22	0.21	0.43	9.9
PM10	0.20	0.18	0.38	9.9

A1300 TA-3 Power Plant

A1302 Emission Limits - TA-3 Power Plant

All TA-3 Power Plant Boilers Combined (TA-33-1, TA-33-2, TA-33-3)

NOx tpy	CO tpy	VOC tpy	SOx tpy	TSP tpy	PM ₁₀ tpy	PM2.5 tpy
31.5	21.5	2.8	4.9	4.7	4.4	4.2

TA-3 Power Plant Turbine (TA-3-22-CT-1)

NOx tpy	CO tpy	VOC tpy	SOx tpy	TSP tpy	PM ₁₀ tpy	PM2.5 tpy
59.4	72.3	1.5	4.2	4.8	4.8	4.8

Reporting Requirement

A1307 A The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NOx, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No Provide comments and identify any supporting documentation as an attachment.

Comments:

Boilers TA-3-22-1, TA-3-22-2, TA-3-22-3	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limit (Condition A1302 A) (tons per year)
NOx	5.62	4.21	9.8	31.5
SO ₂	0.06	0.05	0.1	4.9
TSP	0.74	0.55	1.3	4.7
PM ₁₀	0.74	0.55	1.3	4.4
PM _{2.5}	0.74	0.55	1.3	4.2
CO	3.88	2.90	6.8	21.5
VOC	0.53	0.40	0.9	2.8
HAPs	0.18	0.14	0.3	No Source Limit

Combustion Turbine TA-3-22 CT-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limit (Condition A1302 A) (tons per year)
NOx	0.864	0.429	1.29	59.4
SOx	0.060	0.030	0.09	4.2
TSP	0.116	0.058	0.17	4.8
PM ₁₀	0.116	0.058	0.17	4.8
PM _{2.5}	0.116	0.058	0.17	4.8
CO	0.180	0.089	0.27	72.3
VOC	0.038	0.019	0.06	1.5
HAPs	0.024	0.012	0.04	No Source Limit

A1400 Open Burning

A1402 Emission Limits - Open Burning

Unit No.	Individual HAP ¹ (tpy)	Total HAPs ¹ (tpy)
Facility-Wide Open Burning	8.0	24.0

¹ Individual and Total HAPs emitted by Open Burning are included in facility-wide HAP emission limits at Table 106.B.

Reporting Requirement

A1407 A The permittee shall submit reports as outlined in the Condition 1407.A Requirements, as described in Section A109, and in accordance with Section B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources and the Soil Vapor Extraction equipment at Material Disposal Area L shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No

Provide comments and identify any supporting documentation as an attachment.

Comments:

No open burning activities took place during 2017.

A1500 Evaporative Sprayers

A1502 Emission Limits - Evaporative Sprayers

Unit No.	HAPs tpy
TA-60-EVAP-1	-- ¹
TA-60-EVAP-2	-- ¹
TA-60-EVAP-3	-- ¹
TA-60-EVAP-4	-- ¹
TA-60-EVAP-5	-- ¹

¹ Hazardous air pollutants (HAPs) from the evaporative coolers are included in and subject to the individual and total HAP facility-wide emission limits in Table 106.B: 8.0 tpy per individual HAP, and 24.0 tpy of combined total HAPs.

Reporting Requirement

A1507 A The permittee shall submit reports described in Section A109 and in accordance with B111.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No

Provide comments and identify any supporting documentation as an attachment.

Comments:

Evaporative Sprayer TA-60-EVAP-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1502 A) (tons per year)
Polychlorinated biphenyls	7.14E-10	1.11E-09	1.83E-09	Source limits refer to facility-wide limits.
Chloroform	3.28E-06	5.12E-06	8.40E-06	
Chloromethane	2.25E-06	3.51E-06	5.75E-06	
Bromoform	2.90E-06	4.52E-06	7.42E-06	
Cyanide Compounds	6.67E-06	1.04E-05	1.71E-05	
Manganese Compounds	2.41E-05	3.76E-05	6.17E-05	
Antimony Compounds	1.14E-05	1.78E-05	2.92E-05	
TOTAL HAPs	5.06E-05	7.90E-05	1.30E-04	

Evaporative Sprayer TA-60-EVAP-2	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1502 A) (tons per year)
Polychlorinated biphenyls	3.26E-10	9.38E-10	1.26E-09	Source limits refer to facility-wide limits.
Chloroform	1.50E-06	4.31E-06	5.80E-06	
Chloromethane	1.03E-06	2.95E-06	3.98E-06	
Bromoform	1.32E-06	3.81E-06	5.13E-06	
Cyanide Compounds	3.04E-06	8.76E-06	1.18E-05	
Manganese Compounds	1.10E-05	3.17E-05	4.27E-05	
Antimony Compounds	5.20E-06	1.50E-05	2.02E-05	
TOTAL HAPs	2.31E-05	6.64E-05	8.95E-05	

Continued on the next page.

A1500 Evaporative Sprayers - continued

Evaporative Sprayer TA-60-EVAP-3	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1502 A) (tons per year)
Polychlorinated biphenyls	6.61E-10	5.00E-10	1.16E-09	Source limits refer to facility-wide limits.
Chloroform	3.04E-06	2.30E-06	5.33E-06	
Chloromethane	2.08E-06	1.57E-06	3.65E-06	
Bromoform	2.69E-06	2.03E-06	4.71E-06	
Cyanide Compounds	6.18E-06	4.67E-06	1.08E-05	
Manganese Compounds	2.23E-05	1.69E-05	3.92E-05	
Antimony Compounds	1.06E-05	7.98E-06	1.85E-05	
TOTAL HAPs	4.69E-05	3.54E-05	8.23E-05	

Evaporative Sprayer TA-60-EVAP-4	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1502 A) (tons per year)
Polychlorinated biphenyls	0.000	0.000	0.000	Source limits refer to facility-wide limits.
Chloroform	0.000	0.000	0.000	
Chloromethane	0.000	0.000	0.000	
Bromoform	0.000	0.000	0.000	
Cyanide Compounds	0.000	0.000	0.000	
Manganese Compounds	0.000	0.000	0.000	
Antimony Compounds	0.000	0.000	0.000	
TOTAL HAPs	0.000	0.000	0.000	

Note: The TA-60-EVAP-4 evaporative sprayer has not been installed.

Evaporative Sprayer TA-60-EVAP-5	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1502 A) (tons per year)
Polychlorinated biphenyls	0.000	0.000	0.000	Source limits refer to facility-wide limits.
Chloroform	0.000	0.000	0.000	
Chloromethane	0.000	0.000	0.000	
Bromoform	0.000	0.000	0.000	
Cyanide Compounds	0.000	0.000	0.000	
Manganese Compounds	0.000	0.000	0.000	
Antimony Compounds	0.000	0.000	0.000	
TOTAL HAPs	0.000	0.000	0.000	

Note: The TA-60-EVAP-5 evaporative sprayer has not been installed.

A102 Facility Wide Emission Limits

Table 102.A: Total Potential Criteria Pollutant Emissions from Entire Facility

Pollutant	Emissions (tons per year)
Nitrogen Oxides (NOx)	245.0
Carbon Monoxide (CO)	225.0
Volatile Organic Carbons (VOC)	200.0
Sulfur Dioxide (SO ₂)	150.0
Total Particulate Matter (TSP)	120.0
Particulate Matter less than 10 microns (PM ₁₀)	120.0
Particulate Matter less than 2.5 microns (PM _{2.5})	120.0

Table 102.B: Total Potential HAPs that exceed 1.0 tons per year

Pollutant	Emissions (tons per year)
Individual HAP	8.0
Total HAPs	24.0

Reporting Requirement

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NOx, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

☐

Yes

Date report submitted:

Tracking Number:

☒

No Provide comments and identify any supporting documentation as an attachment.

Comments:

Pollutant	January - June Emissions (tons)	July - December Emissions (tons)	2017 Annual Emissions (tons)	Facility Wide Permit Limits (Condition A102) (tons per year)
Nitrogen Oxides	17.89	12.97	30.9	245
Carbon Monoxide	13.26	9.73	23.0	225
Volatile Organic Carbons	5.17	7.29	12.5	200
Sulfur Dioxide	0.19	0.13	0.3	150
Total Particulate Matter	1.98	1.48	3.5	120
Particulate Matter less than 10 microns	1.96	1.46	3.4	120
Particulate Matter less than 2.5 microns	0.86	0.61	1.5	120
Hazardous Air Pollutants	2.95	2.93	5.9	24